

Analyte	Regulatory Compliance						
	Date Range	Number of Samples	MCL ^a	Number of Samples Exceeding MCL	Exceedances		
					Concentration	Date	
Metals, in milligrams per liter (mg/L)							
ANTIMONY	2/12/2002 - 11/7/2017	18	0.006	0	--	--	
ARSENIC	7/12/2007 - 11/7/2017	15	0.01	0	--	--	
BARIUM	2/12/2002 - 11/7/2017	18	2	0	--	--	
BERYLLIUM	2/12/2002 - 11/7/2017	18	0.004	0	--	--	
CADMIUM	2/12/2002 - 11/7/2017	18	0.005	0	--	--	
CHROMIUM	2/12/2002 - 11/7/2017	18	0.1	0	--	--	
FLUORIDE	2/12/2002 - 11/7/2017	18	4	0	--	--	
MERCURY	2/12/2002 - 11/7/2017	18	0.002	0	--	--	
NICKEL	2/12/2002 - 11/7/2017	18	0.1	0	--	--	
SELENIUM	2/12/2002 - 11/7/2017	18	0.05	0	--	--	
THALLIUM	2/12/2002 - 11/7/2017	18	0.002	0	--	--	
Other Inorganic Chemicals, in mg/L							
NITRATE-NITRITE	2/12/2002 - 4/24/2013	7	10	0	--	--	
NITRATE	2/12/2002 - 6/27/2018	65	10	0	--	--	
NITRITE	2/12/2002 - 4/24/2013	10	1	0	--	--	
Disinfection Byproducts (DBP) and DBP Indicators, in mg/L							
TOTAL HALOACETIC ACIDS (HAA5)	7/21/2004 - 11/28/2018	22	0.06	0	--	--	
TOTAL TRIHALOMETHANES (TTHM)	7/21/2004 - 11/28/2018	22	0.08	0	--	--	
CHLOROFORM	2/12/2002 - 11/28/2018	49	0.1	0	--	--	
BROMOFORM	2/12/2002 - 11/28/2018	49	0.1	0	--	--	
BROMODICHLOROMETHANE	2/12/2002 - 11/28/2018	49	0.1	0	--	--	
DIBROMOCHLOROMETHANE	2/12/2002 - 11/28/2018	49	0.1	0	--	--	
Bacteria, presence or absence							
FECAL COLIFORM	1/1/2004 - 12/31/2018	12	Absence	0	--	--	
E. COLI	1/1/2004 - 12/31/2018	14	Absence	0	--	--	
TOTAL COLIFORM	1/1/2004 - 12/31/2018	727	Absence	18	Presence	2004-2010	

Analyte	Regulatory Compliance						
	Date Range	Number of Samples	MCL ^a	Number of Samples Exceeding MCL	Exceedances		
					Concentration	Date	
Pesticides, in mg/L							
ENDRIN	11/17/2003 - 6/27/2018	31	0.002	0	--	--	
BHC-GAMMA	11/17/2003 - 6/27/2018	31	0.0002	0	--	--	
METHOXYCHLOR	11/17/2003 - 6/27/2018	31	0.04	0	--	--	
TOXAPHENE	11/17/2003 - 6/27/2018	31	0.003	0	--	--	
DALAPON	11/17/2003 - 6/27/2018	31	0.2	0	--	--	
DIQUAT	11/17/2003 - 6/27/2018	30	0.02	0	--	--	
ENDOTHALL	11/17/2003 - 11/17/2004	3	0.1	0	--	--	
GLYPHOSATE	11/17/2003 - 6/27/2018	31	0.7	0	--	--	
DI(2-ETHYLHEXYL) ADIPATE	11/17/2003 - 6/27/2018	31	0.4	0	--	--	
OXAMYL	11/17/2003 - 6/27/2018	31	0.2	0	--	--	
SIMAZINE	11/17/2003 - 6/27/2018	31	0.004	0	--	--	
DI(2-ETHYLHEXYL) PHTHALATE	11/17/2003 - 6/27/2018	29	0.006	1	0.031	9/15/2011	
PICLORAM	11/17/2003 - 6/27/2018	31	0.5	0	--	--	
DINOSEB	11/17/2003 - 6/27/2018	31	0.007	0	--	--	
HEXACHLOROCYCLOPENTADIENE	11/17/2003 - 6/27/2018	31	0.05	0	--	--	
ALDICARB SULFOXIDE	11/17/2003 - 6/27/2018	31	0.004	0	--	--	
ALDICARB SULFONE	11/17/2003 - 6/27/2018	31	0.002	0	--	--	
CARBOFURAN	11/17/2003 - 6/27/2018	31	0.04	0	--	--	
ALDICARB	11/17/2003 - 6/27/2018	31	0.003	0	--	--	
ATRAZINE	11/17/2003 - 6/27/2018	31	0.003	0	--	--	
LASSO	11/17/2003 - 6/27/2018	31	0.002	0	--	--	
HEPTACHLOR	11/17/2003 - 6/27/2018	31	0.0004	0	--	--	
HEPTACHLOR EPOXIDE	11/17/2003 - 6/27/2018	31	0.0002	0	--	--	
2,4-D	11/17/2003 - 6/27/2018	31	0.07	0	--	--	
2,4,5-TP	11/17/2003 - 6/27/2018	31	0.05	0	--	--	
HEXACHLOROBENZENE	11/17/2003 - 6/27/2018	31	0.001	0	--	--	
CHLORDANE	11/17/2003 - 6/27/2018	31	0.002	0	--	--	
ETHYLENE DIBROMIDE	11/17/2003 - 6/27/2018	31	0.00005	0	--	--	
1,2-DIBROMO-3-CHLOROPROPANE	11/17/2003 - 6/27/2018	31	0.0002	0	--	--	
Polychlorinated Biphenyls (PCBs), in mg/L							
PCB 1016	11/17/2003 - 6/27/2018	31	0.0005	0	--	--	
PCB 1221	11/17/2003 - 6/27/2018	31	0.0005	0	--	--	
PCB 1232	11/17/2003 - 6/27/2018	31	0.0005	0	--	--	
PCB 1242	11/17/2003 - 6/27/2018	31	0.0005	0	--	--	
PCB 1248	11/17/2003 - 6/27/2018	31	0.0005	0	--	--	
PCB 1254	11/17/2003 - 6/27/2018	31	0.0005	0	--	--	
PCB 1260	11/17/2003 - 6/27/2018	31	0.0005	0	--	--	

Analyte	Regulatory Compliance						
	Date Range	Number of Samples	MCL ^a	Number of Samples Exceeding MCL	Exceedances		
					Concentration	Date	
Other Organic Chemicals, in mg/L							
BENZO(A)PYRENE	5/5/2003 - 7/30/2014	31	0.0002	0	--	--	
PENTACHLOROPHENOL	11/17/2003 - 6/27/2018	31	0.001	0	--	--	
1,2,4-TRICHLOROBENZENE	2/12/2002 - 11/28/2018	100	0.07	0	--	--	
CIS-1,2-DICHLOROETHYLENE	2/12/2002 - 11/28/2018	100	0.07	0	--	--	
XYLENES, TOTAL	2/12/2002 - 11/28/2018	100	10	0	--	--	
DICHLOROMETHANE	2/12/2002 - 11/28/2018	100	0.005	0	--	--	
O-DICHLOROBENZENE	2/12/2002 - 11/28/2018	100	0.6	0	--	--	
P-DICHLOROBENZENE	2/12/2002 - 11/28/2018	100	0.075	0	--	--	
VINYL CHLORIDE	2/12/2002 - 11/28/2018	100	0.002	0	--	--	
1,1-DICHLOROETHYLENE	2/12/2002 - 11/28/2018	100	0.007	0	--	--	
TRANS-1,2-DICHLOROETHYLENE	2/12/2002 - 11/28/2018	100	0.1	0	--	--	
1,2-DICHLOROETHANE	2/12/2002 - 11/28/2018	100	0.005	0	--	--	
1,1,1-TRICHLOROETHANE	2/12/2002 - 11/28/2018	100	0.2	0	--	--	
CARBON TETRACHLORIDE	2/12/2002 - 11/28/2018	100	0.005	0	--	--	
1,2-DICHLOROPROPANE	2/12/2002 - 11/28/2018	100	0.005	0	--	--	
TRICHLOROETHYLENE	2/12/2002 - 11/28/2018	98	0.005	2	0.0192	9/22/2006	
1,1,2-TRICHLOROETHANE	2/12/2002 - 11/28/2018	100	0.005	0	--	--	
TETRACHLOROETHYLENE	2/12/2002 - 11/28/2018	100	0.005	0	--	--	
CHLOROBENZENE	2/12/2002 - 11/28/2018	100	0.1	0	--	--	
BENZENE	2/12/2002 - 11/28/2018	100	0.005	0	--	--	
TOLUENE	2/12/2002 - 11/28/2018	100	1	0	--	--	
ETHYLBENZENE	2/12/2002 - 11/28/2018	100	0.7	0	--	--	
STYRENE	2/12/2002 - 11/28/2018	100	0.1	0	--	--	
O-XYLENE	2/12/2002 - 11/28/2018	99	10	0	--	--	
Radionuclides, in picoCuries per liter (pCi/L); combined Uranium in micrograms per liter (Ug/L)							
GROSS ALPHA, EXCL. RADON & URANIUM	10/29/2002 - 11/7/2017	20	15	0	--	--	
GROSS ALPHA, INCL. RADON & URANIUM	10/29/2002 - 11/7/2017	3	15	0	--	--	
COMBINED URANIUM	10/29/2002 - 11/7/2017	14	30	0	--	--	
COMBINED RADIUM (-226 & -228)	10/29/2002 - 11/7/2017	21	5	0	--	--	
RADIUM-226	10/29/2002 - 11/7/2017	21	5	0	--	--	
RADIUM-228	10/29/2002 - 11/7/2017	21	5	0	--	--	

a. MCL = Maximum Contaminant Level under the Federal (EPA) Safe Drinking Water Act