



*Please file as a
Record document
for Construction
Permit No. 20,194-IW.*

WASTEWATER

FINAL APPROVAL TO PLACE INTO OPE

Jamy

ISSUED TO: US DEPARTMENT OF ENERGY
SAVANNAH RIVER SITE
BUILDING 705-3C
AIKEN SC 29808

20194-IW

for the operation of a wastewater treatment/collection system permitted under Construction Permit No. 20,234-IW, dated November 1, 2018.

PROJECT NAME: SRS/SALT WASTE PROCESSING FACILITY (SWPF) Final Tie-Ins

COUNTY: Aiken

PROJECT DESCRIPTION: The Salt Waste Processing Facility (SWPF) is designed to extract and concentrate cesium, strontium, and actinides from salt wastes in the tank farms resulting in effluents that are acceptable for treatment at the Defense Waste Processing Facility (DWPF) and the Saltstone Production Facility (SPF). Attachment A provides a list of equipment.

The effluent concentrations of those constituents the wastewater treatment system is designed to remove or reduce for wastewater transferred to Tank 50 to the SPF are contained in Construction Permit No. 18,801-IW for the SPF. The solid waste from the SPF will be disposed in the Saltstone Disposal Facility (SDF) in accordance with Solid Waste Industrial Permit #025500-1603. The wastewater sent to the DWPF will be vitrified and poured into canisters that are transferred to the Glass Waste Storage Buildings.

PERMITTED FLOW: System Nominal Daily Flow: 35,840 gallons per day
System Design Capacity Flow: 185,736 gallons per day

WWTP: US DOE/SAVANNAH RIVER SITE Salt Waste Processing Facility (SWPF)

SPECIAL CONDITIONS:

1. This permit is in addition to Construction Permit No. 19,219-IW (Salt Waste Processing Facility (SWPF)), Construction Permit No. 20,194-IW (SWPF NGS Cold Chemical Feed Facility), Construction Permit No. 18,801-IW (Saltstone Production Facility (SPF)), Construction Permit No. 17,424-IW (F-Area and H-Area Tank Farms), and Construction Permit No. 16,783, Defense Waste Processing Facility.



2. The jumpers that will tie the SWPF in with the SPF and DWPF are permitted by this construction permit. There shall be no radioactive salt solution received from the High Level Waste (HLW) tanks for processing and transfer to the DWPF and/or the SPF until these jumpers have been installed and the Department has issued the Approval to Place into Operation for this construction permit.

This approval is based on the APO request letter (SRR-ESH-2019-00118) signed by Ms. Patricia M. Allen. Note that Attachment 1 is the Engineer's letter of certification (signed by Andrew R. Redwood, P.E., South Carolina Registration No. 20525).

Barry S. Mullinax

Barry S. Mullinax, Engineer
(for) Environmental Affairs
AIKEN EA OFFICE

Date Issued: October 29, 2019

cc: Bureau of Water Permitting File – Construction Permit No. 20,234-IW
Bureau of Water Permitting File – Construction Permit No. 19,219-IW
Bureau of Water Permitting File – Construction Permit No. 20,194-IW
Bureau of Water Permitting File – Construction Permit No. 18,801-IW
Bureau of Water Permitting File – Construction Permit No. 17,424-IW
Bureau of Water Permitting File – Construction Permit No. 16,783-IW
Travis Fuss, Aiken EA Office
Crystal Robertson, Aiken EA Office
Shawn M. Clarke, BOW, Columbia Office
Crystal Rippy, BOW – Columbia Office
Andrew Redwood, P.E., SRR



Attachment A Equipment List

The equipment included in Construction Permit No. 20,234-IW is listed below:

1. Transfer Line SDP1 and Jumper 6-7(SPP2)2 for Raw Salt Solution (RSS) Transfer Line
2. Jumper 6-7(SPP3)3 for Strip Effluent (SE) Waste Transfer Line
3. Jumper 3(SPP3)15 for Monosodium Titanate Precipitate (MSTPCP) Waste Transfer Line
4. Transfer lines DSS-0077, SSP077, and WTS-SSP4 for the Decontaminated Salt Solution to Tank 50 and the Saltstone Production Facility.



Wastewater System Construction

APPROVAL TO PLACE INTO OPERATION

ISSUED TO: US DEPARTMENT OF ENERGY
SAVANNAH RIVER SITE
BUILDING 705-3C
AIKEN SC 29808

for the operation of a wastewater treatment/collection system permitted under Construction Permit No. 19,219-IW, dated August 6, 2008. This construction permit superseded Construction Permit No. 19,164-IW, dated January 2, 2008, that was issued for the installation of three (3) waste transfer line segments.

PROJECT NAME: SRS/SALT WASTE PROCESSING FACILITY (SWPF)

COUNTY: Aiken

PROJECT DESCRIPTION: The Salt Waste Processing Facility (SWPF) is designed to extract and concentrate cesium, strontium, and actinides from salt wastes in the tank farms resulting in effluents that are acceptable for disposal at the Defense Waste Processing Facility (DWPF) and the Saltstone Production Facility (SPF). Attachment A lists the SWPF equipment.

The effluent concentrations of those constituents the wastewater treatment system is designed to remove or reduce for wastewater transferred to Tank 50 to the SPF are contained in Construction Permit No. 18,801-IW for the SPF. The solid waste from the SPF will be disposed in the Saltstone Disposal Facility (SDF) in accordance with Solid Waste Industrial Permit #025500-1603. The wastewater sent to the DWPF will be disposed as a solid waste in canisters that are transferred to the Glass Waste Storage Buildings.

PERMITTED FLOW: System Nominal Daily Flow: 35,840 gallons per day
System Design Capacity Flow: 185,736 gallons per day


WWTP: US DOE/SAVANNAH RIVER SITE Salt Waste
Processing Facility (SWPF)

SPECIAL CONDITIONS:

1. The jumpers that will tie the SWPF in with the SPF and DWPF are permitted by Construction Permit No. 20,234-IW. There shall be no radioactive salt solution received from the HLW tanks for processing and transfer to the DWPF and/or the SPF until these jumpers have been installed and the Department has issued an Approval to Place into Operation for Construction Permit No. 20,234-IW.

2. The use of water, chemicals, and non-radioactive materials to support SWPF activities such as flushing, cleaning, startup testing, and demonstrations to validate performance of components and/or systems is allowed as long as the jumpers in Condition #1 have not been installed or the jumpers are physically isolated from the SWPF.
3. NPDES Permit No. SC0000175 allows the disposal of "scavenger" wastewater. If the wastewater is not scavenger wastewater, a written request shall be submitted to the Department describing this wastewater. No discharge of this wastewater may be performed without the written approval from the Department.
4. Note that Construction Permit No. 20,194-IW was issued for the Next Generation Solvent Cold Chemical Feed Facility. This facility is in addition to Construction Permit No. 19,219-IW that was issued for the SWPF.

This approval is based on the Engineer's letter of certification signed by James C. Somma, P.E., South Carolina Registration No. 14718 (Parsons).


Barry S Mullinax, Engineer
(for) Environmental Affairs
AIKEN EA OFFICE

Date Issued: August 14, 2019

cc: Bureau of Water Permitting File – Construction Permit No. 19,219-IW
Bureau of Water Permitting File – Construction Permit No. 20,194-IW
Bureau of Water Permitting File – Construction Permit No. 20,234-IW
Travis Fuss, Aiken EA Office
Shawn M. Clarke, BOW – Columbia
Crystal Rippey, BOW - Columbia
Crystal Robertson, Aiken EA Office
James Somma, P.E., Parsons

Attachment A for SWPF Approval to Operate (APO)

SWPF Equipment List (Drawing No. G-P1-J-00001)

PROCESS BUILDING – PROCESS EQUIPMENT

Tank Number	Tank Name
Process Cell Area	
TK-101	Alpha Sorption Tank-A (AST-A)
TK-102	Filter Feed Tank-A (FFT-A)
TK-103	Cleaning Solution Dump Tank-A (CSDT-A)
TK-104	Sludge Solids Receipt Tank (SSRT)
TK-105	Wash Water Hold Tank (WWHT)
TK-109	Salt Solution Feed Tank (SSFT)
TK-121A/B/C	Back Pulse Tank
TK-123	Washing Filter Back Pulse Tank
TK-127	Spent Acid Storage Tank (SAST)
TK-205	Strip Effluent Hold Tank (SEHT)
TK-208	Solvent Drain Tank
TK-235	Lab Drain Tank
TK-505	Backup Air Receiver
TK-506	Backup Air Receiver
TK-601	Alpha Sorption Drain Tank (ASDT)
Operating Deck	
TK-122	Back Pulse Charge Tank-A
TK-128	AST-A Air Pulse Agitator Charge Tank
TK-129	FFT-A Air Pulse Agitator Charge Tank
TK-131	SSRT Air Pulse Agitator Charge Tank
TK-132	SSFT Air Pulse Agitator Charge Tank
TK-133	WWHT Air Pulse Agitator Charge Tank
CSSX Tank Cell	
TK-202	Solvent Hold Tank (SHT)
TK-203	Strip Effluent Coalescer
TK-204	Caustic Wash Tank
TK-206	Ba-137 Decay Tank (BDT)
TK-211	Decontaminated Salt Solution Stilling Tank
TK-212	Strip Effluent Stilling Tank
TK-215	Strip Effluent Pump Tank
TK-217	Solvent Strip Feed Tank

Tank Number	Tank Name
CSSX Contactor Drop Area	
TK-201	Decon. Salt Solution Coalescer
Cold Chemicals Area	
TK-106	Filter Cleaning Acid Feed Tank
TK-107	Filter Cleaning Caustic Tank
TK-108	Caustic Dilution Feed Tank
TK-301	Process Water Tank
TK-302	Caustic Receipt Tank
TK-303	Caustic Makeup Tank
TK-304	Nitric Acid Receipt Tank
TK-305	Process Water Pressure Tank
TK-307	Nitric Acid Scrub Makeup Tank
TK-311	MST Storage Tank
TK-312	DI Water Storage Tank
TK-313	Solvent Makeup Tank
TK-314	DI Water Expansion Tank
TK-317	Neutralization Tank
TK-330	Argon Tank
CSSX Contactor Area	
EXT-201A-P	Solvent Extraction Contactors
EXT-202A/B	Scrub Contactors
EXT-203A-P	Stripping Contactors
EXT-204A/B	Caustic Wash Contactors
Process Filters	
FLT-102A/B/C	Alpha Sorption Filters
FLT-104	Washing Filter
Alpha Finishing Facility	
TK-207	DSS Hold Tank (DSSHT)
TK-220	Intermediate Storage Tank (IST)
TK-221	Alpha Sorption Tank - B (AST-B)
TK-222	Filter Feed Tank - B (FFT-B)
TK-223	Cleaning Solution Dump Tank - B (CSDT-B)
TK-224	MST/Sludge Transfer Tank (MSTT)
TK-225A/B/C	Finishing Area Back Pulse Tank
TK-228	Alpha Finishing Drain Tank (AFDT)
TK-233	Back Pulse Charge Tank B
TK-236/237	Lab Collection Tank
TK-604	Low Level Drain Tank
FLT-222A/B/C	Alpha Sorption Filters

PUMPS	
North ASP Pump and Valve Gallery	
P-015A	ASP Secondary Loop Pump Water Pump
P-015B	ASP Secondary Loop Pump Water Pump
P-101A/B	Alpha Sorption Tank-A Transfer Pumps
P-102-1A/B/C	Filter Feed/Solids Trans Pumps
P-102-2 A/B/C	Filter Recirculation Pumps
P-104-1	Washing FLT Feed/Sludge Solids Trans Pump
P-104-2	Washing Filter Recirculation Pump
P-110	ASP Sump Trans Pump
South ASP Pump and Valve Gallery	
P-105A/B	Wash Water Trans Pumps
P-208A/B	Solvent Drain Tank Pumps
P-601A/B	Alpha Sorption Drain TK Transfer Pumps
CSSX Pump and Valve Gallery	
P-109A/B	Salt Solution Feed Pumps
P-202A/B	Solvent Feed Pumps
P-204A/B	Caustic Wash Tank Pumps
P-205A/B	Strip Effluent Trans Pumps
P-206A/B	Ba-137 Decay Tank Trans Pumps
P-212A/B	Strip Effluent Coalescer Feed Pumps
P-215A/B	Strip Effluent Pump Tank Pumps
P-217A/B	Solvent Strip Feed Pumps
P-218	CSSX Tank Cell Sump Transfer Pump
Sample Pump and Valve Gallery	
SP-101	Alpha Sorption Tank-A Sample Pump
SP-102	Filter Feed Tank-A Sample Pump
SP-103	Cleaning Solution Dump Tank-A Sample Pump
SP-104	Sludge Solids Receipt Tank Sample Pump
SP-105	Wash Water Hold Tank Sample Pump
SP-109	Salt Solution Feed Tank Sample Pump
SP-205	Strip Effluent Hold Tank Sample Pump
SP-235	Lab Drain Tank Sample Pump
Drum off/Decon Area	
P-605	Decon Area Sump Pump

PUMPS (continued)

Cold Chemicals Area

P-106	Acid Transfer Pump
P-107	Filter Cleaning Caustic Trans Pump
P-108	Caustic Dilution Trans Pump
P-300	Cold Chemicals Receiving Dock Sump Pump
P-301-1	Process Water Utility Pump
P-301-2	Flush Pump
P-302	Caustic Trans Pump
P-303	Caustic Makeup Trans Pump
P-304-1	Nitric Acid Metering Pump
P-304-2	Neutralization Metering Pump
P-305A/B	Sodium Hypochlorite Addition Pump
P-309A/B	Scrub Feed Pumps
P-310A/B	Strip Feed Pumps
P-311	MST Transfer Pump
P-311-1	MST Drum Pump
P-312-1	DI Water Trans Pump
P-312-2	Scrub Water Feed Pump
P-312-3A/B	Strip Water Feed Pumps
P-313	Solvent Makeup Trans Pump
P-313-1	Solvent Drum Pump
P-317	Neutralization Tank Discharge Pump
P-318	Caustic Sump Pump
P-319	Acid Sump Pump
P-320	Neutralization Sump Pump
P-321	Nitric Acid Sump Pump
P-322	Water Sump Pump
P-326	Pump Seal Make-up Water Supply Pump

Alpha Finishing Facility

P-207A/B	DSS Hold Tank Transfer Pumps
P-220A/B	Intermediate Storage Tank Transfer Pumps
P-221A/B	Alpha Sorption Tank B Transfer Pumps
P-222-1A/B/C	Filter Feed/Solids Transfer Pumps
P-222-2A/B/C	Filter Recirculation Pumps
P-224	MST/Sludge Transfer Pump
P-228	Alpha Finishing Drain Tank Transfer Pump

PUMPS (continued)

P-236	Lab Collection Tank Pump
P-604	Low Level Drain Tank Transfer Pump
P-025A/B	AFF Secondary Cooler Loop Pump
SP-207, SP-220 – SP-224	Sample Pumps
P-210, P-226, P-227, P-228-1	AFF Sump Pumps
P-229	Alpha Finishing Process Filter Loop Drain Pump
AGITATORS	
AGT-107	Filter Cleaning Caustic Tank Agitator
AGT-108	Caustic Dilution Feed Tank Agitator
AGT-303	Caustic Makeup Tank Agitator
AGT-307	Nitric Acid Scrub Makeup Tank Agitator
AGT-311	MST Storage Tank Agitator
AGT-311-1	MST Drum Agitator
AGT-313	Solvent Makeup Tank Agitator
AGT-221	Alpha Sorption Tank B Agitator
AGT-222	Filter Feed Tank B Agitator
AGT-224	MST/Sludge Transfer Tank Agitator
LABORATORY EQUIPMENT	
GB-001 – GB-011, GB-014	Glove Boxes
RH-001 – RH-017	Radio Hoods
FH-001	Fume Hood
HC-001 – HC-004	Hot Cell Windows
STS-101	Sample Transfer System
ELECTRICAL SYSTEMS	
ATS-203 – ATS-205	Automatic Transfer Switch
ATS-207	Automatic Transfer Switch
ATS-208	Automatic Transfer Switch
ATS-210	Automatic Transfer Switch
MCC-201 – MCC-206	Motor Control Center
MCC-209 – MCC-210	Motor Control Center
SWGR-201 – SWGR-204	Switchgear
USX-301	Uninterruptible Power Supply

INSTRUMENTATION

ICP-001 – ICP-013	Instrument Control Panel
ICP-014 – ICP-016	Instrument Control Panel
IR-001 – IR-014, IR-016 – IR-022, IR-024, IR-026 – IR-040	Instrument Control Rack

AIR HANDLING EQUIPMENT

ACU-001	Wall Mounted Heat Pump
AHU-001 – AHU-006	Air Handling Units
AHU-008 – AHU-009	Air Handling Units

Filters/Fans/Coils

CCL-401A/B	Process Vessel Vent Coolers
CCL-402A/B	Pulse Mixer Vent Coolers
FAN-401A/B	Process Vessel Vent Exhaust Fans
FAN-402A/B	Pulse Mixer Vent Exhaust Fans
FAN-001	Exhaust Fan
FAN-002	Exhaust Fan
FAN-003	Exhaust Fan on Roof
FAN-004	Exhaust Fan on Roof
FAN-007	Exhaust Fan on Roof
FAN-009	Exhaust Fan on Roof
FAN-010	Exhaust Fan on Roof
FAN-013	Exhaust Fan on Roof
FAN-014	Exhaust Fan on Roof
FAN-015	Exhaust Fan on Roof
FLT-001 – FLT-004	Exhaust Air HEPA Filters
FLT-009	Lab Exhaust Air HEPA Filter
FLT-010 – FLT-016	Cell Inlet Air HEPA Filters
FLT-017	Lab Exhaust Air HEPA Filter
FLT-020	Hot Lab Intake Filter Above Suspended Ceiling
FLT-021	Hot Cell Exhaust Air HEPA Filter
FLT-022	Hot Cell Exhaust Air HEPA Filter
FLT-023 – FLT-034	Glovebox Inlet Air HEPA Filters
FLT-240 – FLT-242	Solvent Recovery Filters
FLT-250	Solvent Adjustment Filter
FLT-301A/B	Process Water Cartridge Filter
FLT-401A/B	Process Vessel Vent Filters

AIR HANDLING EQUIPMENT (continued)

FLT-402A/B/C/D	Pulse Mixer Vent Filters
HRC-001	Heat Recovery Coil
Scrubbers	
SCB-001	Scrubber
SCB-002	Scrubber
SCB-003	Hot Cell Scrubber
SCB-004	Hot Cell Scrubber
SCFS-001	Scrubber Caustic Feed System
SCFS-002	Scrubber Caustic Feed System
Separators	
SEP-001	Bldg Chilled Water Air Separator
SEP-003	Control Room Chilled Water Air Separator
SEP-005	Process Chilled Water Air Separator
SEP-007	Heat Recovery Air Separator
Pumps	
P-001A/B	Bldg Chilled Water Supply Pumps
P-003A/B	Control Room Chilled Water Pumps
P-005A/B	Process Chilled Water Supply Pumps
P-007A/B	Heat Recovery Water Pumps
Tanks	
TK-001	Bldg Chilled Wtr Exp Tank
TK-002	Bldg Chilled Wtr Chem Feed Tank
TK-003	Control Room Chilled Wtr Exp Tank
TK-004	Control Room Chilled Wtr Chem Feed Tank
TK-005	Process Chilled Wtr Exp Tank
TK-006	Process Chilled Wtr Chem Feed Tank
TK-007	Heat Recovery Bladder Exp Tank
TK-008	Heat Recovery Chemical Feed Tank
TK-015	Process Chilled Water Expansion Tank
TK-016	Chemical Bypass Feeder Tank
TK-025	Process Chilled Water Expansion Tank
Ventilators	
VLR-001	Gravity Roof Ventilator
VLR-002	Gravity Roof Ventilator

MISCELLANEOUS ITEMS

BTR-001	DW Pressure Booster System
CMP-504	Back Up Air Receiver Compressor
DMST-401A/B	Process Vessel Vent Demisters
DMST-402A/B	Pulse Mixer Vent Demisters
FAN-005	Exhaust Fan
FAN-006	Exhaust Fan
FLT-007	Exhaust Air HEPA Filter
HTR-007	Domestic Water Heater/Tank
HTR-017A/B	Strip Contactors Tempered Water Heaters
HTR-203A/B	Solvent Strip Feed Tempered Water Heaters
HTR-310A/B	Strip Feed Heaters
HTR-401A/B	Process Vessel Vent Heaters
HTR-402A/B	Pulse Mixer Vent Heaters
HX-015	ASP Secondary Loop Cooler
HX-025	AFP Secondary Loop Cooler
HX-102A/B/C	Filter Recirculation Coolers
HX-104	Washing Filter Recirculation Cooler
HX-201	Salt Solution Feed Cooler
HX-202A/B	Solvent Feed Coolers
HX-203	Strip Contactor Tempered Water Heat Exchanger
HX-217A/B	Solvent Strip Feed Heat Exchanger
HX-222A/B/C	Filter Recirculation Coolers
HX-250	Solvent Adjustment Heat Exchanger
IX-312	DI Water Package Unit
SEP-015	Process Chiller Water Air Separator
SEP-025	Process Chilled Water Separator
VMP-001	Vibration Monitor Panel



June 21, 2018

Frank Sheppard
US DEPT OF ENERGY SAVANNAH RIVER SITE
BUILDING 705-C
Aiken, SC 29808

Re: Construction Permit No. 20194-IW
USDOE/ SRS/ SWPF/ NGS COLD CHEM FEED
Aiken County

Dear Frank Sheppard:

Enclosed is a SC Wastewater Construction Permit for the above referenced project. Construction is to be performed in accordance with this permit and supporting engineering report, plans, and specifications approved by this Office.

This system cannot be placed into operation until final approval is granted by the appropriate Bureau of Environmental Health Services (BEHS) Regional Office. Your Regional contact is Joshua C Yon, in the MIDLANDS REGION BEHS AIKEN. This regional office should be notified when construction begins at the following address and phone number: 206 BEAUFORT ST NE, AIKEN SC 29801-4476, 803-642-1637.

Upon completion of any construction, a letter must be submitted to the BEHS Regional Office from the registered engineer certifying that the construction has been completed in accordance with the approved plans and specifications. An inspection may then be scheduled. The BEHS Regional Office will approve the system for operation upon successful completion of this project.

Sincerely,

A handwritten signature in cursive script that reads "Barry S Mullinax".

Barry S Mullinax
Industrial Wastewater Permitting Section
Water Facilities Permitting Division

cc: Joshua C Yon, MIDLANDS REGION BEHS AIKEN
James Somma, Usdoe, Building 705-C, AIKEN, SC 29808

Wastewater Construction Permit Bureau of Water



PROJECT NAME: USDOE/ SRS/ SWPF/ NGS COLD CHEM FEED **COUNTY: AIKEN**

PERMISSION IS HEREBY GRANTED TO: US DEPT OF ENERGY SAVANNAH RIVER SITE
1080 Silver Bluff Rd
Aiken SC 29803

for the construction of an upgrade to an existing wastewater treatment plant in accordance with the construction plans, specifications, engineering report and the Construction Permit Application signed by James Somma, Registered Professional Engineer, S.C. Registration Number: 14718.

PROJECT DESCRIPTION: This application describes the location and configuration of the proposed Next Generation Solvent (NGS) Cold Chemical Feed Facility at the Salt Waste Processing Facility (SWPF). The Cold Chemical Feed Facility is required to support the deployment of NGS at SWPF.


The effluent will be discharged to the Salt Waste Processing Facility at a daily average rate of 7200 gallons per day.

This facility is associated with the Savannah River Site with NPDES Permit #SC0000175.

CONDITIONS: See page 2.

In accepting this permit, the owner agrees to the admission of properly authorized persons at all reasonable hours for the purpose of sampling and inspection. This is a permit for construction only and does not constitute DHEC approval, temporary or otherwise, to place the system in operation. An Approval to Place in Operation is required and can be obtained following the completion of construction by contacting the MIDLANDS REGION BEHS AIKEN at 803-642-1637. Additional permits may be required prior to construction (e.g., Stormwater).

PERMIT NUMBER:	20194-IW
ISSUANCE DATE:	June 21, 2018
EXPIRATION DATES:	June 20, 2020 (to begin construction) June 21, 2021 (to obtain Approval to Place in Operation)


Jeffrey P. deBessonnet, P.E., Director
Water Facilities Permitting Division

BSM

CONDITIONS

1. The permittee shall maintain at the permitted facility a complete Operations and Maintenance (O&M) Manual for the wastewater treatment system. The manual shall be made available for on-site review during normal working hours. The manual shall contain operation and maintenance instructions for all equipment and appurtenances associated with the wastewater treatment system. The manual shall contain a general description of the treatment process(es), operating characteristics that will produce maximum treatment efficiency and corrective action to be taken should operating difficulties be encountered.
2. In accordance with Regulation 61-67, Standards for Wastewater Facility Construction, all wastewater treatment facilities shall be closed out within one hundred eighty (180) days when the facility is closed or the effluent disposal permit is inactivated, terminated or revoked, unless otherwise determined by the Department. Closure of wastewater treatment facilities necessitates the submittal of a closure plan and approval of the plan by the Department in accordance with R.61-82 prior to closure of any wastewater treatment unit(s).
3. If necessary, final as-built drawings shall be submitted to the Department when you submit the request for SCDHEC to perform an inspection of this facility to obtain an Approval to Place into Operation.
4. The permittee shall provide for the performance of daily treatment facility inspections by a qualified operator. The inspections shall include, but should not necessarily be limited to, areas which require visual observation to determine efficient operation and for which immediate corrective measures can be taken using the O & M manual as a guide. All inspections shall be recorded and shall include the date, time, and name of the person making the inspection, corrective measures taken, and routine equipment maintenance, repair, or replacement performed. The permittee shall maintain all records of inspections at the permitted facility as required by the permit, and the records shall be made available for on-site review during normal working hours.
5. Operators for the Salt Waste Processing Facility shall perform the daily inspections on the days when the facility is being operated. SWPF operator qualifications are established in administrative procedures.
6. This construction permit is in addition to Construction Permit No. 19,219-IW for the Salt Waste Processing Facility.
7. All waste oil and solid and hazardous waste shall be properly disposed of in accordance with the rules and regulations of the Bureau of Land and Waste Management of SCDHEC.
8. Spill prevention measures shall be taken during the facility operation and during unloading or loading activities for chemical materials.
9. If the equipment identification numbers are changed from the Parsons equipment identification numbering system to the Savannah River equipment identification numbering system, the drawings submitted in the construction permit application package shall be revised, as appropriate, and signed, sealed, and dated by an SC-registered PE. These drawings shall be submitted to the Department as a supplemental record for this construction permit.



RECEIVED
JUN 15 2018
WATER FACILITIES
PERMITTING DIVISION

MEMORANDUM

June 06, 2018

TO: Joshua C Yon
MIDLANDS REGION BEHS AIKEN

FROM: Crystal D Rippey
Industrial Wastewater Permitting Section
Water Facilities Permitting Division

RE: Construction Permit Application
USDOE/ SRS/ SWPF/ NGS COLD CHEM FEED
Aiken County

RECEIVED
JUN 15 2018
WATER FACILITIES
PERMITTING DIVISION

Are you aware of any problems with, or do you have any comments on, the referenced project?
Copies of the application and location map are enclosed.

Please return any comments that you may have by: June 16, 2018. An e-mail response is suitable if you prefer. If you have no comments, please just note so. Thanks.

COMMENTS:

No specific concerns
Josh Yon
Aiken EA Office



South Carolina Department of Health
and Environmental Control

Environmental Quality Control

Wastewater Application Fee
2600 Bull Street
Columbia, SC 29201

US DEPT OF ENERGY SAVANNAH RIVER SITE
1080 SILVER BLUFF RD
AIKEN SC 29803

Invoice Date: 06/06/2018
Invoice Number: QY25894-7
Invoice Amount: \$400.00
Program ID: 1242453

Department Name: BOW - DOMESTIC WW PERM
Department Contact: LINDA S HARRELL
Department Phone: 803-898-4300

Qty	Description	Unit	Extended
1.00	TS => 1MGD - Modification (no expansion)	400.00	400.00
Total			\$400.00

South Carolina Department of Health and Environmental Control

Facility Name: US DEPT OF ENERGY SAVANNAH RIVER
Program ID: 1242453
Invoice Number: QY25894-7 Amount Due: \$400.00

Amount Remitted: \$

To ensure proper credit, please return this portion of the invoice with your payment to the address below or you may go to our agency's website: WWW.SC.DHEC.GOV then click on **PAY INVOICES** under **ONLINE SERVICES & TOOLS** or use the reverse side of this form for credit card payments. *Limit of \$3000.00 per transaction and \$1.00 convenience fee for debit/credit card payments. No limit or fee for ACH/e-checks.* Please include the invoice number on your remittance. **Payment due upon receipt, past due 30 days from invoice date. Change of address and credit card payment forms are on the reverse side.**

SC DHEC
ATTN: BUREAU OF FINANCIAL MANAGEMENT
PO BOX 100103
COLUMBIA, SC 29202-3103



RECEIVED

JUN 15 2018

WATER FACILITIES
PERMITTING DIVISION

June 06, 2018

TO: *Kristy Ellenberg*
~~Richelle Tolton~~ - 208 Planning Contact

SUBJECT: 208 plan conformance (INFORMATION ONLY)
Recommendation NOT required

1. Project Name: USDOE/ SRS/ SWPF/ NGS COLD CHEM FEED
2. County: Aiken
3. Type of Project: WWC WWTP UPGRADE(QUALITY) -
4. Type Waste: INDUSTRIAL Volume (GPD): 7200
5. Disposal Method: US DOE/SAVANNAH RIVER SITE (NPDES SC0000175)
6. Consulting Engineer: USDOE/JAMES SOMMA
7. DHEC contact: Crystal D Rippey
Industrial Wastewater Permitting
Water Facilities Permitting Division
Bureau of Water



BUREAU OF WATER

June 06, 2018

JAMES SOMMA
USDOE
BUILDING 703-C
AIKEN SC 29803

Re: **USDOE/ SRS/ SWPF/ NGS COLD CHEM FEED**
Aiken County
Application Tracking # 1242453

Dear James Somma:


The Industrial Wastewater Permitting section received an engineering submittal on the above project on 05/24/2018. In accordance with R.61-30 we have reviewed your application for completeness. Based on our review, your project application package is administratively incomplete. For this reason, your project will not be in line for a technical review until you satisfy the deficiencies noted below. As a courtesy, we have logged in your project and will keep it here pending your complete response. To complete your application package, please provide the following items:

1. A SC-registered PE must sign and seal and date all plans and specifications and the **Certificate of Authorization (COA)** from the engineering firm must also be affixed near the PE seal. Please resubmit these documents with the appropriate seals. Please note: Each page of design drawings or plans must include the COA and the PE seal/signature with the date regardless of whether or not they are in a bound document that is signed, sealed, dated, and affixed with the COA.

Please return the above noted items as soon as possible. Failure to submit these items will result in significant delays in the review process.

Also, please note that any land clearing activity that is being performed in relation to this project must be permitted under the State Sediment and Erosion Control Program. For more information contact Ann Clark at (803) 898-4028.

If you have any questions, please do not hesitate to contact this office at 803-898-4300.

Sincerely,

Linda S Harrell
Industrial Wastewater Permitting Section
Water Facilities Permitting Division

May 23, 2018

SRR-SWPF-2018-00030
RSM Tracking No.: 10667

Mr. Barry S. Mullinax, Professional Engineer
South Carolina Department of Health and
Environmental Bureau of Water
South Carolina Department of Health and
Environmental Control
2600 Bull Street
Columbia, South Carolina 29201-1208
Savannah River Nuclear Solutions

Dear Mr. Mullinax:

**CONSTRUCTION PERMIT APPLICATION – WATER/WASTEWATER FACILITIES – SALT
WASTE PROCESSING FACILITY (SWPF)**

On behalf of the U.S. Department of Energy and Parsons Government Services, please find the following documents attached for review and approval:

1. Construction Permit Application and Engineering Report for the SWPF – Next Generation Solvent (NGS) Cold Chemical Feed Facility (3 copies)
2. Location Maps (3 copies)
3. Signed and Sealed Engineering Reports (3 copies)
4. One Application Fee

Your timely review and processing of the construction permit application package is requested.

Should you have any questions or concerns, please feel free to contact me at (803) 208-1468.



Keith D. Harp
SWPF Integration Program Manager

csw/jf

c: P. A. Marks, 704-122S
S. S. Farrell, 704-122S
S. A. Stewart, 730-B
K. P. Guay, 704-125S
SWPFDCA, 704-127 S

W. F. Anderson, 766-H
K. R. Liner, 704-S
G. R. Huff, 707-18E
J. S. Kirk, 766-H
K. Smith, 766-H

RECEIVED

MAY 24 2018

WATER FACILITIES
PERMITTING DIVISION



Construction Permit Application

Water/Wastewater Facilities

BUREAU OF WATER

DELEGATED REVIEW PROJECT SUBMITTAL: Yes EXPEDITED REVIEW PROGRAM SUBMITTAL: Yes

SELECT ONE Water Facilities Wastewater Facilities Combined Water & Wastewater Facilities

I. **Project Name:** Next Generation Solvent Cold Chemical Feed Facility County: Aiken

II. **Project Location** (street names, etc.): Savannah River Site, Aiken SC

III. **Project Description(s):** Water System:

RECEIVED

MAY 24 2018

Wastewater System: This application describes the location and configuration of the proposed Next Generation Solvent (NGS) Cold Chemical Feed Facility at the Salt Waste Processing Facility (SWPF)

WATER FACILITIES
PERMITTING DIVISION

Project Type (A-Z): Water: Wastewater: Z (See instructions for the appropriate project code)

IV. **Initial Owner:** [Time of Application] Name/Organization: USDOE-Owner

Address: 1080 Silver Bluff Road (Attn: Frank Sheppard, Jr.) City: Aiken State: SC Zip: 29803

Phone #: (803) 643-7100 E-mail (Initial Owner):

V. **Final Owner:** [After Construction] Name/Organization: USDOE-Owner

Address: Bldg. 703-B, Room 321 (Attn: J. Demass) City: Aiken State: SC Zip: 29808

Phone #: (803) 952-8261 E-mail (Final Owner): jim.demass@srs.gov

VI. **Entity Responsible for Final Operation & Maintenance of System:**

Water System: Name: N/A Address:

City: State: Zip: Phone#: () Fax#: ()

Wastewater System: Name: USDOE-Owner Address: Bldg. 703-B, Room 321 (Attn: J. Demass)

City: Aiken State: SC Zip: 29808 Phone#: (803) 952-8261 Fax#: ()

VII. **Engineering Firm:** Name: N/A Address:

City: State: Zip: Phone #: () Fax #: ()

E-mail (Design Engineer):

VIII. **Is this project:** A) Part of a phased project? No Yes . If Yes, Phase of

B) A revision to a previously permitted project? No Yes . If Yes, Permit#: 19,219-IW

Date Approved: 8/6/08 Project name (if different): Salt Waste Processing Facility

C) Submitted based on a Schedule of Compliance or Order issued by DHEC? No Yes . Order #:

D) Anticipating funding by the State Revolving Fund (SRF)? No Yes .

E) Crossing a water body (e.g., river, creek)? No Yes . If Yes, Name of waterbody:

IX. **Are Standard Specifications approved by DHEC being used on this project?** No Yes . If Yes:

Water: Date Approved: Approved for whom:

Wastewater: Date Approved: Approved for whom:

X. **Wastewater Systems:** A) Type: Domestic Process (Industrial) Combined (Domestic & Process)

B) *Average Design Flow* 1. Project: 7,200 GPD 2. Treatment system: N/A GPD

C) *Sewers or Pretreatment* 1. Name of facility (e.g., POTW) treating the wastewater:

2. NPDES/ND Number of facility in Item #1:

Treatment Systems 3. Date Preliminary Engineering Report (PER) approved:

4. NPDES/ND application submitted? No Yes . If Yes, Date:

Disposal Sites 5. Effluent Disposal Site (Description):

6. Sludge Disposal Site (Description):

XI. **Water Systems:** Project located within city limits? No Yes .

Public water system providing water. Name: _____ System #: _____

New water system (including master meter)? No Yes . If Yes, System name: _____

XII. **Type of Submittal:** Complete **Section A (Standard)** or **Section B (Delegated Review Program - DRP)**.

A) Standard Submittal *must* include the following:

- 1. A transmittal letter outlining the submittal package.
- 2. The **original** construction permit application, properly completed, with one (1) copy.
- 3. Three (3) sets of signed and sealed plans and one (1) set of construction specifications. Specifications may be omitted if approved standard specifications are on file with DHEC. Four (4) sets of plans are required for a combined submittal, if the project includes a wastewater treatment facility.
- 4. One (1) set of the appropriate design calculations. **WASTEWATER:** Design flow (based on R.61-67, Appendix A), pump station calc's. and pump curve. **WATER:** Recent flow test from a location near the tie-on site, design calc's. indicating pressure maintained in the distribution system during max. instantaneous demand, fire flow and flushing velocities achieved. Number/types of service connections, well record form, pumping test results, etc.
- 5. Three (3) copies of a detailed 8½" x 11" location map, separate from the plans.
- 6. Two (2) copies of construction easements unless the project owner has the right of eminent domain.
- 7. A letter(s) from the entity supplying water and/or providing wastewater treatment stating their willingness and ability to serve the project, (state the flow, number of lots, etc.), including pretreatment permits, if applicable.
- 8. A letter(s) from the entity agreeing to be responsible for the operation and maintenance (O&M) of the systems.
- 9. Application fee enclosed \$ 400.00. (Refer to Instructions).
- 10. **WATER SYSTEMS:** a) A letter from the local government which has potable water planning authority over the area, if applicable, in which the project is located, stating project consistency with water supply service plan for area.
b) For wells, four (4) copies of a well head protection area inventory.
c) For new wells, a viability demonstration is required in accordance with Regulation 61-58.1.B.(4).

Note: Other approvals may include 208 (wastewater only) and OCRM CZC Certification, and navigable waterway permitting. To expedite the project review, the 208 and OCRM CZC Certification may be included with the project submittal.

B) DRP submittal *must* include the following:

- 1. A transmittal letter, signed by the professional engineer representing the DRP entity, noting this is a DRP submittal. The letter should state that the project has been reviewed and complies with R.61-58 and/or R.61-67.
- 2. The **original** construction permit application, properly completed, with one (1) copy.
- 3. Two (2) sets of the signed and sealed plans.
- 4. One (1) set of the appropriate design calculations. **WASTEWATER:** Same information as required under Section XII.A.4. above. **WATER:** Same information as required under Section XII.A.4. above.
- 5. One (1) copy of a detailed 8½" x 11" location map, separate from the plans.
- 6. Two (2) copies of construction easements, unless the project owner has the right of eminent domain.
- 7. DHEC's OCRM CZC Certification (for water and/or wastewater facilities, in the eight coastal counties, etc.).
- 8. DHEC's Water Quality permit or conditions for placement in navigable waters, and other Agency Approvals.
- 9. **WASTEWATER SYSTEMS:** a) A letter of acceptance from the entity providing the treatment of the wastewater that includes the specific flow and, when applicable, the specific number of lots being accepted.
b) A letter from the organization agreeing to be responsible for the O&M of the wastewater system.
c) The 208 Plan certification from the appropriate Council of Governments (designated 208 areas), or from the Council on the non-designated 208 areas.
- 10. **WATER SYSTEMS:** A letter from the local government which has potable water planning authority over the area, if applicable, in which the project is located, stating project consistency with water supply service plan for area.
- 11. Fee of \$75 for water and \$75 for wastewater (\$150 if combined).

Note: The DRP entity should ensure that a copy of the final approved plans are returned to the design engineer.

XIII. Construction plans, material and construction specifications, the engineering report including supporting design calculations are herewith submitted and made a part of this application. I have placed my signature and seal on the engineering documents submitted, signifying that I accept responsibility for the design of this system, and that I have submitted a complete administrative package.


Engineer's Name (Printed): James C. Souza Signature: [Signature] No. 14718
S.C. Registration Number: 14718 Registered Professional Engineer


XIV. Prior to final approval, I will submit a statement certifying that construction is complete and in accordance with the approved plans and specifications, to the best of my knowledge, information and belief. This certification will be based upon periodic observations of construction and a final inspection for design compliance by me or a representative of the office who is under my supervision.

Engineer's Name (Printed): James C. Souza Signature: [Signature] No. 14718
S.C. Registration Number: 14718 Registered Professional Engineer



XV. I hereby make application for a permit to construct the project as described above. I have read this application and agree to the requirements and conditions and agree to the admission of properly authorized persons at all reasonable hours for the purpose of sampling and inspection.

Owner's Name (Printed): FRANK SHEPPARD Signature: [Signature]
Owner's Title: SENIOR VP / SUPP PRES. MGMT Date: 5/10/18





LOCATION MAP - SAVANNAH RIVER SITE



LOCATION MAP - SWPF



PARSONS	1080 Silver Bluff Rd. ~ Aiken, SC 29803 (803) 643-7101	DRAWING No.	Sheet No.	LATEST REVISION
UNITED STATES DEPARTMENT OF ENERGY		AS SHOWN	1	1
SAVANNAH RIVER SITE		Site Location Map		
SWPF		SITE LOCATION MAP		

United States Department of Energy

**Savannah River Site
Aiken, South Carolina**

Engineering Report

for

NGS Cold Chemical Feed Facility

Prepared By

PARSONS

1080 Silver Bluff Road
Aiken, South Carolina 29803

for the

United States Department of Energy

20194-IW 6/21/18


Barry Mullinax
BARRY
MULLINAX

Function: Environmental Permitting
Doc. No.: Q-PER-J-00007
Revision: 0
Date: 05/10/2018

RECEIVED

MAY 24 2018

WATER FACILITIES
PERMITTING DIVISION



SUMMARY OF CHANGES

Revision No.	Date	Description of Change
0	05/10/2018	Developed per DMR-4365. Engineering report needed to support the Industrial Wastewater Permit for NGS Building.

TABLE OF CONTENTS

1.0 ENGINEERING REPORT1

2.0 BACKGROUND INFORMATION1

3.0 LOCATION AND FACILITY LAYOUT1

4.0 PROJECT DESCRIPTION4

5.0 PROCESS DESCRIPTION4

5.1 Boric Acid Strip Solution4

 5.1.1 Receipt of Concentrated Boric Acid.....5

 5.1.2 Preparation of Boric Acid Strip Solution5

 5.1.3 Transfer of Boric Acid Strip Solution to SWPF5

5.2 Caustic Scrub Solution5

 5.2.1 Preparation of Caustic Scrub Solution5

 5.2.2 Transfer of Caustic Scrub Solution to SWPF6

6.0 MODIFICATION DESIGN.....6

 6.1 Piping Design6

 6.2 Tank and Vessel Design.....6

 6.3 Secondary Containment6

 6.4 Process Controls.....7

7.0 OPERATIONS AND MAINTENANCE.....7

8.0 AIR EMISSIONS.....7

 8.1 Toxic and Criteria Pollutant Emissions.....7

9.0 REFERENCES.....7

List of Figures

Figure 3-1. NGS Cold Chemical Feed Facility Location2

Figure 3-2. Three Dimensional Design View of the NGS Cold Chemical Feed Facility.....3

List of Appendices

Appendix A. CCFF General Arrangement

Appendix B. CCFF Process Flow Drawings

Appendix C. CCFF Pump Performance Curves and Calculations

Appendix D. CCFF Equipment List

LIST OF ACRONYMS AND ABBREVIATIONS

°F	degrees Fahrenheit
API	American Petroleum Institute
ASME	American Society of Mechanical Engineers
BPCS	Basic Process Control System
CCA	Cold Chemicals Area
CCFF	Cold Chemical Feed Facility
Cs	Cesium
CSSX	Caustic-side Solvent Extraction
DOE	U.S. Department of Energy
DWPF	Defense Waste Processing Facility
ER	Engineering Report
H ₃ BO ₃	Boric Acid
LWR	Liquid Radioactive Waste
M	Molar
Mgal	Million Gallons
NaOH	Sodium Hydroxide (Caustic)
NGS	Next Generation Solvent
SCDHEC	South Carolina Department of Health and Environmental Control
SCR	South Carolina Regulation
SRNS	Savannah River Nuclear Solutions
SRS	Savannah River Site
SWPF	Salt Waste Processing Facility
wt%	Weight Percent

1.0 ENGINEERING REPORT

This Engineering Report (ER) is being submitted pursuant to South Carolina Regulation (SCR) 61-67 (*Standards for Wastewater Facility Construction*¹) to allow the construction of a new Next Generation Solvent (NGS) Cold Chemical Feed Facility (CCFF). This ER describes the location, industrial wastewater treatment processes, and configuration of the proposed new Salt Waste Processing Facility (SWPF) NGS CCFF at Savannah River Site (SRS).

2.0 BACKGROUND INFORMATION

This ER describes a modification at SWPF that requires a construction permit that is in addition to the SWPF Industrial Wastewater Treatment Permit (Construction Permit No. 19219-IW) issued by South Carolina Department of Health and Environmental Control (SCDHEC). The construction of CCFF is required to support deployment of NGS at SWPF. The deployment of NGS, developed through research funded by the U.S. Department of Energy (DOE), for use at SWPF will improve the Cesium (Cs) removal from treated waste and increase the overall throughput of SWPF. The purpose of the proposed CCFF is to receive, dilute, and then transfer the chemicals to SWPF that are necessary for deployment of NGS at SWPF.

3.0 LOCATION AND FACILITY LAYOUT

The CCFF will be constructed adjacent to SWPF in J-Area at SRS, located East of the SWPF Process Building and South of the SWPF Administrative Building. See Figure 3-1 for detailed location of the CCFF.

The CCFF is divided into two diked process areas (i.e., the caustic scrub diked area and the Boric Acid [H_3BO_3] diked area) and one NGS work area that contain a total of seven process pumps, three chemical storage tanks, two process heaters, and one chemical metering pump skid. Also, each diked area is equipped with a collection sump that is piped to a common sump pump. Figure 3-2 provides a three-dimensional design view of the NGS CCFF. Appendix A provides general arrangement of CCFF equipment.

Figure 3-1.1. NGS Cold Chemical Feed Facility Location






Figure 3-2. Three Dimensional Design View of the NGS Cold Chemical Feed Facility



4.0 PROJECT DESCRIPTION

The SWPF is tasked with processing 34 Million gallons (Mgal) of liquid radioactive waste (LRW) stored as salt solution or saltcake in the SRS tank farms. One operational step in the processing of LRW is the Caustic-side Solvent Extraction (CSSX) for removal of Cs. The baseline CSSX process uses a specially engineered solvent that selectively removes Cs. As part of the CSSX process, the engineered solvent must be scrubbed for removal of impurities with 0.05 Molar (M) Nitric Acid and then stripped of Cs with 0.001M Nitric Acid.

Through research funded by the DOE, a NGS has been developed and tested to improve Cs removal and increase LRW throughput in SWPF. Deployment of NGS in the CSSX process at SWPF requires the use of different cold chemicals for scrubbing and stripping of NGS. The installation of CCFF will provide the source of these new scrubbing and stripping chemical solutions.

The scope of this modification is to install systems that will:

1. Receive and provide storage of approximately 2,500 gallons of 0.45M H_3BO_3 . H_3BO_3 will be received from either a chemical tote or tanker truck.
2. Prepare and provide storage for approximately 2,500 gallons of 0.01M H_3BO_3 solution to be used as the strip solution for NGS. Process water for this dilution process will be provided from SWPF.
3. Heat the 0.01M H_3BO_3 strip solution and transfer to SWPF strip contactors.
4. Prepare and provide storage for approximately 2,500 gallons of 0.025M Caustic scrub solution. Caustic and process water required for preparation of scrub solution will be provided from SWPF.
5. Transfer the 0.025M Sodium Hydroxide (NaOH) scrub solution to the SWPF scrub contactors.

These systems will operate 24/7 in conjunction with SWPF, except for outages and times of maintenance.

5.0 PROCESS DESCRIPTION

The CCFF will store and provide chemicals to SWPF that are required for scrubbing and stripping the NGS being deployed in the SWPF CSSX process (see Appendix B through Appendix D). This facility will not process or utilize any radioactive fluids.

5.1 Boric Acid Strip Solution

The purpose of the H_3BO_3 strip solution system is to provide 0.01M H_3BO_3 to the strip stages of the CSSX process for removal of Cs from the Cs-laden solvent stream flowing through the SWPF extraction contactors.

5.1.1 Receipt of Concentrated Boric Acid

The 0.45M H_3BO_3 is normally delivered by tanker truck to the Boric Acid Strip Receipt Tank (TK-710) via the SWPF Cold Chemicals Area (CCA) Receiving Dock. Alternatively, 0.45M H_3BO_3 may be delivered directly to the CCFE via chemical totes.

5.1.2 Preparation of Boric Acid Strip Solution

H_3BO_3 strip solution is made up in the Boric Acid Strip Feed Tank (TK-720) by mixing process water with 0.45M H_3BO_3 (from the Boric Acid Strip Receipt Tank [TK-710]). Process water is provided from the existing Process Water Tank (TK-301) in SWPF.

5.1.3 Transfer of Boric Acid Strip Solution to SWPF

When the SWPF CSSX process is operating, the strip contactors continuously use the 0.01M H_3BO_3 strip solution. One of the CCFE Boric Acid Strip Feed Pumps (P-720A/B) provides the strip solution to SWPF. A Boric Acid Strip Feed Heater (HTR-720A/B), installed on the discharge side of each Boric Acid Strip Feed Pump, maintains the strip solution between 86 degrees Fahrenheit ($^{\circ}F$) and 96 $^{\circ}F$, improving its stripping performance.

When the SWPF is out of operation for an extended period, transfer of 0.01M H_3BO_3 strip solution from CCFE to SWPF is ceased. In place of this continuous transfer, 0.45M H_3BO_3 (from the Boric Acid Strip Receipt Tank [TK-710]) is batch transferred to the existing Strip Effluent Hold Tank (TK-205) in SWPF via the Boric Acid Strip Charge Pump (P-711). The concentrated H_3BO_3 is eventually transferred from SWPF to the Defense Waste Processing Facility (DWPF) in order to support continued formulation of the DWPF glass recipe. The transfer of 0.01M H_3BO_3 strip solution resumes once SWPF operation is restarted.

5.2 Caustic Scrub Solution

The purpose of the caustic scrub solution system is to provide 0.025M NaOH to the scrub stages of the CSSX process for removal of soluble salts from the solvent stream exiting the SWPF extraction contactors.

5.2.1 Preparation of Caustic Scrub Solution

Caustic scrub is made up in the Caustic Scrub Tank (TK-730) by mixing process water with 50 weight percent (wt%) NaOH. Process water is provided from the existing Process Water Tank (TK-301) in SWPF. The 50 wt% NaOH is provided from the existing Caustic Receipt Tank (TK-302) in SWPF.

Alternatively, a dilute caustic solution can be made up in one of two existing SWPF tanks and provided to the CCFE. The dilute caustic solution may be provided from SWPF via either the Caustic Cleaning Tank (TK-107) or the Caustic Makeup Tank (TK-303) to the CCFE Caustic Scrub Tank (TK-730), where additional dilution with process water can be performed as required to create 0.025M NaOH.

5.2.2 Transfer of Caustic Scrub Solution to SWPF

When the SWPF CSSX process is operating, the scrub contactors continuously use the 0.025M NaOH scrub solution. One of the CCFE Caustic Scrub Feed Pumps (P-730A/B) provides the scrub solution to SWPF. When the SWPF is out of operation for an extended period, transfer of 0.025M NaOH scrub solution from CCFE to SWPF is ceased. The transfer of scrub solution resumes once SWPF operations is restarted.

6.0 MODIFICATION DESIGN

6.1 Piping Design

Process piping installed for the CCFE modification shall be designed, fabricated, examined, and tested in accordance with American Society of Mechanical Engineers (ASME) B31.3-2002, *Process Piping*² requirements.

6.2 Tank and Vessel Design

Cold chemical storage tanks (Boric Acid Strip Receipt Tank [TK-710], Boric Acid Strip Feed Tank [TK-720] and the Caustic Scrub Tank [TK-730]) shall be designed, fabricated, examined and tested in accordance with the American Petroleum Institute (API) 650, *Welded Steel Tanks for Oil Storage*³ requirements.

Pressure vessels installed for the CCFE modification (Boric Acid Strip Feed Heaters [HTR-720A/B] and Fire Protection Water Surge Tank [TK-014]) shall be designed, fabricated, examined and tested in accordance with ASME Section VIII, Division 1, *Boiler and Pressure Vessel Code*⁴ requirements.

6.3 Secondary Containment

Major process equipment within the CCFE is located within concrete diked areas that provide secondary containment for leaks resulting from equipment failure or from routine operation and maintenance activities. Each diked area is capable of containing 100% minimum of contents of the largest tank located within the diked area. The floor of each diked area is sloped to a sump, equipped with leak detection and alarm, which can be pumped to a tanker truck via NGS Sump Pump (P-740).

Chemicals for use in the CCFE are received at the SWPF CCA receiving dock, where they are unloaded from a tanker truck and transferred either directly (H_3BO_3) or indirectly (NaOH) to the CCFE. The CCA receiving dock area provides containment of chemical spills and is sloped to a sump that collects spillage for disposition by SWPF personnel. Personnel performing activities associated with receipt of CCFE chemicals will be SWPF trained and qualified operators, working to approved procedures.

6.4 Process Controls

Normal operations sequences for the CCFF are automated and are controlled/monitored by the SWPF Basic Process Control System (BPCS). The BPCS is also responsible for gathering and recording process data to provide process history from the CCFF.

7.0 OPERATIONS AND MAINTENANCE

SWPF trained and qualified operations personnel will operate the equipment per approved procedures. Normal operations will not require “hands on” activities with the equipment within the CCFF.

SWPF trained and qualified maintenance personnel will perform required maintenance of equipment per approved procedures, work orders and per equipment manufacturer Installation-Operation-Maintenance manuals.

8.0 AIR EMISSIONS

8.1 Toxic and Criteria Pollutant Emissions

Emissions from CCFF have been evaluated (see Savannah River Nuclear Solutions [SRNS]-J2210-2017-00224, *Supporting Documentation for Emission Rate Calculations for Three Tanks Located in Building Southeast of 221-J [006J, 007J, and 008J]*⁵) and it has been determined that no toxic or criteria pollutants will be emitted from each of the three tanks in CCFF. Based upon Section A, Item 19 of SCDHEC, *Bureau of Air Quality Permitting Exemption List (December 2016)*⁶ these sources are considered insignificant and are not required to be documented with respect to construction permitting. Based upon Section A, Item 25 of SCDHEC *Insignificant Activities List for S.C. Regulation 61-62.70 “Title V Operating Permit Program”*⁷, these tanks are considered insignificant and are not required to be included in a Title V permit application.


9.0 REFERENCES

-
- ¹ SCR 61-67, *South Carolina Standards for Wastewater Facility Construction*. South Carolina Department of Health and Environmental Control, Columbia, South Carolina. May 24, 2002.
 - ² ASME B31.3, *Process Piping*. American Society of Mechanical Engineers, New York, New York. May 1, 2002.
 - ³ API 650, *Welded Steel Tanks for Oil Storage*. 11th Edition American Petroleum Institute, Washington D.C. November 1, 1998, including Addendum 1 (2008) and Addendum 2 (2009).
 - ⁴ ASME Section VIII, Division 1, *Boiler and Pressure Vessel Code*. American Society of Mechanical Engineers, New York, New York. 2004.
-

-
- ⁵ SRNS-J2210-2017-00224, *Supporting Documentation for Emission Rate Calculations for Three Tanks Located in Building Southeast of 221-J (006J, 007J, and 008J)*. Letter from K.A. Wolfe (SRNS) to A.R. Waller (SRNS). November 6, 2017.
- ⁶ SCDHEC, *Bureau of Air Quality Permitting Exemption List (December 2016)*. South Carolina Department of Health and Environmental Control. 2016.
(<http://www.scdhec.gov/ENVIRONMENT/DOCS/NEWEXEMPTIONS.PDF>)
- ⁷ SCDHEC *Insignificant Activities List for S.C. Regulation 61-62.70 "Title V Operating Permit Program"*. South Carolina Department of Health and Environmental Control. Revised February 4, 2013.
(http://www.scdhec.gov/environment/docs/air_Activities4SC.pdf)
-

Appendix A. CCFE General Arrangement

*P-PG-J-0024, SWPF Next Generation Solvent Building General Arrangement Plan at
Elevation 98'-9" And Sections (U)*




PLAN AT ELEVATION 98'-9"

NEXT GENERATION SOLVENT - PROCESS EQUIPMENT

EQUIPMENT	QTY	TYPE	SIZE	WGT
SOLVENT FEED TANK	2	T-100	18'-0" DIA	15,000
SOLVENT FEED TANK	2	T-100	18'-0" DIA	15,000
SOLVENT FEED TANK	2	T-100	18'-0" DIA	15,000
SOLVENT FEED TANK	2	T-100	18'-0" DIA	15,000
SOLVENT FEED TANK	2	T-100	18'-0" DIA	15,000
SOLVENT FEED TANK	2	T-100	18'-0" DIA	15,000
SOLVENT FEED TANK	2	T-100	18'-0" DIA	15,000
SOLVENT FEED TANK	2	T-100	18'-0" DIA	15,000
SOLVENT FEED TANK	2	T-100	18'-0" DIA	15,000
SOLVENT FEED TANK	2	T-100	18'-0" DIA	15,000

- EQUIPMENT DESIGNATIONS**
- PUMPS
 - P-100A
 - P-100B
 - P-100C
 - P-100D
 - P-100E
 - P-100F
 - P-100G
 - P-100H
 - P-100I
 - P-100J
 - P-100K
 - P-100L
 - P-100M
 - P-100N
 - P-100O
 - P-100P
 - P-100Q
 - P-100R
 - P-100S
 - P-100T
 - P-100U
 - P-100V
 - P-100W
 - P-100X
 - P-100Y
 - P-100Z
 - AGITATORS
 - A-100A
 - A-100B
 - A-100C
 - A-100D
 - A-100E
 - A-100F
 - A-100G
 - A-100H
 - A-100I
 - A-100J
 - A-100K
 - A-100L
 - A-100M
 - A-100N
 - A-100O
 - A-100P
 - A-100Q
 - A-100R
 - A-100S
 - A-100T
 - A-100U
 - A-100V
 - A-100W
 - A-100X
 - A-100Y
 - A-100Z
 - AIR HANDLING EQUIPMENT
 - HE-100A
 - HE-100B
 - HE-100C
 - HE-100D
 - HE-100E
 - HE-100F
 - HE-100G
 - HE-100H
 - HE-100I
 - HE-100J
 - HE-100K
 - HE-100L
 - HE-100M
 - HE-100N
 - HE-100O
 - HE-100P
 - HE-100Q
 - HE-100R
 - HE-100S
 - HE-100T
 - HE-100U
 - HE-100V
 - HE-100W
 - HE-100X
 - HE-100Y
 - HE-100Z
 - ELECTRICAL SYSTEMS
 - MS-100A
 - MS-100B
 - MS-100C
 - MS-100D
 - MS-100E
 - MS-100F
 - MS-100G
 - MS-100H
 - MS-100I
 - MS-100J
 - MS-100K
 - MS-100L
 - MS-100M
 - MS-100N
 - MS-100O
 - MS-100P
 - MS-100Q
 - MS-100R
 - MS-100S
 - MS-100T
 - MS-100U
 - MS-100V
 - MS-100W
 - MS-100X
 - MS-100Y
 - MS-100Z
 - INSTRUMENTATION SYSTEMS
 - IM-100A
 - IM-100B
 - IM-100C
 - IM-100D
 - IM-100E
 - IM-100F
 - IM-100G
 - IM-100H
 - IM-100I
 - IM-100J
 - IM-100K
 - IM-100L
 - IM-100M
 - IM-100N
 - IM-100O
 - IM-100P
 - IM-100Q
 - IM-100R
 - IM-100S
 - IM-100T
 - IM-100U
 - IM-100V
 - IM-100W
 - IM-100X
 - IM-100Y
 - IM-100Z
 - MISCELLANEOUS ITEMS
 - MT-100A
 - MT-100B
 - MT-100C
 - MT-100D
 - MT-100E
 - MT-100F
 - MT-100G
 - MT-100H
 - MT-100I
 - MT-100J
 - MT-100K
 - MT-100L
 - MT-100M
 - MT-100N
 - MT-100O
 - MT-100P
 - MT-100Q
 - MT-100R
 - MT-100S
 - MT-100T
 - MT-100U
 - MT-100V
 - MT-100W
 - MT-100X
 - MT-100Y
 - MT-100Z



NOTES

- FOR GENERAL NOTES, REFER TO ARCHITECTURAL DRAWING AND MECHANICAL DRAWING SHEET P-100-001.
- THE BUILDING ELEVATION IS BASED ON THE FINISH FLOOR ELEVATION INDICATED BY MEAN TO LEVEL.
- FOR FINISH FLOOR ELEVATION, REFER TO THE MEAN TO LEVEL.
- FOR FINISH FLOOR ELEVATION, REFER TO THE MEAN TO LEVEL.



PROJECT NO.	2019A-IW
DATE	6/24/18
DESIGNER	BRAY MULLEN
CHECKER	
APPROVER	
SCALE	AS SHOWN
SHEET NO.	34 OF 41
TITLE	APPENDIX A, LVTS GENERAL ARRANGEMENT
CLIENT	UNITED STATES DEPARTMENT OF ENERGY
PROJECT LOCATION	SAVANNAH RIVER SITE
PROJECT DESCRIPTION	NEWT GENERATION SOLVENT BUILDING GENERAL ARRANGEMENT PLAN AT ELEVATION 98'-9" AND SECTIONS
DATE	P-PS-0024
SCALE	AS SHOWN
PROJECT NO.	2019A-IW
DATE	6/24/18
DESIGNER	BRAY MULLEN
CHECKER	
APPROVER	
SCALE	AS SHOWN
SHEET NO.	34 OF 41
TITLE	APPENDIX A, LVTS GENERAL ARRANGEMENT
CLIENT	UNITED STATES DEPARTMENT OF ENERGY
PROJECT LOCATION	SAVANNAH RIVER SITE
PROJECT DESCRIPTION	NEWT GENERATION SOLVENT BUILDING GENERAL ARRANGEMENT PLAN AT ELEVATION 98'-9" AND SECTIONS
DATE	P-PS-0024
SCALE	AS SHOWN

Appendix B. CCFE Process Flow Drawings

M-M5-J-0007, *SWPF Solvent Extraction and Acid Scrub PFD (U)*

M-M5-J-0008, *SWPF Solvent Stripping and Caustic Wash PFD (U)*

M-M5-J-0010, *SWPF Cold Chemical Makeup and Process Water Tank PFD (U)*

M-M5-J-0020, *SWPF Next Generation Solvent Building Cold Chemical Makeup Tanks PFD (U)*

1. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A PRESSURE OF 100 PSIG.
2. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A TEMPERATURE OF 100°F.
3. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A FLOW RATE OF 100 GPM.
4. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A HEAD OF 100 FEET.
5. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A SPEED OF 100 RPM.
6. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A VIBRATION OF 100 IN/IN.
7. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A NOISE LEVEL OF 100 DBA.
8. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A POWER CONSUMPTION OF 100 KW.
9. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A MAINTENANCE TIME OF 100 HOURS.
10. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A SAFETY FACTOR OF 100.
11. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A RELIABILITY OF 100%.
12. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A COST OF 100,000 DOLLARS.
13. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A WEIGHT OF 100,000 LBS.
14. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A LENGTH OF 100 FEET.
15. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A WIDTH OF 100 FEET.
16. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A HEIGHT OF 100 FEET.
17. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A DEPTH OF 100 FEET.
18. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A DIAMETER OF 100 FEET.
19. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A THICKNESS OF 100 FEET.
20. THE SYSTEM SHALL BE DESIGNED TO OPERATE AT A SURFACE AREA OF 100 FEET.

APPENDIX B (continued)

APPENDIX B (continued)

APPENDIX B (continued)

APPENDIX B (continued)

APPENDIX B (continued)


APPENDIX B (continued)

APPENDIX B (continued)

APPENDIX B (continued)

APPENDIX B (continued)

APPENDIX B (continued)



NO. 14718

ITEM NO.	DESCRIPTION	QTY	UNIT	PRICE	TOTAL
1	EXTRACTOR	1	EA	100,000	100,000
2	SOLVENT TANK	1	EA	50,000	50,000
3	STILL	1	EA	30,000	30,000
4	SCRUBBER	1	EA	20,000	20,000
5	PUMP	6	EA	10,000	60,000
6	VALVE	10	EA	5,000	50,000
7	PIPE	100	FT	1,000	100,000
8	ELECTRICAL	1	EA	10,000	10,000
9	LABOR	1	EA	50,000	50,000
10	PERMITS	1	EA	10,000	10,000
11	CONTINGENCY	1	EA	10,000	10,000
12	TOTAL				600,000

2019A-IU
 6/2/18
 Bang Mullins






NOTES

1. ALL DIMENSIONS ARE IN FEET AND INCHES UNLESS OTHERWISE NOTED.
2. ALL MATERIALS SHALL BE AS SPECIFIED IN THE MATERIAL SPECIFICATIONS.
3. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE ASCE AND AIA STANDARDS.
4. ALL WORK SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE AGENCY.
5. ALL WORK SHALL BE SUBJECT TO THE AGENCY'S REQUIREMENTS FOR CONSTRUCTION.
6. ALL WORK SHALL BE SUBJECT TO THE AGENCY'S REQUIREMENTS FOR OPERATION.
7. ALL WORK SHALL BE SUBJECT TO THE AGENCY'S REQUIREMENTS FOR MAINTENANCE.
8. ALL WORK SHALL BE SUBJECT TO THE AGENCY'S REQUIREMENTS FOR SAFETY.
9. ALL WORK SHALL BE SUBJECT TO THE AGENCY'S REQUIREMENTS FOR ENVIRONMENTAL PROTECTION.
10. ALL WORK SHALL BE SUBJECT TO THE AGENCY'S REQUIREMENTS FOR QUALITY CONTROL.

REVISIONS

NO.	DATE	DESCRIPTION
1	08/14/13	ISSUED FOR PERMIT
2	08/14/13	ISSUED FOR CONSTRUCTION
3	08/14/13	ISSUED FOR OPERATION
4	08/14/13	ISSUED FOR MAINTENANCE
5	08/14/13	ISSUED FOR SAFETY
6	08/14/13	ISSUED FOR ENVIRONMENTAL PROTECTION
7	08/14/13	ISSUED FOR QUALITY CONTROL



APPROVED: SCHEC
 2014-10-10
 BY: [Signature]
 PROJECT: [Signature]

NO.	DATE	DESCRIPTION
1	08/14/13	ISSUED FOR PERMIT
2	08/14/13	ISSUED FOR CONSTRUCTION
3	08/14/13	ISSUED FOR OPERATION
4	08/14/13	ISSUED FOR MAINTENANCE
5	08/14/13	ISSUED FOR SAFETY
6	08/14/13	ISSUED FOR ENVIRONMENTAL PROTECTION
7	08/14/13	ISSUED FOR QUALITY CONTROL


NO.	DATE	DESCRIPTION
1	08/14/13	ISSUED FOR PERMIT
2	08/14/13	ISSUED FOR CONSTRUCTION
3	08/14/13	ISSUED FOR OPERATION
4	08/14/13	ISSUED FOR MAINTENANCE
5	08/14/13	ISSUED FOR SAFETY
6	08/14/13	ISSUED FOR ENVIRONMENTAL PROTECTION
7	08/14/13	ISSUED FOR QUALITY CONTROL

Appendix C. CCFE Pump Performance Curves and Calculations

1. Pump Performance Curve for P-710A/B
 2. Pump Performance Curve for P-720A/B
 3. Pump Performance Curve for P-730A/B
 4. Pump Performance Curve for P-711
 5. M-CLC-J-00223, *Boric Acid Strip Transfer Pumps Sizing Calculation, P-710A/B*
 6. M-CLC-J-00225, *Boric Acid Strip Feed Pumps Sizing Calculation, P-720A/B*
 7. M-CLC-J-00226, *Caustic Scrub Feed Pumps Sizing Calculation, P-730A/B*
 8. M-CLC-J-00224, *Boric Acid Strip Charge Pump Sizing Calculation, P-711*
-

A01
 Equipment Tag # P-710A/B
 Page 1 of 4

GA/GC6 GEARCHEM PUMP
 3/4" PORTS
 FLUID VISCOSITY 1 CPS



* BRAKE HORSEPOWER SHOWN AS DASHED CURVES



PERFORMANCE CURVE
 GA / GC6


SECTION/PAGE	C/G6 / 6601	EFFECTIVE	08/16/13	DWN BY:	PTP	AE00056-001
REF	updated drawing	08/16/13	DATE	12/01/97	DATE:	
REVISION UPDATE		DATE		SUPERSEDES		

A01

Equipment Tag # P-720A/B

Page 2 of 4

**GA/GC6 GEARCHEM PUMP
3/4" PORTS
FLUID VISCOSITY 1 CPS**




* BRAKE HORSEPOWER SHOWN AS DASHED CURVES

		SECTION/PAGE C166 / 6601		PERFORMANCE CURVE GA / GC6	
updat ed drawing REVISION UPDATE		08/16/13 DATE		DWN BY: PTP DATE: 02/11/98	
REF		SUPERSEDES 12/01/97		AE00056-001	

A01
 Equipment Tag # P-730A/B
 Page 3 of 4

**GA/GC6 GEARCHEM PUMP
 3/4" PORTS
 FLUID VISCOSITY 1 CPS**




* BRAKE HORSEPOWER SHOWN AS DASHED CURVES

		SECTION/PAGE C/G6 / 6601		ECO FIL SAFEDER <small>A Unit of DEX Corporation</small>	
		EFFECTIVE 08/16/13		PERFORMANCE CURVE GA / GC6	
REF	updated drawing	08/16/13	SUPERSEDES 12/01/97	DWN BY: PTP	AE00056-001
	REVISION UPDATE	DATE		DATE: 02/11/98	

Differential Pressure Performance Curve


P-711 Boric Acid Pump



Calculated Values
 Input Flow: 60 GPM
 Calculated Speed: 1062.11 RPM
 Power at calc speed: 5.72 BHP

Application Settings
 Model: LVP41057
 Viscosity: 0.8 cP
 Diff. Pressure: 89.9 PSI
 Temperature: 77 F
 Specific Gravity: 1

Viking Pump, A Unit of IDEX Corporation, 406 State Street, Cedar Falls, Iowa, USA, 50613.

PARSONS				
Calculation Cover Sheet				
Project: NGS Deployment at SWPF		Calculation No.: M-CLC-J-00223		Project Number: 749600
Title: Boric Acid Strip Transfer Pumps Sizing Calculation, P-710A B				Sheet 1 of 10
Software Classification: <input checked="" type="checkbox"/> N/A		Discipline: Process		<input type="checkbox"/> Preliminary <input checked="" type="checkbox"/> Confirmed
Computer Program Name <input checked="" type="checkbox"/> N/A				
<input type="checkbox"/> Software Quality Assurance Plan Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Evaluation Report Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Requirement Specification Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Design Description Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software User Documentation Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Verification/Validation Plan Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Verification/Validation Report Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Installation & Checkout Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Change Request Unique Identifier _____		Approval Date _____		
Version / Release No. _____				
Purpose and Objective The purpose of this calculation is to evaluate the design criteria for the Boric Acid Strip Transfer Pumps, P-710A.B. The objective of this calculation is to size pumps P-710A.B.				
Summary of Conclusion The design points is: 5 gpm & 15.17 psi differential pressure				
				
Revisions <i>5/10/18</i>				
Rev. No.	Revision Description -			
0	Issued for Use			
Sign Off				
Rev. No.	Originator (Print) Sign / Date	Verification / Checking Method	Verifier / Checker (Print) Sign / Date	Lead Discipline Engineer (Print) Sign / Date
0	Nicholas DesRocher <i>[Signature]</i> 10/28/17	Independent Review/ Math Check	Donna Yarbrough <i>[Signature]</i> 10-28-17	Cliff Conner <i>[Signature]</i> 10-28-17 CC

Calculation Continuation Sheet

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00223			
		Title: Boric Acid Strip Transfer Pumps Sizing Calculation, P-710A/B							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/26/2017	Donna Yarbrough	10-28-17					
Table of Contents									
									Sheet
1.0	Purpose and Objectives								3
2.0	References								3
3.0	Inputs								4
4.0	Assumptions								4
5.0	Analytical Method								5
6.0	Calculations								6
7.0	Results and/or Recommendations								7
8.0	Conclusions								7
9.0	Attachments								7
9.1	Pump Suction Line Loss Calculation, 2"								8
9.2	Pump Suction Line Loss Calculation, 3/4"								9
9.3	Pump Discharge Line Loss Calculation								10

Calculation Continuation Sheet

PARSONS		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00223			
Engineering Calculation		Title: Boric Acid Strip Transfer Pumps Sizing Calculation, P-710A/B							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/26/2017	Donna Yarbrough	10-28-17					

1.0 Purpose and Objectives

The purpose of this calculation is to evaluate the design criteria for the Boric Acid Strip Transfer Pumps, P-710A/B.

The objective of this calculation is to size pumps P-710A/B.

2.0 References

- 2.1 P-DB-J-00006, Rev. 0, NGS Deployment at SWPF Basis of Design
- 2.2 DSG-MP-03, Parsons Engineering Department Design Guide: Pump Head Calculations
- 2.3 P-PG-J-0024, Rev. 0, SWPF Next Generation Solvent Building General Arrangement Plan at Elevation 98'-9" and Sections
- 2.4 Crane, Flow of Fluids through Valves, Fittings and Pipe, Technical Paper No. 410
- 2.5 Cameron Hydraulic Data, 19th Edition
- 2.6 Pump Handbook, 2nd Edition
- 2.7 M-M6-J-0201, Rev. 5, SWPF Next Generation Solvent Building Boric Acid Strip Receipt Tank TK-710 P&ID
 M-M6-J-0202, Rev. 5, SWPF Next Generation Solvent Building Boric Acid Strip Feed Tank TK-720 P&ID
- 2.8 Specification 15120, Rev. 25, Piping Material Specification
- 2.9 M-M5-J-0020, Rev. 0, SWPF Next Generation Solvent Building Cold Chemical Makeup Tank PFD
- 2.10 P-PI-J-14-10005-01, Rev. 0, SWPF Piping Isometric 2"-BOR-10005-PS200A-
 P-PI-J-14-10005-02, Rev. 0, SWPF Piping Isometric 2"-BOR-10005-PS200A-
 P-PI-J-14-10006-01, Rev. 0, SWPF Piping Isometric 2"-BOR-10006-PS200A-
 P-PI-J-14-10007-01, Rev. 0, SWPF Piping Isometric 3/4"-BOR-10007-PS200A-
 P-PI-J-14-10008-01, Rev. 0, SWPF Piping Isometric 3/4"-BOR-10008-PS200A-
 P-PI-J-14-10008-02, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10008-PS200A-
 P-PI-J-14-10008-03, Rev. 0, SWPF Piping Isometric 3/4"-BOR-10008-PS200A-
 P-PI-J-14-10008-04, Rev. 0, SWPF Piping Isometric 2"-BOR-10008-PS200A-

Calculation Continuation Sheet

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00223			
		Title: Boric Acid Strip Transfer Pumps Sizing Calculation, P-710A/B								
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date	
0	N. DesRocher	10/26/2017	Donna Yarbrough	10-25-17						
3.0 Inputs										
3.1 Fluid Properties:										
• Fluid: Boric Acid										
• Operating Temperature 77 °F Ref. 2.9										
• Viscosity 1 cP Sec. 4.3.1										
• Specific Gravity 1 Sec. 4.3.1										
• Vapor Pressure 0.46 psia Sec. 4.3.1										
3.2 Service Conditions										
0.45M Boric Acid for Strip Solution										
3.3 Operating Conditions:										
• Normal Flow Rate 1.4 gpm Ref. 2.9										
• Design Flow Rate 5 gpm Sec. 4.3.2										
• Source Pressure 14.7 psia Ref. 2.7										
• Suction Static Head From Low Level *** -1.19 ft										
• Delivery Pressure 14.7 psia Ref. 2.7										
• Discharge Static Head *** 11.13 ft										
• Vessel PSV or Vent Setting 14.7 psia Ref. 2.7										
• Low Level ** 1 ft										
• Pump Centerline ** 2.19 ft Ref. 2.10										
• Flow Meter Pressure Drop 2 psi Sec. 4.3.4										
• Highest Pipe Elevation on Discharge Line ** 13.32 ft Ref. 2.10										
** Elevation with respect to floor elevation (98'-9")										
*** Elevation with respect to the pump centerline										
4.0 Assumptions										
4.1 Assumptions Containing Unverified Design										
None										
4.2 Assumptions Requiring Re-Verification										
4.2.1 Elevations, pipe routing, and valve cvs are based on preliminary information and will be verified with final isometrics and vendor information.										

Calculation Continuation Sheet

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00223			
		Title: Boric Acid Strip Transfer Pumps Sizing Calculation, P-710A/B								
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date	
0	N. DesRocher	10/26/2017	Donna Yarbrough	10-28-17						

4.3 Assumptions Not Requiring Re-Verification

4.3.1 The fluid properties of the 0.45M boric acid are assumed to be equal to the fluid properties of water.

4.3.2 The normal flow rate 1.4 gpm. For conservatism, the design flow rate is set at 5 gpm.

4.3.3 Piping is PS200A. Per Ref. 2.8 this is 304L SS, Sch 40S between sizes 1/2" and 6".

4.3.4 The pressure drop through the flow meter is assumed to be 2 psi.

5.0 Analytical Method

5.1 Suction Pressure:

Source pressure is calculated using Eq. 5.1
 Suction Pressure = source pressure + the suction static head from min. suction height
 - the suction line losses. Eq. 5.1

Convert Suction Static Head from feet of liquid to psi using Eq. 5.2

$$P = SG \times \rho \times \left(\frac{g}{g_c} \right) \times h \quad \text{Eq. 5.2}$$

where

ρ = density of water = 62.4 lb_m/ft³
 g = gravitational acceleration = 32.2 ft/s²
 g_c = universal constant = 32.2 (ft - lb_m)/(lb_f - s²)
 1 ft² = 144 in²

Eq. 5.2 is simplified to Eq. 5.3:
 $P = SG \times 0.433 \times h \quad \text{Eq. 5.3}$

5.2 Net Inlet Pressure

The net inlet pressure is calculated using Eq. 5.4:
 Net Inlet Pressure = suction pressure (absolute) - vapor pressure (absolute) Eq. 5.4

5.3 Discharge Pressure:

The discharge pressure is calculated using Eq. 5.5:
 Discharge Pressure = Delivery Pressure + Discharge Static Head + Dynamic line and
 component losses Eq. 5.5

Calculation Continuation Sheet

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00223			
		Title: Boric Acid Strip Transfer Pumps Sizing Calculation, P-710A/B								
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date	
0	N. DesRocher	10/26/2017	Donna Yarbrough	10-28-17						

5.4 Differential Pressure

The differential pressure is calculated using Eq. 5.6:
 Differential Pressure = discharge pressure - suction pressure **Eq. 5.6**

6.0 Calculations

6.1 Suction Pressure:

Using Eq. 5.3, the suction static head from min. suction height is:

Suction Static Head from Min. Suction Height (psi) = -0.52 psi

Using Eq. 5.1, the suction pressure is:

(from Att. 9.1 - 9.2, Suction Line Loss = 0.37 psi)

Suction Pressure = 13.81 psia

6.2 Net Inlet Pressure

Using Eq. 5.4, the net inlet pressure is:

Net Inlet Pressure = 13.35 psia

6.3 Discharge Pressure:

Using Eq. 5.3, the discharge static head is converted to psi:


Discharge Static Head = 4.82 psi

Using Eq. 5.5, the discharge pressure is:

Discharge Line Loss = 7.46 psi Att. 9.3

Discharge Pressure = 28.98 psia

Calculation Continuation Sheet

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00223																														
		Title: Boric Acid Strip Transfer Pumps Sizing Calculation, P-710A/B																																			
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date																												
0	N. DesRocher	10/26/2017	 Donna Yarbrough	10-28-17																																	
<p>6.4 Differential Pressure</p> <p>Using Eq. 5.6, the differential pressure is:</p> <p style="padding-left: 40px;">Differential Pressure = 15.17 psi</p> <p>7.0 Results and/or Recommendations</p> <table style="width:100%; border: none;"> <tr> <td style="width: 5%;">7.1</td> <td style="width: 75%;">Suction Pressure:</td> <td style="width: 15%; text-align: right;">13.81 psia</td> <td style="width: 5%; text-align: right;">Sec 6.1</td> </tr> <tr> <td>7.2</td> <td>Net Inlet Pressure:</td> <td style="text-align: right;">13.35 psia</td> <td style="text-align: right;">Sec 6.2</td> </tr> <tr> <td>7.3</td> <td>Discharge Pressure:</td> <td style="text-align: right;">28.98 psia</td> <td style="text-align: right;">Sec 6.3</td> </tr> <tr> <td>7.4</td> <td>Differential Pressure:</td> <td style="text-align: right;">15.17 psi</td> <td style="text-align: right;">Sec 6.4</td> </tr> </table> <p>8.0 Conclusions</p> <p>The design point is: 5 gpm & 15.17 psi differential pressure</p> <p>9.0 Attachments</p> <table style="width:100%; border: none;"> <tr> <td style="width: 5%;">9.1</td> <td style="width: 75%;">Pump Suction Line Loss Calculation, 2"</td> <td style="width: 10%; text-align: right;">Sheets</td> <td style="width: 5%; text-align: right;">1</td> </tr> <tr> <td>9.2</td> <td>Pump Suction Line Loss Calculation, 3/4"</td> <td style="text-align: right;">Sheets</td> <td style="text-align: right;">1</td> </tr> <tr> <td>9.3</td> <td>Pump Discharge Line Loss Calculation</td> <td style="text-align: right;">Sheets</td> <td style="text-align: right;">1</td> </tr> </table>										7.1	Suction Pressure:	13.81 psia	Sec 6.1	7.2	Net Inlet Pressure:	13.35 psia	Sec 6.2	7.3	Discharge Pressure:	28.98 psia	Sec 6.3	7.4	Differential Pressure:	15.17 psi	Sec 6.4	9.1	Pump Suction Line Loss Calculation, 2"	Sheets	1	9.2	Pump Suction Line Loss Calculation, 3/4"	Sheets	1	9.3	Pump Discharge Line Loss Calculation	Sheets	1
7.1	Suction Pressure:	13.81 psia	Sec 6.1																																		
7.2	Net Inlet Pressure:	13.35 psia	Sec 6.2																																		
7.3	Discharge Pressure:	28.98 psia	Sec 6.3																																		
7.4	Differential Pressure:	15.17 psi	Sec 6.4																																		
9.1	Pump Suction Line Loss Calculation, 2"	Sheets	1																																		
9.2	Pump Suction Line Loss Calculation, 3/4"	Sheets	1																																		
9.3	Pump Discharge Line Loss Calculation	Sheets	1																																		

Calculation Sheet

PARSONS Engineering Information Only Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00223			
		Subject: Pump Suction Line Loss Calculation, 2"								Sheet No. 8 of 10
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date	
0	N. DesRocher	10/26/2017	Donna Yarbrough	10-28-17						
Line Number:		2"-BOR-10005-PS200D			Fluid:		Boric Acid		Sec. 3.1	
P&ID Number:		M-M6-J-0201		Ref. 2.7	Flow Rate (Q) :		5 gpm		Sec. 3.1	
ISO DWG No.:		P-PI-J-14-10005-01		Ref. 2.10	Viscosity (μ):		1 cp		Sec. 3.1	
					Specific Gravity:		1		Sec. 3.1	
From: TK-710										
To: 2"x3/4"										
Basis Internal Dia.(d): 2.067 in. Internal Area = 0.023303 ft ² = π x 0.25 x d ² /144										
Surface Roughness (ε) : 0.00015 ft										
Relative Roughness ε/D: 0.000871 [2.5]										
Reynolds Number: 7,638 = $\frac{[50.6][Q][SG][62.4]}{[\mu][d]}$ [2.5]										
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.										
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = [-2] \text{Log} \left[\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{[Re][f^{1/2}]} \right]$										
Colebrook Friction Factor (f) : = 0.034 [2.4]										
Laminar Friction Factor f = 64/Re = 0.008 Velocity (v) = 0.478 fps [2.5]										
f _t = 0.019 [2.4]										
Friction Factor For This Calc. = 0.034										
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K		
1	Entrance	1	K = 0.78					0.78		
2	Pipe	82.8 in.	K = f L/d					1.36		
3	Ball Valve	1	Cv = 376 [4.2.1] K= 891 d ⁴ /Cv ²					0.12		
4	Pipe Bend (45° or 90°)	1	K = 14 f _t					0.27		
5	Tee Run	1	K = 20 f _t					0.38		
6	Tee Branch	1	K = 60 f _t					1.14		
7	Reducer	1	K = 0.5 (1- β ²) / β ⁴	0.824	2.067	0.159	0.025	16.82		
8	Total K							20.87		
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 \text{ ft}^2)}{2 g_c (144 \text{ in}^2)}$ = 0.03 psi [2.5]										


Calculation Sheet

PARSONS Engineering Information Only Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00223			
		Subject: Pump Suction Line Loss Calculation, 3/4"						Sheet No. 9 of 10	
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/26/2017	Donna Yarbrough	10-28-17					
Line Number:		3/4"-BOR-10005-PS200D			Fluid:		Boric Acid		Sec. 3.1
P&ID Number:		M-M6-J-0201 Ref. 2.7			Flow Rate (Q) :		5 gpm		Sec. 3.1
ISO DWG No.:		P-PI-J-14-10005-02 Ref. 2.10			Viscosity (μ):		1 cp		Sec. 3.1
					Specific Gravity:		1		Sec. 3.1
From: 2"x3/4"									
To: P-710A									
Basis Internal Dia.(d): <u>0.824</u> in. Internal Area = 0.003703 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε) : <u>0.00015</u> ft [2.5]									
Relative Roughness ε/D: <u>0.002184</u>									
Reynolds Number: 19,159 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = [-2] \text{Log} \left[\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{(Re)(f^{1/2})} \right]$									
Colebrook Friction Factor (f) : = 0.030 [2.4]									
Laminar Friction Factor f = 64/Re = 0.003 Velocity (v) = 3.008 fps [2.5]									
$f_l = 0.025$ [2.4]									
Friction Factor For This Calc. = 0.030									
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K	
1	Pipe	72 in.	K = f L/d					2.62	
2	Ball Valve	2	Cv = 51 [4.2.1] K= 891 d ⁴ /Cv ²					0.32	
3	Pipe Bend (45° or 90°)	2	K = 14 f _l					0.70	
4	Tee Run	1	K = 20 f _l					0.50	
5	Tee Branch	1	K = 60 f _l					1.50	
6	Total K							5.64	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$ = 0.34 psi [2.5]									

Calculation Sheet

PARSONS Engineering Information Only Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00223			
		Subject: Pump Discharge Line Loss Calculation						Sheet No. 10 of 10	
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/26/2017	Donna Yarbrough	10-26-17					
Line Number:		1/2"-BOR-10008-PS200D			Fluid:		Boric Acid		Sec. 3.1
P&ID Number:		M-M6-J-0201 Ref. 2.7			Flow Rate (Q) :		5 gpm		Sec. 3.1
ISO DWG No.:		P-PI-J-14-10008-01 to -04 Ref. 2.10			Viscosity (μ):		1 cp		Sec. 3.1
				Specific Gravity:		1		Sec. 3.1	
From: P-710A									
To: TK-720									
Basis Internal Dia.(d): <u>0.622</u> in. Internal Area = 0.00211 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε) : <u>0.00015</u> ft [2.5]									
Relative Roughness ε/D: <u>0.002894</u>									
Reynolds Number: 25,381 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = [-2] \text{Log} \left(\left[\frac{\epsilon/D}{3.7} \right] + \frac{2.51}{[Re] [f^{1/2}]} \right)$									
Colebrook Friction Factor (f) : = 0.030 [2.4]									
Laminar Friction Factor f = 64/Re = 0.003 Velocity (v) = 5.279 fps [2.5]									
$f_t = 0.027$ [2.4]									
Friction Factor For This Calc. = 0.030									
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K	
1	Pipe	450 in.	K = f L/d					21.7	
2	Ball Valve	4	Cv = 26 [4.2.1] K= 891 d ⁴ /Cv ²					0.79	
3	Check Valve	1	K = 100 f _t					2.70	
4	Pipe Bend (45° or 90°)	11	K = 14 f _t					4.16	
5	Tee Run	4	K = 20 f _t					2.16	
6	Expander	2	K = (1- β ²) ²	0.622	0.824	0.570		0.37	
7	Reducer	2	K = 0.5 (1- β ²)	0.622	0.824	0.570		0.43	
8	Tee Branch	4	K = 60 f _t					6.48	
9	Exit	1	K = 1.0					1	
10	Total K							39.79	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$ = 7.46 psi [2.5]									

PARSONS				
Calculation Cover Sheet				
Project: NGS Deployment at SWPF		Calculation No.: M-CLC-J-00225		Project Number: 749600
Title: Boric Acid Strip Feed Pumps Sizing Calculation. P-720A/B				Sheet 1 of 11
Software Classification:		<input checked="" type="checkbox"/> N/A		Discipline: Process
				<input type="checkbox"/> Preliminary <input checked="" type="checkbox"/> Confirmed
Computer Program Name		<input checked="" type="checkbox"/> N/A		
<input type="checkbox"/>	Software Quality Assurance Plan Unique Identifier _____	Approval Date _____		
<input type="checkbox"/>	Software Evaluation Report Unique Identifier _____	Approval Date _____		
<input type="checkbox"/>	Software Requirement Specification Unique Identifier _____	Approval Date _____		
<input type="checkbox"/>	Software Design Description Unique Identifier _____	Approval Date _____		
<input type="checkbox"/>	Software User Documentation Unique Identifier _____	Approval Date _____		
<input type="checkbox"/>	Software Verification-Validation Plan Unique Identifier _____	Approval Date _____		
<input type="checkbox"/>	Software Verification-Validation Report Unique Identifier _____	Approval Date _____		
<input type="checkbox"/>	Software Installation & Checkout Unique Identifier _____	Approval Date _____		
<input type="checkbox"/>	Software Change Request Unique Identifier _____	Approval Date _____		
Version / Release No. _____				
Purpose and Objective				
The purpose of this calculation is to evaluate the design criteria for the Boric Acid Strip Feed Pumps. P-720A/B.				
The objective of this calculation is to size pumps P-720A B.				
Summary of Conclusion				
The design points is: 3 gpm & 65.74 psi differential pressure				
Revisions				
Rev. No.	Revision Description -			
0	Issued for Use			
Sign Off				
Rev. No.	Originator (Print) Sign / Date	Verification / Checking Method	Verifier / Checker (Print) Sign / Date	Lead Discipline Engineer (Print) Sign / Date
0	Nicholas DesRocher <i>[Signature]</i> 11/7/17	Independent Review Math Check	Donna Yarbrough <i>[Signature]</i> 11-7-17	Cliff Conner <i>[Signature]</i> 11-7-17



Calculation Continuation Sheet

PARSONS		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00225			
Engineering Calculation		Title: Boric Acid Strip Feed Pumps Sizing Calculation, P-720AB							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-7-17					
Table of Contents									
									Sheet
1.0 Purpose and Objectives									3
2.0 References									3
3.0 Inputs									4
4.0 Assumptions									5
5.0 Analytical Method									5
6.0 Calculations									6
7.0 Results and/or Recommendations									8
8.0 Conclusions									8
9.0 Attachments									8
9.1 Pump Suction Line Loss Calculation, 1"									9
9.2 Pump Suction Line Loss Calculation, 3/4"									10
9.3 Pump Discharge Line Loss Calculation									11

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00225			
		Title: Boric Acid Strip Feed Pumps Sizing Calculation, P-720A/B							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-7-17					

1.0 Purpose and Objectives

The purpose of this calculation is to evaluate the design criteria for the Boric Acid Strip Feed Pumps, P-720A/B.

The objective of this calculation is to size pumps P-720A/B.

2.0 References

2.1 P-DB-J-00006, Rev. 0, NGS Deployment at SWPF Basis of Design

2.2 DSG-MP-03, Parsons Engineering Department Design Guide: Pump Head Calculations

2.3 P-PG-J-0024, Rev. 0, SWPF Next Generation Solvent Building General Arrangement Plan at Elevation 98'-9" and Sections

2.4 Crane, Flow of Fluids through Valves, Fittings and Pipe, Technical Paper No. 410

2.5 Cameron Hydraulic Data, 19th Edition

2.6 Pump Handbook, 2nd Edition

2.7 M-M6-J-0202, Rev. 5, SWPF Next Generation Solvent Building Boric Acid Strip Feed Tank TK-720 P&ID
 M-M6-J-0081, Rev. 11, SWPF Process Building Strip Feed Pumps P-310A/B P&ID as modified by DCN-7000
 M-M6-J-0042 SH2, Rev. 8, SWPF Process Building Stripping Contactors EXT-2030/P P&ID

2.8 Specification 15120, Rev. 25, Piping Material Specification

2.9 M-M5-J-0020, Rev. 0, SWPF Next Generation Solvent Building Cold Chemical Makeup Tanks PFD

2.10 P-PI-J-14-10011-01, Rev. 0, SWPF Piping Isometric 2"-BOR-10011-PS200A-
 P-PI-J-14-10012-01, Rev. 0, SWPF Piping Isometric 1"-BOR-10012-PS200A-
 P-PI-J-14-10013-01, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10013-PS200A-
 P-PI-J-14-10014-01, Rev. 0, SWPF Piping Isometric 2"-BOR-10014-PS200A-HCN
 P-PI-J-14-10015-01, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10015-PS200A-

2.11 P-PI-J-14-10016-01, Rev. 0, SWPF Piping Isometric 1"-BOR-10016-PS200A-HCN
 P-PI-J-14-10016-10, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10016-PS200A-HCN
 P-PI-J-15-10016-10, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10016-PS200A-ETN

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00225			
		Title: Boric Acid Strip Feed Pumps Sizing Calculation, P-720A/B							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-7-17					
<p>P-PI-J-15-10016-11, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10016-PS200A-ETN P-PI-J-15-10016-12, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10016-PS200A-ETN P-PI-J-15-10016-13, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10016-PS200A-ETN P-PI-J-15-10016-14, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10016-PS200A-ETN P-PI-J-15-10016-15, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10016-PS200A-ETN P-PI-J-03-10016-01, Rev. 0, SWPF Piping Isometric 3/4"-BOR-10016-PS200A-HCN P-PI-J-03-10016-10, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10016-PS200A-ETN P-PI-J-03-10016-11, Rev. 0, SWPF Piping Isometric 1/2"-BOR-10016-PS200A-HCN P-PI-J-03-7012-03, Rev. 4, SWPF Piping Isometric 1/2"-HNO3-7012-PS200D-HCN P-PI-J-03-7013-02, Rev. 7, SWPF Piping Isometric 3/4"-HNO3-7013-PS200D-HCN as modified by DCN-7010 P-PI-J-03-7012-10, Rev. 4, SWPF Piping Isometric 1/2"-HNO3-7012-PS200D-HCN P-PI-J-02-7012-01, Rev. 5, SWPF Piping Isometric 1/2"-HNO3-7012-PS200D-HCN P-PI-J-02-7012-02, Rev. 8, SWPF Piping Isometric 1-1/2"-HNO3-7012-PS200D-HCD P-PI-J-02-7012-10, Rev. 6, SWPF Piping Isometric 3"-HNO3-7012-PS200D-HCN</p> <p>2.12 P-DB-J-00004, Rev. 6, Salt Waste Processing Facility Balance of Plant Basis of Design</p> <p>3.0 Inputs</p> <p>3.1 Fluid Properties:</p> <ul style="list-style-type: none"> • Fluid: Boric Acid • Operating Temperature 77 °F Ref. 2.9 • Viscosity 1 cP Sec. 4.3.1 • Specific Gravity 1 Sec. 4.3.1 • Vapor Pressure 0.46 psia Sec. 4.3.1 <p>3.2 Service Conditions 0.01M Boric Acid for Solvent Stripping</p> <p>3.3 Operating Conditions:</p> <ul style="list-style-type: none"> • Normal Flow Rate 1.4 gpm Ref. 2.9 • Design Flow Rate 3 gpm Sec. 4.3.2 • Source Pressure 14.7 psia Ref. 2.7 • Suction Static Head From Low Level *** -1.19 ft • Delivery Pressure 14.56 psia Ref. 2.12 • Discharge Static Head *** 33.06 ft • Vessel PSV or Vent Setting 14.7 psia Ref. 2.7 • Low Level ** 1 ft • Pump Centerline ** 2.19 ft Ref. 2.10 									

Calculation Continuation Sheet

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00225			
		Title: Boric Acid Strip Feed Pumps Sizing Calculation, P-720A/B								
Rev 0	Originator N. DesRocher	Date 11/6/2017	Checker Donna Yarborough	Date 11-7-17	Rev	Originator	Date	Checker	Date	
<p>3.3 Operating Conditions (cont'd):</p> <ul style="list-style-type: none"> • Flow Meter Pressure Drop 2 psi Sec. 4.3.4 • Highest Pipe Elevation on Discharge Line ** 35.25 ft Ref. 2.11 • Heater Pressure Drop 5 psi Sec. 4.2.1 <p>** Elevation with respect to floor elevation (98'-9") *** Elevation with respect to the pump centerline</p> <p>4.0 Assumptions</p> <p>4.1 Assumptions Containing Unverified Design None</p> <p>4.2 Assumptions Requiring Re-Verification</p> <p>4.2.1 Elevations, pipe routing, valve cvs, and equipment pressure drops are based on preliminary information and will be verified with final isometrics and vendor information.</p> <p>4.3 Assumptions Not Requiring Re-Verification</p> <p>4.3.1 The fluid properties of the 0.01M boric acid are assumed to be equal to the fluid properties of water.</p> <p>4.3.2 The normal flow rate 1.4 gpm. For conservatism, the design flow rate is set at 3 gpm.</p> <p>4.3.3 Piping is PS200A. Per Ref. 2.8 this is 304L SS, Sch 40S between sizes 1/2" and 6".</p> <p>4.3.4 The pressure drop through the flow meter is assumed to be 2 psi.</p> <p>5.0 Analytical Method</p> <p>5.1 Suction Pressure:</p> <p>Source pressure is calculated using Eq. 5.1 Suction Pressure = source pressure + the suction static head from min. suction height - the suction line losses. Eq. 5.1</p> <p>Convert Suction Static Head from feet of liquid to psi using Eq. 5.2</p> $P = SG \times \rho \times \left(\frac{g}{g_c}\right) \times h$ Eq. 5.2										

Calculation Continuation Sheet

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00225			
		Title: Boric Acid Strip Feed Pumps Sizing Calculation, P-720A/B								
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date	
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-7-17						

where

ρ = density of water = 62.4 lb_m/ft³

g = gravitational acceleration = 32.2 ft/s²

g_c = universal constant = 32.2 (ft - lb_m)/(lb_f - s²)

1 ft² = 144 in²

Eq. 5.2 is simplified to Eq. 5.3:

$P = SG \times 0.433 \times h$ **Eq. 5.3**

5.2 Net Inlet Pressure

The net inlet pressure is calculated using Eq. 5.4:

Net Inlet Pressure = suction pressure (absolute) - vapor pressure (absolute) **Eq. 5.4**

5.3 Discharge Pressure:

The discharge pressure is calculated using Eq. 5.5:

Discharge Pressure = Delivery Pressure + Discharge Static Head + Dynamic line and component losses **Eq. 5.5**

5.4 Differential Pressure

The differential pressure is calculated using Eq. 5.6:

Differential Pressure = discharge pressure - suction pressure **Eq. 5.6**

6.0 Calculations

6.1 Suction Pressure:

Using Eq. 5.3, the suction static head from min. suction height is:

Suction Static Head from Min. Suction Height (psi) = -0.52 psi

Using Eq. 5.1, the suction pressure is:

(from Att. 9.1 & 9.2, Suction Line Loss = 0.10 psi)

Suction Pressure = 14.08 psia

PARSONS		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00225			
Engineering Calculation		Title: Boric Acid Strip Feed Pumps Sizing Calculation, P-720A/B							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-7-17					

6.2 Net Inlet Pressure

Using Eq. 5.4, the net inlet pressure is:

Net Inlet Pressure = 13.62 psia

6.3 Discharge Pressure:

Using Eq. 5.3, the discharge static head is converted to psi:

Discharge Static Head = 14.31 psi

Using Eq. 5.5, the discharge pressure is:

Discharge Line Loss = 43.95 psi Att. 9.3

Component Loss = 7.00 psi

Discharge Pressure = 79.82 psia

6.4 Differential Pressure

Using Eq. 5.6, the differential pressure is:

Differential Pressure = 65.74 psi

Calculation Continuation Sheet

PARSONS		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00225			
Engineering Calculation		Title: Boric Acid Strip Feed Pumps Sizing Calculation, P-720A/B							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-7-17					
<p>7.0 Results and/or Recommendations</p> <p>7.1 Suction Pressure: 14.08 psia Sec 6.1</p> <p>7.2 Net Inlet Pressure: 13.62 psia Sec 6.2</p> <p>7.3 Discharge Pressure: 79.82 psia Sec 6.3</p> <p>7.4 Differential Pressure: 65.74 psi Sec 6.4</p> <p>8.0 Conclusions</p> <p>The design point is: 3 gpm & 65.74 psi differential pressure</p> <p>9.0 Attachments</p> <p>9.1 Pump Suction Line Loss Calculation, 1" Sheets 1</p> <p>9.2 Pump Suction Line Loss Calculation, 3/4" Sheets 1</p> <p>9.3 Pump Discharge Line Loss Calculation Sheets 1</p>									


PARSONS Engineering Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00225			
		Subject: Pump Suction Line Loss Calculation, 1"						Sheet No. 9 of 11	
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-7-17					
Line Number:		1"-BOR-10011-PS200A			Fluid:		Boric Acid		Sec. 3.1
P&ID Number:		M-M6-J-0202			Flow Rate (Q) :		3 gpm		Sec.3.3
ISO DWG No.:		P-PI-J-14-10011-01			Viscosity (μ):		1 cp		Sec. 3.1
					Specific Gravity:		1.00		Sec. 3.1
From: TK-720									
To: 1"x3/4" reducer									
Basis Internal Dia.(d): 1.049 in. Internal Area = 0.006002 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε) : 0.00015 ft [2.5]									
Relative Roughness ε/D: 0.001716									
Reynolds Number: 9,030 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = [-2] \text{Log} \left[\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{(Re)(f^{1/2})} \right]$									
Colebrook Friction Factor (f) : = 0.034 [2.4]									
Laminar Friction Factor f = 64/Re = 0.007 Velocity (v) = 1.114 fps [2.5]									
Friction Factor For This Calc. = 0.034 f _i = 0.023 [2.4]									
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K	
1	Entrance	1	K = 0.78					0.78	
2	Pipe	138 in.	K = fL/d					4.47	
3	Ball Valve	2	Cv = 68 [4.2.1] K= 891 d ⁴ /Cv ²					0.47	
4	Pipe Bend (45° or 90°)	2	K = 14 f _i					0.64	
5	Tee Run	1	K = 20 f _i					0.46	
6	Tee Branch	1	K = 60 f _i					1.38	
7	Reducer	1	K = 0.5 (1- β ²)	1.049	2.067	0.258	0.067	0.37	
8	Total K							8.57	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$ = 0.07 psi [2.5]									

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00225			
		Subject: Pump Suction Line Loss Calculation, 3/4"						Sheet No. 10 of 11	
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-7-17					
Line Number:		3/4"-BOR-10011-PS200A			Fluid:		Boric Acid		Sec. 3.1
P&ID Number:		M-M6-J-0202			Flow Rate (Q) :		3 gpm		Sec.3.3
ISO DWG No.:		P-PI-J-14-10011-01			Viscosity (μ):		1 cp		Sec. 3.1
					Specific Gravity:		1.00		Sec. 3.1
From: 1"x3/4"									
To: P-720A									
Basis Internal Dia.(d): <u>0.824</u> in. Internal Area = 0.003703 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε) : <u>0.00015</u> ft [2.5]									
Relative Roughness ε/D: <u>0.002184</u>									
Reynolds Number: 11,496 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = (-2) \text{Log} \left(\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{[Re] (f^{1/2})} \right)$									
Colebrook Friction Factor (f) : = 0.033 [2.4]									
Laminar Friction Factor f = 64/Re = 0.006 Velocity (v) = 1.805 fps [2.5]									
Friction Factor For This Calc. = 0.033 f _t = 0.025 [2.4]									
Item	Component	QTY	"K" Formula	d ₁	d ₂	β ²	β ⁴	K	
1	Pipe	12 in.	K = f L/d					0.48	
2	Ball Valve	1	Cv = 51 [4.2.1] K= 891 d ⁴ /Cv ²					0.16	
3	Reducer	1	K = 0.5 (1- β ²)	0.824	1.049	0.617		0.19	
4	Pipe Bend (45° or 90°)	1	K = 14 f _t					0.35	
5	Total K							1.18	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$ = 0.03 psi [2.5]									

Calculation Sheet

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00225			
		Subject: Pump Discharge Line Loss Calculation							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-7-17					
Line Number:		1/2"-BOR-10013/14/16-PS200A/-HNO3-7013/7012-PS200D			Fluid:		Boric Acid		Sec. 3.1
P&ID Number:		M-M6-J-0202, -0081, -0042SH2 Ref. 2.7			Flow Rate (Q) :		3 gpm		Sec.3.3
ISO DWG No.:		See Ref. 2.10 and 2.11			Viscosity (μ):		1 cp		Sec. 3.1
					Specific Gravity:		1.00		Sec. 3.1
From: P-720A									
To: SB-310									
Basis Internal Dia.(d): <u>0.622</u> in. Internal Area = 0.00211 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε) : <u>0.00015</u> ft [2.5]									
Relative Roughness ε/D: <u>0.002894</u>									
Reynolds Number: 15,229 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = [-2] \text{ Log } \left[\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{(Re)(f^{1/2})} \right]$									
Colebrook Friction Factor (f) : = 0.033 [2.4]									
Laminar Friction Factor f = 64/Re = 0.004 Velocity (v) = 3.167 fps [2.5]									
Friction Factor For This Calc. = 0.033 f _t = 0.027 [2.4]									
Item	Component	QTY	"K" Formula	d ₁	d ₂	β ²	β ⁴	K	
1	Pipe	11,400 in.	K = f L/d					604.82	
2	Ball Valve	3	Cv = 26 [4.2.1] K= 891 d ⁴ /Cv ²					0.59	
3	Check Valve	1	K = 100 f _t					2.70	
4	Pipe Bend (45° or 90°)	75	K = 14 f _t					28.35	
5	Tee Run	10	K = 20 f _t					5.40	
6	Tee Branch	5	K = 60 f _t					8.10	
7	Reducer	1	K = 0.5 (1- β ²)	0.622	0.824	0.570		0.22	
8	Exit	1	K = 1.0					1	
9	Total K							651.20	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$ = 43.95 psi [2.5]									

PARSONS				
Calculation Cover Sheet				
Project: NGS Deployment at SWPF		Calculation No.: M-CLC-J-00226		Project Number: 749600
Title: Caustic Scrub Feed Pumps Sizing Calculation, P-730A/B				Sheet 1 of 9
Software Classification: <input checked="" type="checkbox"/> N/A		Discipline: Process		<input type="checkbox"/> Preliminary <input checked="" type="checkbox"/> Confirmed
Computer Program Name <input checked="" type="checkbox"/> N/A				
<input type="checkbox"/> Software Quality Assurance Plan Unique Identifier	_____	Approval Date _____		
<input type="checkbox"/> Software Evaluation Report Unique Identifier	_____	Approval Date _____		
<input type="checkbox"/> Software Requirement Specification Unique Identifier	_____	Approval Date _____		
<input type="checkbox"/> Software Design Description Unique Identifier	_____	Approval Date _____		
<input type="checkbox"/> Software User Documentation Unique Identifier	_____	Approval Date _____		
<input type="checkbox"/> Software Verification Validation Plan Unique Identifier	_____	Approval Date _____		
<input type="checkbox"/> Software Verification Validation Report Unique Identifier	_____	Approval Date _____		
<input type="checkbox"/> Software Installation & Checkout Unique Identifier	_____	Approval Date _____		
<input type="checkbox"/> Software Change Request Unique Identifier	_____	Approval Date _____		
Version / Release No. _____				
Purpose and Objective				
The purpose of this calculation is to evaluate the design criteria for the Caustic Scrub Feed Pumps, P-730A-B.				
The objective of this calculation is to size pumps P-730A-B.				
Summary of Conclusion				
The design points is: 3 gpm & 55.40 psi differential pressure				
Revisions				
Rev. No.	Revision Description -			
0	Issued for Use			
Sign Off				
Rev. No.	Originator (Print) Sign / Date	Verification / Checking Method	Verifier / Checker (Print) Sign / Date	Lead Discipline Engineer (Print) Sign / Date
0	Nicholas DesRocher <i>7/27/11/6/17</i>	Independent Review Math Check	Donna Yarbrough <i>7/27/11/6/17</i>	Cliff Conner <i>7/27/11/6/17</i>



PARSONS Engineering Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00226			
		Title: Caustic Scrub Feed Pumps Sizing Calculation, P-730AB							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-6-17					
Table of Contents									
									Sheet
1.0 Purpose and Objectives									3
2.0 References									3
3.0 Inputs									4
4.0 Assumptions									5
5.0 Analytical Method									5
6.0 Calculations									6
7.0 Results and/or Recommendations									7
8.0 Conclusions									7
9.0 Attachments									7
9.1 Pump Suction Line Loss Calculation									8
9.2 Pump Discharge Line Loss Calculation									9

PARSONS		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00226			
Engineering Calculation		Title: Caustic Scrub Feed Pumps Sizing Calculation, P-730A/B							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-6-17					

1.0 Purpose and Objectives

The purpose of this calculation is to evaluate the design criteria for the Caustic Scrub Feed Pumps, P-730A/B.

The objective of this calculation is to size pumps P-730A/B.

2.0 References

2.1 P-DB-J-00006, Rev. 0, NGS Deployment at SWPF Basis of Design

2.2 DSG-MP-03, Parsons Engineering Department Design Guide: Pump Head Calculations

2.3 P-PG-J-0024, Rev. 0, SWPF Next Generation Solvent Building General Arrangement Plan at Elevation 98'-9" and Sections

2.4 Crane, Flow of Fluids through Valves, Fittings and Pipe, Technical Paper No. 410

2.5 Cameron Hydraulic Data, 19th Edition

2.6 Pump Handbook, 2nd Edition

2.7 M-M6-J-0203, Rev. 5, SWPF Next Generation Solvent Building Caustic Scrub Feed Tank TK-730 P&ID
 M-M6-J-0082, Rev. 9, SWPF Process Building Nitric Acid Scrub Makeup Tank P&ID as modified by DCN-7000
 M-M6-J-0038, Rev. 0, SWPF Process Building Scrub Contactors EXT-202A/B P&ID

2.8 Specification 15120, Rev. 25, Piping Material Specification

2.9 M-M5-J-0020, Rev. 0, SWPF Next Generation Solvent Building Cold Chemical Makeup Tanks PFD

2.10 P-PI-J-14-10024-01, Rev. 0, SWPF Piping Isometric 2"-NAOH-10024-PS200A-
 P-PI-J-14-10024-02, Rev. 0, SWPF Piping Isometric 1"-NAOH-10024-PS200A-
 P-PI-J-14-10025-01, Rev. 0, SWPF Piping Isometric 1"-NAOH-10025-PS200A-

2.11 P-PI-J-14-10026-01, Rev. 0, SWPF Piping Isometric 3/4"-NAOH-10026-PS200A-
 P-PI-J-14-10027-01, Rev. 0, SWPF Piping Isometric 3/4"-NAOH-10027-PS200A-
 P-PI-J-14-10027-10, Rev. 0, SWPF Piping Isometric 1/2"-NAOH-10027-PS200A-
 P-PI-J-15-10027-10, Rev. 0, SWPF Piping Isometric 1/2"-NAOH-10027-PS200A-ETN

Calculation Continuation Sheet

PARSONS		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00226			
Engineering Calculation		Title: Caustic Scrub Feed Pumps Sizing Calculation, P-730A/B								
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date	
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-6-17						
<p>P-PI-J-15-10027-11, Rev. 0, SWPF Piping Isometric 1/2"-NAOH-10027-PS200A-ETN P-PI-J-15-10027-12, Rev. 0, SWPF Piping Isometric 1/2"-NAOH-10027-PS200A-ETN P-PI-J-15-10027-13, Rev. 0, SWPF Piping Isometric 1/2"-NAOH-10027-PS200A-ETN P-PI-J-15-10027-14, Rev. 0, SWPF Piping Isometric 1/2"-NAOH-10027-PS200A-ETN P-PI-J-15-10027-15, Rev. 0, SWPF Piping Isometric 1/2"-NAOH-10027-PS200A-ETN P-PI-J-03-10027-01, Rev. 0, SWPF Piping Isometric 3/4"-NAOH-10027-PS200A- P-PI-J-03-10027-10, Rev. 0, SWPF Piping Isometric 1/2"-NAOH-10027-PS200A-ETN P-PI-J-03-10027-11, Rev. 0, SWPF Piping Isometric 1/2"-NAOH-10027-PS200A- P-PI-J-03-7037-03, Rev. 4, SWPF Piping Isometric 1/2"-HNO3-7037-PS200D- as modified by DCN-7010 P-PI-J-03-7037-10, Rev. 6, SWPF Piping Isometric 1/2"-HNO3-7037-PS200D- P-PI-J-02-7037-01, Rev. 4, SWPF Piping Isometric 1/2"-HNO3-7037-PS200D- P-PI-J-02-7037-02, Rev. 5, SWPF Piping Isometric 1/2"-HNO3-7037-PS200D-</p> <p>2.12 P-DB-J-00004, Rev. 6, Salt Waste Processing Facility Balance of Plant Basis of Design</p> <p>3.0 Inputs</p> <p>3.1 Fluid Properties:</p> <ul style="list-style-type: none"> • Fluid: Dilute NaOH • Operating Temperature 77 °F Ref. 2.9 • Viscosity 1 cP Sec. 4.3.1 • Specific Gravity 1 Sec. 4.3.1 • Vapor Pressure 0.46 psia Sec. 4.3.1 <p>3.2 Service Conditions Dilute (0.025M) NaOH for CSSX Scrub</p> <p>3.3 Operating Conditions:</p> <ul style="list-style-type: none"> • Normal Flow Rate 1.4 gpm Ref. 2.9 • Design Flow Rate 3 gpm Sec. 4.3.2 • Source Pressure 14.7 psia Ref. 2.7 • Suction Static Head From Low Level *** -1.19 ft • Delivery Pressure 14.56 psia Ref. 2.12 • Discharge Static Head *** 26.19 ft • Vessel PSV or Vent Setting 14.7 psia Ref. 2.7 • Low Level ** 1 ft • Pump Centerline ** 2.19 ft Ref. 2.10 • Flow Meter Pressure Drop 2 psi Sec. 4.3.4 										

Calculation Continuation Sheet

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00226			
		Title: Caustic Scrub Feed Pumps Sizing Calculation, P-730A/B								
Rev 0	Originator N. DesRocher	Date 11/6/2017	Checker Donna Yarbrough	Date 11-6-17	Rev	Originator	Date	Checker	Date	
<p>• Highest Pipe Elevation on Discharge Line ** 28.38 ft Ref. 2.11</p> <p>** Elevation with respect to floor elevation (98'-9")</p> <p>*** Elevation with respect to the pump centerline</p> <p>4.0 Assumptions</p> <p>4.1 Assumptions Containing Unverified Design None</p> <p>4.2 Assumptions Requiring Re-Verification</p> <p>4.2.1 Elevations, pipe routing, valve cvs, and equipment pressure drops are based on preliminary information and will be verified with final isometrics and vendor information.</p> <p>4.3 Assumptions Not Requiring Re-Verification</p> <p>4.3.1 The fluid properties of the 0.025M NaOH are assumed to be equal to the fluid properties of water.</p> <p>4.3.2 The normal flow rate 1.4 gpm. For conservatism, the design flow rate is set at 3 gpm.</p> <p>4.3.3 Piping is PS200A. Per Ref. 2.8 this is 304L SS, Sch 40S between sizes 1/2" and 6".</p> <p>4.3.4 The pressure drop through the flow meter is assumed to be 2 psi.</p> <p>5.0 Analytical Method</p> <p>5.1 Suction Pressure:</p> <p>Source pressure is calculated using Eq. 5.1 Suction Pressure = source pressure + the suction static head from min. suction height - the suction line losses. Eq. 5.1</p> <p>Convert Suction Static Head from feet of liquid to psi using Eq. 5.2</p> $P = SG \times \rho \times \left(\frac{g}{g_c} \right) \times h \quad \text{Eq. 5.2}$ <p>where</p> <p>ρ = density of water = 62.4 lb_m/ft³</p> <p>g = gravitational acceleration = 32.2 ft/s²</p> <p>g_c = universal constant = 32.2 (ft - lb_m)/(lb_f - s²)</p>										

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00226			
		Title: Caustic Scrub Feed Pumps Sizing Calculation, P-730A/B								
Rev 0	Originator N. DesRocher	Date 11/6/2017	Checker Donna Yarbrough	Date 11-6-17	Rev	Originator	Date	Checker	Date	
<p>1 ft² = 144 in² Eq. 5.2 is simplified to Eq. 5.3: $P = SG \times 0.433 \times h$ Eq. 5.3</p> <p>5.2 Net Inlet Pressure</p> <p>The net inlet pressure is calculated using Eq. 5.4: Net Inlet Pressure = suction pressure (absolute) - vapor pressure (absolute) Eq. 5.4</p> <p>5.3 Discharge Pressure:</p> <p>The discharge pressure is calculated using Eq. 5.5: Discharge Pressure = Delivery Pressure + Discharge Static Head + Dynamic line and component losses Eq. 5.5</p> <p>5.4 Differential Pressure</p> <p>The differential pressure is calculated using Eq. 5.6: Differential Pressure = discharge pressure - suction pressure Eq. 5.6</p> <p>6.0 Calculations</p> <p>6.1 Suction Pressure:</p> <p>Using Eq. 5.3, the suction static head from min. suction height is:</p> <p>Suction Static Head from Min. Suction Height (psi) = -0.52 psi</p> <p>Using Eq. 5.1, the suction pressure is: (from Att. 9.1, Suction Line Loss = 0.08 psi)</p> <p>Suction Pressure = 14.10 psia</p> <p>6.2 Net Inlet Pressure</p> <p>Using Eq. 5.4, the net inlet pressure is:</p> <p>Net Inlet Pressure = 13.64 psia</p>										

Calculation Continuation Sheet


PARSONS		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00226																					
Engineering Calculation		Title: Caustic Scrub Feed Pumps Sizing Calculation, P-730A/B																									
Rev 0	Originator N. DesRocher	Date 11/6/2017	Checker Donna Yarbrough	Date 11-6-17	Rev	Originator	Date	Checker	Date																		
<p>6.3 Discharge Pressure:</p> <p>Using Eq. 5.3, the discharge static head is converted to psi:</p> <p>Discharge Static Head = 11.34 psi</p> <p>Using Eq. 5.5, the discharge pressure is:</p> <p>Discharge Line Loss = 41.60 psi Att. 9.2</p> <p>Discharge Pressure = 69.50 psia</p> <p>6.4 Differential Pressure</p> <p>Using Eq. 5.6, the differential pressure is:</p> <p>Differential Pressure = 55.40 psi</p> <p>7.0 Results and/or Recommendations</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 15%;">7.1 Suction Pressure:</td> <td style="width: 40%;">14.10 psia</td> <td style="width: 45%; text-align: right;">Sec 6.1</td> </tr> <tr> <td>7.2 Net Inlet Pressure:</td> <td>13.64 psia</td> <td style="text-align: right;">Sec 6.2</td> </tr> <tr> <td>7.3 Discharge Pressure:</td> <td>69.50 psia</td> <td style="text-align: right;">Sec 6.3</td> </tr> <tr> <td>7.4 Differential Pressure:</td> <td>55.40 psi</td> <td style="text-align: right;">Sec 6.4</td> </tr> </table> <p>8.0 Conclusions</p> <p>The design point is: 3 gpm & 55.40 psi differential pressure</p> <p>9.0 Attachments</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 70%;">9.1 Pump Suction Line Loss Calculation</td> <td style="width: 10%; text-align: right;">Sheets</td> <td style="width: 20%; text-align: right;">1</td> </tr> <tr> <td>9.2 Pump Discharge Line Loss Calculation</td> <td style="text-align: right;">Sheets</td> <td style="text-align: right;">1</td> </tr> </table>										7.1 Suction Pressure:	14.10 psia	Sec 6.1	7.2 Net Inlet Pressure:	13.64 psia	Sec 6.2	7.3 Discharge Pressure:	69.50 psia	Sec 6.3	7.4 Differential Pressure:	55.40 psi	Sec 6.4	9.1 Pump Suction Line Loss Calculation	Sheets	1	9.2 Pump Discharge Line Loss Calculation	Sheets	1
7.1 Suction Pressure:	14.10 psia	Sec 6.1																									
7.2 Net Inlet Pressure:	13.64 psia	Sec 6.2																									
7.3 Discharge Pressure:	69.50 psia	Sec 6.3																									
7.4 Differential Pressure:	55.40 psi	Sec 6.4																									
9.1 Pump Suction Line Loss Calculation	Sheets	1																									
9.2 Pump Discharge Line Loss Calculation	Sheets	1																									

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00226			
		Subject: Pump Suction Line Loss Calculation							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-6-17					
Line Number:		1"-NAOH-10024-PS200A			Fluid:		Dilute NaOH		
P&ID Number:		M-M6-J-0203			Flow Rate (Q) :		3 gpm		
ISO DWG No.:		P-PI-J-10024-01, -02			Viscosity (μ):		1 cp		
					Specific Gravity:		1.00		
From: TK-730									
To: P-730B									
Basis Internal Dia.(d): <u>1.049</u> in. Internal Area = 0.006002 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε) : <u>0.00015</u> ft [2.5]									
Relative Roughness ε/D: <u>0.001716</u>									
Reynolds Number: 9,030 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = (-2) \log \left(\frac{\epsilon/D}{3.7} + \frac{2.51}{Re \sqrt{f^{1/2}}} \right)$									
Colebrook Friction Factor (f) : = 0.034 [2.4]									
Laminar Friction Factor f = 64/Re = 0.007 Velocity (v) = 1.114 fps [2.5]									
Friction Factor For This Calc. = 0.034 f _l = 0.023 [2.4]									
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K	
1	Entrance	1	K = 0.78					0.78	
2	Pipe	130.8 in.	K = f L/d					4.24	
3	Ball Valve	2	Cv = 68 [4.2.1] K = 891 d ⁴ /Cv ²					0.47	
4	Pipe Bend (45° or 90°)	3	K = 14 f _l					0.97	
5	Tee Run	2	K = 20 f _l					0.92	
6	Tee Branch	1	K = 60 f _l					1.38	
7	Reducer	1	K = 0.5 (1- β ²)	1.049	2.067	0.258		0.37	
8	Reducer	1	K = 0.5 (1- β ²) / β ⁴	0.824	1.049	0.617	0.381	0.50	
9	Total K							9.63	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$ = 0.08 psi [2.5]									

Calculation Sheet

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00226			
		Subject: Pump Discharge Line Loss Calculation							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	11/6/2017	Donna Yarbrough	11-6-17					
Line Number:		1/2"-NAOH-10027-PS200A/-HNO3-7037-PS200D			Fluid:		Dilute NaOH		Sec. 3.1
P&ID Number:		M-M6-J-0203, -0082, -0038 Ref. 2.7			Flow Rate (Q) :		3 gpm		Sec. 3.1
ISO DWG No.:		See Ref. 2.11			Viscosity (μ):		1 cp		Sec. 3.1
					Specific Gravity:		1.00		Sec. 3.1
From: P-730B									
To: SB-309									
Basis Internal Dia.(d): 0.622 in. Internal Area = 0.00211 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε) : 0.00015 ft [2.5]									
Relative Roughness ε/D: 0.002894									
Reynolds Number: 15,229 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = [-2] \text{Log} \left[\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{(Re)(f^{1/2})} \right]$									
Colebrook Friction Factor (f) : = 0.033 [2.4]									
Laminar Friction Factor f = 64/Re = 0.004 Velocity (v) = 3.167 fps [2.5]									
Friction Factor For This Calc. = 0.033 f _t = 0.027 [2.4]									
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K	
1	Pipe	10,800 in.	K = f L/d					573.00	
2	Ball Valve	3	Cv = 26 [4.2.1] K= 891 d ⁴ /Cv ²					0.59	
3	Check Valve	2	K = 100 f _t					5.40	
4	Pipe Bend (45° or 90°)	60	K = 14 f _t					22.68	
5	Tee Run	10	K = 20 f _t					5.40	
6	Tee Branch	5	K = 60 f _t					8.10	
7	Reducer	1	K = 0.5 (1- β ²)	0.622	0.824	0.570		0.22	
8	Exit	1	K = 1.0					1	
9	Total K							616.4	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 \text{ ft}^2)}{2 g_c (144 \text{ in}^2)}$ = 41.60 psi [2.5]									

PARSONS				
Calculation Cover Sheet				
Project: NGS Deployment at SWPF		Calculation No.: M-CLC-J-00224		Project Number: 749600
Title: Boric Acid Strip Charge Pump Sizing Calculation, P-711				Sheet 1 of 15
Software Classification: <input checked="" type="checkbox"/> N/A		Discipline: Process		<input type="checkbox"/> Preliminary <input checked="" type="checkbox"/> Confirmed
Computer Program Name <input checked="" type="checkbox"/> N/A				
<input type="checkbox"/> Software Quality Assurance Plan Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Evaluation Report Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Requirement Specification Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Design Description Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software User Documentation Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Verification/Validation Plan Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Verification/Validation Report Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Installation & Checkout Unique Identifier _____		Approval Date _____		
<input type="checkbox"/> Software Change Request Unique Identifier _____		Approval Date _____		
Version / Release No. _____				
Purpose and Objective The purpose of this calculation is to evaluate the design criteria for the Boric Acid Strip Charge Pump. P-711. The objective of this calculation is to size pump P-711.				
Summary of Conclusion The design points are: 60 gpm & 10.33 psi differential pressure 10 gpm & 65.07 psi differential pressure				
Revisions				
Rev. No.	Revision Description -			
0	Issued for Use			
Sign Off				
Rev. No.	Originator (Print) Sign / Date	Verification / Checking Method	Verifier / Checker (Print) Sign / Date	Lead Discipline Engineer (Print) Sign / Date
0	Nicholas DesRocher <i>Nicholas DesRocher</i> 10/25/17	Independent Review/ Math Check	Donna Yarbrough <i>Donna Yarbrough</i> 10-25-17	Cliff Conner <i>Cliff Conner</i> 10-25-17 CC 10-25-17



PARSONS Engineering Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00224			
		Title: Boric Acid Strip Charge Pump Sizing Calculation, P-711								
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date	
0	N. DesRocher	10/24/2017	Donna Yarbrough	10-25-17						
Table of Contents										
									Sheet	
1.0 Purpose and Objectives									3	
2.0 References									3	
3.0 Inputs									4	
4.0 Assumptions									5	
5.0 Analytical Method									6	
6.0 Calculations									7	
7.0 Results and/or Recommendations									8	
8.0 Conclusions									8	
9.0 Attachments										
9.1 Pump Suction Line Loss Calculation, 60 gpm									9	
9.2 Pump Suction Line Loss Calculation, 10 gpm									10	
9.3 Pump Discharge Line Loss Calculation, to Tee, 60 gpm									11	
9.4 Pump Discharge Line Loss Calculation, to Tee, 10 gpm									12	
9.5 Pump Discharge Line Loss Calculation, Tee to TK-720									13	
9.6 Pump Discharge Line Loss Calculation, Tee to SB-205, 1-1/2"									14	
9.7 Pump Discharge Line Loss Calculation, Tee to SB-205, 1/2"									15	

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00224			
		Title: Boric Acid Strip Charge Pump Sizing Calculation, P-711							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/24/2017	Donna Yarbrough	10-25-17					

1.0 Purpose and Objectives

The purpose of this calculation is to evaluate the design criteria for the Boric Acid Strip Charge Pump, P-711.

The objective of this calculation is to size pumps P-711.

2.0 References

2.1 P-DB-J-00006, Rev. 0, NGS Deployment at SWPF Basis of Design

2.2 DSG-MP-03, Parsons Engineering Department Design Guide: Pump Head Calculations

2.3 P-PG-J-0024, Rev. 0, SWPF Next Generation Solvent Building General Arrangement Plan at Elevation 98'-9" and Sections

2.4 Crane, Flow of Fluids through Valves, Fittings and Pipe, Technical Paper No. 410

2.5 Cameron Hydraulic Data, 19th Edition

2.6 P-DB-J-00004, Rev. 5, Salt Waste Processing Facility Project Balance of Plant Basis of Design

2.7 M-M6-J-0201, Rev. 5, SWPF Next Generation Solvent Building Boric Acid Strip Receipt Tank TK-710 P&ID
 M-M6-J-0202, Rev. 5, SWPF Next Generation Solvent Building Boric Acid Strip Feed Tank TK-720 P&ID
 M-M6-J-0024, Rev. 6, SWPF Process Building Central Processing Area Breakpots P&ID as modified by DCN-7000

2.8 Specification 15120, Rev. 25, Piping Material Specification

2.9 M-M5-J-0020, Rev. 0, SWPF Next Generation Solvent Building Cold Chemical Makeup Tanks PFD

2.10 P-PI-J-14-10005-01, Rev. 0, SWPF Piping Isometric 2"-BOR-10005-PS200D-
 P-PI-J-14-10006-01, Rev. 0, SWPF Piping Isometric 2"-BOR-10006-PS200D-
 P-PI-J-14-10006-02, Rev. 0, SWPF Piping Isometric 2"-BOR-10006-PS200D-

2.11 P-PI-J-14-10009-01, Rev. 0, SWPF Piping Isometric 2"-BOR-10009-PS200D-
 P-PI-J-14-10009-10, Rev. 0, SWFP Piping Isometric 1-1/2"-BOR-10009-PS200D-
 P-PI-J-14-10040-01, Rev. 0, SWPF Piping Isometric 2"-BOR-10040-PS200D-
 P-PI-J-14-10040-02, Rev. 0, SWPF Piping Isometric 2"-BOR-10040-PS200D-
 P-PI-J-15-10009-10, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D-ETN

Calculation Continuation Sheet

PARSONS		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00224			
Engineering Calculation		Title: Boric Acid Strip Charge Pump Sizing Calculation, P-711							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/24/2017	Donna Yarbrough	10-25-17					
<p>P-PI-J-15-10009-11, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D-ETN P-PI-J-15-10009-12, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D-ETN P-PI-J-15-10009-13, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D-ETN P-PI-J-15-10009-14, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D-ETN P-PI-J-15-10009-15, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D-ETN P-PI-J-03-10009-10, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D-ETN P-PI-J-03-10009-11, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D- P-PI-J-03-10009-12, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D- P-PI-J-02-10009-01, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D- P-PI-J-01-10009-01, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D- P-PI-J-01-10009-02, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D- P-PI-J-01-10009-10, Rev. 0, SWPF Piping Isometric 1-1/2"-BOR-10009-PS200D-</p> <p>2.12 51086-SDC-0008, Rev. 0, Flow Coefficients: Max Cv & Cv Curve Top Entry 00909-SDC-001, Rev. 6, Valve Drawings</p> <p>2.13 <u>Pump Handbook</u>, 2nd Edition</p> <p>2.14 P-PI-J-01-7213-01, Rev. 8, SWPF Piping Isometric 3/4"-NAOH-7213-PS200D- as modified by DCN-7010 P-PI-J-01-7213-02, Rev. 5, SWPF Piping Isometric 1/2"-NAOH-7213-PS200D as modified by DCN-7010 P-PI-J-01-7213-03, Rev. 5, SWPF Piping Isometric 3/4"-NAOH-7213-PS200D- P-PI-J-01-7213-04, Rev. 0, SWPF Piping Isometric 3/4"-NAOH-7213-PS200D-</p> <p>3.0 Inputs</p> <p>3.1 Fluid Properties:</p> <ul style="list-style-type: none"> • Fluid: Boric Acid • Operating Temperature 77 °F Ref. 2.9 • Viscosity 1 cP Sec. 4.3.1 • Specific Gravity 1 Sec. 4.3.1 • Vapor Pressure 0.46 psia Sec. 4.3.1 <p>3.2 Service Conditions 0.45M Boric Acid for Strip Solution and Concentrated Supply to DWPF</p> <p>3.3 Operating Conditions:</p> <ul style="list-style-type: none"> • Design Flow Rate, to TK-720 60 gpm Sec. 4.3.3 • Design Flow Rate, to SB-205 10 gpm Sec. 4.3.3 • Source Pressure 14.7 psia Ref. 2.7 									

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00224			
		Title: Boric Acid Strip Charge Pump Sizing Calculation, P-711								
Rev 0	Originator N. DesRocher	Date 10/24/2017	Checker Donna Yarbrough	Date 10-25-17	Rev	Originator	Date	Checker	Date	
<p>3.3 Operating Conditions (cont'd):</p> <ul style="list-style-type: none"> • Suction Static Head From Low Level *** -1.4 ft • Delivery Pressure, TK-720 14.7 psia Ref. 2.7 • Delivery Pressure, SB-205 14.56 psia Ref. 2.6 • Discharge Static Head, TK-720 *** 11.10 ft • Discharge Static Head, SB-205 *** 52.10 ft • Vessel PSV or Vent Setting 14.7 psia Ref. 2.7 • Low Level ** 1 ft Ref. 2.10 • Pump Centerline ** 2.4 ft Ref. 2.10 • Flow Meter Pressure Drop 2 psi Sec. 4.3.2 • Highest Pipe Elevation on Discharge Line, TK-720 ** 13.5 ft Ref. 2.10 • Highest Pipe Elevation on Discharge Line, SB-205 ** 54.5 ft Ref. 2.14 <p>** Elevation with respect to floor elevation (98'-9") *** Elevation with respect to the pump centerline</p> <p>4.0 Assumptions</p> <p>4.1 Assumptions Containing Unverified Design</p> <p style="padding-left: 20px;">Npne</p> <p>4.2 Assumptions Requiring Re-Verification</p> <p>4.2.1 Elevations, pipe routing, and valve cvs are based on preliminary information and will be verified with final isometrics and vendor information.</p> <p>4.3 Assumptions Not Requiring Re-Verification</p> <p>4.3.1 The fluid properties of the 0.45M boric acid are assumed to be equal to the fluid properties of water.</p> <p>4.3.2 The pressure drop through the flow meter is assumed to be 2 psi.</p> <p>4.3.3 Factoring in line lengths and fill volumes, the flow rate is conservatively assumed to be 60 gpm to TK-720 and 10 gpm to SB-205.</p>										

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF						Calculation No. M-CLC-J- 00224	
		Title: Boric Acid Strip Charge Pump Sizing Calculation, P-711							
Rev 0	Originator N. DesRocher	Date 10/24/2017	Checker Donna Yarbrough	Date 10-25-17	Rev	Originator	Date	Checker	Date

5.0 Analytical Method

5.1 Suction Pressure:

Source pressure is calculated using Eq. 5.1
 Suction Pressure = source pressure + the suction static head from min. suction height - the suction line losses. Eq. 5.1

Convert Suction Static Head from feet of liquid to psi using Eq. 5.2

$$P = SG \times \rho \times \left(\frac{g}{g_c} \right) \times h \quad \text{Eq. 5.2}$$

where

ρ = density of water = 62.4 lb_m/ft³
 g = gravitational acceleration = 32.2 ft/s²
 g_c = universal constant = 32.2 (ft - lb_m)/(lb_f - s²)
 1 ft² = 144 in²

Eq. 5.2 is simplified to Eq. 5.3:
 $P = SG \times 0.433 \times h$ Eq. 5.3

5.2 Net Inlet Pressure

The net inlet pressure is calculated using Eq. 5.4:
 Net Inlet Pressure = suction pressure (absolute) - vapor pressure (absolute) Eq. 5.4

5.3 Discharge Pressure:

The discharge pressure is calculated using Eq. 5.5:
 Discharge Pressure = Delivery Pressure + Discharge Static Head + Dynamic line and component losses Eq. 5.5

5.4 Differential Pressure

The differential pressure is calculated using Eq. 5.6:
 Differential Pressure = discharge pressure - suction pressure Eq. 5.6

Calculation Continuation Sheet

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF						Calculation No. M-CLC-J- 00224	
		Title: Boric Acid Strip Charge Pump Sizing Calculation, P-711							
Rev 0	Originator N. DesRocher	Date 10/24/2017	Checker Donna Yarbrough	Date 10-25-17	Rev	Originator	Date	Checker	Date

6.0 Calculations

6.1 Suction Pressure:

Using Eq. 5.3, the suction static head from min. suction height is:
 Suction Static Head from Min. Suction Height (psi) = -0.61 psi

Using Eq. 5.1, the suction pressure is:

(from Att. 9.1 Suction Line Loss	=	1.35 psi	(to TK-720)
(from Att. 9.2 Suction Line Loss	=	0.04 psi	(to SB-205)

Suction Pressure	=	12.74 psia	(to TK-720)
Suction Pressure	=	14.05 psia	(to SB-205)

6.2 Net Inlet Pressure

Using Eq. 5.4, the net inlet pressure is:

Net Inlet Pressure	=	12.28 psia	(to TK-720)
Net Inlet Pressure	=	13.59 psia	(to SB-205)

6.3 Discharge Pressure:

Using Eq. 5.3, the discharge static head is converted to psi:

Discharge Static Head	=	4.81 psi	(to TK-720)
Discharge Static Head	=	22.56 psi	(to SB-205)

Using Eq. 5.5, the discharge pressure is:

Discharge Line Loss	=	1.56 psi	(to TK-720)	Att. 9.3, Att. 9.5
Discharge Line Loss	=	38.00 psi	(to SB-205)	Att. 9.4, Att. 9.6, Att. 9.7

Discharge Pressure	=	23.07 psia	(to TK-720)
Discharge Pressure	=	79.12 psia	(to SB-205)

6.4 Differential Pressure

Using Eq. 5.6, the differential pressure is:

Differential Pressure	=	10.33 psi	(to TK-720)
Differential Pressure	=	65.07 psi	(to SB-205)

PARSONS Engineering Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00224			
		Title: Boric Acid Strip Charge Pump Sizing Calculation, P-711							
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/24/2017	Donna Yarbrough	10-25-17					
7.0 Results and/or Recommendations									
7.1	Suction Pressure:		12.74 psia	(to TK-720)					Sec 6.1
			14.05 psia	(to SB-205)					Sec 6.1
7.2	Net Inlet Pressure:		12.28 psia	(to TK-720)					Sec 6.2
			13.59 psia	(to SB-205)					Sec 6.2
7.3	Discharge Pressure:		23.07 psia	(to TK-720)					Sec 6.3
			79.12 psia	(to SB-205)					Sec 6.3
7.4	Differential Pressure:		10.33 psi	(to TK-720)					Sec 6.4
			65.07 psi	(to SB-205)					Sec 6.4
7.0 Conclusions									
	The design points are:		60 gpm & 10.33 psi differential pressure						
			10 gpm & 65.07 psi differential pressure						
8.0 Attachments									
8.1	Pump Suction Line Loss Calculation, 60 gpm							Sheets	1
8.2	Pump Suction Line Loss Calculation, 10 gpm							Sheets	1
8.3	Pump Discharge Line Loss Calculation, to Tee, 60 gpm							Sheets	1
8.4	Pump Discharge Line Loss Calculation, to Tee, 10 gpm							Sheets	1
8.5	Pump Discharge Line Loss Calculation, Tee to TK-720							Sheets	1
8.6	Pump Discharge Line Loss Calculation, Tee to SB-205, 1-1/2"							Sheets	1
8.7	Pump Discharge Line Loss Calculation, Tee to SB-205, 1/2"							Sheets	1

PARSONS Engineering Information Only Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00224		
		Subject: Pump Suction Line Loss Calculation, 60 gpm							Sheet No. 9 of 15
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/24/2017	Donna Yarbrough	10-25-17					
Line Number:		2"-BOR-10006-PS200D			Fluid:		Boric Acid		Sec. 3.1
P&ID Number:		M-M6-J-0201 Ref. 2.7			Flow Rate (Q) :		60 gpm		Sec. 3.1
ISO DWG No.:		P-PI-J-14-10006-01/-02, -10005-01 Ref. 2.10			Viscosity (μ):		1 cp		Sec. 3.1
					Specific Gravity:		1.00		Sec. 3.1
From: TK-710									
To: P-711									
Basis Internal Dia.(d): <u>2.067</u> in. Internal Area = 0.023303 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε) : <u>0.00015</u> ft									
Relative Roughness ε/D: <u>0.000871</u> [2.5]									
Reynolds Number: 91,653 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = [-2] \text{Log} \left[\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{(Re)(f^{1/2})} \right]$									
Colebrook Friction Factor (f) : = 0.022 [2.4]									
Laminar Friction Factor f = 64/Re = 0.001 Velocity (v) = 5.736 fps [2.5]									
Friction Factor For This Calc. = 0.022 f _t = 0.019 [2.4]									
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K	
1	Entrance	1	K = 0.78					0.78	
2	Pipe	188 in.	K = fL/d					2.00	
3	Ball Valve	2	Cv = 376 [4.2.1] K= 891 d ⁴ /Cv ²					0.23	
4	Pipe Bend (45° or 90°)	3	K = 14 f _t					0.80	
5	Tee Run	3	K = 20 f _t					1.14	
6	Tee Branch	1	K = 60 f _t					1.14	
7	Total K							6.09	
Pressure Drop: = $\frac{K SG \rho_{H2O}}{2 g_c} \left(\frac{v^2 \text{ ft}^2}{144 \text{ in}^2} \right)$ = 1.35 psi [2.5]									

PARSONS Engineering		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00224			
Information Only Calculation		Subject: Pump Suction Line Loss Calculation, 10 gpm						Sheet No. 10 of 15	
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/24/2017	Donna Yarbrough	10-25-17					
Line Number:		2"-BOR-10006-PS200D			Fluid:		Boric Acid		Sec. 3.1
P&ID Number:		M-M6-J-0201 Ref. 2.7			Flow Rate (Q):		10 gpm		Sec. 3.1
ISO DWG No.:		P-PI-J-14-10006-01/-02, -10005-01 Ref. 2.10			Viscosity (μ):		1 cp		Sec. 3.1
					Specific Gravity:		1.00		Sec. 3.1
From: TK-710									
To: P-711									
Basis Internal Dia.(d): <u>2.067</u> in. Internal Area = 0.023303 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε): <u>0.00015</u> ft									
Relative Roughness ε/D: <u>0.000871</u> [2.5]									
Reynolds Number: 15,275 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = (-2) \log \left(\frac{\epsilon/D}{3.7} + \frac{2.51}{Re \sqrt{f^{1/2}}} \right)$									
Colebrook Friction Factor (f): = 0.029 [2.4]									
Laminar Friction Factor f = 64/Re = 0.004 Velocity (v) = 0.956 fps [2.5]									
Friction Factor For This Calc. = 0.029 f _i = 0.019 [2.4]									
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K	
1	Entrance	1	K = 0.78					0.78	
2	Pipe	188 in.	K = fL/d					2.64	
3	Ball Valve	2	Cv = 376 [4.2.1] K = 891 d ⁴ /Cv ²					0.23	
4	Pipe Bend (45° or 90°)	3	K = 14 f _i					0.80	
5	Tee Run	3	K = 20 f _i					1.14	
6	Tee Branch	1	K = 60 f _i					1.14	
7	Total K							6.73	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$ = 0.04 psi [2.5]									

Calculation Sheet

PARSONS Engineering		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00224			
Information Only Calculation		Subject: Pump Discharge Line Loss Calculation, to Tee, 60 gpm						Sheet No. 11 of 15	
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/24/2017	Donna Yarbrough	10-25-17					
Line Number:		2"-BOR-10040-PS200D			Fluid:		Boric Acid		Sec. 3.1
P&ID Number:		M-M6-J-0201 Ref. 2.7			Flow Rate (Q) :		60 gpm		Sec. 3.1
ISO DWG No.:		P-PI-J-14-10040-01, -02 Ref. 2.11			Viscosity (μ):		1 cp		Sec. 3.1
					Specific Gravity:		1.00		Sec. 3.1
From: P-711									
To: Tee									
Basis Internal Dia.(d): 2.067 in. Internal Area = 0.023303 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε) : 0.00015 ft									
Relative Roughness ε/D: 0.000871 [2.5]									
Reynolds Number: 91,653 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = [-2] \text{Log} \left[\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{(Re)(f^{1/2})} \right]$									
Colebrook Friction Factor (f) : = 0.022 [2.4]									
Laminar Friction Factor f = 64/Re = 0.001 Velocity (v) = 5.736 fps [2.5]									
Friction Factor For This Calc. = 0.022 f _i = 0.019 [2.4]									
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K	
1	Pipe	36 in.	K = f L/d					0.38	
2	Ball Valve	1	Cv = 376 [4.2.1] K= 891 d ⁴ /Cv ²					0.12	
3	Pipe Bend (45° or 90°)	1	K = 14 f _i					0.27	
4	Tee Run	3	K = 20 f _i					1.14	
5	Tee Branch	1	K = 60 f _i					1.14	
6	Total K							0.38	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$ = 0.08 psi [2.5]									

Calculation Sheet

PARSONS Engineering Information Only Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00224			
		Subject: Pump Discharge Line Loss Calculation, to Tee, 10 gpm					Sheet No. 12 of 15			
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date	
0	N. DesRocher	10/24/2017	Donna Yarbrough	10-25-17						
Line Number:		2"-BOR-10040-PS200D			Fluid:		Boric Acid			Sec. 3.1
P&ID Number:		M-M6-J-0201			Flow Rate (Q):		10 gpm			Sec. 3.1
ISO DWG No.:		P-PI-J-14-10040-01, -02			Viscosity (μ):		1 cp			Sec. 3.1
					Specific Gravity:		1.00			Sec. 3.1
From: P-711										
To: Tee										
Basis Internal Dia.(d): 2.067 in. Internal Area = 0.023303 ft ² = π x 0.25 x d ² /144										
Surface Roughness (ε): 0.00015 ft										
Relative Roughness ε/D: 0.000871 [2.5]										
Reynolds Number: 15,275 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]										
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.										
Colebrook Equation (For Reynolds Numbers > 4,000): $\frac{1}{f^{1/2}} = [-2] \text{Log} \left[\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{(Re)(f^{1/2})} \right]$										
Colebrook Friction Factor (f): = 0.029 [2.4]										
Laminar Friction Factor f = 64/Re = 0.004 Velocity (v) = 0.956 fps [2.5]										
Friction Factor For This Calc. = 0.029 f _t = 0.019 [2.4]										
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K		
1	Pipe	36	in. K = fL/d					0.51		
2	Ball Valve	1	Cv = 376 [4.2.1] K = 891 d ⁴ /Cv ²					0.12		
3	Pipe Bend (45° or 90°)	1	K = 14 f _t					0.27		
4	Tee Run	3	K = 20 f _t					1.14		
5	Tee Branch	1	K = 60 f _t					1.14		
6	Total K							0.51		
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$ = 0.003 psi [2.5]										

Calculation Sheet

PARSONS Engineering Information Only Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00224		
		Subject: Pump Discharge Line Loss Calculation, Tee to TK-720							Sheet No. 13 of 15
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/24/2017	Donna Yarbrough	10-25-17					
Line Number:		2"-BOR-10040-PS200D			Fluid:		Boric Acid		Sec. 3.1
P&ID Number:		M-M6-J-0201 Ref. 2.7			Flow Rate (Q) :		60 gpm		Sec. 3.1
ISO DWG No.:		P-PI-J-14-10040-02 Ref. 2.11			Viscosity (μ):		1 cp		Sec. 3.1
					Specific Gravity:		1.00		Sec. 3.1
From: Tee									
To: TK-720									
Basis Internal Dia.(d): 2.067 in. Internal Area = 0.023303 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε) : 0.00015 ft									
Relative Roughness ε/D: 0.000871 [2.5]									
Reynolds Number: 91,653 = $\frac{(50.6)(Q)(SG)(62.4)}{\mu(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = (-2) \text{ Log } \left(\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{(Re)(f^{1/2})} \right)$									
Colebrook Friction Factor (f) : = 0.022 [2.4]									
Laminar Friction Factor f = 64/Re = 0.001 Velocity (v) = 5.736 fps [2.5]									
Friction Factor For This Calc. = 0.022 f _t = 0.019 [2.4]									
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K	
1	Pipe	300 in.	K = f L/d					3.19	
2	Ball Valve	1	Cv = 376 [4.2.1] K= 891 d ⁴ /Cv ²					0.12	
3	Pipe Bend (45° or 90°)	9	K = 14 f _t					2.39	
4	Exit	1	K = 1.0					1	
5	Total K							6.7	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$ = 1.48 psi [2.5]									

Calculation Sheet

PARSONS Engineering Information Only Calculation		Project: NGS Deployment at SWPF					Calculation No. M-CLC-J- 00224		
		Subject: Pump Discharge Line Loss Calculation, Tee to SB-205, 1-1/2"							Sheet No. 14 of 15
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/24/2017	Donna Yarbrough	10-25-17					
Line Number:		1-1/2"-BOR-10009-PS200D			Fluid:		Boric Acid		Sec. 3.1
P&ID Number:		M-M6-J-0201 M-M6-J-0024 Ref. 2.7			Flow Rate (Q):		10 gpm		Sec. 3.1
ISO DWG No.:		See Ref. 2.11			Viscosity (μ):		1 cp		Sec. 3.1
					Specific Gravity:		1.00		Sec. 3.1
From: Tee									
To: Reduction before SI-7015									
Basis Internal Dia.(d): <u>1.610</u> in. Internal Area = 0.014138 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε): <u>0.00015</u> ft									
Relative Roughness ε/D: <u>0.001118</u> [2.5]									
Reynolds Number: 19,611 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = (-2) \text{Log} \left[\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{(Re)(f^{1/2})} \right]$									
Colebrook Friction Factor (f) : = 0.028 [2.4]									
Laminar Friction Factor f = 64/Re = 0.003 Velocity (v) = 1.576 fps [2.5]									
Friction Factor For This Calc. = 0.028 f _i = 0.021 [2.4]									
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K	
1	Pipe	11,500 in.	K = f L/d					200	
2	Ball Valve	2	Cv = 170 [4.2.1] K= 891 d ⁴ /Cv ²					0.41	
3	Pipe Bend (45° or 90°)	60	K = 14 f _i					23.52	
4	Reducer	1	K = 0.5 (1- β ²)	1.610	2.067	0.607		0.20	
5	Tee Run	2	K = 20 f _i					0.84	
6	Tee Branch	5	K = 60 f _i					6.30	
7	Exit	1	K = 1.0					1	
8	Total K							231.27	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$ = 3.87 psi [2.5]									

PARSONS Engineering Information Only Calculation		Project: NGS Deployment at SWPF				Calculation No. M-CLC-J- 00224			
		Subject: Pump Discharge Line Loss Calculation, Tee to SB-205, 1/2"						Sheet No. 15 of 15	
Rev	Originator	Date	Checker	Date	Rev	Originator	Date	Checker	Date
0	N. DesRocher	10/24/2017	Donna Yarbrough	10-25-17					
Line Number:		1/2"-NAOH-7213-PS200D			Fluid:		Boric Acid		Sec. 3.1
P&ID Number:		M-M6-J-0024 Ref. 2.7			Flow Rate (Q) :		10 gpm		Sec. 3.1
ISO DWG No.:		P-PI-J-01-7213-01, -02, -03 Ref. 2.14			Viscosity (μ):		1 cp		Sec. 3.1
					Specific Gravity:		1.00		Sec. 3.1
From: Reduction before SI-7015									
To: SB-205									
Basis Internal Dia.(d): <u>0.622</u> in. Internal Area = 0.00211 ft ² = π x 0.25 x d ² /144									
Surface Roughness (ε) : <u>0.00015</u> ft [2.5]									
Relative Roughness ε/D: <u>0.002894</u>									
Reynolds Number: 50,763 = $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$ [2.5]									
Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.									
Colebrook Equation (For Reynolds Numbers > 4,000) : $\frac{1}{f^{1/2}} = [-2] \text{Log} \left(\left(\frac{\epsilon/D}{3.7} \right) + \frac{2.51}{[Re] [f^{1/2}]} \right)$									
Colebrook Friction Factor (f) : = 0.028 [2.4]									
Laminar Friction Factor f = 64/Re = 0.001 Velocity (v) = 10.56 fps [2.5]									
Friction Factor For This Calc. = 0.028 f _t = 0.027 [2.4]									
Item	Component	QTY	"K" Formula [2.4]	d ₁	d ₂	β ²	β ⁴	K	
1	Pipe	800 in.	K = f L/d					36.01	
2	Ball Valve	1	Cv = 20 [2.12] K= 891 d ⁴ /Cv ²					0.33	
3	Pipe Bend (45° or 90°)	9	K = 14 f _t					3.40	
4	Reducer	1	K = 0.5 (1- β ²)	0.622	1.610	0.149		0.43	
5	Plug Valve, 2 way	1	Cv = 16 [2.12] K= 891 d ⁴ /Cv ²					0.52	
6	Plug Valve, 3 way	1	Cv = 9 [2.12] K= 891 d ⁴ /Cv ²					1.65	
7	Tee Run	1	K = 20 f _t					0.54	
8	Tee Branch	1	K = 60 f _t					1.62	
9	Exit	1	K = 1.0					1	
10	Total K							45.50	
Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 \text{ ft}^2)}{2 g_c (144 \text{ in}^2)}$ = 34.13 psi [2.5]									

Appendix D. CCFF Equipment List

M-MX-J-0001, *SWPF Equipment Database (U)* (NGS only)

PARSONS

Project: SWPF

Job No.: 749478

SWPF EQUIPMENT DATABASE (NGS ONLY)

M-MX-J-0001 REV 18

Thursday, November 30, 2017

Page 1 of 2

DISCIPLINE	SITE AREA	BLDG AREA	BLDG ID.	FUNK ID.	SEQ NUMBER	EQUIPMENT NAME	EQUIPMENT DESCRIPTION	EQUIPMENT DESCRIPTION				CONTROL NUMBER	PROC LEVEL	PERFORM CATEGORY	FUNCTION CLASSIFICATION (NBS 5)	PTD	PFD/HVAC DRAWING	ELECTRICAL DIAGRAM	Detail/Equipment Schedule Specification Section	REMARKS								
								CAPACITY / (NBS 5)	MATERIAL	STEAM (LBM/HR)	PLANT (SCFM)										COOLING (BTU/HR)	FILES LOAD	VOLTAJE	PHASE	TYPE	STARTER	BACKUP POWER	
Process	J	14	221-6J	AGT	710	Boric Acid Strip Receipt Tank Agitator	Mechanical Mixer, Used to agitate TK-710 contents	NA	316L Stainless Steel	NA	NA	1 HP	480V	3	VFD	NA	NO	NO	NO	08653	PL-4	PC-1	GS-2	M-HS-J-0020	M-HS-J-0201	E-E2-J-00039	M-DS-J-00411	
Process	J	14	221-6J	AGT	720	Boric Acid Strip Feed Tank Agitator	Mechanical Mixer, Used to agitate TK-720 contents	NA	316L Stainless Steel	NA	NA	1 HP	480V	3	VFD	NA	NO	NO	NO	08653	PL-4	PC-1	GS-2	M-HS-J-0020	M-HS-J-0202	E-E2-J-00039	M-DS-J-00421	
Process	J	14	221-6J	AGT	730	Cosmetic Scrub Feed Tank Agitator	Mechanical Mixer, Used to agitate TK-730 contents	NA	316L Stainless Steel	NA	NA	1 HP	480V	3	VFD	NA	NO	NO	NO	08653	PL-4	PC-1	GS-2	M-HS-J-0020	M-HS-J-0203	E-E2-J-00039	M-DS-J-00431	
HVAC	J	14	221-6J	FAN	016	NGS Building Exhaust Fan	Used to Exhaust Air from NGS Building	10,000 CFM	Aluminum	NA	NA	0.75 HP	480V	3	STR	NA	NO	NO	NO	TBD	PL-4	PC-1	GS-2	NA	TBD	E-E2-J-00039		
HVAC	J	14	221-6J	FAN	017	NGS Building Exhaust Fan	Used to Exhaust Air from NGS Building	10,000 CFM	Aluminum	NA	NA	0.75 HP	480V	3	STR	NA	NO	NO	NO	TBD	PL-4	PC-1	GS-2	NA	TBD	E-E2-J-00039		
HVAC	J	14	221-6J	HTR	018	Electric Unit Heater	Provide Heat to NGS Building	400 CFM	Steel	NA	NA	5.0 KW	480V	3	BKR	NA	NO	NO	NO	TBD	PL-4	PC-1	GS-2	NA	TBD	E-E2-J-00039		
HVAC	J	14	221-6J	HTR	019	Electric Unit Heater	Provide Heat to NGS Building	400 CFM	Steel	NA	NA	5.0 KW	480V	3	BKR	NA	NO	NO	NO	TBD	PL-4	PC-1	GS-2	NA	TBD	E-E2-J-00039		
HVAC	J	14	221-6J	HTR	020	Electric Unit Heater	Provide Heat to NGS Building	400 CFM	Steel	NA	NA	5.0 KW	480V	3	BKR	NA	NO	NO	NO	TBD	PL-4	PC-1	GS-2	NA	TBD	E-E2-J-00039		
HVAC	J	14	221-6J	HTR	021	Electric Unit Heater	Provide Heat to NGS Building	400 CFM	Steel	NA	NA	5.0 KW	480V	3	BKR	NA	NO	NO	NO	TBD	PL-4	PC-1	GS-2	NA	TBD	E-E2-J-00039		
Process	J	14	221-6J	HTR	720A	Boric Acid Strip Feed Heater	Electric Heater, Used to Heat Strip Feed	24 KW	304 Stainless Steel	NA	NA	24 KW	480V	3	BKR	NA	NO	NO	NO	08654	PL-4	PC-1	GS-2	M-HS-J-0020	M-HS-J-0202	E-E2-J-00039	M-DS-J-00400	
Process	J	14	221-6J	HTR	720B	Boric Acid Strip Feed Heater	Electric Heater, Used to Heat Strip Feed	24 KW	304 Stainless Steel	NA	NA	24 KW	480V	3	BKR	NA	NO	NO	NO	08654	PL-4	PC-1	GS-2	M-HS-J-0020	M-HS-J-0202	E-E2-J-00039	M-DS-J-00400	
Electrical	J	14	221-6J	MCC	211	NGS-480V Normal Power MCL	Motor Control Center	600 Ampere	Steel	NA	NA	300 Amps	480V	3	BKR	NA	NO	NO	NO	TBD	PL-4	PC-1	GS-2	NA	NA	E-E2-J-0002	16443	
Material Handling	J	14	221-6J	MR	141	AGT-710 Monorail	Monorail to Remove/Replace AGT-710	1/4 Ton	Steel	NA	NA	NA	NA	NA	NA	NA	NA	NA	NO	TBD	PL-4	PC-1	GS-2	NA	NA	NA	NA	
Material Handling	J	14	221-6J	MR	142	AGT-720 Monorail	Monorail to Remove/Replace AGT-720	1/4 Ton	Steel	NA	NA	NA	NA	NA	NA	NA	NA	NA	NO	TBD	PL-4	PC-1	GS-2	NA	NA	NA	NA	
Material Handling	J	14	221-6J	MR	143	AGT-730 Monorail	Monorail to Remove/Replace AGT-730	1/4 Ton	Steel	NA	NA	NA	NA	NA	NA	NA	NA	NA	NO	TBD	PL-4	PC-1	GS-2	NA	NA	NA	NA	
Process	J	14	221-6J	P	700A	Boric Acid Addition Pump	Used for Total/Drum Unloading	20 GPM	CPVC	NA	NA	1.20V	NA	1	BKR	NA	NO	NO	NO	TBD	PL-4	PC-1	GS-2	NA	M-HS-J-0020	E-E2-J-00040	M-DS-J-00401	

PARSONS

Project: SWPF

Job No.: 749478

SWPF EQUIPMENT DATABASE (NGS ONLY)

Thursday, November 30, 2017

Page 2 of 2

DISCIPLINE	SITE AREA	DESIGN AREA	BLDG	FUNC. ID.	SEQ. NUMBER	EQUIPMENT NAME	EQUIPMENT DESCRIPTION	EQUIPMENT DESCRIPTION										EQUIPMENT DESCRIPTION	ELECTRICAL DIAGRAM	DATE/REV. / EDITION/ISSUE / SPECIFICATION SECTION	REMARKS				
								CAPACITY/ (GPM/5)	MATERIAL	STRAN. LBW/(FR)	PLANT SCH#	COOLING (GPM/HR)	ELECT. LOAD	VOLTAGE	PHASE	TYPE	STARTED					BACKUP POWER	CONTROL NUMBER	PROC. LEVEL	REFORM CATEGORY
Process	J	14	221-6	P	700B	Boric Acid Addition Pump	Used for Tote/Drum Unloading	20 GPM	CPVC	NA	NA	NA	120V	1	BKR	NA	NO	TBD	PL-4	PC-1	GS-2	M-HS-J-0020	E-ES-J-0040	M-DS-J-0040	
Process	J	14	221-6	P	710A	Boric Acid Strip Transfer Pump	Pump Used to Transfer Concentrated Boric Acid to TK-720	5 GPM	316L Stainless Steel	NA	NA	NA	480V	3	VFD	NA	NO	08655	PL-4	PC-1	GS-2	M-HS-J-0020	E-E2-J-00039	M-DS-J-00402	
Process	J	14	221-6	P	710B	Boric Acid Strip Transfer Pump	Pump Used to Transfer Concentrated Boric Acid to TK-720	5 GPM	316L Stainless Steel	NA	NA	NA	480V	3	VFD	NA	NO	08655	PL-4	PC-1	GS-2	M-HS-J-0020	E-E2-J-00039	M-DS-J-00402	
Process	J	14	221-6	P	711	Boric Acid Strip Charge Pump	Pump Used to Transfer Concentrated Boric Acid to SB-205	60 GPM	316L Stainless Steel	NA	NA	NA	480V	3	VFD	NA	NO	08655	PL-4	PC-1	GS-2	M-HS-J-0020	E-E2-J-00039	M-DS-J-00403	
Process	J	14	221-6	P	720A	Boric Acid Strip Feed Pump	Pump Used to Supply Boric Acid Strip Solution to CSSX Contactors	3 GPM	316L Stainless Steel	NA	NA	NA	480V	3	VFD	NA	NO	08655	PL-4	PC-1	GS-2	M-HS-J-0020	E-E2-J-00039	M-DS-J-00404	
Process	J	14	221-6	P	720B	Boric Acid Strip Feed Pump	Pump Used to Supply Boric Acid Strip Solution to CSSX Contactors	3 GPM	316L Stainless Steel	NA	NA	NA	480V	3	VFD	NA	NO	08655	PL-4	PC-1	GS-2	M-HS-J-0020	E-E2-J-00039	M-DS-J-00404	
Process	J	14	221-6	P	730A	Caustic Scrub Feed Pump	Pump Used to Supply Caustic Scrub Solution to CSSX Contactors	3 GPM	316L Stainless Steel	NA	NA	NA	480V	3	VFD	NA	NO	08655	PL-4	PC-1	GS-2	M-HS-J-0020	E-E2-J-00039	M-DS-J-00405	
Process	J	14	221-6	P	730B	Caustic Scrub Feed Pump	Pump Used to Supply Caustic Scrub Solution to CSSX Contactors	3 GPM	316L Stainless Steel	NA	NA	NA	480V	3	VFD	NA	NO	08655	PL-4	PC-1	GS-2	M-HS-J-0020	E-E2-J-00039	M-DS-J-00405	
Process	J	14	221-6	P	740	NGS Sump Pump	Pump Used to Empty Contents of NGS Building Sumps	5 GPM	316L Stainless Steel	NA	5	NA	NA	NA	NA	NA	NA	08656	PL-4	PC-1	GS-2	M-HS-J-0020	M-HS-J-0024	M-DS-J-00406	
Electrical	J	14	221-6	PHL	346	208Y/120V Panel	Supplies 120V to Misc Loads	225 Ampere	Steel	NA	NA	NA	480V	3	BKR	NA	NA	TBD	PL-4	PC-1	GS-2	NA	E-E2-J-00039	16442	
Fire Protection	J	14	221-6	TK	014	Fire Protection Water Surge Tank	Bladder type used for Fire Protection Surge Suppression	317 GAL	Steel	NA	NA	NA	NA	NA	NA	NA	NA	NA	PL-4	PC-1	GS-2	M-HS-J-0020	NA	NA	
Engineering Mechanics	J	14	221-6	TK	710	Boric Acid Strip Receipt Tank	Tank, Used to Receive/Store Concentrated Boric Acid	2500 GAL	316L Stainless Steel	NA	NA	NA	NA	NA	NA	NA	NA	08652	PL-4	PC-1	GS-2	M-HS-J-0020	NA	M-DS-J-00410	
Engineering Mechanics	J	14	221-6	TK	720	Boric Acid Strip Feed Tank	Tank, Used for Make-Up of Dilute Boric Acid for Strip Feed	2500 GAL	316L Stainless Steel	NA	NA	NA	NA	NA	NA	NA	NA	08652	PL-4	PC-1	GS-2	M-HS-J-0020	NA	M-DS-J-00420	
Engineering Mechanics	J	14	221-6	TK	730	Caustic Scrub Feed Tank	Tank, Used for Make-Up of Dilute Caustic for Scrub Feed	2500 GAL	316L Stainless Steel	NA	NA	NA	NA	NA	NA	NA	NA	08652	PL-4	PC-1	GS-2	M-HS-J-0020	NA	M-DS-J-00430	