

16. The facility will continue to pump and haul the contents of the guard shack domestic wastewater holding tank at an approximate rate of 30 gallons per day or 1500 gallons every 45 days. This wastewater will be hauled to Berkeley County Water & Sanitation's Lower Berkeley Wastewater Treatment Plant (NPDES No. SC0046060) for final disposal. The pump and haul operation shall comply with the following:
- a. All pumping and hauling of the wastewaters shall be in accordance with the rules and regulations of the State Department of Transportation and other agencies as applicable.
 - b. The receiving facility must be able to maintain current discharge limits set forth in their discharge permit (e.g., NPDES or pretreatment). If the receiving facility is unable/unwilling to receive this waste stream, the permittee must notify the Department and propose an alternative facility or plan for Department approval.
 - c. The following Best Management Practices must be adhered to during the transfer of the wastewater to the vehicle receiving the wastewater:
 - i. A dedicated line will be used to pump the wastewater from the waste tank to the tanker truck. The line will be firmly secured at the tanker truck.
 - ii. Operators will fill the tanker truck to less than 85% of the tanker truck capacity. Administrative procedures will be implemented to assure against overfilling. Routine observations of the discharge line and tanker truck will be made to assure against leaks and spills.
 - iii. Spill absorbent materials will be made available to assure adequate response to leaks and spills.
 - d. An up-to-date letter of approval from the receiving facility agreeing to accept and treat the wastewater must be kept on-site and available for Department review upon request. The approval letter must contain an expiration date and not be expired to be considered up to date.
 - e. The permittee must receive written approval from the Department, prior to making any changes to the pump and haul disposal. Changes could include, but is not limited to, changing the receiving facility, or increasing the amount of wastewater being disposed.