



**Table 2. Other PFAS Data (excluding PFOA and PFOS) by EPA Method 537.1 from Surface Water-Sourced Community Drinking Water Systems -- August 2020**

System		Sampling Date	Results in nanograms per liter (ng/L) [parts per trillion]																Observations	
			EPA Method 537.1																	
Number	Name		PFBS	PFHxA	PFHxS	PFHpA	PFNA	PFDA	N-EtFOSAA	PFUnA	N-MeFOSAA	PFDoA	PFTDA	PFTA	HFPO-DA	F53B Major	F53B Minor	ADONA	n/N, where N = 16	Σ of Detects (ng/L)
0110001	Abbeville	15-Jun-20	2.9	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	2.9
0210001	Aiken	15-Jun-20	*	*	3.2	*	*	*	*	*	*	*	*	*	*	*	*	*	1	3.2
0420011	Anderson Regional	10-Jun-20	2.2	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	2.2
3210002	Batesburg-Leesville	9-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
0410011	Belton-Honea Path	10-Jun-20	*	2.6	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	2.6
3410001	Bennettsville	9-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
0220006	Breezy Hill	15-Jun-20	3.2	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	3.2
2810001	Camden	9-Jun-20	*	3.2	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	3.2
2920002	Catawba River	17-Jun-20	*	3.5	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	3.5
3210003	Cayce	8-Jun-20	2.4	4.0	*	*	*	*	*	*	*	*	*	*	*	*	*	*	2	6.4
1310001	Cheraw	9-Jun-20	*	3.1	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	3.1
1220002	Chester Metro	17-Jun-20	*	2.7	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	2.7
4010001	Columbia Canal	8-Jun-20	3.1	5.1	*	*	*	*	*	*	*	*	*	*	*	*	*	*	2	8.2
4010001	Columbia Lake Murray	8-Jun-20	*	2.2	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	2.2
3920001	Easley Central	17-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
1920001	Edgefield County	15-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
2110001	Florence	9-Jun-20	2.2	3.5	*	*	*	*	*	*	*	*	*	*	*	*	*	*	2	5.7
1110001	Gaffney	16-Jun-20	2.3	2.2	5.0	3.1	*	*	*	*	*	*	*	*	*	*	*	*	4	12.6
2220010	GCWSD - Waccamaw	15-Jun-20	2.2	3.9	*	2.8	*	*	*	*	*	*	*	*	*	*	*	*	3	8.9
2210001	Georgetown	15-Jun-20	*	2.4	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	2.4
2310001	Greenville Adkins	17-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
2310001	Greenville Stovall	17-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
2410001	Greenwood	16-Jun-20	2.3	2.8	*	*	*	*	*	*	*	*	*	*	4.7	*	*	*	4	9.8
3010001	Laurens CPW	16-Jun-20	2.2	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	2.2
2820001	Lugoff-Elgin	9-Jun-20	*	3.2	*	*	*	*	*	*	*	*	*	*	*	*	*	*	1	3.2
3510001	McCormick	15-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
3610001	Newberry	9-Jun-20	2.3	3.2	*	*	*	*	*	*	*	*	*	*	5.0	*	*	*	3	10.5
3620002	Newberry County	9-Jun-20	*	3.0	*	*	*	*	*	*	*	*	*	*	3.4	*	*	*	2	6.4
0210003	North Augusta	15-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
3910001	Pickens	17-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
3720001	Pioneer Rural WD	9-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
4120001	Saluda County	16-Jun-20	2.1	3.1	*	*	*	*	*	*	*	*	*	*	4.6	*	*	*	4	9.8
3710002	Seneca	10-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
4220006	SJWD	16-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
4210001	Spartanburg	16-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
4210003	Spartanburg - Landrum	16-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
4410001	Union	17-Jun-20	2.3	4.3	*	2.4	*	*	*	*	*	*	*	*	*	*	*	*	3	9.0
3710004	Walhalla	9-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
3210004	West Columbia Lake Murray	8-Jun-20	*	2.9	*	*	*	*	*	*	*	*	*	*	2.2	*	*	*	2	5.1
3210004	West Columbia Sunset	8-Jun-20	2.2	3.9	*	*	*	*	*	*	*	*	*	*	*	*	*	*	2	6.1
3710003	Westminster	9-Jun-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	0	*
3610004	Whitmire	16-Jun-20	9.1	6.5	3.4	*	*	*	*	*	*	*	*	*	*	*	*	*	3	19
2010001	Winnsboro	17-Jun-20	*	2.3	3.4	*	*	*	*	*	*	*	*	*	*	*	*	*	3	5.7
4220007	Woodruff-Roebuck	17-Jun-20	2.9	3.6	*	2.3	*	*	*	*	*	*	*	*	*	*	*	*	3	8.8

Note: All samples were collected from finished water by SCDHEC staff at each treatment plant immediately prior to entering the distribution system  
a. \* = not detected; detection limit for Method 537.1 was 2.1 ng/L; none elevated

Summary																		
Minimum detection (ng/L)	2.1	2.2	3.2	2.3	*	*	*	*	*	*	*	*	*	*	2.2	*	*	*
Maximum detection (ng/L)	9.1	6.5	5.0	3.1	*	*	*	*	*	*	*	*	*	*	5.0	*	*	*
number of detects (n), where number of systems (N) = 44	16	23	4	4	0	0	0	0	0	0	0	0	0	0	5	0	0	0