



**Table 6. Summary of PFOA and PFOS Data by River Basin from Surface Water-Sourced Community Drinking Water Systems -- August 2020**

Basin	Method 537.1 in nonograms per liter (parts per trillion)									Method 533 in nonograms per liter (parts per trillion)								
	PFOA			PFOS			Σ PFOA + PFOS			PFOA			PFOS			Σ PFOA + PFOS		
	n/N <sup>a</sup>	Range <sup>b</sup>	Mean <sup>c</sup>	n/N	Range	Mean	n/N	Range	Mean	n/N	Range	Mean	n/N	Range	Mean	n/N	Range	Mean
Broad	5/9	* - 12	<b>6.1</b>	6/9	* - 16	<b>6.8</b>	6/9	* - 28.0	<b>12.0</b>	7/9	* - 14	<b>5.8</b>	7/9	* - 18	<b>7.4</b>	7/9	* - 32	<b>12.4</b>
Catawba	4/4	2.2 - 3.2	<b>2.9</b>	4/4	2.5 - 4.3	<b>3.4</b>	4/4	4.7 - 7.7	<b>6.3</b>	4/4	2.6 - 4.3	<b>3.5</b>	4/4	3.1 - 5.7	<b>4.2</b>	4/4	5.7 - 10.0	<b>7.7</b>
Edisto																		
Pee Dee	5/5	2.6 - 8.0	<b>4.2</b>	4/5	* - 12	<b>7.5</b>	5/5	2.6 - 20	<b>10.2</b>	5/5	3.1 - 8.8	<b>4.9</b>	5/5	2.2 - 13	<b>7.6</b>	5/5	5.5 - 21.8	<b>12.5</b>
Salkehatchie																		
Saluda	8/10	* - 4.2	<b>3.4</b>	10/10	2.1 - 8.2	<b>5.3</b>	10/10	2.1 - 12.4	<b>8.1</b>	9/10	* - 4.7	<b>4.0</b>	10/10	2.5 - 8.9	<b>6.5</b>	10/10	3.9 - 14.3	<b>10.1</b>
Santee	1/1	3.6	--	1/1	4.6	--	1/1	8.2	--	1/1	3.8	--	1/1	5.4	--	1/1	9.2	--
Savannah	4/13	* - 4.1	<b>2.6</b>	5/13	* - 8.2	<b>3.3</b>	6/13	* - 12.4	<b>4.5</b>	6/7	* - 3.6	<b>3.0</b>	7/7	* - 9.3	<b>3.7</b>	7/7	* - 12.4	<b>6.3</b>
Saluda & Savannah	0/2	--	--	0/2	--	--	0/2	--	--	0/2	--	--	0/2	--	--	0/2	--	--

a. n/N = number of systems with detections/number of systems sampled; unitless

b. \* = non-detect

c. mean of detected values

Descending Rank of Mean Values:

1	Broad & Pee Dee
2	
3	Saluda
4	Catawba
5	Savannah