



Table 8B. Other PFAS Data (Excluding PFOA and PFOS) by USEPA Method 533 from SCDHEC Sampling of Surface Water Sourced Community Drinking Water Systems that Provided PFAS Data to SCDHEC

System Number			Concentration in nanograms per liter (ng/L) [parts per trillion] bu USEPA Method 533																							
Number	Name	Sampling Date	11Cl-PF3OUdS	8:2FtS	4:2FtS	6:2FtS	ADONA	9CL-PF3ONS	HFPO-DA	NFDHA	PFEESA	PFMIPA	PFMIBA	PFBS	PFBA	PFDA	PFDoA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFPeS	PFPeA	PFUnA	
0820008	Santee Cooper Regional Water	16-Sep-20	*	*	*	*	*	*	8.0	*	*	*	3.5	*	6.2	*	4.5	*	*	*	2.7	*	*	3.3	7.1	
0720003	Beaufort Jasper Water and Sewer Authority	Chelsea	21-Sep-20	*	*	*	*	*	*	*	*	*	*	3.9	3.0	*	*	*	*	*	2.8	*	*	3.3	*	
0720004		Purrysburg	21-Sep-20	*	*	*	*	*	*	*	*	*	*	3.2	2.2	*	*	*	*	*	2.4	*	*	2.8	*	
1010001	Charleston Water System	16-Sep-20	*	*	*	*	*	*	*	*	*	*	*	2.9	3.0	*	*	*	*	2.0	*	4.3	*	*	5.0	*
2310005	Greer Commission of Public Works	14-Sep-20	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
2620004	Grand Strand Water and Sewer Authority	Bull Creek	22-Sep-20	*	*	*	*	*	*	*	*	*	*	2.8	3.6	*	*	*	*	3.2	*	5.7	*	*	8.0	*
2620009		Myrtle Beach	22-Sep-20	*	*	*	*	*	*	*	*	*	*	*	2.4	*	*	*	*	*	*	*	*	*	*	*
3010002	Clinton	14-Sep-20	*	*	*	*	*	*	*	*	*	*	*	12	16	*	*	*	*	3.3	4.4	15	*	*	23	*
3210003	Cayce	16-Sep-20	*	*	*	*	*	*	*	*	*	*	*	3.3	3.4	*	*	*	*	3.1	*	6.5	*	*	7.7	*
3810001	Orangeburg	15-Sep-20	*	*	*	*	*	*	*	*	*	*	*	*	2.1	*	*	*	*	*	*	*	*	2.3	*	
3820003	Lake Marion Regional	15-Sep-20	*	*	*	*	*	*	*	*	*	*	*	3.9	3.9	*	*	*	*	2.8	2.0	6.7	*	*	8.2	*
3910002	Easley Combined Utilities	14-Sep-20	*	*	*	*	*	*	*	*	*	*	*	*	2.2	*	*	*	*	*	*	3.9	*	*	5.4	*
4610002	Rock Hill	23-Sep-20	*	*	*	*	*	*	*	*	*	*	*	*	2.1	*	*	*	*	*	*	2.9	*	*	3.0	*

Notes:
 1. See Table 8 for PFAS data (other than PFOA and PFOS) provided to SCDHEC by the Water Systems
 2. All samples were collected from finished water from each well by SCDHEC staff immediately prior to entering the distribution system
 a. * = not detected; detection limit was 2.0 ng/L; none elevated