

- (4) If the daily maximum limitation on the 30-day rolling average flow of bottom ash purge water is increased, a brief description of the circumstances that resulted in the increase to the limitation (e.g. "bottom ash overflow tank outage", or "one inch rainfall event introducing 5,000 gallons to the bottom ash system")
 - (5) A "yes" or "no" answer to the question, "Does the daily maximum 30-day rolling average of the flow of bottom ash purge water exceed the limitation?"
- e. In accordance with 40 CFR 423.13(k)(2)(i)(B), the total volume discharged shall be reduced or eliminated to the extent achievable using control measures (including best management practices) that are technologically available and economically achievable in light of best industry practice.

**draft
public notice**