

---

---

**Work Order No. 15730.001.008**

**Pulp Dryer, No. 3 Paper Machine Vents,  
No. 2 and 3 Smelt Dissolving Tank Vents,  
and No. 1 and 2 Combination Boilers  
Emission Test Report  
New-Indy Catawba, LLC  
Catawba, South Carolina  
Test Dates: 21-27 June 2021**

Prepared For

**NEW-INDY CATAWBA, LLC**  
5300 Cureton Ferry Road  
Catawba, South Carolina 29704



---

Wayne Roberts  
Project Manager  
Approved for Transmittal



---

Natalie Hammonds  
Quality Assurance Manager  
Approved for Transmittal

Prepared By

**WESTON SOLUTIONS, INC.**  
1625 Pumphrey Ave.  
Auburn, Alabama 36832-4303  
Phone: (334) 466-5600 Fax: (334) 466-5660

**21 July 2021**

---

---

**WESTON SOLUTIONS, INC. (WESTON®)**  
**INTEGRATED AIR SERVICES – AUBURN OPERATIONS**  
**ACCREDITATION STIPULATION**

<b>Laboratory:</b>	Weston Solutions, Inc.
<b>Accreditor(s):</b>	Louisiana Environmental Laboratory Accreditation Program (LELAP) – Laboratory and Emission Testing Practice
<b>Accreditation ID:</b>	LELAP – 03024
<b>Scope:</b>	Total Reduced Sulfur and Sulfur Dioxide Sampling and Analysis
<b>Effective:</b>	LELAP – 21 December 2001
<b>Renewal Date:</b>	LELAP – 30 June 2022



---

## Data Qualifiers



The following are general reporting notes that are applicable to all WESTON reports, unless otherwise noted.

- **NL** denotes data that was not from a LELAP accredited method.
- **LNL** denotes lab results that are not from an accredited LELAP laboratory.
- **NN** denotes data that was not from The NELAC Institute (TNI) accredited method.
- **NNL** denotes lab results that are not from an accredited TNI laboratory.
- **ED** denotes data that is not to be used for compliance purposes and may deviate from approved procedures.
- **Q** denotes data whose QA/QC check did not fall within the specified range. This data is still considered valid.
- **A** denotes data that is anomalously high with no explanation for the outlier.
- **BDL** denotes values that were below the limit of detection of the analyzer and 2% of the span gas was used to calculate an emission rate.
- **DF** denotes a dilution factor.
- **NAP** denotes emission testing performed by personnel from a non-TNI accredited laboratory.
- **S** denotes analysis that has been subcontracted.
- All values are reported on a “dry” basis, unless otherwise designated as “actual” or “wet” basis.



## TABLE OF CONTENTS

<b>SECTION 1</b>	<b>INTRODUCTION .....</b>	<b>6</b>
<b>SECTION 2</b>	<b>RESULTS AND DISCUSSION.....</b>	<b>7</b>
<b>SECTION 3</b>	<b>SOURCE TESTING METHODOLOGY.....</b>	<b>20</b>
<b>SECTION 4</b>	<b>QUALITY ASSURANCE/ QUALITY CONTROL .....</b>	<b>21</b>
	4.1 Quality Control Procedures.....	21
	4.2 Gas Stream Sampling QA/QC Procedures.....	21
	4.3 QA/QC Checks for Data Reduction and Validation .....	22
<b>APPENDIX A SAMPLE CALCULATIONS</b>		
<b>APPENDIX B TEST METHODOLOGY</b>		
<b>APPENDIX C FIELD DATA – PULP DRYER</b>		
<b>APPENDIX D FIELD DATA – NO. 3 PAPER MACHINE</b>		
<b>APPENDIX E FIELD DATA – NO. 2 AND 3 SMELT DISSOLVING TANK VENTS</b>		
<b>APPENDIX F FIELD DATA – NO. 1 AND 2 COMBINATION BOILERS</b>		
<b>APPENDIX G LABORATORY REPORT</b>		
<b>APPENDIX H QUALITY CONTROL DATA</b>		
<b>APPENDIX I PROCESS OPERATING/PRODUCTION DATA</b>		

### LIST OF TABLES

Table 2-1	Summary of Mean Emission Results.....	9
Table 2-2	Pulp Dryer Summary of TRS Emission Results .....	10
Table 2-3	No. 3 Paper Machine Vent 1 Summary of TRS Emission Results .....	10
Table 2-4	No. 3 Paper Machine Vent 2 Summary of TRS Emission Results.....	11
Table 2-5	No. 3 Paper Machine Vent 3 Summary of TRS Emission Results.....	11
Table 2-6	No. 3 Paper Machine Vent 4 Summary of TRS Emission Results.....	12
Table 2-7	No. 3 Paper Machine Vent 6 Summary of TRS Emission Results.....	12
Table 2-8	No. 3 Paper Machine Vent 7 Summary of TRS Emission Results.....	13
Table 2-9	No. 3 Paper Machine Vent 8 Summary of TRS Emission Results.....	13



---

Table 2-10	No. 2 and 3 Smelt Dissolving Tank Vents Summary of TRS Emission Results.....	14
Table 2-11	No. 1 Combination Boiler Condition 1: NCG and SOG Gases Summary of TRS and SO <sub>2</sub> Emission Results.....	15
Table 2-12	No. 1 Combination Boiler Condition 2: NCG Gases Only Summary of TRS and SO <sub>2</sub> Emission Results.....	15
Table 2-13	No. 2 Combination Boiler Condition 1: NCG and SOG Gases Summary of TRS and SO <sub>2</sub> Emission Results.....	16
Table 2-14	No. 2 Combination Boiler Condition 2: NCG Gases Only Summary of TRS and SO <sub>2</sub> Emission Results.....	16
Table 2-15	Paper Machine 3 Whitewater (Sample ID: 3A) Summary of Results .....	17
Table 2-16	Pulp Dryer Water (Sample ID: 3B) Summary of Results.....	18
Table 2-17	Steam Stripper Inlet Foul Condensate (Sample ID: 2A) Summary of Results.....	18
Table 2-18	Steam Stripper Out (Sample ID: 2B) Summary of Results .....	19
Table 3-1	Source Testing Methodology .....	20



## SECTION 1 INTRODUCTION

Weston Solutions, Inc. (WESTON®) was contracted by New-Indy Catawba, LLC (NIC) to conduct emission testing on the Pulp Dryer, No. 3 Paper Machine Vents, No. 2 and 3 Smelt Dissolving Tank Vents (SDTV), and No. 2 and 3 Combination Boilers (CB) at the NIC mill in Catawba, South Carolina. The purpose of the testing was to document the emissions from sources identified in Condition No. 5 (Order to Correct Undesirable Level of Air Contaminants) issued by the South Carolina Department of Health and Environmental Control (SC DHEC).

WESTON performed the emission testing during 21-27 June 2021. The project team included the following individuals.

<b>Name</b>	<b>Project Role</b>
Wayne Roberts	Project Manager/Test Team Leader (Team 2)
Van Dubay	Test Team Leader (Team 1)
Tyler Robinson	Test Team Member (Team 1)
Cory Lestochi	Test Team Member (Team 1)
Bryan Alldredge	Test Team Member (Team 2)
Brock Ennis	Test Team Member (Team 2)
Templeton Simpkins	Test Team Member
Chris Hartsy	Test Team Member (Liquid Sample Collection)
Natalie Hammonds	Quality Assurance Manager
Ashley Bryant	Report Coordinator

Mr. Dan Mallett of NIC coordinated the testing with mill operations and served as WESTON's technical contact throughout the effort. Mr. David Monroe of SC DHEC was present during the testing on 22, 23, and 26 June 2021. Mr. James Justice of SC DHEC was present during the testing on 22-26 June 2021. Mr. Derek Williams of SC DHEC was present during the testing on 27 June 2021.

The Louisiana Environmental Laboratory Accreditation Program (LELAP) is the accrediting body through which WESTON obtains both its LELAP and TNI accreditations. WESTON is accredited for operations in the states of Texas, Florida, and Virginia through reciprocity agreements with LELAP.



## SECTION 2 RESULTS AND DISCUSSION

---

---

The test program was to be completed between 15 June 2021 and 30 June 2021 as described in Condition 5. A WESTON test team conducted cyclonic flow checks on the No. 3 Paper Machine Vents on 15 June 2021. Stack extensions were installed on all vents to meet Method 1 criteria. All vents were determined to be noncyclonic and suitable for testing.

WESTON utilized two separate mobile laboratories and two separate test teams to complete the scope of work within the described timeline. The two teams traveled to NIC on 21 June 2021 and set up all the necessary equipment for testing. Team 1 was located on the No. 1 and 2 CBs with Team 2 located at the Paper Machine. Testing was scheduled to begin on 22 June 2021 but was delayed due to issues with the pulp mill that resulted in plugging of the process lines during the evening of 21 June 2021. Mill operations were back under normal operations on 23 June 2021, and testing was initiated. Team 1 conducted sulfur dioxide (SO<sub>2</sub>) and total reduced sulfur (TRS) measurements on CB1 operating with non-condensable gases (NCG) and stripper off gases (SOG) in the boiler followed by Condition 2, which consisted of three more sample runs with only the NCGs in CB1. Team 2 conducted testing on Paper Machine Vent 1. After reviewing the flow data collected on 23 June with the cyclonic flow data collected on 15 June, it was apparent that there was an issue with the fan on the No. 1 Paper Machine. Mill maintenance personnel verified that the belts on No. 1 and No. 2 Paper Machine Vents were damaged. The belts were replaced, and the No. 1 Paper Machine Vent testing was rescheduled for later in the week. The data collected on the No. 1 Paper Machine Vent (6-23-21) has been included in Appendix D for reference only.

On 24 June 2021, Test Team 1 conducted SO<sub>2</sub> and TRS measurements on CB2 while burning both the NCG and SOG gases. Test Team 2 started testing on the Paper Machine Vent 3 conducting three TRS sample runs. After completing Paper Machine Vent 3, the team moved to Paper Machine Vent 2 and conducted three one-hour TRS sample runs. It was determined through multiple discussions that the Paper Machine had a total of 7 vents rather than the 6 vents previously included in the scope of work and test plan. The 7 Paper Machine Vents are designated as Vents 1, 2, 3, 4, 6, 7, and 8. Adjustments were made to the schedule to sample all 7 vents.

On 25 June 2021, Test Team 1 conducted SO<sub>2</sub> and TRS measurements on CB2 while burning NCG gases only. Test Team 2 started testing on Paper Machine Vent 1 followed by Paper Machine Vent 4 and finally Paper Machine Vent 6. Three one-hour TRS sample runs were conducted on each vent.

On 26 June 2021, Test Team 1 conducted TRS measurements on the Pulp Dryer following the installation of the stack extension and scaffold. A cyclonic flow determination was conducted prior to the start of testing, and the stack was determined to be noncyclonic. Test Team 2 started testing on Paper Machine Vent 7 followed by Paper Machine Vent 8.

On 27 June 2021, Test Team 1 conducted TRS measurements on the No. 2 and 3 Combined SDTVs. All Paper Machine testing had been completed and verified as accurate.

Although cyclonic flow checks had been conducted on all the Paper Machine Vents prior to the start of testing, a second cyclonic flow check was conducted on the day of testing for each vent. The TRS concentrations on all Paper Machine Vents were less than 1 ppm. Volumetric flow rate (VFR) measurements were conducted using a Method 5 train with a heated probe, heated filter, and a cold box. A full 16-point traverse was conducted on each vent. Gravimetric measurements were conducted on each impinger before and after each run. Volumetric flow rate run time was set at 48 minutes for all flow measurements conducted simultaneously with the 60-minute TRS measurement to allow time for port changes and leak checks.

Cyclonic flow checks were also conducted prior to the start of testing on CB1, CB2, Pulp Dryer, and the SDTV. Volumetric flow rate measurements were conducted using a Method 5 train with a heated probe, heated filter, and a cold box. Gravimetric measurements were conducted on each impinger before and after each run. The VFR run time was set at 48-60 minutes for all flow measurements conducted simultaneously with the pollutant measurement.

Water samples were also collected by NIC personnel during 24-26 June 2021. These samples were analyzed by ALS Environmental at their Simi Valley, California laboratory. The samples were analyzed for five sulfur compounds using a gas chromatograph equipped with a sulfur chemiluminescence detector (SCD). The laboratory report can be found in Appendix G.

All testing proceeded as planned. The test teams coordinated with mill operations to ensure each process was operating at normal operating rates. Process data is included in Appendix H to document the operating rate for each source.

Table 2-1 provides a summary of the mean emission results for each source. Tables 2-2 through 2-14 provide detailed summaries of the emission results. Tables 2-15 through 2-18 provide detailed summaries of the water sample test results. Measurement uncertainty is not shown but has been taken into consideration during method development. Any differences between the calculated results presented in the appendices and the results reported in the summary tables are due to rounding for presentation.

**TABLE 2-1  
SUMMARY OF MEAN EMISSION RESULTS**

Source/Parameter	Mean Test Value
<b>Pulp Dryer</b> Total Reduced Sulfur, lb/hr	0.19
<b>No. 3 Paper Machine Vent 1</b> Total Reduced Sulfur, lb/hr	0.09
<b>No. 3 Paper Machine Vent 2</b> Total Reduced Sulfur, lb/hr	0.18
<b>No. 3 Paper Machine Vent 3</b> Total Reduced Sulfur, lb/hr	0.21
<b>No. 3 Paper Machine Vent 4</b> Total Reduced Sulfur, lb/hr	0.10
<b>No. 3 Paper Machine Vent 6</b> Total Reduced Sulfur, lb/hr	0.13
<b>No. 3 Paper Machine Vent 7</b> Total Reduced Sulfur, lb/hr	0.16
<b>No. 3 Paper Machine Vent 8</b> Total Reduced Sulfur, lb/hr	0.19
<b>No. 2 and 3 Smelt Dissolving Tank Vents</b> Total Reduced Sulfur, lb/hr	1.13
<b>No. 1 Combination Boiler (Condition 1: NCG &amp; SOG Gases)</b> Total Reduced Sulfur, lb/hr Sulfur Dioxide, lb/hr	0.52 360.9
<b>No. 1 Combination Boiler (Condition 2: NCG Gases Only)</b> Total Reduced Sulfur, lb/hr Sulfur Dioxide, lb/hr	0.44 436.1
<b>No. 2 Combination Boiler (Condition 1: NCG &amp; SOG Gases)</b> Total Reduced Sulfur, lb/hr Sulfur Dioxide, lb/hr	0.68 504.0
<b>No. 2 Combination Boiler (Condition 2: NCG Gases Only)</b> Total Reduced Sulfur, lb/hr Sulfur Dioxide, lb/hr	0.77 376.4

**TABLE 2-2**  
**PULP DRYER**  
**SUMMARY OF TRS EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/26/21	6/26/21	6/26/21	----
Time Began	1230	1347	1506	----
Time Ended	1339	1454	1611	----
<b>Stack Gas Data</b>				
Temperature, °F	158	159	158	158
Velocity, ft/sec	43	44	44	43
Moisture, %	7.8	11	9.2	9.2
CO <sub>2</sub> Concentration, %	0.0	0.0	0.0	0.0
O <sub>2</sub> Concentration, %	20.8	20.9	20.9	20.9
VFR, x 10 <sup>4</sup> dscfm	3.93	3.90	3.97	3.93
<b>Total Reduced Sulfur</b>				
Concentration, ppm	0.99	0.89	0.83	0.90
Emission Rate, lb/hr	0.21	0.18	0.17	0.19

**TABLE 2-3**  
**NO. 3 PAPER MACHINE VENT 1**  
**SUMMARY OF TRS EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/25/21	6/25/21	6/25/21	----
Time Began	0755	0900	1005	----
Time Ended	0855	1000	1105	----
<b>Stack Gas Data</b>				
Temperature, °F	171	172	173	172
Velocity, ft/sec	64	63	63	63
Moisture, %	19	19	18	19
CO <sub>2</sub> Concentration, %	0.2	0.2	0.2	0.2
O <sub>2</sub> Concentration, %	20.2	20.2	20.2	20.2
VFR, x 10 <sup>4</sup> dscfm	3.50	3.47	3.47	3.48
<b>Total Reduced Sulfur</b>				
Concentration, ppm	0.43	0.48	0.57	0.49
Emission Rate, lb/hr	0.08	0.09	0.10	0.09



**TABLE 2-4**  
**NO. 3 PAPER MACHINE VENT 2**  
**SUMMARY OF TRS EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/24/21	6/24/21	6/24/21	----
Time Began	1310	1416	1522	----
Time Ended	1410	1516	1622	----
<b>Stack Gas Data</b>				
Temperature, °F	178	178	179	179
Velocity, ft/sec	78	77	80	78
Moisture, %	20	19	19	19
CO <sub>2</sub> Concentration, %	0.2	0.2	0.2	0.2
O <sub>2</sub> Concentration, %	20.2	20.2	20.2	20.2
VFR, x 10 <sup>4</sup> dscfm	5.20	5.26	5.45	5.30
<b>Total Reduced Sulfur</b>				
Concentration, ppm	0.68	0.62	0.57	0.62
Emission Rate, lb/hr	0.19	0.17	0.16	0.18

**TABLE 2-5**  
**NO. 3 PAPER MACHINE VENT 3**  
**SUMMARY OF TRS EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/24/21	6/24/21	6/24/21	----
Time Began	0937	1042	1145	----
Time Ended	1037	1142	1245	----
<b>Stack Gas Data</b>				
Temperature, °F	185	187	182	185
Velocity, ft/sec	83	82	82	82
Moisture, %	21	21	20	21
CO <sub>2</sub> Concentration, %	0.2	0.2	0.2	0.2
O <sub>2</sub> Concentration, %	20.2	20.2	20.2	20.2
VFR, x 10 <sup>4</sup> dscfm	5.45	5.30	5.51	5.42
<b>Total Reduced Sulfur</b>				
Concentration, ppm	0.81	0.69	0.73	0.74
Emission Rate, lb/hr	0.23	0.19	0.21	0.21

**TABLE 2-6  
NO. 3 PAPER MACHINE VENT 4  
SUMMARY OF TRS EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/25/21	6/25/21	6/25/21	----
Time Began	1135	1240	1345	----
Time Ended	1235	1340	1445	----
<b>Stack Gas Data</b>				
Temperature, °F	193	194	194	194
Velocity, ft/sec	55	58	55	56
Moisture, %	27	27	26	27
CO <sub>2</sub> Concentration, %	0.2	0.2	0.2	0.2
O <sub>2</sub> Concentration, %	20.2	20.2	20.2	20.2
VFR, x 10 <sup>4</sup> dscfm	3.32	3.47	3.31	3.37
<b>Total Reduced Sulfur</b>				
Concentration, ppm	0.56	0.53	0.62	0.57
Emission Rate, lb/hr	0.10	0.10	0.11	0.10

**TABLE 2-7  
NO. 3 PAPER MACHINE VENT 6  
SUMMARY OF TRS EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/25/21	6/25/21	6/25/21	----
Time Began	1555	1715	1820	----
Time Ended	1655	1816	1920	----
<b>Stack Gas Data</b>				
Temperature, °F	191	191	190	191
Velocity, ft/sec	79	80	76	78
Moisture, %	25	26	22	25
CO <sub>2</sub> Concentration, %	0.2	0.2	0.2	0.2
O <sub>2</sub> Concentration, %	20.2	20.2	20.2	20.2
VFR, x 10 <sup>4</sup> dscfm	4.18	4.18	4.21	4.19
<b>Total Reduced Sulfur</b>				
Concentration, ppm	0.57	0.59	0.59	0.58
Emission Rate, lb/hr	0.13	0.13	0.13	0.13

**TABLE 2-8**  
**NO. 3 PAPER MACHINE VENT 7**  
**SUMMARY OF TRS EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/26/21	6/26/21	6/26/21	----
Time Began	0945	1050	1155	----
Time Ended	1046	1150	1255	----
<b>Stack Gas Data</b>				
Temperature, °F	188	188	190	189
Velocity, ft/sec	75	74	76	75
Moisture, %	26	24	25	25
CO <sub>2</sub> Concentration, %	0.2	0.1	0.2	0.2
O <sub>2</sub> Concentration, %	20.2	20.2	20.2	20.2
VFR, x 10 <sup>4</sup> dscfm	6.40	6.42	6.52	6.45
<b>Total Reduced Sulfur</b>				
Concentration, ppm	0.42	0.43	0.52	0.46
Emission Rate, lb/hr	0.14	0.15	0.18	0.16

**TABLE 2-9**  
**NO. 3 PAPER MACHINE VENT 8**  
**SUMMARY OF TRS EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/26/21	6/26/21	6/26/21	----
Time Began	1315	1420	1525	----
Time Ended	1415	1520	1625	----
<b>Stack Gas Data</b>				
Temperature, °F	184	184	184	184
Velocity, ft/sec	72	74	70	72
Moisture, %	24	23	23	23
CO <sub>2</sub> Concentration, %	0.1	0.1	0.1	0.1
O <sub>2</sub> Concentration, %	20.2	20.2	20.2	20.2
VFR, x 10 <sup>4</sup> dscfm	6.31	6.57	6.27	6.38
<b>Total Reduced Sulfur</b>				
Concentration, ppm	0.59	0.51	0.56	0.55
Emission Rate, lb/hr	0.20	0.18	0.19	0.19

**TABLE 2-10  
NO. 2 AND 3 SMELT DISSOLVING TANK VENTS  
SUMMARY OF TRS EMISSION RESULTS**

	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Mean</b>
Date	6/27/21	6/27/21	6/27/21	----
Time Began	1100	1222	1344	----
Time Ended	1210	1331	1454	----
<b>Stack Gas Data</b>				
Temperature, °F	168	170	169	169
Velocity, ft/sec	31	33	32	32
Moisture, %	39	41	41	40
CO <sub>2</sub> Concentration, %	0.0	0.0	0.0	0.0
O <sub>2</sub> Concentration, %	20.1	20.0	20.3	20.1
VFR, x 10 <sup>4</sup> dscfm	2.60	2.61	2.54	2.58
<b>Total Reduced Sulfur</b>				
Concentration, ppm	7.36	9.23	8.20	8.26
Emission Rate, lb/hr	1.02	1.28	1.10	1.13

**TABLE 2-11**  
**NO. 1 COMBINATION BOILER**  
**CONDITION 1: NCG AND SOG GASES**  
**SUMMARY OF TRS AND SO<sub>2</sub> EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/23/21	6/23/21	6/23/21	----
Time Began	1158	1400	1541	----
Time Ended	1258	1500	1641	----
<b>Stack Gas Data</b>				
Temperature, °F	415	418	415	416
Velocity, ft/sec	59	57	57	57
Moisture, %	17	18	16	17
CO <sub>2</sub> Concentration, %	7.8	8.4	7.7	8.0
O <sub>2</sub> Concentration, %	12.1	11.4	12.0	11.8
VFR, x 10 <sup>5</sup> dscfm	1.35	1.31	1.33	1.33
<b>Total Reduced Sulfur</b>				
Concentration, ppm	0.78	0.71	0.70	0.73
Emission Rate, lb/hr	0.56	0.49	0.50	0.52
<b>Sulfur Dioxide</b>				
Concentration, ppm	195	278	344	272
Emission Rate, lb/hr	262.7	362.5	457.4	360.9

**TABLE 2-12**  
**NO. 1 COMBINATION BOILER**  
**CONDITION 2: NCG GASES ONLY**  
**SUMMARY OF TRS AND SO<sub>2</sub> EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/23/21	6/23/21	6/23/21	----
Time Began	1824	2019	2202	----
Time Ended	1924	2119	2302	----
<b>Stack Gas Data</b>				
Temperature, °F	416	411	415	414
Velocity, ft/sec	56	56	56	56
Moisture, %	16	16	17	17
CO <sub>2</sub> Concentration, %	8.3	7.8	8.1	8.1
O <sub>2</sub> Concentration, %	11.4	11.9	11.6	11.6
VFR, x 10 <sup>5</sup> dscfm	1.30	1.31	1.30	1.30
<b>Total Reduced Sulfur</b>				
Concentration, ppm	0.63	0.60	0.67	0.63
Emission Rate, lb/hr	0.43	0.42	0.46	0.44
<b>Sulfur Dioxide</b>				
Concentration, ppm	313	348	349	337
Emission Rate, lb/hr	404.4	452.9	450.8	436.1

**TABLE 2-13**  
**NO. 2 COMBINATION BOILER**  
**CONDITION 1: NCG AND SOG GASES**  
**SUMMARY OF TRS AND SO<sub>2</sub> EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/24/21	6/24/21	6/24/21	----
Time Began	1445	1630	1806	----
Time Ended	1545	1730	1906	----
<b>Stack Gas Data</b>				
Temperature, °F	475	474	479	476
Velocity, ft/sec	69	69	69	69
Moisture, %	14	14	15	14
CO <sub>2</sub> Concentration, %	6.6	6.9	7.3	6.9
O <sub>2</sub> Concentration, %	13.1	12.7	12.3	12.7
VFR, x 10 <sup>5</sup> dscfm	1.57	1.56	1.54	1.56
<b>Total Reduced Sulfur</b>				
Concentration, ppm	0.92	0.76	0.77	0.82
Emission Rate, lb/hr	0.77	0.63	0.63	0.68
<b>Sulfur Dioxide</b>				
Concentration, ppm	324	327	322	324
Emission Rate, lb/hr	508.7	507.2	496.1	504.0

**TABLE 2-14**  
**NO. 2 COMBINATION BOILER**  
**CONDITION 2: NCG GASES ONLY**  
**SUMMARY OF TRS AND SO<sub>2</sub> EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	6/25/21	6/25/21	6/25/21	----
Time Began	1000	1135	1315	----
Time Ended	1100	1235	1415	----
<b>Stack Gas Data</b>				
Temperature, °F	468	470	481	473
Velocity, ft/sec	68	69	69	69
Moisture, %	14	14	14	14
CO <sub>2</sub> Concentration, %	6.9	6.8	7.3	7.0
O <sub>2</sub> Concentration, %	12.8	12.7	12.3	12.6
VFR, x 10 <sup>5</sup> dscfm	1.56	1.55	1.56	1.56
<b>Total Reduced Sulfur</b>				
Concentration, ppm	1.04	0.99	0.76	0.93
Emission Rate, lb/hr	0.86	0.82	0.63	0.77
<b>Sulfur Dioxide</b>				
Concentration, ppm	247	245	235	242
Emission Rate, lb/hr	383.2	380.0	366.2	376.4

**TABLE 2-15  
PAPER MACHINE 3 WHITEWATER (SAMPLE ID: 3A)  
SUMMARY OF RESULTS**

Date	Time	Hydrogen Sulfide (µg/L)	Methyl Mercaptan (µg/L)	Dimethyl Sulfide (µg/L)	Carbon Disulfide (µg/L)	Dimethyl Disulfide (µg/L)
6/24/21	10:00	200,000	740	ND	ND	ND
6/24/21	11:15	210,000	700	ND	ND	ND
6/24/21	11:15 (Duplicate)	190,000	840	310	ND	680
6/24/21	12:10	170,000	640	ND	ND	ND
6/24/21	13:31	160,000	540	ND	ND	ND
6/24/21	14:50	170,000	560	ND	ND	ND
6/24/21	16:00	190,000	830	360	ND	710
6/25/21	08:17	190,000	790	ND	ND	ND
6/25/21	09:24	130,000	560	170	ND	ND
6/25/21	10:30	150,000	710	170	ND	ND
6/25/21	12:00	130,000	620	340	ND	550
6/25/21	12:55	140,000	730	180	ND	ND
6/25/21	14:03	180,000	1,200	400	ND	840
6/25/21	16:30	160,000	1,300	ND	ND	430
6/25/21	17:40	170,000	1,300	ND	ND	250
6/25/21	18:45	140,000	1,300	ND	ND	ND
6/26/21	10:10	90,000	1,100	420	ND	710
6/26/21	11:25	75,000	1,700	180	ND	170
6/26/21	12:30	59,000	2,000	170	ND	ND
6/26/21	14:00	42,000	1,500	150	ND	170
6/26/21	14:45	37,000	1,500	ND	ND	120
6/26/21	15:50	41,000	1,700	190	22	81

Note: ND (Not Detected). The compound was analyzed but not detected above the laboratory report limit.

**TABLE 2-16  
PULP DRYER WATER (SAMPLE ID: 3B)  
SUMMARY OF RESULTS**

Date	Time	Hydrogen Sulfide (µg/L)	Methyl Mercaptan (µg/L)	Dimethyl Sulfide (µg/L)	Carbon Disulfide (µg/L)	Dimethyl Disulfide (µg/L)
6/26/21	13:05	9.4	7.7	37	ND	11
6/26/21	14:15	7.7	5.8	42	ND	15
6/26/21	15:30	5.4	5.9	47	ND	17

Note: ND (Not Detected). The compound was analyzed but not detected above the laboratory report limit.

**TABLE 2-17  
STEAM STRIPPER INLET FOUL CONDENSATE (SAMPLE ID: 2A)  
SUMMARY OF RESULTS**

Date	Time	Hydrogen Sulfide (µg/L)	Methyl Mercaptan (µg/L)	Dimethyl Sulfide (µg/L)	Carbon Disulfide (µg/L)	Dimethyl Disulfide (µg/L)
6/24/21	15:10	130,000	14,000	16,000	ND	13,000
6/24/21	15:10 Duplicate	140,000	14,000	16,000	ND	17,000
6/24/21	17:00	140,000	17,000	18,000	ND	14,000
6/24/21	18:45	150,000	19,000	18,000	ND	16,000
6/25/21	10:35	130,000	12,000	12,000	ND	11,000
6/25/21	12:05	120,000	10,000	12,000	ND	9,600
6/25/21	13:45	190,000	22,000	22,000	ND	23,000

Note: ND (Not Detected). The compound was analyzed but not detected above the laboratory report limit.



**TABLE 2-18**  
**STEAM STRIPPER OUT (SAMPLE ID: 2B)**  
**SUMMARY OF RESULTS**

<b>Date</b>	<b>Time</b>	<b>Hydrogen Sulfide (µg/L)</b>	<b>Methyl Mercaptan (µg/L)</b>	<b>Dimethyl Sulfide (µg/L)</b>	<b>Carbon Disulfide (µg/L)</b>	<b>Dimethyl Disulfide (µg/L)</b>
6/24/21	15:15	5,000	200	2,800	ND	4,100
6/24/21	15:15 Duplicate	3,200	94	3,000	ND	4,400
6/24/21	17:05	7,100	540	2,900	ND	3,900
6/24/21	18:50	8,100	760	3,000	ND	4,100
6/25/21	10:40	3,300	100	2,400	ND	3,600
6/25/21	12:10	550	4.8	1,900	2.0	3,000
6/25/21	13:50	3,500	260	2,500	ND	4,300

Note: ND (Not Detected). The compound was analyzed but not detected above the laboratory report limit.



## SECTION 3 SOURCE TESTING METHODOLOGY

The emission testing program was conducted in accordance with the U.S. EPA Reference Methods summarized in Table 3-1. Method descriptions and quality assurance data are provided in the referenced appendices.

**TABLE 3-1  
SOURCE TESTING METHODOLOGY**

Parameter	Method Number	Appendix Reference		Comments
		Method Description	Quality Control Data	
Volumetric Flow Rate	1,2,4	B.1	H	
Gas Composition	3A	B.2	H	Instrumental
Gas Composition (Bags)	3A	B.3	H	See Note
Total Reduced Sulfur	16	B.4	H	
Sulfur Dioxide	6C	B.5	H	Instrumental

Note: Oxygen (O<sub>2</sub>) and carbon dioxide (CO<sub>2</sub>) concentrations for the Pulp Dryer, No. 3 Paper Machine Vents, and the No. 2 and 3 SDTVs were determined from integrated bag samples collected concurrently with the TRS sampling. These samples were analyzed instrumentally using an analyzer calibrated according to the procedures of Method 3A.

These results meet all requirements of TNI unless otherwise specified.

The results within this report relate only to the samples listed in the body of this report.



## SECTION 4 QUALITY ASSURANCE/ QUALITY CONTROL

---

---

### 4.1 QUALITY CONTROL PROCEDURES

As part of all testing, WESTON implements a QA/QC program. The field team leader is responsible for implementation of field QA/QC procedures. Individual laboratory managers are responsible for implementation of analytical QA/QC procedures. The overall project manager and the Quality Assurance Manager oversee all QA/QC procedures to ensure that sampling and analyses meet the QA/QC requirements and that accurate data results are generated from the test program.

### 4.2 GAS STREAM SAMPLING QA/QC PROCEDURES

General checks that are conducted during testing and apply to all methods include the following:

- Performance of leak checks.
- Use of standardized forms, labels, and checklists.
- Maintenance of sample traceability.
- Collection of appropriate blanks.
- Use of calibrated instrumentation.
- Review of data sheets in the field to verify completeness.
- Use of validated spreadsheets for calculation of results.

The following section details the specific procedures applied to the reference method sampling system.

#### **Instrumental Reference Method Sampling Systems**

- The sampling system (probe to sample conditioner) is leak-checked prior to the testing.
- All analyzers are calibrated prior to testing to ensure precise and accurate data. Protocol standards are used to calibrate each of the analyzers. Each analyzer is calibrated at three to four points (zero, low, mid, and high range) depending on reference method requirements. Nitrogen or hydrocarbon-free air is used to set the instrument zero. The CO<sub>2</sub> and O<sub>2</sub> calibration standards are 40 to 60 and 100% of span.
- Pre- and post-test calibration bias and calibration drift tests are performed for each test run. The bias check is performed with the calibration standard that is closest to the observed concentration in the sample gas. The average pretest/posttest bias did not exceed 5% of full scale. The calibration drift did not exceed 3%.

- Prior to formal testing, a 12-point stratification check is performed at the test location. Alternatively, per Section 8.1.2 of EPA Method 7E, a three-point stratification check passing through the centroidal area of the stack is performed. The three points (16.7, 50, and 83.3% of the stack diameter) are sampled a minimum of two times the system response.
- A response time check is performed before sampling. Sample flow rate must be maintained within 10% of the flow rate at which the system response time was measured.
- A permanent data record of analyzer responses is recorded using computer software designed by WESTON.

### 4.3 QA/QC CHECKS FOR DATA REDUCTION AND VALIDATION

All data and/or calculations for flow rates and moisture contents, which are made using a computer software program, are validated by an independent check. In addition, all calculations are spot checked for accuracy and completeness by the Field Team Manager.

In general, all measurement data are validated based on the following criteria:

- Process conditions during sampling or testing.
- Acceptable sample collection procedures.
- Consistency with expected or other results.
- Adherence to prescribed QC procedures.

Any suspect data are flagged and identified with respect to the nature of the problem and potential effect on the data quality.

Upon completion of testing, the Field Team Manager is responsible for preparation of a complete data summary including calculation results, raw data sheets, and laboratory reports.



## APPENDIX A SAMPLE CALCULATIONS

---

## SAMPLE CALCULATIONS

### No. 3 Paper Machine Vent 1 Run No. 1

**Meter Pressure (Pm), in. Hg**

$$P_m = P_b + \frac{\Delta H}{13.6 \text{ in. H}_2\text{O/in. Hg}}$$

where,  $P_b$  = barometric pressure, in. Hg  
 $\Delta H$  = Pressure differential of orifice in. H<sub>2</sub>O

$$P_m = 29.68 \text{ in. Hg} + \frac{1.300 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.78 \text{ in. Hg}$$

**Absolute Stack Gas Pressure (Ps), in. Hg**

$$P_s = P_b + \frac{P_g}{13.6 \text{ in. H}_2\text{O/in. Hg}}$$

where,  $P_b$  = barometric pressure, in. Hg  
 $P_g$  = Static Pressure, in. H<sub>2</sub>O

$$P_s = 29.68 \text{ in. Hg} + \frac{-0.65 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.63 \text{ in. Hg}$$

**Standard Meter Volume (Vmstd), dscf**

$$V_{mstd} = \frac{17.64 \text{ }^\circ\text{R/in. Hg} \times Y \times V_m \times P_m}{T_m}$$

where,  $Y$  = meter correction factor  
 $V_m$  = meter volume, dscf  
 $P_m$  = meter pressure, in. Hg  
 $T_m$  = meter temperature, °R

$$V_{mstd} = \frac{17.64 \text{ }^\circ\text{R/in. Hg} \times 1.003 \times 29.740 \text{ dscf} \times 29.78 \text{ in. Hg}}{522.2 \text{ }^\circ\text{R}} = 30.003 \text{ dscf}$$

**Standard Wet Volume (Vwstd), scf**

$$V_{wstd} = 0.04707 \text{ ft}^3/\text{mL} \times V_{lc}$$

where,  $V_{lc}$  = volume of H<sub>2</sub>O collected, mL

$$V_{wstd} = 0.04707 \text{ ft}^3/\text{mL} \times 147.7 \text{ mL} = 6.952 \text{ scf}$$

**Moisture Fraction (Measured), (Bws)**

$$B_{ws} = \frac{V_{wstd}}{(V_{wstd} + V_{mstd})} = \frac{6.952 \text{ scf}}{6.952 \text{ scf} + 30.003 \text{ dscf}} = 0.188$$

where,  $V_{wstd}$  = standard wet volume, scf  
 $V_{mstd}$  = standard meter volume, dscf

**Moisture %, (Bws %)**

$$B_{ws} = B_{ws} \times 100 = 0.188 \times 100 = 18.8$$

where,  $B_{ws}$  = moisture fraction, measured or at saturation, whichever is lowest

**Molecular Weight (DRY) (Md), lb/lb-mole**

$$M_d = (0.44 \times \% \text{CO}_2) + (0.32 \times \% \text{O}_2) + (0.28 (100 - \% \text{CO}_2 - \% \text{O}_2))$$

$$M_d = (0.44 \times 0.2) + (0.32 \times 20.2) + (0.28 (100 - 0.2 - 20.2)) = 28.84 \text{ lb/lb-mole}$$

**Molecular Weight (WET) (Ms), lb/lb-mole**

$$M_s = M_d (1 - B_{ws}) + 18 (B_{ws})$$

where,  $M_d$  = molecular weight (DRY), lb/lb-mole  
 $B_{ws}$  = moisture fraction, dimensionless

$$M_s = 28.84 \text{ lb/lb-mole} (1 - 0.188) + 18 (0.188) = 26.80 \text{ lb/lb-mole}$$

**Average Velocity (Vs), ft/sec**

$$V_s = 85.49 \frac{\text{ft}}{\text{sec}} \sqrt{\frac{(\text{lb/lb-mole})(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. H}_2\text{O})}} \times C_p \times \sqrt{\Delta P \text{ avg.}} \times \sqrt{\frac{T_s}{P_s \times M_s}}$$

where,  $C_p$  = pitot tube coefficient  
 $\Delta P$  = velocity head of stack gas, in.  $\text{H}_2\text{O}$   
 $T_s$  = absolute stack temperature,  $^{\circ}\text{R}$   
 $P_s$  = absolute stack gas pressure, in. Hg  
 $M_s$  = molecular weight of stack gas, lb/lb-mole

$$V_s = 85.49 \frac{\text{ft}}{\text{sec}} \sqrt{\frac{(\text{lb/lb-mole})(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. H}_2\text{O})}} \times 0.84 \times 0.993 \text{ in. H}_2\text{O} \times \sqrt{\frac{631.2 \text{ }^{\circ}\text{R}}{29.63 \text{ in. Hg} \times 26.80 \text{ lb/lb-mole}}}$$

$$V_s = 63.60 \text{ ft/sec}$$

**Average Stack Gas Flow at Stack Conditions (Qa), acfm**

$$Q_a = 60 \text{ sec/min} \times V_s \times A_s \quad \text{where, } V_s = \text{stack gas velocity, ft/sec}$$

$$A_s = \text{cross-sectional area of stack, ft}^2$$

$$Q_a = 60 \text{ sec/min} \times 63.60 \text{ ft/sec} \times 13.64 \text{ ft}^2 = 5.20 \text{ E}+4 \text{ acfm}$$

**Average Stack Gas Flow at Standard Conditions (Qs), dscfm**

$$Q_s = 17.64 \frac{^{\circ}\text{R}}{\text{in. Hg}} \times Q_a \times (1 - B_{ws}) \times \frac{P_s}{T_s}$$

where,  $Q_a$  = average stack gas flow at stack conditions,  $\text{ft}^3/\text{min}$   
 $B_{ws}$  = moisture content (dimensionless)  
 $P_s$  = absolute stack gas pressure, in. Hg  
 $T_s$  = absolute stack temperature,  $^{\circ}\text{R}$

$$Q_s = 17.64 \frac{^{\circ}\text{R}}{\text{in. Hg}} \times 5.20 \text{ E}+4 \frac{\text{acf}}{\text{min}} \times (1 - 0.188) \times \frac{29.63 \text{ in. Hg}}{631.2 \text{ }^{\circ}\text{R}} = 3.50 \text{ E}+4 \text{ dscfm}$$

**Total Reduced Sulfur Emission Rate (EMR), lb/hr**

$$EMR = \frac{TRS \text{ conc.} \times MW \times Q_s \frac{\text{dscf}}{\text{min}} \times 60 \frac{\text{min}}{\text{hr}} \times 28.32 \frac{\text{L}}{\text{dscf}}}{24.04 \frac{\text{L}}{\text{g-mole}} \times 1.0 \times 10^6 \frac{\mu\text{L}}{\text{L}} \times 454 \frac{\text{g}}{\text{lb}}}$$

where,  $MW$  = molecular weight of TRS, 34.08 g/g-mole  
 $Q_s$  = stack gas flow at standard conditions, dscfm

$$EMR = \frac{0.43 \text{ ppm} \times 34.08 \frac{\text{g}}{\text{g-mole}} \times 3.50 \text{ E}+4 \frac{\text{dscf}}{\text{min}} \times 60 \frac{\text{min}}{\text{hr}} \times 28.32 \frac{\text{L}}{\text{dscf}}}{24.04 \frac{\text{L}}{\text{g-mole}} \times 1.0 \times 10^6 \frac{\mu\text{L}}{\text{L}} \times 454 \frac{\text{g}}{\text{lb}}} = 0.08 \text{ lb/hr}$$

**Note:** Sulfur dioxide was calculated using the same equation as presented for TRS, substituting molecular weight.





## APPENDIX B TEST METHODOLOGY

---

- B.1 VOLUMETRIC FLOW RATE**
- B.2 GAS COMPOSITION**
- B.3 GAS COMPOSITIONS (BAGS)**
- B.4 TOTAL REDUCED SULFUR**
- B.5 SULFUR DIOXIDE**

## B.1 VOLUMETRIC FLOW RATE

Mass emission rates are calculated by multiplying measured target analyte concentrations by calculated volumetric flow rates. Volumetric flow rates are determined using measurement data obtained by EPA Reference Methods 1-4.

The ductwork is measured at the sample location to the nearest 0.25 inch using a steel tape measure. Traverse points are selected in accordance with EPA Reference Method 1 on the basis of ductwork dimensions, geometry, and upstream and downstream disturbances. When a sample location does not meet EPA Reference Method 1 criteria, the maximum recommended number of traverse points are used.

### Gas Velocity

The velocity of the gas stream is measured in accordance with EPA Reference Method 2 by reading the instantaneous velocity pressure at each traverse point using an “S” type pitot tube and a leveled, inclined manometer with a scale of 0 to 10 inches. In rare cases of highly negative pressure sources, a Magnahelic gauge with scales of 0 to 5 or 0 to 25 inches of water may be used in place of an inclined manometer. The stack pressure is calculated from the measured static pressure of the stack and the ambient barometric pressure corrected for elevation when applicable. The static pressure is measured by using the static side of the pitot tube, and the barometric pressure is measured using a calibrated aneroid barometer. The stack temperature is measured at each traverse point with a calibrated thermocouple and pyrometer.

### Gas Composition and Moisture Content

The composition of the gas stream will be measured in accordance with EPA Reference Method 3 and/or 3A using an Orsat analyzer or Paramagnetic O<sub>2</sub> and Infrared CO<sub>2</sub> analyzers using Protocol-1 gases. Gas composition determinations are conducted using integrated sampling techniques.

Integrated samples are collected by withdrawing a sample from the M5 sampling train into a Tedlar sample bag.

The moisture content of the gas stream is determined according to EPA Reference Method 4, by collecting an integrated sample of source gas from a single point on the gas stream. At the conclusion of each run the volume of condensed moisture collected in the impingers of the sampling train is measured and used to evaluate the moisture content of the gas stream.

When sources are saturated or contain entrained water droplets, moisture content is also determined using the temperature measured at each traverse point and psychometric chart values corrected for stack pressure or by use of saturation vapor pressure tables. In these conditions, the lower moisture of the measured and saturation based values is used for volumetric flow rate calculations.

The molecular weight of the gas stream is calculated using the determined moisture, oxygen, and carbon dioxide concentrations. The balance of the gas stream is assumed to be nitrogen. The volumetric flow is then calculated at stack and standard conditions using the calculated molecular weight, the measured stack temperature, and measured velocity, stack and barometric pressures. Standard conditions are 68 °F and 29.92 inches of mercury and 0% moisture.

### **Data Acquisition and Reporting**

Data are recorded at the time of collection on preprinted data sheets. Calculations are performed (where possible) with preprogrammed calculators or spreadsheet software.

### **Quality Control**

Quality control procedures for volumetric flow measurements involve leak checks of pitot tubes, pitot tube lines and manometers; calibration of gas metering systems; and periodic calibration checks of thermocouples and pyrometers. Magnahelics are verified against inclined manometers prior to each use.

Data transfers are minimized. Data sheets are checked for completeness and accuracy. Calculations are verified by a second person.

## **B.2 GAS COMPOSITION (INSTRUMENTAL)**

Oxygen (O<sub>2</sub>) and carbon dioxide (CO<sub>2</sub>) testing is conducted in accordance with EPA Reference Method 3A.

### **Sampling Equipment and Procedures**

Figure B-1 illustrates the sampling system. The sample is withdrawn continuously from the source through a heated probe, filter, and sample line to a sample conditioner which removes moisture from the gas stream. The sample is then transported to a Paramagnetic O<sub>2</sub> analyzer and an Infrared CO<sub>2</sub> analyzer.

### **Sample Analysis**

The O<sub>2</sub> analyzer uses an electrochemical cell or a paramagnetic detector, and the CO<sub>2</sub> analyzer uses a non-dispersive infra-red (NDIR) detector to produce an electrical signal which is linearly proportional to the O<sub>2</sub> and CO<sub>2</sub> concentration, respectively.




Figure B-1 Continuous Emission Monitoring System

### **Data Acquisition and Reduction**

Data are acquired electronically using a computer with software designed by WESTON for EPA Reference Method 3A analysis. This system generates a calibration curve, converts electronic signals into concentrations, and provides one-minute averages during the sample run and an average concentration over the duration of the sample run.

### **Quality Control**

At the time of analysis, O<sub>2</sub> and CO<sub>2</sub> in nitrogen calibration gases certified according to EPA Protocol-1, are used to calibrate the analyzer and to determine a bias correction factor for the entire system bias in accordance with EPA Reference Method 3A. The calibration gases are introduced directly to the analyzer to generate the calibration curve. A zero gas and an upscale calibration gas are introduced at the probe and recovered through the sampling and analytical system. A bias correction factor is calculated using the ratio of the concentration measured from the sampling system and concentration measured directly at the analyzer. Sample run averages are corrected for system bias results.

## **B.3 GAS COMPOSITION (BAGS WITH INSTRUMENTAL ANALYSIS)**

Oxygen (O<sub>2</sub>) and carbon dioxide (CO<sub>2</sub>) measurement is conducted by collecting integrated samples in Tedlar<sup>®</sup> gas-sampling bags collected according to the procedures specified in EPA Reference Method 3. The samples are analyzed on equipment operated and calibrated according to EPA Reference Method 3A.

### **Sampling Equipment and Procedures**

Samples of the source gas are collected in Tedlar<sup>®</sup> gas-sampling bags. The gas is sampled at a constant flow rate over the duration of a test run at each traverse point. The flow rate is set to a value which results in a sample volume that is adequate for analysis without overfilling the bag. The sample passes through a moisture condenser before entering the bag.

### **Sample Analysis**

Analysis of the sample is performed by attaching the bag directly to the inlets of electronic O<sub>2</sub> and CO<sub>2</sub> analyzers. These analyzers are calibrated before analysis using the procedures described in Method 3A. At least three data points are recorded for each sample, and the sample concentration is taken as the average of these values.

The oxygen analyzer uses a paramagnetic detector. This device exploits magnetic properties unique to O<sub>2</sub> to produce an electrical signal that is linearly proportional to the concentration of the gas.

The carbon dioxide analyzer uses non-dispersive infrared (NDIR) technology. The sample gas is passed through a chamber through which is passed infrared light of a wavelength that is specific to CO<sub>2</sub>. The CO<sub>2</sub> in the gas absorbs light of this wavelength to a degree that is proportional to the CO<sub>2</sub> concentration. The electronics in the analyzer measure the absorption of the light and produce a signal that is linearly proportional to the gas concentration.

### **Data Acquisition and Reduction**

The electrical outputs of the analyzers are connected to an analog-to-digital (A/D) conversion device installed in a Windows®-based computer running software designed by WESTON for analysis by Method 3A and similar EPA Methods.

The software reads the values presented by the A/D device at one-second intervals and periodically records averages of these readings. The software also handles calibrations and the generation of calibration curves and performs all calculations, including the determination of gas concentrations from the recorded inputs.

### **Quality Control**

The bags and the equipment used to fill the bags are checked for leaks before sampling begins. Bags are analyzed as soon as possible after sample collection and are not held for more than 8 hours before analysis.

The analyzers are calibrated prior to analysis using gas mixtures certified by their manufacturer according to EPA Protocol 1. For calibration, the gases are introduced directly to the analyzers.

## **B.4 TOTAL REDUCED SULFUR**

Total reduced sulfur testing is performed using the procedures described in EPA Reference Method 16. When TRS data must be oxygen corrected, EPA Reference Method 3A using a calibrated O<sub>2</sub> analyzer, is performed on an integrated bag sample to measure oxygen concentration.

### **Sampling Equipment and Procedures**

Figure B-2 illustrates the sampling system. A Teflon®-lined, stainless steel probe of sufficient length to monitor the gas stream (without wall effects) is used to extract a gas sample from the emission source. The probe tip is directed away from stack gas flow to minimize particulate and moisture entrainment. The probe is connected directly to the recovery gas line and sample conditioning system.




Figure B-2 EPA Reference Method 16 Sampling and Analytical Train

The sample conditioning system consists of a Teflon® impinger containing 1.5M citrate buffer, adjusted to a pH of 5.4 to 5.6, maintained in an ice bath. Moisture is condensed in the impingers, yielding a dry sample and thus eliminating the need for heated sample lines. Even though the impinger set traps entrained particulate matter, very fine particulate matter is removed by a Balston® AQ Microfiber filter installed at the impinger outlet.

An unheated nylon line is connected from the filter to the sample pump inlet. Sample line length and connections are minimized to reduce surface adsorption of TRS and the possibility of leaks.

The pump outlet is connected directly to a constant pressure bottle. At this point, a major portion of the sample is vented to the atmosphere, and the remainder is used to charge the gas chromatograph (GC) sample loop. The GC sample loop outlet is connected to a Tedlar® gas collection bag gas sample collection and subsequent analysis using a calibrated O<sub>2</sub> analyzer.

### **Sample Analysis**

Separation of hydrogen sulfide (H<sub>2</sub>S), methyl mercaptan (MeSH), dimethyl sulfide (DMS), and dimethyl disulfide (DMDS) is accomplished by gas chromatography using a column suitable for separating these compounds. After resolution of H<sub>2</sub>S, MeSH, and DMS, the column is backflushed to achieve resolution of DMDS within 2-3 minutes from sample injection. The gas chromatograph is operated on periodic cycle to produce a minimum of 20 injections per hour.

Detection of reduced sulfur compounds is accomplished with a flame photometric detector (FPD). The FPD response is calibrated before and after testing using gas phase standards prepared from gravimetrically certified permeation devices.

### **Data Acquisition and Reduction**

The FPD responses are recorded by a computer equipped with software designed by WESTON for reduced sulfur compound analysis. The software controls the timing of the gas-chromatographic cycle, integrates and records peaks, performs calculations, and prints the results. Calibration curves are generated by the software using log-log linear least squares best fit of the data.

### **Quality Control**

Permeation devices certified by the vendor are used to calibrate the FPD response. They are kept in a permeation chamber that is maintained at a constant temperature of 50° ± 1°C, the temperature at which the vendor certified the permeation rates. This assures that the actual permeation rates are the same as the certified rates. This temperature is verified at the time of sampling using a National Institute of Standards and Technology (NIST) traceable mercury-in-glass thermometer.



VICI-Metronics, Santa Clara, California, supplied the permeation devices for the testing. The devices are gravimetrically analyzed to measure the emission rate before shipment.

Various concentrations of the permeants are generated by varying the flow of the diluent gas stream over the devices. A calibration curve is constructed of at least three concentrations of each permeant; three successive injections at each concentration yield peak areas that differ from the mean peak area value by less than 5%.

Sampling system integrity is evaluated after every three hours of sampling by injecting a known concentration of H<sub>2</sub>S at the probe tip and recovering the sample through the sample conditioning and sample transport subsystems. The same gas stream is then introduced directly to the GC sample loop. The ratio of concentrations corresponds to the system correction factor. This factor is then used to adjust measured reduced sulfur compound concentrations.

A system audit gas (of appropriate H<sub>2</sub>S concentration) is used to evaluate the analytical system integrity each test day.

## **B.5 SULFUR DIOXIDE (INSTRUMENTAL)**

Sulfur dioxide (SO<sub>2</sub>) testing is conducted in accordance with EPA Reference Method 6C.

### **Sampling Equipment and Procedures**

Figure B-1 illustrates the sampling system. The sample is withdrawn from the source through a heated probe, heated filter, and heated sample line to a sample conditioner which removes moisture from the gas stream. The sample is then transported to the analyzer through a Teflon® line.

### **Sample Analysis**

The analyzer measures, at two discrete wavelengths, the absorption of ultraviolet radiation by the gas sample. The concentration of the components absorbing the light are then determined from relationships developed through application of the ideal gas law in concert with the laws of Bouguer, Beer, and Lambert.

### **Data Acquisition and Reduction**

Data are acquired electronically using a computer with software designed by WESTON for EPA Reference Method 6C analysis. This system generates a calibration curve, converts electronic signals into concentrations, and provides bias-corrected averages.

### **Quality Control**

At the time of analysis, SO<sub>2</sub> in nitrogen calibration gases (certified according to EPA Protocol-1) are used to calibrate the analyzer and to determine a bias correction factor for the entire system in accordance with EPA Reference Method 6C.

Calibration gases are introduced directly to the analyzer to generate the calibration curve. Zero level and upscale calibration gases are introduced at the probe and recovered through the sampling and analytical system. A bias correction factor is then calculated using the ratio of the measured concentration of the bias gas introduced through the sampling system and the measured concentration of the bias gas introduced directly to the analyzer. Run averages are adjusted for this bias correction factor.



## APPENDIX C FIELD DATA – PULP DRYER

---

New Indy  
Catawba, SC

15730.001.008  
Pulp Dryer

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
Date	6/26/21	6/26/21	6/26/21	---
Time Began	1230	1347	1506	---
Time Ended	1339	1454	1611	---
Volumetric Flow Rate, (Qs), DSCFM	3.93E+04	3.90E+04	3.97E+04	3.93E+04
BWS	0.078 ✓	0.106 ✓	0.092 ✓	0.092 ✓
% Oxygen	20.8 ✓	20.9 ✓	20.9 ✓	20.9
<hr/>				
<b>Total Reduced Sulfur</b> (TRS MW)=	34.08			
Concentration, ppm	0.99 ✓	0.89 ✓	0.83 ✓	0.90
Emission Rate, lb/hr	0.21	0.18	0.17	0.19

5/4

New Indy  
Catawba, SC

15730.001.008  
Pulp Dryer

ISOKINETIC CALCULATIONS

Run Number		1	2	3	Mean
Date		6/26/21 ✓	6/26/21	6/26/21	---
Time Began		1230 ✓	1347 ✓	1506 ✓	---
Time Ended		1341 ✓	1455 ✓	1614 ✓	---
INPUT DATA					
Sampling Time, min	(Theta)	64.0 ✓	64	64	64
Stack Diameter, in.	(Dia.)	60 ✓	60	60	60
Barometric Pressure, in. Hg	(Pb)	29.70 ✓	29.70	29.70	29.70
Static Pressure, in. H2O	(Pg)	-0.27 ✓	-0.27	-0.27	-0.27
Pitot Tube Coefficient	(Cp)	0.84 ✓	0.84	0.84	0.84
Meter Correction Factor	(Y)	0.9880 ✓	0.9880	0.9880	0.9880
Orifice Calibration Value	(Delta H@)	1.7320 ✓	1.7320	1.7320	1.7320
Nozzle Diameter, in.	(Dn)	0.250 ✓	0.250	0.250	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	42.959 ✓	43.492 ✓	43.845 ✓	43.432
Meter Temperature, °F	(Tm)	86.8 ✓	92.3 ✓	93.6 ✓	90.9
Meter Temperature, °R	(Tm-R)	546.8	552.3	553.6	550.9
Meter Orifice Pressure, in. H2O	(Delta H)	1.300 ✓	1.300 ✓	1.300 ✓	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> avg)	1.140 ✓	1.140 ✓	1.140 ✓	1.140
Volume H2O Collected, mL	(Vlc)	73.0 ✓	102.8 ✓	88.4 ✓	88.1
CO2 Concentration, %	(CO2)	0.0 ✓	0.0 ✓	0.0 ✓	0.0
O2 Concentration, %	(O2)	20.8 ✓	20.9 ✓	20.9 ✓	20.9
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> avg)	0.689 ✓	0.702 ✓	0.705 ✓	0.699
Stack Temperature, °F	(Ts)	157.8 ✓	158.8 ✓	157.8 ✓	158.1
Stack Temperature, °R	(Ts-R)	617.8	618.8	617.8	618.1
Moisture Fraction (at Saturation)	(BWS)	0.309	0.316	0.309	0.311
CALCULATED DATA					
Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	19.63 ✓	19.63	19.63	19.63
Stack Pressure, in. Hg	(Ps)	29.68	29.68	29.68	29.68
Meter Pressure, in. Hg	(Pm)	29.80	29.80	29.80	29.80
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	40.797	40.896	41.130	40.941
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	3.436	4.839	4.161	4.145
Moisture Fraction (Measured)	(BWS)	0.078	0.106	0.092	0.092
Moisture Fraction (lower sat/meas)	(BWS)	0.078	0.106	0.092	0.092
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	28.83	28.84	28.84	28.83
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	27.99	27.69	27.84	27.84
Average Stack Gas Velocity, ft/sec	(Vs)	42.65	43.74	43.78	43.39
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	50245	51527	51580	51118
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	39272	38983	39695	39317
Calibration check	(Yqa)	0.9904	0.9831	0.9763	0.983
Percent difference from Y					-0.48%

SK



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: Pulp Dryer  
 Sample Location: Stack outlet  
 W. O. Number: 15730.001.008  
 Run Number: 1  
 Date: 6/26/12  
 Test Personnel: AR/LC  
 Sample Time: 64 min.

Console ID: A610  
 Meter Corr., Y: 1.988  
 Console ΔH@: 1.132  
 Probe ID/Length: PR5B 3'  
 Liner Material: SS  
 Pitot ID/Coeff.: PI12 0.84  
 Thermo ID: A010  
 Nozzle ID/Diams.: .250 1.250 1.250  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp.: 85 °F  
 Baro. Pressure\*: 29.70 in. Hg  
 Static Pressure: -2.7 in. H<sub>2</sub>O  
 Impinger Gain: 64.7 mL  
 Silica Gel Gain: 8.3 g  
 Stack Area: 14.63 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: NA  
**Leak Checks**  
 Volume, ft<sup>3</sup>: Initial \_\_\_\_\_ Final 1,000  
 @ Vac., in. Hg: 8  
 Pitot: 1000  
 Filter ID: NA  
 Sample ID: Ryn 4

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
0	0	12:30			352.466									
A-1	4		.42	1.3	335.1	156		83	237	241		67	2.5	
2	8		.43	1.3	357.7	156		83	238	253		66	2.5	
3	12		.45	1.3	366.361.0	156		84	245	253		65	2.5	
4	16		.48	1.3	363.2	158		84	252	254		64	2.5	*Purge
5	20		.53	1.3	365.7	158		85	253	254		64	2.5	12:40-12:44
6	24		.51	1.3	368.2	163		86	244	254		65	2.5	
7	28		.50	1.3	371.0	161		86	250	251		64	2.5	
8	32	13:06	.48	1.3	373.7	159		86	249	252		63	2.5	
B-1	36	13:04	.52	1.3	376.5	155		86	250	253		65	3	
2	40		.53	1.3	374.4	156		87	248	253		64	3	
3	44		.48	1.3	391.8	156		88	249	252		65	3	
4	48		.50	1.3	384.6	157		88	245	253		66	3	
5	52		.46	1.3	381.2	158		89	244	250		66	3	
6	56		.45	1.3	390.0	158		91	246	249		65	3.5	
7	60		.43	1.3	393.0	159		91	246	249		65	3.5	
8	64	13:41	.43	1.3	395.354	154		92	247	250		66	3.5	
			Avg ΔP	Avg ΔH	Total Volume	Avg T <sub>m</sub>	Avg T <sub>in</sub>		Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	
			.6886	1.3	42.454	157.81	86.81		237/253	241/254	241/254	67	3.5	

\*Barometric Pressure is at port elevation

Flue Gas Composition: Oxygen, % \_\_\_\_\_ Carbon Dioxide, % \_\_\_\_\_ Moisture, % \_\_\_\_\_  
 O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite MSA \_\_\_\_\_  
 Leak Check, Pre-run \_\_\_\_\_ Post-run \_\_\_\_\_  
 Thermocouple Check: Meter Temp., °F \_\_\_\_\_ % Isokinetic \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_ Calculated by \_\_\_\_\_ QC by \_\_\_\_\_  
 Result \_\_\_\_\_





# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: Pulp Dryer  
 Sample Location: stair cutback  
 W. O. Number: 15730.001.008  
 Run Number: 2  
 Date: 6/26/21  
 Test Personnel: AR/CL  
 Sample Time: 64 min.

Console ID: A010  
 Meter Corr., Y: 1.988  
 Console ΔH@: 1.732  
 Probe ID/Length: PR5B 3'  
 Liner Material: SS  
 Pitot ID/Coeff.: P172 0.84  
 Thermo ID: A010  
 Nozzle ID/Diams.: .250 .250  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp. 90 °F  
 Baro. Pressure\* 29.70 in. Hg  
 Static Pressure -.27 in. H<sub>2</sub>O  
 Impinger Gain 43.8 mL  
 Silica Gel Gain 9 g  
 Stack Area 14.63 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: NA  
 Leak Checks: Initial Final  
 Volume, ft<sup>3</sup>: 1,000 1,000  
 @ Vac., in. Hg: 8  
 Pitot: 1,000 1,000  
 Filter ID: NA  
 Sample ID: R444

TRAVERSE POINT NO	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM IN-LET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
1	4	13:47	.50	1.3	395.500	157		91	240	245		66	3.5	
2	8		.51	1.3	397.8	158		91	242	246		66	3.5	
3	12		.52	1.3	401.1	158		92	244	238		64	3.5	
4	16		.50	1.3	403.7	159		92	246	247		64	3.5	
5	20		.47	1.3	406.3	160		92	246	249		63	3.5	
6	24		.47	1.3	404.3	160		92	248	249		62	4	
7	28		.45	1.3	415.2	161		91	246	248		61	4	
8	32	14:14	.43	1.3	417.0	161		92	247	249		60	4	
1	36	14:23	.44	1.3	414.7	158		92	249	260		63	4	
2	40		.44	1.3	421.9	154		92	250	252		58	4	
3	44		.45	1.3	425.2	159		92	231	249		58	4	
4	48		.48	1.3	428.6	158		92	253	249		59	4	
5	52		.55	1.3	431.0	154		93	253	251		59	4	
6	56		.53	1.3	433.3	158		94	232	252		60	4	
7	60		.56	1.3	436.4	158		94	251	252		60	4	
8	64	14:55	.60	1.3	438.442	158		94	250	253		61	4	
*Barometric Pressure is at port elevation			Avg. ΔP	Avg. ΔH	Total Volume	Avg. T <sub>s</sub>	Avg. T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-stk</sub> scf
			.70189	1.5	43.442	158.81	92.25	240/253	238/260	238/260	238/260	66	4	

Flue Gas Composition: O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Oxygen, %: \_\_\_\_\_  
 Carbon Dioxide, %: \_\_\_\_\_  
 Moisture, %: \_\_\_\_\_  
 Leak Check, Pre-run: \_\_\_\_\_  
 Post-run: \_\_\_\_\_  
 Thermocouple Check: Meter Temp., °F: \_\_\_\_\_  
 Ref. Temp., °F: \_\_\_\_\_  
 % Isokinetic: \_\_\_\_\_  
 Calculated by: \_\_\_\_\_  
 QC by: \_\_\_\_\_





# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: Pulp Dryer  
 Sample Location: Stack outlet  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/26/21  
 Test Personnel: ATL/CL  
 Sample Time: 64 min.

Console ID: A010  
 Meter Corr., Y: ATL  
 Console ΔH@: 1.732  
 Probe ID/Length: PA 5B  
 Liner Material: SS  
 Pitot ID/Coeff.: P172  
 Thermo ID: A016  
 Nozzle ID/Diams.: 1.250  
 Avg. Nozzle Diam.: 1.250 in.  
 Ambient Temp.: 40 °F  
 Baro. Pressure\*: 29.70 in. Hg  
 Static Pressure: -2.27 in. Hg  
 Impinger Gain: 93.8 g  
 Silica Gel Gain: 4.5 g  
 Stack Area: 14.63 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: NA  
 Leak Checks: Initial NA, Final .000  
 Volume, ft<sup>3</sup>: 0.00  
 @ Vac., in. Hg: 8  
 Pitot: .000  
 Filter ID: NA  
 Sample ID: R441

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INJET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
0	0	14:06			4434.200									
A-1	4	15:08	.42	1.3	442.0	156		43	246	254	66		3.5	
2	8		.41	1.3	444.6	158		43	248	254	64		3.5	
3	12		.45	1.3	447.8	157		43	249	253	65		3.5	
4	16		.46	1.3	450.2	157		44	248	253	64		3.5	
5	20		.52	1.3	453.8	157		44	247	254	64		3.5	
6	24		.53	1.3	455.5	158		44	246	254	64		4	
7	28		.54	1.3	458.3	158		43	246	253	63		4	
8	32	15:38	.53	1.3	460.4	158		44	247	254	63		4	
B-1	36	15:42	.48	1.3	463.7	158		43	246	255	66		4	
2	40		.55	1.3	466.6	158		43	245	254	62		4	
3	44		.55	1.3	469.2	159		43	248	253	63		4	
4	48		.52	1.3	472.1	158		44	249	252	63		4	
5	52		.49	1.3	474.9	158		44	250	251	63		4	
6	56		.50	1.3	477.8	158		44	249	253	64		4	
7	60		.49	1.3	480.5	159		44	249	251	65		4	
8	64	16:14	.53	1.3	483.045	158		44	248	250	65		4	
*Barometric Pressure is at port elevation			Avg. ΔAP	Avg. ΔH	Total Volume	Avg. T <sub>s</sub>	Avg. T <sub>in</sub>		Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	
			1.7051V	1.3	43.845	157.81	43.56	245.50	250.25	66	66	66	4	
			1.4981V	1.140V	483.045	158	43.56	245.50	250.25	66	66	66	4	
			Flue Gas Composition		O <sub>2</sub> /CO <sub>2</sub> by Orsat		Fyrite		M3A		Thermocouple Check		Q <sub>s</sub> , dscfm	
			Oxygen, %		Leak Check, Pre-run		Post-run		Meter Temp., °F		% Isokinetic		Calculated by	
			Carbon Dioxide, %		Moisture, %				Ref. Temp., °F		Result		QC by	





# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source Pulp Dryer  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/26/21 Recovery Date 6/26/21  
 Sample ID Run 1 Filter ID NA Analyst ATR

	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Contents	<u>DI</u>	<u>DI</u>	<u>empty</u>			
Final	<u>643.27001</u>	<u>780.3</u>	<u>643.2</u>		<u>917.9</u>	
Initial	<u>643.2</u>	<u>774.3</u>	<u>643.4</u>	<input checked="" type="checkbox"/>	<u>909.6</u>	
Gain	<u>56.9</u> ✓	<u>6</u> ✓	<u>1.8</u> ✓	<u>64.7</u>	<u>8.3</u> ✓	<u>73</u> ✓

Impinger Color clear Labeled? -  
 Silica Gel Condition good Sealed? -

Run No. 2 Sample Date 6/26/21 Recovery Date 6/26/21  
 Sample ID Run 2 Filter ID NA Analyst ATR

	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Contents	<u>DI</u>	<u>DI</u>	<u>empty</u>			
Final	<u>809.2</u>	<u>804.2</u>	<u>636.4</u>		<u>835.7</u>	
Initial	<u>721.0</u>	<u>800.1</u>	<u>634.9</u>	<input checked="" type="checkbox"/>	<u>826.7</u>	
Gain	<u>88.2</u> ✓	<u>4.1</u> ✓	<u>1.5</u> ✓	<u>43.8</u>	<u>9</u> ✓	<u>102.8</u> ✓

Impinger Color clear Labeled? ✓  
 Silica Gel Condition used Sealed? ✓

Run No. 3 Sample Date 6/26/21 Recovery Date 6/26/21  
 Sample ID Run 3 Filter ID NA Analyst ATR

	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Contents	<u>DI</u>	<u>DI</u>	<u>empty</u>			
Final	<u>778.1</u>	<u>785.2</u>	<u>646.2</u>		<u>922.9</u>	
Initial	<u>700.1</u>	<u>780.3</u>	<u>645.2</u>	<input checked="" type="checkbox"/>	<u>917.9</u>	
Gain	<u>78</u> ✓	<u>4.9</u> ✓	<u>1.0</u> ✓	<u>83.9</u>	<u>4.5</u> ✓	<u>88.4</u> ✓

Impinger Color clear Labeled? -  
 Silica Gel Condition used Sealed? -

Check COC for Sample IDs of Media Blanks

*ATR*





# Sample and Velocity Traverse Point Data Sheet - Method 1

15730.001.008  
Pulp Dryer #3 Paper Machine,  
#2-3 SDTVs, & #1-2 CBs  
Emission Report

Client New Indy  
Location/Plant Catawba, SC  
Source Pulp Dryer

Operator VD  
Date 25-Jun-21  
W.O. Number 15730.001.008

**Duct Type**  Circular  Rectangular Duct Indicate appropriate type  
**Traverse Type**  Particulate Traverse  Velocity Traverse

Distance from far wall to outside of port (in.) = C	60.125
Port Depth (in.) = D	0.125
Depth of Duct, diameter (in.) = C-D	60
Area of Duct (ft <sup>2</sup> )	19.63
Total Traverse Points	16
Total Traverse Points per Port	8

**Rectangular Ducts Only**



Width of Duct, rectangular duct only (in.)	
Total Ports (rectangular duct only)	

**Traverse Point Locations**

Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	3.2	2	2
2	10.5	6 1/2	6 1/2
3	19.4	11 1/2	12
4	32.3	19 1/2	19 1/2
5	67.7	40 1/2	40 1/2
6	80.6	48 1/2	48 1/2
7	89.5	53 1/2	54
8	96.8	58	58
9			
10			
11			
12			

**Flow Disturbances**

Upstream - A (ft)	8.75
Downstream - B (ft)	13.125
Upstream - A (duct diameters)	1.75
Downstream - B (duct diameters)	2.63



Equivalent Diameter =  $(2 * L * W) / (L + W)$

**Traverse Point Location Percent of Stack -Circular**

Traverse Point	Number of Traverse Points											
	1	2	3	4	5	6	7	8	9	10	11	12
1		14.6		6.7		4.4		3.2		2.6		2.1
2		85.4		25		14.6		10.5		8.2		6.7
3			75		29.6		19.4		14.6		11.8	
4				93.3		70.4		32.3		22.6		17.7
5					85.4		67.7		34.2		25	
6						95.6		80.6		65.8		35.6
7							89.5		77.4		64.4	
8								96.8		85.4		75
9									91.8		82.3	
10										97.4		88.2
11											93.3	
12												97.9

Duct Diameters Downstream from Flow Disturbance\* (Distance B)

**Traverse Point Location Percent of Stack -Rectangular**

Traverse Point	Number of Traverse Points											
	1	2	3	4	5	6	7	8	9	10	11	12
1		25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
2		75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
3			83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
4				87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
5					90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
6						91.7	78.6	68.8	61.1	55.0	50.0	45.8
7							92.9	81.3	72.2	65.0	59.1	54.2
8								93.8	83.3	75.0	68.2	62.5
9									94.4	85.0	77.3	70.8
10										95.0	86.4	79.2
11											95.5	87.5
12												95.8


**Rectangular Stack Points & Matrix**

- 9 - 3 x 3
- 12 - 4 x 3
- 16 - 4 x 4
- 20 - 5 x 4
- 25 - 5 x 5
- 30 - 6 x 5
- 36 - 6 x 6
- 42 - 7 x 6
- 49 - 7 x 7

Port Diam. (in) = \_\_\_\_\_  
Number of Ports = \_\_\_\_\_

Tape Measure I.D. # \_\_\_\_\_








HAT WAS REMOVED & EXTENDED TO THE SIDE

15730.001.009  
Pulp Dryer, #3 Paper Machine  
92-530174 & 94-274  
Emission Report



# RUN SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

**Start Time 12:30    End Time 13:39**

---

**Average Measured TRS Conc.**    0.96 ppm ✓  
**Recovery No. 2**    96.6 % ✓  
**TRS Corrected for Recovery**    0.99 ppm ✓

✓

# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

Start Time 13:47    End Time 14:54

---

Average Measured TRS Conc.	0.86 ppm ✓
Recovery No. 2	96.6 % ✓
TRS Corrected for Recovery	0.89 ppm ✓

✓

# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

**Start Time 15:06    End Time 16:11**

---

**Average Measured TRS Conc.**    0.80 ppm ✓  
**Recovery No. 2**    96.6 % ✓  
**TRS Corrected for Recovery**    0.83 ppm ✓

✓

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
12:30	5	0.11	95	0.91	<2	<0.080	<2	<0.038	1.02
12:33	6	0.13	96	0.91	<2	<0.080	<2	<0.038	1.04
12:36	<2	<0.070	95	0.91	<2	<0.080	<2	<0.038	0.91
12:39	4	0.11	95	0.91	<2	<0.080	<2	<0.038	1.02
12:42	7	0.13	95	0.91	<2	<0.080	<2	<0.038	1.04
12:45	6	0.12	95	0.91	<2	<0.080	<2	<0.038	1.04
12:48	5	0.11	95	0.91	<2	<0.080	<2	<0.038	1.02
12:51	5	0.11	94	0.91	<2	<0.080	<2	<0.038	1.01
12:54	4	0.11	94	0.91	<2	<0.080	<2	<0.038	1.01
12:57	<2	<0.070	92	0.90	<2	<0.080	<2	<0.038	0.90
<b>Paused for port change</b>									
13:09	<2	<0.070	88	0.88	<2	<0.080	<2	<0.038	0.88
13:12	<2	<0.070	89	0.88	<2	<0.080	<2	<0.038	0.88
13:15	3	0.09	88	0.87	<2	<0.080	<2	<0.038	0.97
13:18	<2	<0.070	91	0.89	<2	<0.080	<2	<0.038	0.89
13:21	3	0.09	89	0.88	<2	<0.080	<2	<0.038	0.97
13:24	<2	<0.070	89	0.88	<2	<0.080	<2	<0.038	0.88
13:27	2	0.08	91	0.89	<2	<0.080	<2	<0.038	0.97
13:30	<2	<0.070	86	0.86	<2	<0.080	<2	<0.038	0.86
13:33	4	0.10	87	0.87	<2	<0.080	<2	<0.038	0.97
13:36	2	0.08	87	0.87	<2	<0.080	<2	<0.038	0.95
<b>Average</b>		<b>&lt;0.070</b>		<b>0.89</b>		<b>&lt;0.080</b>		<b>&lt;0.038</b>	<b>0.96</b> ✓

N



# RUN DATA

Number 2

15730.001.008  
Pulp Dryer, #3 Paper Machine,  
#2-3 SDTVs, & #1-2 CBs  
Emission Report

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
13:47	3	0.09	79	0.83	<2	<0.080	<2	<0.038	0.92
13:50	<2	<0.070	79	0.83	<2	<0.080	<2	<0.038	0.83
13:53	<2	<0.070	80	0.83	<2	<0.080	2	0.04	0.92
13:56	<2	<0.070	80	0.83	2	0.08	<2	<0.038	0.92
13:59	3	0.09	79	0.82	<2	<0.080	<2	<0.038	0.91
14:02	3	0.09	79	0.82	<2	<0.080	<2	<0.038	0.91
14:05	4	0.11	79	0.83	<2	<0.080	<2	<0.038	0.93
14:08	<2	<0.070	78	0.82	<2	<0.080	<2	<0.038	0.82
14:11	<2	<0.070	75	0.81	<2	<0.080	2	0.04	0.89
14:14	<2	<0.070	77	0.82	<2	<0.080	<2	<0.038	0.82
14:24	<2	<0.070	74	0.80	<2	<0.080	<2	<0.038	0.80
14:27	<2	<0.070	73	0.79	<2	<0.080	<2	<0.038	0.79
14:30	3	0.09	75	0.81	<2	<0.080	<2	<0.038	0.89
14:33	<2	<0.070	76	0.81	<2	<0.080	<2	<0.038	0.81
14:36	<2	<0.070	76	0.81	<2	<0.080	<2	<0.038	0.81
14:39	<2	<0.070	75	0.80	<2	<0.080	<2	<0.038	0.80
14:42	2	0.08	75	0.81	<2	<0.080	<2	<0.038	0.88
14:45	3	0.09	77	0.81	<2	<0.080	<2	<0.038	0.90
14:48	<2	<0.070	77	0.81	<2	<0.080	<2	<0.038	0.81
14:51	<2	<0.070	73	0.79	<2	<0.080	<2	<0.038	0.79
<b>Average</b>		<b>&lt;0.070</b>		<b>0.81</b>		<b>&lt;0.080</b>		<b>&lt;0.038</b>	<b>0.86</b> ✓

# RUN DATA

Number 3

15730.001.008  
Pulp Dryer, #3 Paper Machine,  
#2-3 SDTVs, & #1-2 CBs  
Emission Report

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
15:06	<2	<0.070	68	0.77	<2	<0.080	2	0.04	0.85
15:09	<2	<0.070	72	0.79	<2	<0.080	<2	<0.038	0.79
15:12	<2	<0.070	71	0.78	<2	<0.080	<2	<0.038	0.78
15:15	<2	<0.070	73	0.79	<2	<0.080	<2	<0.038	0.79
15:18	<2	<0.070	75	0.81	<2	<0.080	<2	<0.038	0.81
15:21	<2	<0.070	74	0.80	<2	<0.080	<2	<0.038	0.80
15:24	<2	<0.070	74	0.80	<2	<0.080	<2	<0.038	0.80
15:27	<2	<0.070	75	0.81	<2	<0.080	<2	<0.038	0.81
15:30	2	0.08	75	0.80	<2	<0.080	<2	<0.038	0.88
15:33	3	0.08	75	0.80	<2	<0.080	<2	<0.038	0.89
15:41	<2	<0.070	70	0.78	<2	<0.080	<2	<0.038	0.78
15:44	<2	<0.070	71	0.78	<2	<0.080	<2	<0.038	0.78
15:47	<2	<0.070	69	0.77	<2	<0.080	<2	<0.038	0.77
15:50	<2	<0.070	72	0.79	<2	<0.080	<2	<0.038	0.79
15:53	<2	<0.070	70	0.78	<2	<0.080	<2	<0.038	0.78
15:56	<2	<0.070	70	0.78	<2	<0.080	<2	<0.038	0.78
15:59	<2	<0.070	74	0.80	<2	<0.080	<2	<0.038	0.80
16:02	<2	<0.070	71	0.78	<2	<0.080	<2	<0.038	0.78
16:05	<2	<0.070	69	0.77	<2	<0.080	<2	<0.038	0.77
16:08	<2	<0.070	70	0.78	<2	<0.080	<2	<0.038	0.78
<b>Average</b>		<b>&lt;0.070</b>		<b>0.79</b>		<b>&lt;0.080</b>		<b>&lt;0.038</b>	<b>0.80</b> ✓

# RUN DATA

Number 0

Client: **New Indy**  
 Location: **Catawba, NC**  
 Source: **Pulp Dryer**

Method **16**  
 Calibration **1**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **27 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm	
	area	ppm	area	ppm	area	ppm	area	ppm		
			<b>CC416806 7.257 ppm</b>							
09:13	13230	7.45	<2	<0.12	<2	<0.080	<2	<0.038	7.45	
09:16	13533	7.54	<2	<0.12	<2	<0.080	<2	<0.038	7.54	
09:19	13251	7.45	<2	<0.12	<2	<0.080	<2	<0.038	7.45	
<b>Average</b>		<b>7.48</b>		<b>&lt;0.12</b>		<b>&lt;0.080</b>		<b>&lt;0.038</b>	<b>7.48</b>	

# RECOVERY DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

**Before Run 1**  
Start Time 10:47    End Time 11:08

---

**Recovery Gas to Probe, Time 10:47**

<b>Peak Areas, mv-sec</b>			<b>Average</b>	<b>ppm</b>
11865	11836	11866	11856 ✓	7.03

---

**Recovery Gas to GC, Time 11:06**

<b>Peak Areas, mv-sec</b>			<b>Average</b>	<b>ppm</b>
14001	14035	13928	13988 ✓	7.67

---

**Recovery 91.6%** ✓

---

✓

# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

After Run 3    Before Run 4  
Start Time 16:11    End Time 16:23

---

Recovery Gas to Probe, Time 16:11

Peak Areas, mv-sec			Average	ppm
12698	12844	13017	12853 ✓	7.33

---

Recovery Gas to GC, Time 16:20

Peak Areas, mv-sec			Average	ppm
13674	13559	13930	13721 ✓	7.59

---

Recovery 96.6% ✓

---

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Method **16**

Ambient Temperature: 72°C

Barometric Pressure: 29.70 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51828	33-53274	89-53332	89-53266
Perm. Rate, nL/min	346	363	470	238
Ret. Time, sec	16.0	22.5	48.0	127.0

1 Flow = 38.9 mL/Min      8.90 ppm      9.36 ppm      12.1 ppm      6.12 ppm

Time: 06:02

Peak Areas, mv-sec

	18368	8795	28785	34758
	18368	8383	27462	34707
	18202	8971	28270	35006
<u>Average Area</u>	<b>18313</b> ✓	<b>8716</b> ✓	<b>28172</b> ✓	<b>34824</b> ✓

2 Flow = 82.3 mL/Min      4.21 ppm      4.42 ppm      5.72 ppm      2.89 ppm

Time: 07:54

Peak Areas, mv-sec

	4512	2067	6969	8481
	4642	2032	7036	8510
	4706	2195	7080	8577
<u>Average Area</u>	<b>4620</b> ✓	<b>2098</b> ✓	<b>7028</b> ✓	<b>8523</b> ✓

3 Flow = 175 mL/Min      1.98 ppm      2.08 ppm      2.69 ppm      1.36 ppm

Time: 08:29

Peak Areas, mv-sec

	1065	476	1647	1910
	1045	464	1599	1954
	1126	467	1556	1919
<u>Average Area</u>	<b>1079</b> ✓	<b>469</b> ✓	<b>1601</b> ✓	<b>1928</b> ✓

# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Project Number: **15730.001.008**

Operator: **VD**

Date: **25 Jun 2021**

Method **16**

<b>H<sub>2</sub>S</b>	<b>1</b>	<b>2</b>	<b>3</b>		
<b>Time</b>	06:02	07:54	08:29		
<b>Concentration, ppm</b>	8.90	4.21	1.98		
<b>Area, mv-sec</b>	18313	4620	1079		
<b>Calc. Conc., ppm</b>	8.85	4.26	1.97		
<b>% Error</b>	-0.6	1.2	-0.6		
<b>Calibration Curve</b>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8832	2.4794	0.9999	2	0.070

<b>MeSH</b>	<b>1</b>	<b>2</b>	<b>3</b>		
<b>Time</b>	06:02	07:54	08:29		
<b>Concentration, ppm</b>	9.36	4.42	2.08		
<b>Area, mv-sec</b>	8716	2098	469		
<b>Calc. Conc., ppm</b>	9.31	4.47	2.07		
<b>% Error</b>	-0.5	1.1	-0.5		
<b>Calibration Curve</b>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9432	2.0579	0.9999	2	0.12

<b>DMS</b>	<b>1</b>	<b>2</b>	<b>3</b>		
<b>Time</b>	06:02	07:54	08:29		
<b>Concentration, ppm</b>	12.1	5.72	2.69		
<b>Area, mv-sec</b>	28172	7028	1601		
<b>Calc. Conc., ppm</b>	12.0	5.80	2.67		
<b>% Error</b>	-0.7	1.4	-0.7		
<b>Calibration Curve</b>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9072	2.3902	0.9999	2	0.080

<b>DMDS</b>	<b>1</b>	<b>2</b>	<b>3</b>		
<b>Time</b>	06:02	07:54	08:29		
<b>Concentration, ppm</b>	6.12	2.89	1.36		
<b>Area, mv-sec</b>	34824	8523	1928		
<b>Calc. Conc., ppm</b>	6.08	2.93	1.35		
<b>% Error</b>	-0.6	1.2	-0.6		
<b>Calibration Curve</b>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9245	3.0328	0.9999	2	0.038

*VD*

# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Ambient Temperature: 72°C

Barometric Pressure: 29.70 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51828	33-53274	89-53332	89-53266
Perm. Rate, nL/min	346	363	470	238
Ret. Time, sec	16.0	22.5	48.0	127.0

1 Flow = 37.1 mL/Min      9.32 ppm      9.79 ppm      12.7 ppm      6.41 ppm

Time: 07:00

Peak Areas, mv-sec

	17531	8727	27825	33485
	17951	8703	27443	33712
	18066	8758	27669	33342
<u>Average Area</u>	<b>17849</b> ✓	<b>8730</b> ✓	<b>27646</b> ✓	<b>33513</b> ✓

2 Flow = 78.5 mL/Min      4.41 ppm      4.63 ppm      5.99 ppm      3.03 ppm

Time: 08:24

Peak Areas, mv-sec

	4366	2153	6888	8191
	4464	2149	6729	8050
	4361	2131	6827	8110
<u>Average Area</u>	<b>4397</b> ✓	<b>2145</b> ✓	<b>6815</b> ✓	<b>8117</b> ✓

3 Flow = 172 mL/Min      2.01 ppm      2.11 ppm      2.73 ppm      1.38 ppm

Time: 08:47

Peak Areas, mv-sec

	1026	464	1561	1864
	980	466	1558	1873
	996	463	1569	1872
<u>Average Area</u>	<b>1001</b> ✓	<b>464</b> ✓	<b>1563</b> ✓	<b>1870</b> ✓

*M*



# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Method **16**

H <sub>2</sub> S	1	2	3		
Time	07:00	08:24	08:47		
Concentration, ppm	9.32	4.41	2.01		
Area, mv-sec	17849	4397	1001		
Calc. Conc., ppm	9.31	4.42	2.01		
% Error	-0.1	0.2	-0.1		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8784	2.4316	>0.9999	2	0.073

MeSH	1	2	3		
Time	07:00	08:24	08:47		
Concentration, ppm	9.79	4.63	2.11		
Area, mv-sec	8730	2145	464		
Calc. Conc., ppm	9.74	4.68	2.10		
% Error	-0.5	1.0	-0.5		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9131	2.0496	0.9999	2	0.12

DMS	1	2	3		
Time	07:00	08:24	08:47		
Concentration, ppm	12.7	5.99	2.73		
Area, mv-sec	27646	6815	1563		
Calc. Conc., ppm	12.7	6.00	2.73		
% Error	-0.1	0.1	-0.1		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8729	2.3765	>0.9999	2	0.078

DMDS	1	2	3		
Time	07:00	08:24	08:47		
Concentration, ppm	6.41	3.03	1.38		
Area, mv-sec	33513	8117	1870		
Calc. Conc., ppm	6.42	3.02	1.38		
% Error	0.1	-0.3	0.1		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8815	3.0064	>0.9999	2	0.036

## ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Analyte Molecular Weight	H <sub>2</sub> S 34.08	MeSH 48.11	DMS 62.14	DMDS 94.20
Retention Time, sec	16.0	22.5	48.0	127.0
Peak Detection Window, sec	3.0	7.0	10.0	10.0
Minimum Peak Area, mv-sec	2	2	2	2
Minimum Peak Height, mv	1	1	1	1
Beginning Peak Width, sec	1.0	1.0	2.0	3.0
Ending Peak Width, sec	2.0	6.0	4.0	5.0
Permeation Device ID	T-51828 ✓	33-53274 ✓	89-53332	89-53266 ✓
Permeation Rate, ng/min	483 ✓	716 ✓	1197 ✓	918 ✓
Permeation Rate, nL/min*	346	363	470	238

**Barometric Pressure:** 29.70 in. Hg     **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- PR<sub>ng</sub>** = Permeation Rate by weight, ng/min
- V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole
- W<sub>mol</sub>** = Molecular Weight of compound
- T<sub>a</sub>** = Ambient Temperature, °F
- T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)
- P<sub>s</sub>** = Standard Pressure = 29.92 in Hg
- P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 483 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.70) = 346 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

- C** = Concentration, ppmv
- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- F<sub>d</sub>** = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **Pulp Dryer**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

File: C:\Data\210626 New Indy Catawba Pulp Dryer.trs  
Program Version: 2.0, built 15 May 2017 File Version: 2.0  
Computer: WLT5 Trailer: 281

Analog Input Device: MCC USB-1608G GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: Shimadzu GC8-A Serial No. C10493615061  
Detector Range: 10

Gases		Temperatures, °C		Columns
Press.	Flow	Column:	Detector:	Primary:
psi	mL/min			Secondary:
H <sub>2</sub>	30	50	140	Carbopack
Air	30	60	140	N/A
Carrier	50	30		Sample Loop: 4"

## Injection Cycle

Total Length: 180 sec Sampling Time: 170 sec Load/Backflush Time: 80 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 2 mv-sec Minimum peak height 1 mv above baseline

## Dynacalibrator

Chamber Temperature 50.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.70 in. Hg

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Pulp Dryer**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Calibration 1

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>Pulp Dryer Run 1</b>				
13:37:08	7063	20.8	-8	0.0
13:37:18	7062	20.8	-6	0.0
13:37:28	7061	20.8	-5	0.0
13:37:38	7061	20.8	-5	0.0
13:37:48	7062	20.8	-5	0.0
13:37:58	7061	20.8	-5	0.0
13:38:08	7061	20.8	-6	0.0
13:38:18	7061	20.8	-8	0.0
13:38:28	7061	20.8	-8	0.0
13:38:38	7061	20.8	-6	0.0
13:38:48	7062	20.8	-5	0.0
13:38:58	7061	20.8	-5	0.0
<b>Avg</b>	<b>7061</b>	<b>20.8</b>	<b>-6</b>	<b>0.0</b>

# RUN DATA

Number 2

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Pulp Dryer**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **26 Jun 2021**

Calibration 1

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>Pulp Dryer Run 2</b>				
14:57:11	7115	20.9	-5	0.0
14:57:21	7115	20.9	-5	0.0
14:57:31	7115	20.9	-5	0.0
14:57:41	7116	20.9	-5	0.0
14:57:51	7115	20.9	-5	0.0
14:58:01	7116	20.9	-8	0.0
14:58:11	7116	20.9	-5	0.0
14:58:21	7114	20.9	-5	0.0
14:58:31	7116	20.9	-5	0.0
14:58:41	7115	20.9	-5	0.0
14:58:51	7114	20.9	-5	0.0
14:59:01	7114	20.9	-5	0.0
<b>Avg</b>	<b>7115</b>	<b>20.9</b>	<b>-5</b>	<b>0.0</b>

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Pulp Dryer**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Calibration 1

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>Pulp Dryer Run 3</b>				
16:13:58	7118	20.9	-6	0.0
16:14:08	7118	20.9	-5	0.0
16:14:18	7116	20.9	-5	0.0
16:14:28	7118	20.9	-5	0.0
16:14:38	7116	20.9	-5	0.0
16:14:48	7116	20.9	-5	0.0
16:14:58	7117	20.9	-7	0.0
16:15:08	7118	20.9	-8	0.0
16:15:18	7118	20.9	-6	0.0
16:15:28	7118	20.9	-5	0.0
16:15:38	7115	20.9	-5	0.0
16:15:48	7118	20.9	-5	0.0
<b>Avg</b>	<b>7117</b>	<b>20.9</b>	<b>-6</b>	<b>0.0</b>

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Pulp Dryer**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Start Time: 10:58

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	-5
10.1 ✓	XC013544B	3430
20.2 ✓	CC275468	6891

Curve Coefficients

Slope	Intercept	Corr. Coeff.
340.7	✓ -12	✓ >0.9999 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	-7
10.2 ✓	XC013544B	4123
20.3 ✓	CC275468	8231

Curve Coefficients

Slope	Intercept	Corr. Coeff.
406.4	✓ -7	✓ 1.0000 ✓

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Pulp Dryer**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **26 Jun 2021**

Calibration 1

Start Time: 10:58

**O<sub>2</sub>**

Method: EPA 3A  
 Span Conc. 20.2 %

Slope 340.7                      Intercept -11.6

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-5	0.0	0.0	0.0 ✓	Pass
10.1	3430	10.1	0.0	0.0 ✓	Pass
20.2	6891	20.3	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A  
 Span Conc. 20.3 %

Slope 406.4                      Intercept -6.7

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-7	0.0	0.0	0.0 ✓	Pass
10.2	4123	10.2	0.0	0.0 ✓	Pass
20.3	8231	20.3	0.0	0.0 ✓	Pass

✓



# CALIBRATION ERROR DATA

Number 2

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Pulp Dryer**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **26 Jun 2021**

Calibration 1

Start Time: 16:23

**O<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.2 %

Slope 340.7

Intercept -11.6

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-5	0.0	0.0	0.0 ✓	Pass
10.1	3430	10.1	0.0	0.0 ✓	Pass
20.2	6891	20.3	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.3 %

Slope 406.4

Intercept -6.7

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-7	0.0	0.0	0.0 ✓	Pass
10.2	4123	10.2	0.0	0.0 ✓	Pass
20.3	8231	20.3	0.0	0.0 ✓	Pass

*[Handwritten mark]*

# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Pulp Dryer**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

**File:** C:\Data\210626 New Indy Catawba Pulp Dryer.com  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** WSAUBCHEMLABGC1 **Trailer:** 281  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T802 s/n: 172</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.2</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T802 s/n: 172</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.3</b>



## APPENDIX D

### FIELD DATA – NO. 3 PAPER MACHINE

---



## VENT 1

New Indy  
Catawba, SC

15730.001.008  
No. 1 Hood Exhaust  
Paper Machine Vent 1

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
Date	6/25/21 ✓	6/25/21 ✓	6/25/21 ✓	---
Time Began	755 ✓	900 ✓	1005 ✓	---
Time Ended	855 ✓	1000 ✓	1105 ✓	---
Volumetric Flow Rate, (Qs), DSCFM	3.50E+04 ✓	3.47E+04 ✓	3.47E+04 ✓	3.48E+04
BWS	0.188 ✓	0.188 ✓	0.182 ✓	0.186
% Oxygen	20.2 ✓	20.2 ✓	20.2 ✓	20.2
<hr/>				
<b>Total Reduced Sulfur</b> (TRS MW)=	34.08			
Concentration, ppm	0.43 ✓	0.48 ✓	0.57 ✓	0.49
Emission Rate, lb/hr	0.08 ✓	0.09	0.10	0.09

M2

New Indy  
Catawba, SC

15730.001.008  
No. 1 Hood Exhaust

## Paper Machine Vent 1

### ISOKINETIC CALCULATIONS

Run Number	1	2	3	Mean
Date	6/25/21 ✓	6/25/21 ✓	6/25/21 ✓	---
Time Began	755 ✓	900 ✓	1005 ✓	---
Time Ended	844 ✓	952 ✓	1054 ✓	---

### INPUT DATA

Sampling Time, min	(Theta)	48.0 ✓	48 ✓	48 ✓	48
Stack Diameter, in.	(Dia.)	50.00 ✓	50.00 ✓	50.00 ✓	50.00
Barometric Pressure, in. Hg	(Pb)	29.68 ✓	29.68 ✓	29.68 ✓	29.68
Static Pressure, in. H2O	(Pg)	-0.65 ✓	-0.68 ✓	-0.68 ✓	-0.67
Pitot Tube Coefficient	(Cp)	0.84 ✓	0.84 ✓	0.84 ✓	0.84
Meter Correction Factor	(Y)	1.0030 ✓	1.0030 ✓	1.0030 ✓	1.0030
Orifice Calibration Value	(Delta H@)	1.8000 ✓	1.8000 ✓	1.8000 ✓	1.8000
Nozzle Diameter, in.	(Dn)	0.250 ✓	0.250 ✓	0.250 ✓	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	29.740 ✓	29.705 ✓	30.008 ✓	29.818
Meter Temperature, °F	(Tm)	62.2 ✓	69.8 ✓	75.6 ✓	69.2
Meter Temperature, °R	(Tm-R)	522.2	529.8	535.6	529.2
Meter Orifice Pressure, in. H2O	(Delta H)	1.300 ✓	1.300 ✓	1.300 ✓	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> )avg	1.140 ✓	1.140 ✓	1.140 ✓	1.140
Volume H2O Collected, mL	(Vlc)	147.7 ✓	145.6 ✓	139.1 ✓	144.1
CO2 Concentration, %	(CO2)	0.2 ✓	0.2 ✓	0.2 ✓	0.2
O2 Concentration, %	(O2)	20.2 ✓	20.2 ✓	20.2 ✓	20.2
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> )avg	0.993 ✓	0.987 ✓	0.980 ✓	0.987
Stack Temperature, °F	(Ts)	171.2 ✓	172.3 ✓	173.1 ✓	172.2
Stack Temperature, °R	(Ts-R)	631.2	632.3	633.1	632.2
Moisture Fraction (at Saturation)	(BWS)	0.423 ✓	0.434 ✓	0.442 ✓	0.433

### CALCULATED DATA

Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	13.64 ✓	13.64 ✓	13.64 ✓	13.64
Stack Pressure, in. Hg	(Ps)	29.63 ✓	29.63	29.63	29.63
Meter Pressure, in. Hg	(Pm)	29.78 ✓	29.78	29.78	29.78
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	30.003 ✓	29.538	29.516	29.686
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	6.952 ✓	6.853	6.547	6.784
Moisture Fraction (Measured)	(BWS)	0.188 ✓	0.188	0.182	0.186
Moisture Fraction (lower sat/meas)	(BWS)	0.188 ✓	0.188	0.182	0.186
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	28.84 ✓	28.84	28.84	28.84
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	26.80 ✓	26.80	26.87	26.82
Average Stack Gas Velocity, ft/sec	(Vs)	63.60 ✓	63.25	62.73	63.19
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	52031 ✓	51745	51320	51699
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	34982	34718	34676	34792

Calibration check	(Yqa)	1.0288	1.0375	1.0326	1.033
Percent difference from Y					2.99%



# No. 1 Hood Exhaust

## Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 1 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001-008  
 Run Number: 1  
 Date: 6/25/12  
 Test Personnel: DEATRE  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: P166 6'  
 Liner Material: SS  
 Pitot ID/Coeff.: P77 0.84  
 Thermo ID: A023  
 Nozzle ID/Diams.: .250 in.  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp.: 63 °F  
 Baro. Pressure\*: 28.68 in. Hg  
 Static Pressure: -1.65 in. H<sub>2</sub>O  
 Impinger Gain: 140.7 mL  
 Silica Gel Gain: 7 g  
 Stack Area: 13.64 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A  
 Leak Checks: Good

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	0-00	0.001
Pitot	13"	5"
	Good	Good

Filter ID: N/A  
 Sample ID: RY

TRAVERSE POINT NO	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
0		7:55			731.506									
A-1	3		1.0	1.3	733.4	170	114	57	244	241	N/A	58	3	
2	6		1.2	1.3	735.9	170		58	240	249		52	3	
3	9		1.5	1.3	737.2	171		60	242	253		52	3	
4	12		1.1	1.3	737.1	172		60	243	250		53	3	
5	15		1.0	1.3	741.0	172		61	244	254		53	3	
6	18		1.0	1.3	742.8	172		61	241	254		54	3	
7	21		1.0	1.3	744.7	172		62	241	256		54	3	
8	24		1.0	1.3	746.5	172		62	240	255		55	3	
B-1	27		0.97	1.3	748.3	170		63	242	254		55	3	
2	30		0.98	1.3	750.1	171		62	243	254		54	3	
3	33		0.99	1.3	752.0	171		63	242	256		54	3	
4	36		0.98	1.3	753.8	171		64	242	257		55	3	
5	39		0.99	1.3	755.7	171		65	243	256		55	3	
6	42		0.97	1.3	757.5	172		65	242	254		56	3	
7	45		0.94	1.3	759.4	172		66	242	258		57	3	
8	48	8:44	0.75	1.3	761.246	170		64	241	254		57	3	
			Avg. VAP	Avg. ΔH	Total Volume	Avg. T <sub>m</sub>	Avg. T <sub>o</sub>	Avg. T <sub>h</sub>	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-sta</sub> scf
			0.9934	1.300	29.74	171.2	62.2	241/258	241/254	241/258	58	58	3	

\*Barometric Pressure is at port elevation



Flue Gas Composition  
 Oxygen, %: 20.3  
 Carbon Dioxide, %: 0.2  
 Moisture, %: 19.8

Leak Check, Pre-run: O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Post-run: O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A

Thermocouple Check  
 Meter Temp., °F: \_\_\_\_\_  
 Ref. Temp., °F: \_\_\_\_\_  
 Result: \_\_\_\_\_

15730.001.008  
 Pulp Dryer, #3 Paper Machine,  
 #2-3 SDTV & #1-2 CBs  
 Emission Report



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 1 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 2  
 Date: 6/25/21  
 Test Personnel: BEA/BS  
 Sample Time: 48 min.

Console ID: AO 23  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PR66-6'  
 Liner Material: SS  
 Pitot ID/Coeff.: P77  
 Thermo ID: AO23  
 Nozzle ID/Diams.: .250  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp.: 70 °F  
 Baro. Pressure\*: 29.68 in. Hg  
 Static Pressure: -.68 in. H<sub>2</sub>O  
 Impinger Gain: 139.6 mL  
 Silica Gel Gain: 6 g  
 Stack Area: 13.64 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A  
 Leak Checks: N/A  
 Volume, ft<sup>3</sup>: .005  
 @ Vac., in. Hg: 12"  
 Pitot: Good  
 Initial: .001  
 Final: 5"  
 Filter ID: N/A  
 Sample ID: RUN 2

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH <sub>o</sub> (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
0	09:00				761.500									
A-1	3	7:13Z	1.1	1.3	763.4	173	N/A	68	244	254	N/A	51	3	
2	6		1.1	1.3	765.2	173		68	241	256		49	3	
3	9		1.2	1.3	767.0	173		68	242	264		48	3	
4	12		1.1	1.3	769.1	173		69	243	254		47	3	
5	15		1.0	1.3	770.8	173		69	244	258		49	3	
6	18		.99	1.3	772.6	173		68	242	256		50	3	
7	21		.96	1.3	774.5	173		69	244	258		51	3	
8	24		.94	1.3	776.3	172		70	245	254		51	3	
B-1	27		.95	1.3	778.1	172		70	243	255		54	3	
2	30		.94	1.3	780.0	172		70	242	254		52	3	
3	33		.97	1.3	781.8	172		71	241	256		52	3	
4	36		.98	1.3	783.7	173		71	243	255		53	3	
5	39		1.0	1.3	785.6	173		71	244	256		53	3	
6	42		.99	1.3	787.5	173		72	244	254		54	3	
7	45		.71	1.3	789.3	169		70	241	253		54	3	
8	48	09:52	.72	1.3	791.205	169		72	242	253		54	3	
			Avg. V <sub>ap</sub> : <u>.9870</u>	Avg. ΔH: <u>1.300</u>	Total Volume: <u>29.705</u>	Avg. T <sub>m</sub> : <u>172.3</u>	Avg. T <sub>o</sub> : <u>69.8</u>	Min/Max: <u>241/245</u>	Min/Max: <u>253/264</u>	Min/Max: <u>253/264</u>	Min/Max: <u>54/54</u>	Max Temp: <u>54</u>	Max Vac: <u>3</u>	V <sub>m-std.</sub> : <u>3</u>

\*Barometric Pressure is at port elevation  
 Flue Gas Composition:  
 Oxygen, %: 20.2  
 Carbon Dioxide, %: 0.2  
 Moisture, %: 18.8  
 Thermocouple Check: Q<sub>s</sub> dscfm  
 Meter Temp, °F: Isokinetic  
 Ref. Temp, °F: Calculated by  
 Result: QC by





# Isokinetic Field Data

# Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 1 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/25/21  
 Test Personnel: BJA/BZ  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PR6C-6'  
 Liner Material: SS  
 Pitot ID/Coeff.: P77 0.84  
 Thermo ID: 1023  
 Nozzle ID/Diams.: .250 in.

Ambient Temp.: 74 °F  
 Baro. Pressure\*: 29.68 in. Hg  
 Static Pressure: -6.8 in. H<sub>2</sub>O  
 Impinger Gain: 136.7 mL  
 Silica Gel Gain: 2.4 g  
 Stack Area: 13.64 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A  
 Leak Checks: Good  
 Volume, ft<sup>3</sup>: 0.000  
 @ Vac., in. Hg: 12"  
 Pitot: Good  
 Filter ID: N/A  
 Sample ID: Rm3

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
	0	10:05			791.500									
A-1	3		.92	1.3	793.7	172	N/A	73	244	256	N/A	5858	2	
2	6		.91	1.3	795.2	172		74	241	250		59	2	
3	9		.96	1.3	797.0	173		74	241	255		57	2	
4	12		.98	1.3	799.0	173		74	244	255		56	2	
5	15		1.0	1.3	800.9	173		75	242	254		54	2	
6	18		.99	1.3	802.8	174		75	240	253		54	2	
7	21		.98	1.3	804.7	174		75	242	256		54	2	
8	24		.92	1.3	806.6	173		76	240	255		55	2	
B-1	27		.82	1.3	808.5	171		76	244	250		58	2	
2	30		1.1	1.3	810.4	173		76	243	253		57	2	
3	33		1.1	1.3	812.2	174		76	244	252		56	2	
4	36		1.1	1.3	814.1	174		77	241	254		56	2	
5	39		.93	1.3	816.0	174		77	240	255		57	2	
6	42		.94	1.3	817.8	174		77	241	253		58	2	
7	45		.87	1.3	819.6	173		77	240	255		58	2	
8	48	10:54	.86	1.3	821.508	172		78	243	250		60	2	
*Barometric Pressure is at port elevation					Total Volume	Avg T <sub>s</sub>	Avg T <sub>i</sub>	Avg T <sub>o</sub>	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-sid</sub> scf
					30.008	173.1	75.6	75.6	240/244	250/256	250/256	60	2	
					Avg ΔH	Avg Δp	Flue Gas Composition		O <sub>2</sub> /CO <sub>2</sub> by Orsat Fyrite M3A		Thermocouple Check		Q <sub>s</sub> , dscfm	
					1.300	1.300	Oxygen, %		20.2		Meter Temp., °F		% Isokinetic	
					1.1402	1.1402	Carbon Dioxide, %		0.2		Ref. Temp., °F		Calculated by	
							Moisture, %				Result		QC by	



Integrated Air Services

15730.001.008  
 Pulp Dryer, Paper Machine,  
 #1-3 SPM & #1-2 CBs  
 Emission Report



# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 1 Hood Exhaust  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	864.6	896.1	651.1		881.7	
Initial	747.5	828.6	645.0		879.7	
Gain	117.1 ✓	17.5 ✓	6.1 ✓	140.7	7 ✓	147.7

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 2 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	881.6	711.8	551.5		911.0	
Initial	759.5	696.2	549.6		905.0	
Gain	122.1 ✓	15.6 ✓	1.9 ✓	139.6	6 ✓	145.6

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 3 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	879.4	823.0	652.9		852.1	
Initial	764.4	803.9	650.3		849.7	
Gain	115 ✓	19.1 ✓	2.6 ✓	136.7	2.4 ✓	139.1

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Check COC for Sample IDs of Media Blanks

*(Handwritten signature)*



# Sample and Velocity Traverse Point Data Sheet - Method 1

15730.001.008  
 Shop Order, #3 Paper Machine,  
 #2-3 SDTVs, & #1-2 CBs  
 Emission Report

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 1 Hood Exhaust

Operator VD / LF  
 Date 15-Jun-21  
 W.O. Number 15730.001.008

**Duct Type**     Circular     Rectangular Duct    Indicate appropriate type  
**Traverse Type**     Particulate Traverse     Velocity Traverse

Distance from far wall to outside of port (in.) = C	50.125
Port Depth (in.) = D	0.125
Depth of Duct, diameter (in.) = C-D	50
Area of Duct (ft <sup>2</sup> )	13.64
Total Traverse Points	16
Total Traverse Points per Port	8



**Rectangular Ducts Only**

Width of Duct, rectangular duct only (in.) \_\_\_\_\_

Total Ports (rectangular duct only) \_\_\_\_\_

Traverse Point Locations			
Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	3.2	1 1/2	1 1/2
2	10.5	5 1/2	5 1/2
3	19.4	9 1/2	10
4	32.3	16	16 1/2
5	67.7	34	34
6	80.6	40 1/2	40 1/2
7	89.5	45	45
8	96.8	48 1/2	48 1/2
9			
10			
11			
12			

Flow Disturbances	
Upstream - A (ft)	4.417
Downstream - B (ft)	25.0
Upstream - A (duct diameters)	1.06
Downstream - B (duct diameters)	6.00



Equivalent Diameter =  $(2 * L * W) / (L + W)$

Traverse Point Location Percent of Stack -Circular													
		Number of Traverse Points											
		1	2	3	4	5	6	7	8	9	10	11	12
T r a v e r s e P o i n t	1		14.6		6.7		4.4		3.2		2.6		2.1
	2		85.4		25		14.6		10.5		8.2		6.7
	3				75		29.6		19.4		14.6		11.8
	4				93.3		70.4		32.3		22.6		17.7
	5						85.4		67.7		34.2		25
	6						95.6		80.6		65.8		35.6
	7								89.5		77.4		64.4
	8								96.8		85.4		75
	9										91.8		82.3
	10										97.4		88.2
	11												93.3
	12												97.9


Traverse Point Location Percent of Stack -Rectangular													
		Number of Traverse Points											
		1	2	3	4	5	6	7	8	9	10	11	12
T r a v e r s e P o i n t	1		25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
	2		75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
	3			83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
	4				87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
	5					90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
	6						91.7	78.6	68.8	61.1	55.0	50.0	45.8
	7							92.9	81.3	72.2	65.0	59.1	54.2
	8								93.8	83.3	75.0	68.2	62.5
	9									94.4	85.0	77.3	70.8
	10										95.0	86.4	79.2
	11											95.5	87.5
	12												95.8

Rectangular Stack Points & Matrix  
 9 - 3 x 3  
 12 - 4 x 3  
 16 - 4 x 4  
 20 - 5 x 4  
 25 - 5 x 5  
 30 - 6 x 5  
 36 - 6 x 6  
 42 - 7 x 6  
 49 - 7 x 7

Port Diam. (in) = 4  
 Number of Ports = 2

Tape Measure I.D. # TM-07





**RECEIVED Reference# 218002**  
 By Facility Number of 68-29-00, Apr 11 2009

**PROJECT/CLIENT:** 200809 - Project Columbia

USE THIS DRAWING IN CONJUNCTION WITH THE PROJECT MANUAL, SPECIFICATIONS, AND ALL APPLICABLE CODES. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR VERIFYING THE ACCURACY OF ALL DIMENSIONS AND CONDITIONS SHOWN ON THIS DRAWING. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR VERIFYING THE ACCURACY OF ALL DIMENSIONS AND CONDITIONS SHOWN ON THIS DRAWING.

**DATE:** 4/27/2009 **Shenny Skovds**

1. DESIGNER'S RESPONSIBILITY

2. CONTRACTOR'S RESPONSIBILITY

3. ENGINEER'S RESPONSIBILITY

4. ARCHITECT'S RESPONSIBILITY

5. MANUFACTURER'S RESPONSIBILITY

#1

2-50" Ø x 50'  
 3-52" Ø x 48'  
 2-NO MODIF.

**EMERSON**  
 ISSUED CERTIFIED  
 50% QUALITY ASSURANCE ONLY  
 50% QUALITY ASSURANCE ONLY  
 50% QUALITY ASSURANCE ONLY

**SEE DWG 19-488-148 FOR ALL NOTES**

PROJECT NO. 19-488-148  
 SHEET NO. 19-488-148-1  
 DATE: 04/27/09

**EMERSON**  
 100% QUALITY ASSURANCE ONLY  
 100% QUALITY ASSURANCE ONLY  
 100% QUALITY ASSURANCE ONLY

NO.	DATE	DESCRIPTION	BY	CHECKED	APPROVED
1	04/27/09	ISSUED FOR CONSTRUCTION			
2	04/27/09	ISSUED FOR CONSTRUCTION			
3	04/27/09	ISSUED FOR CONSTRUCTION			
4	04/27/09	ISSUED FOR CONSTRUCTION			
5	04/27/09	ISSUED FOR CONSTRUCTION			
6	04/27/09	ISSUED FOR CONSTRUCTION			
7	04/27/09	ISSUED FOR CONSTRUCTION			
8	04/27/09	ISSUED FOR CONSTRUCTION			
9	04/27/09	ISSUED FOR CONSTRUCTION			
10	04/27/09	ISSUED FOR CONSTRUCTION			
11	04/27/09	ISSUED FOR CONSTRUCTION			
12	04/27/09	ISSUED FOR CONSTRUCTION			
13	04/27/09	ISSUED FOR CONSTRUCTION			
14	04/27/09	ISSUED FOR CONSTRUCTION			
15	04/27/09	ISSUED FOR CONSTRUCTION			
16	04/27/09	ISSUED FOR CONSTRUCTION			
17	04/27/09	ISSUED FOR CONSTRUCTION			
18	04/27/09	ISSUED FOR CONSTRUCTION			
19	04/27/09	ISSUED FOR CONSTRUCTION			
20	04/27/09	ISSUED FOR CONSTRUCTION			
21	04/27/09	ISSUED FOR CONSTRUCTION			
22	04/27/09	ISSUED FOR CONSTRUCTION			
23	04/27/09	ISSUED FOR CONSTRUCTION			
24	04/27/09	ISSUED FOR CONSTRUCTION			
25	04/27/09	ISSUED FOR CONSTRUCTION			
26	04/27/09	ISSUED FOR CONSTRUCTION			
27	04/27/09	ISSUED FOR CONSTRUCTION			
28	04/27/09	ISSUED FOR CONSTRUCTION			
29	04/27/09	ISSUED FOR CONSTRUCTION			
30	04/27/09	ISSUED FOR CONSTRUCTION			
31	04/27/09	ISSUED FOR CONSTRUCTION			
32	04/27/09	ISSUED FOR CONSTRUCTION			
33	04/27/09	ISSUED FOR CONSTRUCTION			
34	04/27/09	ISSUED FOR CONSTRUCTION			
35	04/27/09	ISSUED FOR CONSTRUCTION			
36	04/27/09	ISSUED FOR CONSTRUCTION			
37	04/27/09	ISSUED FOR CONSTRUCTION			
38	04/27/09	ISSUED FOR CONSTRUCTION			
39	04/27/09	ISSUED FOR CONSTRUCTION			
40	04/27/09	ISSUED FOR CONSTRUCTION			
41	04/27/09	ISSUED FOR CONSTRUCTION			
42	04/27/09	ISSUED FOR CONSTRUCTION			
43	04/27/09	ISSUED FOR CONSTRUCTION			
44	04/27/09	ISSUED FOR CONSTRUCTION			
45	04/27/09	ISSUED FOR CONSTRUCTION			
46	04/27/09	ISSUED FOR CONSTRUCTION			
47	04/27/09	ISSUED FOR CONSTRUCTION			
48	04/27/09	ISSUED FOR CONSTRUCTION			
49	04/27/09	ISSUED FOR CONSTRUCTION			
50	04/27/09	ISSUED FOR CONSTRUCTION			

# RUN SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**Start Time 07:55    End Time 08:55**

---

**Average Measured TRS Conc.**    0.42 ppm  
**Recovery No. 2**    97.6 %  
**TRS Corrected for Recovery**    0.43 ppm ✓

*VW4*

# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**Start Time 09:00    End Time 10:00**

---

**Average Measured TRS Conc.**    0.47 ppm  
**Recovery No. 2**    97.6 %  
**TRS Corrected for Recovery**    0.48 ppm ✓

*VDH*

# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**Start Time 10:05    End Time 11:05**

---

**Average Measured TRS Conc.**    0.56 ppm  
**Recovery No. 2**    97.6 %  
**TRS Corrected for Recovery**    0.57 ppm ✓

*VDH*



# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
07:55	<2	<0.07	<2	<0.08	<2	<0.07	<2	<0.02	-
07:58	<2	<0.07	<2	<0.08	<2	<0.07	<2	<0.02	-
08:01	19	0.24	6	0.15	27	0.28	<2	<0.02	0.67
08:04	<2	<0.07	<2	<0.08	10	0.17	<2	<0.02	0.17
08:07	<2	<0.07	20	0.28	<2	<0.07	<2	<0.02	0.28
08:10	12	0.18	<2	<0.08	<2	<0.07	<2	<0.02	0.18
08:13	24	0.27	16	0.24	33	0.32	<2	<0.02	0.82
08:16	10	0.17	<2	<0.08	<2	<0.07	33	0.11	0.39
08:19	10	0.16	<2	<0.08	8	0.15	<2	<0.02	0.31
08:22	23	0.26	24	0.30	<2	<0.07	<2	<0.02	0.56
08:25	20	0.24	14	0.23	<2	<0.07	49	0.13	0.73
08:28	29	0.29	<2	<0.08	<2	<0.07	42	0.12	0.54
08:31	17	0.22	37	0.38	<2	<0.07	<2	<0.02	0.59
08:34	23	0.26	11	0.20	<2	<0.07	27	0.10	0.66
08:37	<2	<0.07	<2	<0.08	25	0.27	<2	<0.02	0.27
08:40	19	0.23	<2	<0.08	37	0.34	71	0.16	0.90
08:43	21	0.25	12	0.21	<2	<0.07	<2	<0.02	0.45
08:46	<2	<0.07	<2	<0.08	<2	<0.07	<2	<0.02	-
08:49	<2	<0.07	<2	<0.08	54	0.41	<2	<0.02	0.41
08:52	24	0.26	<2	<0.08	<2	<0.07	25	0.09	0.45
<b>Average</b>		<b>0.15</b>		<b>0.10</b>		<b>0.10</b>		<b>0.04</b>	<b>0.42</b>



# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
09:00	5	0.12	<2	<0.08	12	0.18	<2	<0.02	0.30
09:03	<2	<0.07	<2	<0.08	<2	<0.07	<2	<0.02	-
09:06	12	0.18	65	0.51	<2	<0.07	<2	<0.02	0.69
09:09	39	0.34	<2	<0.08	<2	<0.07	<2	<0.02	0.34
09:12	<2	<0.07	<2	<0.08	<2	<0.07	<2	<0.02	-
09:15	11	0.17	9	0.18	<2	<0.07	<2	<0.02	0.36
09:18	41	0.35	<2	<0.08	<2	<0.07	26	0.10	0.54
09:21	67	0.45	63	0.50	<2	<0.07	13	0.07	1.08
09:24	19	0.23	<2	<0.08	<2	<0.07	<2	<0.02	0.23
09:27	16	0.21	32	0.35	9	0.16	<2	<0.02	0.72
09:30	23	0.26	16	0.24	<2	<0.07	<2	<0.02	0.50
09:33	5	0.11	<2	<0.08	10	0.17	<2	<0.02	0.28
09:36	<2	<0.07	<2	<0.08	<2	<0.07	40	0.12	0.24
09:39	18	0.23	<2	<0.08	<2	<0.07	<2	<0.02	0.23
09:42	<2	<0.07	<2	<0.08	<2	<0.07	54	0.14	0.28
09:45	29	0.29	<2	<0.08	17	0.22	<2	<0.02	0.51
09:48	17	0.22	<2	<0.08	39	0.35	46	0.13	0.83
09:51	7	0.14	30	0.34	<2	<0.07	<2	<0.02	0.48
09:54	24	0.26	7	0.15	<2	<0.07	<2	<0.02	0.42
09:57	22	0.25	65	0.51	62	0.44	30	0.10	1.41
<b>Average</b>		<b>0.19</b>		<b>0.14</b>		<b>0.08</b>		<b>0.03</b>	<b>0.47</b>

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
10:05	9	0.16	<2	<0.08	<2	<0.07	<2	<0.02	0.16
10:08	8	0.15	<2	<0.08	27	0.28	<2	<0.02	0.43
10:11	40	0.35	<2	<0.08	<2	<0.07	<2	<0.02	0.35
10:14	29	0.29	11	0.20	18	0.23	<2	<0.02	0.72
10:17	23	0.26	22	0.29	<2	<0.07	9	0.05	0.65
10:20	66	0.45	<2	<0.08	<2	<0.07	6	0.05	0.54
10:23	6	0.13	16	0.25	44	0.37	<2	<0.02	0.75
10:26	22	0.25	23	0.29	14	0.20	16	0.07	0.89
10:29	12	0.18	22	0.29	<2	<0.07	<2	<0.02	0.47
10:32	46	0.37	<2	<0.08	<2	<0.07	18	0.08	0.53
10:35	14	0.20	32	0.35	24	0.27	<2	<0.02	0.82
10:38	<2	<0.07	<2	<0.08	<2	<0.07	13	0.07	0.13
10:41	17	0.22	<2	<0.08	38	0.34	<2	<0.02	0.56
10:44	10	0.16	<2	<0.08	6	0.13	20	0.08	0.46
10:47	<2	<0.07	32	0.35	12	0.19	<2	<0.02	0.54
10:50	16	0.21	25	0.31	11	0.17	18	0.08	0.85
10:53	<2	<0.07	23	0.30	44	0.37	<2	<0.02	0.67
10:56	13	0.19	15	0.24	<2	<0.07	<2	<0.02	0.43
10:59	<2	<0.07	9	0.18	25	0.27	<2	<0.02	0.46
11:02	61	0.43	<2	<0.08	28	0.29	<2	<0.02	0.72
<b>Average</b>		<b>0.20</b>		<b>0.15</b>		<b>0.16</b>		<b>0.02</b>	<b>0.56</b>

# RUN DATA

Number 14

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine Vent 1**

Method **16**  
 Calibration **1**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
<b>Calibration drift check</b>									
20:16	14345	7.84	<2	<0.08	<2	<0.07	<2	<0.02	7.84
20:19	14713	7.94	<2	<0.08	<2	<0.07	<2	<0.02	7.94
20:22	14122	7.77	<2	<0.08	<2	<0.07	<2	<0.02	7.77
<b>Average</b>		<b>7.85</b>		<b>&lt;0.08</b>		<b>&lt;0.07</b>		<b>&lt;0.02</b>	<b>7.85</b>

# RECOVERY DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

## Before Run 1

Start Time 07:25    End Time 07:33

---

### Recovery Gas to Probe, Time 07:25

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
14784	14214	14219	14406	7.85

---

### Recovery Gas to GC, Time 07:29

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
14953	14792	14800	14848	7.98

---

Recovery 98.4%

---

*WJH*

# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

After Run 3    Before Run 4  
Start Time 11:06    End Time 11:15

---

Recovery Gas to Probe, Time 11:06

Peak Areas, mv-sec			Average	ppm
13991	13801	13923	13905	7.71

---

Recovery Gas to GC, Time 11:12

Peak Areas, mv-sec			Average	ppm
14345	14801	14524	14556	7.90

---

Recovery 97.6%

---

*WVH*

# CALIBRATION DATA

Number 1

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine Vent 1**

Method **16**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

Analyte	Ambient Temperature: 72°C		Barometric Pressure: 29.70 in. Hg		
	H <sub>2</sub> S	MeSH	DMS	DMDS	
Perm. Device ID	T-51831	33-50536	89-50725	89-53405	
Perm. Rate, nL/min	460	457	298	232	
Ret. Time, sec	25.0	35.0	63.0	132.0	

**1** Flow = **42.9 mL/Min**      **10.7 ppm**      **10.7 ppm**      **6.95 ppm**      **5.41 ppm**

**Time: 06:02**

**Peak Areas, mv-sec**

25099	20594	10407	44232
24750	21533	10445	46016
25597	21979	10703	45950
<b>Average Area</b>	<b>25149</b>	<b>21369</b>	<b>45399</b>

**2** Flow = **82.8 mL/Min**      **5.56 ppm**      **5.52 ppm**      **3.60 ppm**      **2.80 ppm**

**Time: 06:53**

**Peak Areas, mv-sec**

7926	6406	2923	14068
7950	6306	2884	13591
8444	6460	2990	14698
<b>Average Area</b>	<b>8107</b>	<b>6390</b>	<b>14119</b>

**3** Flow = **130 mL/Min**      **3.54 ppm**      **3.52 ppm**      **2.29 ppm**      **1.79 ppm**

**Time: 07:08**

**Peak Areas, mv-sec**

3069	2599	1371	5786
3064	2578	1331	5729
3088	2512	1340	5842
<b>Average Area</b>	<b>3074</b>	<b>2563</b>	<b>5786</b>

*JWH*

# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Method **16**

H <sub>2</sub> S	1	2	3		
Time	06:02	06:53	07:08		
Concentration, ppm	10.7	5.56	3.54		
Area, mv-sec	25149	8107	3074		
Calc. Conc., ppm	10.6	5.79	3.46		
% Error	-1.6	4.2	-2.4		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8847	2.4717	0.9980	2	0.07

MeSH	1	2	3		
Time	06:02	06:53	07:08		
Concentration, ppm	10.7	5.52	3.52		
Area, mv-sec	21369	6390	2563		
Calc. Conc., ppm	10.6	5.62	3.48		
% Error	-0.7	1.8	-1.1		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9089	2.3742	0.9996	2	0.08

DMS	1	2	3		
Time	06:02	06:53	07:08		
Concentration, ppm	6.95	3.60	2.29		
Area, mv-sec	10519	2932	1347		
Calc. Conc., ppm	7.00	3.53	2.32		
% Error	0.8	-2.0	1.2		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8617	2.4483	0.9995	2	0.07

DMDS	1	2	3		
Time	06:02	06:53	07:08		
Concentration, ppm	5.41	2.80	1.79		
Area, mv-sec	45399	14119	5786		
Calc. Conc., ppm	5.37	2.86	1.77		
% Error	-0.8	2.0	-1.2		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8537	3.3043	0.9995	2	0.02

*VD*

# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

**Ambient Temperature: 72°C**

**Barometric Pressure: 29.70 in. Hg**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	460	457	298	232
Ret. Time, sec	25.0	35.0	63.0	132.0

<b>1</b> Flow = <b>43.6</b> mL/Min	<b>10.5</b> ppm	<b>10.5</b> ppm	<b>6.82</b> ppm	<b>5.31</b> ppm
<b>Time: 19:32</b>	<b>Peak Areas, mv-sec</b>			
	23668	22380	10086	46114
	24884	23771	10653	47622
	24624	24375	10810	50274
<b>Average Area</b>	<b>24392</b>	<b>23509</b>	<b>10516</b>	<b>48003</b>
<b>2</b> Flow = <b>65.8</b> mL/Min	<b>6.99</b> ppm	<b>6.95</b> ppm	<b>4.53</b> ppm	<b>3.53</b> ppm
<b>Time: 19:43</b>	<b>Peak Areas, mv-sec</b>			
	14069	11744	5164	24545
	13746	12537	5293	24899
	13905	12112	5280	24958
<b>Average Area</b>	<b>13907</b>	<b>12131</b>	<b>5246</b>	<b>24800</b>
<b>3</b> Flow = <b>123</b> mL/Min	<b>3.74</b> ppm	<b>3.71</b> ppm	<b>2.42</b> ppm	<b>1.88</b> ppm
<b>Time: 19:59</b>	<b>Peak Areas, mv-sec</b>			
	4288	3691	1547	7409
	4623	3823	1561	7662
	4672	3745	1545	7541
<b>Average Area</b>	<b>4527</b>	<b>3753</b>	<b>1551</b>	<b>7538</b>

*Handwritten mark*



# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

H <sub>2</sub> S	1	2	3			
Time	19:32	19:43	19:59			
Concentration, ppm	10.5	6.99	3.74			
Area, mv-sec	24392	13907	4527			
Calc. Conc., ppm	10.3	7.29	3.68			
% Error	-2.5	4.3	-1.6			
<u>Calibration Curve</u>	<u>Slope</u>	<u>Intercept</u>	<u>Corr. Coeff.</u>	<u>Min. Area</u>	<u>Det. Lim.</u>	
	1.6380	2.7299	0.9976	2	0.03	

MeSH	1	2	3			
Time	19:32	19:43	19:59			
Concentration, ppm	10.5	6.95	3.71			
Area, mv-sec	23509	12131	3753			
Calc. Conc., ppm	10.3	7.11	3.68			
% Error	-1.4	2.4	-0.9			
<u>Calibration Curve</u>	<u>Slope</u>	<u>Intercept</u>	<u>Corr. Coeff.</u>	<u>Min. Area</u>	<u>Det. Lim.</u>	
	1.7779	2.5690	0.9992	2	0.05	

DMS	1	2	3			
Time	19:32	19:43	19:59			
Concentration, ppm	6.82	4.53	2.42			
Area, mv-sec	10516	5246	1551			
Calc. Conc., ppm	6.73	4.63	2.40			
% Error	-1.3	2.2	-0.9			
<u>Calibration Curve</u>	<u>Slope</u>	<u>Intercept</u>	<u>Corr. Coeff.</u>	<u>Min. Area</u>	<u>Det. Lim.</u>	
	1.8539	2.4865	0.9993	2	0.07	

DMDS	1	2	3			
Time	19:32	19:43	19:59			
Concentration, ppm	5.31	3.53	1.88			
Area, mv-sec	48003	24800	7538			
Calc. Conc., ppm	5.23	3.62	1.86			
% Error	-1.6	2.7	-1.0			
<u>Calibration Curve</u>	<u>Slope</u>	<u>Intercept</u>	<u>Corr. Coeff.</u>	<u>Min. Area</u>	<u>Det. Lim.</u>	
	1.7949	3.3916	0.9990	2	0.02	

*VD*

## ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
<b>Molecular Weight</b>	34.08	48.11	62.14	94.20
<b>Retention Time, sec</b>	25.0	35.0	63.0	132.0
<b>Peak Detection Window, sec</b>	10.0	10.0	10.0	10.0
<b>Minimum Peak Area, mv-sec</b>	2	2	2	2
<b>Minimum Peak Height, mv</b>	1	1	1	1
<b>Beginning Peak Width, sec</b>	1.0	1.0	3.0	3.0
<b>Ending Peak Width, sec</b>	2.0	3.0	5.0	5.0
<b>Permeation Device ID</b>	T-51831	33-50536	89-50725	89-53405
<b>Permeation Rate, ng/min</b>	642 ✓	901	758 ✓	895 ✓
<b>Permeation Rate, nL/min*</b>	460	457	298	232

**Barometric Pressure:** 29.70 in. Hg    **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**PR<sub>ng</sub>** = Permeation Rate by weight, ng/min

**V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole

**W<sub>mol</sub>** = Molecular Weight of compound

**T<sub>a</sub>** = Ambient Temperature, °F

**T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)

**P<sub>s</sub>** = Standard Pressure = 29.92 in Hg

**P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 642 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.70) = 460 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

**C** = Concentration, ppmv

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**F<sub>d</sub>** = Flow rate of diluent, mL/min

## INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

File: E:\6-25-21.trs  
Program Version: 2.0, built 21 Feb 2015 File Version: 2.0  
Computer: JWS-PROGRAMMING Trailer: 271

Analog Input Device: Keithley KUSB-3108 GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: GC-8A Serial No. C10494419420SA  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 100	Primary: 3'
Air	30	60	Detector: 120	Secondary:
Carrier	50	30		Sample Loop: 6" unlined

### Injection Cycle

Total Length: 180 sec Sampling Time: 160 sec Load/Backflush Time: 85 sec

### Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 5 mv-sec Minimum peak height 5 mv above baseline

### Dynacalibrator

Chamber Temperature 130.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.70 in. Hg

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent |**

Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM vent 1 Run 1</b>				
09:07:29	6776	20.2	40	0.2
09:07:44	6774	20.2	41	0.2
09:07:59	6775	20.2	40	0.2
09:08:14	6774	20.2	43	0.2
09:08:29	6776	20.2	42	0.2
09:08:44	6773	20.2	43	0.2
09:08:59	6776	20.2	43	0.2
09:09:14	6777	20.2	43	0.2
09:09:29	6776	20.2	43	0.2
09:09:44	6773	20.2	42	0.2
09:09:59	6775	20.2	42	0.2
09:10:14	6775	20.2	40	0.2
09:10:29	6775	20.2	41	0.2
09:10:44	6773	20.2	41	0.2
09:10:59	6774	20.2	41	0.2
09:11:14	6774	20.2	39	0.2
09:11:29	6774	20.2	42	0.2
<b>Avg</b>	<b>6775</b>	<b>20.2</b>	<b>42</b>	<b>0.2</b>

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 1**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
	<b>PM vent 1</b>		<b>Run 2</b>	
10:12:11	6777	20.2	36	0.2
10:12:26	6776	20.2	38	0.2
10:12:41	6774	20.2	37	0.2
10:12:56	6777	20.2	36	0.2
10:13:11	6774	20.2	37	0.2
10:13:26	6776	20.2	38	0.2
10:13:41	6775	20.2	37	0.2
10:13:56	6777	20.2	37	0.2
10:14:11	6775	20.2	37	0.2
10:14:26	6774	20.2	37	0.2
10:14:41	6773	20.2	38	0.2
10:14:56	6776	20.2	36	0.2
10:15:11	6776	20.2	36	0.2
10:15:26	6775	20.2	37	0.2
10:15:41	6774	20.2	36	0.2
10:15:56	6774	20.2	35	0.2
10:16:11	6776	20.2	37	0.2
10:16:26	6775	20.2	38	0.2
10:16:41	6773	20.2	37	0.2
10:16:56	6776	20.2	36	0.2
<b>Avg</b>	<b>6775</b>	<b>20.2</b>	<b>37</b>	<b>0.2</b>

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 1**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM vent 1 Run 3</b>				
11:20:14	6778	20.2	37	0.2
11:20:29	6777	20.2	35	0.2
11:20:44	6776	20.2	36	0.2
11:20:59	6778	20.2	33	0.2
11:21:14	6776	20.2	34	0.2
11:21:29	6778	20.2	33	0.2
11:21:44	6775	20.2	33	0.2
11:21:59	6777	20.2	35	0.2
11:22:14	6776	20.2	34	0.2
11:22:29	6775	20.2	34	0.2
11:22:44	6773	20.2	35	0.2
11:22:59	6778	20.2	35	0.2
11:23:14	6777	20.2	34	0.2
11:23:29	6775	20.2	34	0.2
11:23:44	6774	20.2	33	0.2
11:23:59	6776	20.2	35	0.2
11:24:14	6775	20.2	35	0.2
11:24:29	6776	20.2	35	0.2
11:24:44	6774	20.2	34	0.2
11:24:59	6775	20.2	34	0.2
11:25:14	6776	20.2	34	0.2
<b>Avg</b>	<b>6776</b>	<b>20.2</b>	<b>34</b>	<b>0.2</b>

# RUN DATA

Number 4

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine vent**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **25 Jun 2021**

Calibration 1

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
11:31:32	3335	10.0	3225	9.9
11:31:47	3332	10.0	3232	9.9
11:32:02	3330	10.0	3232	9.9
11:32:17	3330	10.0	3236	9.9
<b>Cylinder # SG9168283BAL</b>	<b>10.12</b>	<b>O2 and 10.16</b>	<b>CO2</b>	
11:32:32	3328	10.0	3235	9.9
11:32:47	3328	10.0	3238	9.9
11:33:02	3330	10.0	3237	9.9
11:33:17	3329	10.0	3237	9.9
11:33:32	3327	10.0	3240	9.9
11:33:47	3329	10.0	3241	9.9
11:34:02	3328	10.0	3237	9.9
11:34:17	3330	10.0	3242	9.9
11:34:32	3329	10.0	3239	9.9
11:34:47	3328	10.0	3238	9.9
11:35:02	3331	10.0	3239	9.9
11:35:17	3331	10.0	3238	9.9
11:35:32	3333	10.0	3235	9.9
11:35:47	3334	10.0	3235	9.9
<b>Avg</b>	<b>3330</b>	<b>10.0</b>	<b>3236</b>	<b>9.9</b>

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 08:20

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	8
10.1 ✓	SG9168283BAL	3287
19.5 ✓	CC454190	6576

Curve Coefficients

Slope	Intercept	Corr. Coeff.
336.7 ✓	-31 ✓	0.9998 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	5
10.2 ✓	SG9168283BAL	3276
20.4 ✓	CC454190	6722

Curve Coefficients

Slope	Intercept	Corr. Coeff.
329.3 ✓	-20 ✓	0.9999 ✓

*Handwritten signature*



# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 08:20

**O<sub>2</sub>**

Method: EPA 3A  
Span Conc. 19.5 %

Slope 336.7                      Intercept -31.5

Standard %	Response mv	Result %	Difference %	Error %	Status
Zero	8	0.1	0.1	0.5 ✓	Pass
10.1	3287	9.9	-0.2	-1.0 ✓	Pass
19.5	6576	19.6	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.4 %

Slope 329.3                      Intercept -19.9

Standard %	Response mv	Result %	Difference %	Error %	Status
Zero	5	0.1	0.1	0.5 ✓	Pass
10.2	3276	10.0	-0.2	-1.0 ✓	Pass
20.4	6722	20.5	0.1	0.5 ✓	Pass

*mm*

# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**File:** C:\Users\Trailer 271\Documents\New Indy\6-25-21.cem  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** DESKTOP-GQ0I9UV **Trailer:** 271  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>20.0</b>
Span Concentration, %	<b>19.5</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.4</b>



## VENT 2

New Indy  
Catawba, SC

15730.001.008  
No. 2 Hood Exhaust  
Paper Machine Vent 2

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
Date	6/24/21 ✓	6/24/21 ✓	6/24/21 ✓	---
Time Began	1310 ✓	1416 ✓	1522 ✓	---
Time Ended	1410 ✓	1516 ✓	1622 ✓	---
Volumetric Flow Rate, (Qs), DSCFM	5.20E+04 ✓	5.26E+04 ✓	5.45E+04 ✓	5.30E+04
BWS	0.202 ✓	0.187 ✓	0.187 ✓	0.192
% Oxygen	20.2 ✓	20.2 ✓	20.2 ✓	20.2
<hr/>				
<b>Total Reduced Sulfur</b>	(TRS MW)= 34.08			
Concentration, ppm	0.68 ✓	0.62 ✓	0.57 ✓	0.62
Emission Rate, lb/hr	0.19 ✓	0.17 ✓	0.16 ✓	0.18

*Ag for SHW*

New Indy  
Catawba, SC

15730.001.008  
No. 2 Hood Exhaust

## Paper Machine Vent 2

### ISOKINETIC CALCULATIONS

Run Number		1	2	3	Mean
Date		6/24/21	6/24/21	6/24/21	---
Time Began		1310	1416	1522	---
Time Ended		1401	1508	1613	---
INPUT DATA					
Sampling Time, min	(Theta)	48.0	48	48	48
Stack Diameter, in.	(Dia.)	55.875	55.875	55.875	55.875
Barometric Pressure, in. Hg	(Pb)	29.70	29.70	29.70	29.70
Static Pressure, in. H2O	(Pg)	-0.82	-0.82	-0.82	-0.82
Pitot Tube Coefficient	(Cp)	0.84	0.84	0.84	0.84
Meter Correction Factor	(Y)	1.0030	1.0030	1.0030	1.0030
Orifice Calibration Value	(Delta H@)	1.8000	1.8000	1.8000	1.8000
Nozzle Diameter, in.	(Dn)	0.250	0.250	0.250	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	30.104	30.681	30.709	30.498
Meter Temperature, °F	(Tm)	89.3	87.4	87.8	88.2
Meter Temperature, °R	(Tm-R)	549.3	547.4	547.8	548.2
Meter Orifice Pressure, in. H2O	(Delta H)	1.300	1.300	1.300	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> avg)	1.140	1.140	1.140	1.140
Volume H2O Collected, mL	(Vlc)	155.6	144.8	144.0	148.1
CO2 Concentration, %	(CO2)	0.2	0.2	0.2	0.2
O2 Concentration, %	(O2)	20.2	20.2	20.2	20.2
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> avg)	1.207	1.202	1.244	1.218
Stack Temperature, °F	(Ts)	178.2	178.4	179.1	178.6
Stack Temperature, °R	(Ts-R)	638.2	638.4	639.1	638.6
Moisture Fraction (at Saturation)	(BWS)	0.496	0.498	0.506	0.500
CALCULATED DATA					
Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	17.03	17.03	17.03	17.03
Stack Pressure, in. Hg	(Ps)	29.64	29.64	29.64	29.64
Meter Pressure, in. Hg	(Pm)	29.80	29.80	29.80	29.80
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	28.891	29.547	29.553	29.330
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	7.324	6.816	6.778	6.973
Moisture Fraction (Measured)	(BWS)	0.202	0.187	0.187	0.192
Moisture Fraction (lower sat/meas)	(BWS)	0.202	0.187	0.187	0.192
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	28.84	28.84	28.84	28.84
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	26.65	26.81	26.82	26.76
Average Stack Gas Velocity, ft/sec	(Vs)	77.94	77.40	80.12	78.49
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	79629	79074	81860	80188
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	52043	52622	54475	53047
Calibration check	(Yqa)	1.0420	1.0207	1.0201	1.028
Percent difference from Y					2.45%

*AB For SHW*



No. 2 Hood Exhaust

55.875 dia

### Isokinetic Field Data

### Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 2 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 1  
 Date: 6/24/21  
 Test Personnel: BCA/BE  
 Sample Time: 46 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PR6C-6'  
 Liner Material: SS  
 Pitot ID/Coeff.: P77 0.84  
 Thermo ID: A023  
 Nozzle ID/Diams.: .250  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp.: 79 °F  
 Baro. Pressure\*: 29.70 in. Hg  
 Static Pressure: -.82 in. H<sub>2</sub>O  
 Impinger Gain: 149.2 mL  
 Silica Gel Gain: 6.1 g  
 Stack Area: 17.03 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A  
 Leak Checks:  
 Volume, ft<sup>3</sup>: 0.002  
 @ Vac., in. Hg: 12"  
 Pitot: Good  
 Filter ID: N/A  
 Sample ID: Run 1

TRAVERSE POINT NO	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
A-1	0	13:10			638.676									
	3		1.5	1.3	640.4	178	N/A	89	250	245	N/A	62	3	
	6		1.7	1.3	642.3	178		89	250	244		53	3	
	9		1.7	1.3	644.1	178		90	250	243		49	3	
	12		1.7	1.3	646.0	178		90	250	241		48	3	
	15		1.6	1.3	648.0	178		90	252	247		48	3	
	18		1.6	1.3	649.7	178		90	254	246		49	3	
	21		1.3	1.3	651.6	179		90	244	246		50	3	
	24		1.3	1.3	653.6	180		89	253	246		49	3	
B-1	27		1.2	1.3	655.5	178		89	255	242		53	3	
	30		1.2	1.3	657.4	179		87	250	245		50	3	
	33		1.2	1.3	659.3	179		89	251	244		50	3	
	36		1.4	1.3	661.2	179		89	251	245		49	3	
	39		1.4	1.3	663.1	178		89	252	245		49	3	
	42		1.4	1.3	664.9	178		89	252	245		50	3	
	45		1.4	1.3	666.8	178		89	253	244		50	3	
	48	14:01	1.6	1.3	668.800	175		89	256	247		51	3	
*Barometric Pressure is at port elevation			Avg Δp	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Min/Max	Max Vac	V <sub>m-std</sub> , scf
			1.207	1.300	30.104	178.2	89.3	249/256	241/248	247	62	62	3	3



Flue Gas Composition  
 Oxygen, %  
 Carbon Dioxide, %  
 Moisture, %

Thermocouple Check  
 Meter Temp., °F  
 Ref. Temp., °F  
 Result

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run  
 Post-run

15730.001.008  
 Paper Machine,  
 #2-3 SFTVs & #1-2 CBs  
 Emission Report

QC by



No. 2 Hood Exhaust

**Isokinetic Field Data**

**Method: EPA 4, Moisture**

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 2 Hood Exhaust  
 Sample Location Loop  
 W. O. Number 15730.001.008  
 Run Number 2  
 Date 6/24/21  
 Test Personnel BEA/EE  
 Sample Time 48 min.

Console ID A023  
 Meter Corr., Y 1.003  
 Console ΔH@ 1.800  
 Probe ID/Length PR6C-6'  
 Liner Material 55  
 Pitot ID/Coeff. P77 0.84  
 Thermo ID A023  
 Nozzle ID/Diams. 0.250 in.  
 Avg. Nozzle Diam. 0.250 in.  
 Total Traverse Points 16

K Factor N/A  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	<u>0.006</u>	<u>0.004</u>
Pitot	<u>12.1'</u>	<u>12.1'</u>
	<u>Good</u>	<u>Good</u>

Filter ID N/A  
 Sample ID run 2

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS	
															Avg ΔH
A-1	0	14:16	1.3	1.3	669.605	178	N/A	88	282	293	N/A	62	2		
2	3		1.2	1.3	671.5	178		88	283	295		60	2		
3	6		1.2	1.3	673.3	178		88	282	296		57	2		
4	9		1.3	1.3	675.3	179		87	284	293		56	2		
5	12		1.3	1.3	677.2	179		87	282	247		56	2		
6	15		1.4	1.3	679.1	179		87	253	299		58	2		
7	18		1.4	1.3	681.1	179		88	288	239		58	2		
8	21		1.5	1.3	683.0	176		88	256	294		59	2		
B-1	24		1.6	1.3	684.0	176		88	256	295		60	2		
2	27		1.5	1.3	686.9	176		87	249	295		62	2		
3	30		1.6	1.3	688.8	179		88	252	291		63	2		
4	33		1.7	1.3	690.7	179		87	250	247		66	2		
5	36		1.7	1.3	692.6	179		87	251	295		67	2		
6	39		1.7	1.3	694.4	180		87	249	245		64	2		
7	42		1.4	1.3	696.3	180		87	251	245		65	2		
8	45		1.4	1.3	698.3	180		87	251	247		65	2		
8	48	15:08	1.4	1.3	700.286	180		87	251	244		62	2		
*Barometric Pressure is at port elevation			Avg ΔP	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub>
			1.2024	1.300	36.681	178.4	87.4	249/258	239/297				67	2	

**WESTON SOLUTIONS**  
 Integrated Air Services

Flue Gas Composition  
 Oxygen, % \_\_\_\_\_  
 Carbon Dioxide, % \_\_\_\_\_  
 Moisture, % \_\_\_\_\_

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A \_\_\_\_\_  
 Leak Check, Pre-run \_\_\_\_\_  
 Post-run \_\_\_\_\_

Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 Result \_\_\_\_\_

Q<sub>s</sub> dscfm \_\_\_\_\_  
 % Isokinetic \_\_\_\_\_  
 Calculated by \_\_\_\_\_  
 QC by \_\_\_\_\_

15730.001.008  
 Pump Driver, Paper Machine,  
 #2-3 SPPV's, & #1-2 CBs  
 Emission Report



# Isokinetic Field Data

# Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 2 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/29/21  
 Test Personnel: BEA/BE  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PR66-6-  
 Liner Material: SS  
 Pitot ID/Coeff.: P77 0.84  
 Thermo ID: A023  
 Nozzle ID/Diams.: \_\_\_\_\_  
 Avg. Nozzle Diam.: .250 in. Total Traverse Points: 16

Ambient Temp. 81 °F  
 Baro. Pressure\* 29.70 in. Hg  
 Static Pressure -82 in. H<sub>2</sub>O  
 Impinger Gain 138.9 mL  
 Silica Gel Gain 5.1 g  
 Stack Area 17.03 ft<sup>2</sup>

K Factor		Leak Checks	
Initial	Final	Initial	Final
<u>1.004</u>	<u>.002</u>	<u>12"</u>	<u>5"</u>
<u>6.00</u>	<u>6.00</u>	<u>6.00</u>	<u>6.00</u>

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
A-1	0	15:22	1.5	1.3	700.564	179	N/A	87	253	247	N/A	67	3	
2	3		1.5	1.3	762.5	180		87	255	246		57	3	
3	6		1.6	1.3	706.4	179		87	252	242		52	3	
4	9		1.6	1.3	708.3	179		88	253	246		51	3	
5	12		1.7	1.3	710.3	180		88	248	242		51	3	
6	15		1.7	1.3	712.2	179		87	251	248		52	3	
7	18		1.7	1.3	714.1	179		87	251	247		52	3	
8	21		1.5	1.3	716.0	179		87	250	245		52	3	
B-1	24		1.5	1.3	717.9	179		88	252	243		55	3	
2	27		1.5	1.3	719.8	179		88	254	245		52	3	
3	30		1.5	1.3	721.7	179		88	250	241		51	3	
4	33		1.6	1.3	723.6	179		88	249	242		52	3	
5	36		1.6	1.3	725.5	179		88	251	247		53	3	
6	39		1.5	1.3	727.4	179		89	251	247		53	3	
7	42		1.5	1.3	729.3	179		89	252	248		54	3	
8	45		1.3	1.3	731.273	179		89	254	246		53	3	
8	48	16:13	1.2443	1.300	80.709	179.1	87.8	87.8	248	241	248	67	3	

\*Barometric Pressure is at port elevation  
 Flue Gas Composition: Oxygen, % \_\_\_\_\_ Carbon Dioxide, % \_\_\_\_\_ Moisture, % \_\_\_\_\_  
 O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A \_\_\_\_\_  
 Leak Check, Pre-run \_\_\_\_\_ Post-run \_\_\_\_\_  
 Thermocouple Check: Meter Temp., °F \_\_\_\_\_ Ref. Temp., °F \_\_\_\_\_  
 Q<sub>s</sub>, dscfm \_\_\_\_\_ % Isokinetic \_\_\_\_\_  
 Calculated by \_\_\_\_\_ QC by AV



Integrated Air Services



# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 2 Hood Exhaust  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/24/21 Recovery Date 6/24/21  
 Sample ID Run 1 Filter ID N/A Analyst BA

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	835.1	721.3	560.2		877.9	
Initial	742.4	668.1	556.9		893.5	
Gain	92.7 ✓	53.2 ✓	3.3 ✓	149.2	6.4	155.6

Impinger Color clear ✓ Labeled? ✓ ✓  
 Silica Gel Condition Good Sealed? ✓ ✓

Run No. 2 Sample Date 6/24/21 Recovery Date 6/24/21  
 Sample ID Run 2 Filter ID N/A Analyst BA

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	868.1	841.8	648.0		874.7	
Initial	752.4	824.3	645.0		866.1	
Gain	115.7 ✓	17.5 ✓	3 ✓	136.2	8.6	144.8

Impinger Color clear ✓ Labeled? ✓ ✓  
 Silica Gel Condition Good Sealed? ✓ ✓

Run No. 3 Sample Date 6/24/21 Recovery Date 6/24/21  
 Sample ID Run 3 Filter ID N/A Analyst BA

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	868.5	696.7	553.9		905.0	
Initial	760.2	669.1	550.9		899.9	
Gain	108.3 ✓	27.6 ✓	3 ✓	138.9	5.1	144.0

Impinger Color clear ✓ Labeled? ✓ ✓  
 Silica Gel Condition Good Sealed? ✓ ✓

Check COC for Sample IDs of Media Blanks

AP3 ✓



# Sample and Velocity Traverse Point Data Sheet - Method 1

15730.001.008  
 Slip Paper, #3 Paper Machine,  
 #2-3 SDTVs, & #1-2 CBs  
 Emission Report

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 2 Hood Exhaust

Operator VD / LF  
 Date 15-Jun-21  
 W.O. Number 15730.001.008

**Duct Type**  Circular  Rectangular Duct Indicate appropriate type  
**Traverse Type**  Particulate Traverse  Velocity Traverse



Distance from far wall to outside of port (in.) = C	<b>56.000</b>
Port Depth (in.) = D	<b>0.125</b>
Depth of Duct, diameter (in.) = C-D	<b>55.875</b>
Area of Duct (ft <sup>2</sup> )	<b>17.03</b>
Total Traverse Points	<b>16</b>
Total Traverse Points per Port	<b>8</b>

**Rectangular Ducts Only**

Width of Duct, rectangular duct only (in.)	
Total Ports (rectangular duct only)	

Traverse Point Locations			
Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	3.2	2	2
2	10.5	6	6
3	19.4	11	11
4	32.3	18	18
5	67.7	38	38
6	80.6	45	45
7	89.5	50	50
8	96.8	54	54
9			
10			
11			
12			

Flow Disturbances	
Upstream - A (ft)	<b>7.208</b>
Downstream - B (ft)	<b>25.0</b>
Upstream - A (duct diameters)	<b>1.55</b>
Downstream - B (duct diameters)	<b>5.37</b>



Equivalent Diameter =  $(2 * L * W) / (L + W)$

Traverse Point Location Percent of Stack -Circular													
Number of Traverse Points													
	1	2	3	4	5	6	7	8	9	10	11	12	
T	1	14.6		6.7		4.4		3.2		2.6		2.1	
r	2		85.4		25		14.6		10.5		8.2		6.7
a	3			75		29.6		19.4		14.6		11.8	
v	4				93.3		70.4		32.3		22.6		17.7
e	5					85.4		67.7		34.2		25	
r	6						95.6		80.6		65.8		35.6
s	7							89.5		77.4		64.4	
a	8								96.8		85.4		75
e	9									91.8		82.3	
t	10										97.4		88.2
P	11											93.3	
o	12												97.9

Traverse Point Location Percent of Stack -Rectangular													
Number of Traverse Points													
	1	2	3	4	5	6	7	8	9	10	11	12	
T	1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2	
r	2		75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
a	3			83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
v	4				87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
e	5					90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
r	6						91.7	78.6	68.8	61.1	55.0	50.0	45.8
s	7							92.9	81.3	72.2	65.0	59.1	54.2
a	8								93.8	83.3	75.0	68.2	62.5
e	9									94.4	85.0	77.3	70.8
t	10										95.0	86.4	79.2
P	11											95.5	87.5
o	12												95.8

**Rectangular Stack Points & Matrix**  
 9 - 3 x 3  
 12 - 4 x 3  
 16 - 4 x 4  
 20 - 5 x 4  
 25 - 5 x 5  
 30 - 6 x 5  
 36 - 6 x 6  
 42 - 7 x 6  
 49 - 7 x 7

Port Diam. (in) = 4  
 Number of Ports = 2

Tape Measure I.D. # TM-07





# RUN SUMMARY

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent # 2**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

Start Time 13:10    End Time 14:10

---

Average Measured TRS Conc.    0.67 ppm ✓  
Recovery No. 3                    98.0 % ✓  
TRS Corrected for Recovery    0.68 ppm ✓

SK



# RUN SUMMARY

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3 2**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

Start Time 14:16    End Time 15:16

---

Average Measured TRS Conc.    0.61 ppm ✓  
Recovery No. 3    98.0 % ✓  
TRS Corrected for Recovery    0.62 ppm ✓

TS

# RUN SUMMARY

Number 6

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent # 2**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

Start Time 15:22    End Time 16:22

---

Average Measured TRS Conc.    0.56 ppm ✓  
Recovery No. 3    98.0 % ✓  
TRS Corrected for Recovery    0.57 ppm ✓

SX

# RUN DATA

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent #2**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
<b>Run 1 on PM vent 2</b>									
13:10	31	0.32	4	0.13	8	0.18	29	0.11	0.86
13:13	26	0.29	10	0.22	<2	<0.091	<2	<0.027	0.51
13:16	14	0.21	44	0.45	<2	<0.091	<2	<0.027	0.66
13:19	23	0.27	9	0.21	<2	<0.091	<2	<0.027	0.48
13:22	13	0.20	18	0.29	<2	<0.091	<2	<0.027	0.49
13:25	10	0.17	27	0.35	<2	<0.091	<2	<0.027	0.53
13:28	36	0.35	9	0.20	<2	<0.091	20	0.09	0.73
13:31	10	0.17	7	0.18	<2	<0.091	11	0.07	0.49
13:34	78	0.53	60	0.53	<2	<0.091	<2	<0.027	1.06
13:37	8	0.15	19	0.30	37	0.40	31	0.12	1.09
13:40	10	0.18	<2	<0.095	<2	<0.091	15	0.08	0.34
13:43	8	0.16	66	0.56	<2	<0.091	<2	<0.027	0.71
13:46	24	0.28	24	0.33	14	0.24	<2	<0.027	0.85
13:49	6	0.14	<2	<0.095	<2	<0.091	28	0.11	0.36
13:52	217	0.90	<2	<0.095	<2	<0.091	<2	<0.027	0.90
13:55	64	0.47	<2	<0.095	19	0.29	<2	<0.027	0.76
13:58	24	0.29	15	0.26	<2	<0.091	<2	<0.027	0.54
14:01	14	0.21	16	0.27	<2	<0.091	16	0.08	0.64
14:04	16	0.23	25	0.34	<2	<0.091	<2	<0.027	0.57
14:07	55	0.44	25	0.34	<2	<0.091	<2	<0.027	0.78
<b>Average</b>		<b>0.30</b>		<b>0.25</b>		<b>&lt;0.091</b>		<b>0.03</b>	<b>0.67</b>

54



# RUN DATA

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3 2**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
<b>Run 2 PM vent 2</b>									
14:16	<2	<0.076	<2	<0.095	<2	<0.091	<2	<0.027	-
14:19	17	0.23	9	0.20	<2	<0.091	5	0.04	0.52
14:22	91	0.57	<2	<0.095	31	0.37	<2	<0.027	0.93
14:25	59	0.45	25	0.34	<2	<0.091	<2	<0.027	0.79
14:28	19	0.25	<2	<0.095	13	0.24	13	0.07	0.64
14:31	6	0.13	40	0.43	<2	<0.091	25	0.10	0.77
14:34	<2	<0.076	<2	<0.095	12	0.22	11	0.07	0.36
14:37	4	0.11	253	1.10	<2	<0.091	<2	<0.027	1.21
14:40	20	0.26	25	0.34	5	0.14	62	0.17	1.07
14:43	<2	<0.076	<2	<0.095	<2	<0.091	17	0.09	0.17
14:46	<2	<0.076	50	0.48	22	0.31	49	0.15	1.09
14:49	<2	<0.076	<2	<0.095	<2	<0.091	<2	<0.027	-
14:52	<2	<0.076	7	0.17	<2	<0.091	15	0.08	0.33
14:55	<2	<0.076	83	0.62	56	0.50	<2	<0.027	1.12
14:58	97	0.59	<2	<0.095	<2	<0.091	<2	<0.027	0.59
15:01	32	0.33	<2	<0.095	34	0.39	18	0.09	0.89
15:04	9	0.17	17	0.28	10	0.21	13	0.07	0.80
15:07	<2	<0.076	<2	<0.095	<2	<0.091	<2	<0.027	-
15:10	9	0.17	6	0.17	<2	<0.091	<2	<0.027	0.34
15:13	13	0.20	7	0.18	13	0.24	<2	<0.027	0.62
<b>Average</b>		<b>0.17</b>		<b>0.22</b>		<b>0.13</b>		<b>0.05</b>	<b>0.61</b> ✓

*JK*

# RUN DATA

Number 6

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 2**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
<b>Run 3 PM vent 2</b>									
15:22	8	0.16	<2	<0.095	<2	<0.091	<2	<0.027	0.16
15:25	14	0.22	14	0.26	41	0.42	<2	<0.027	0.89
15:28	266	1.00	<2	<0.095	<2	<0.091	<2	<0.027	1.00
15:31	9	0.17	<2	<0.095	43	0.43	11	0.07	0.73
15:34	12	0.20	5	0.16	18	0.28	<2	<0.027	0.63
15:37	13	0.21	7	0.18	9	0.20	17	0.08	0.76
15:40	58	0.45	24	0.33	<2	<0.091	<2	<0.027	0.78
15:43	154	0.75	<2	<0.095	21	0.30	<2	<0.027	1.06
15:46	3	0.09	43	0.45	<2	<0.091	22	0.10	0.73
15:49	7	0.15	8	0.19	<2	<0.091	<2	<0.027	0.33
15:52	8	0.16	9	0.20	<2	<0.091	43	0.14	0.64
15:55	15	0.22	<2	<0.095	11	0.21	<2	<0.027	0.43
15:58	14	0.22	13	0.24	<2	<0.091	<2	<0.027	0.46
16:01	32	0.33	<2	<0.095	<2	<0.091	<2	<0.027	0.33
16:04	<2	<0.076	<2	<0.095	33	0.38	<2	<0.027	0.38
16:07	24	0.29	5	0.15	<2	<0.091	<2	<0.027	0.44
16:10	10	0.17	<2	<0.095	<2	<0.091	9	0.06	0.29
16:13	<2	<0.076	12	0.24	<2	<0.091	<2	<0.027	0.24
16:16	9	0.17	22	0.32	5	0.15	<2	<0.027	0.63
16:19	<2	<0.076	<2	<0.095	<2	<0.091	60	0.16	0.33
<b>Average</b>		<b>0.25</b>		<b>0.14</b>		<b>0.12</b>		<b>0.03</b>	<b>0.56</b>

JS

# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3<sup>2</sup>**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

After Run 3 Before Run 4  
Start Time 12:45 End Time 12:55

## Recovery Gas to Probe, Time 12:45

Peak Areas, mv-sec			Average	ppm
12908	13446	13416	13257	7.84

## Recovery Gas to GC, Time 12:51

Peak Areas, mv-sec			Average	ppm
13746	14196	14064	14002	8.07

Recovery 97.2% ✓

SH

# RECOVERY DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent # 2**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

After Run 6 Before Run 7  
Start Time 16:23 End Time 16:31

## Recovery Gas to Probe, Time 16:23

Peak Areas, mv-sec			Average	ppm
13311	13711	14111	13711	7.98

## Recovery Gas to GC, Time 16:28

Peak Areas, mv-sec			Average	ppm
14746	14386	13597	14243	8.14

Recovery 98.0% ✓

RS

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent # 2**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

**Ambient Temperature: 72°C**

**Barometric Pressure: 29.60 in. Hg**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	461	458	299	233
Ret. Time, sec	25.0	35.0	63.0	132.0

**1 Flow = 42.9 mL/Min      10.8 ppm      10.7 ppm      6.97 ppm      5.43 ppm**

**Time: 06:01**

**Peak Areas, mv-sec**

23635	22744	10268	43754
23397	21865	10275	43943
23478	22059	10303	44074
<b>Average Area</b>	<b>23503</b>	<b>10282</b>	<b>43924</b>

**2 Flow = 80.0 mL/Min      5.77 ppm      5.73 ppm      3.73 ppm      2.91 ppm**

**Time: 07:13**

**Peak Areas, mv-sec**

8086	7277	3039	14674
7612	6821	2896	13428
7977	6961	2956	14718
<b>Average Area</b>	<b>7892</b>	<b>2964</b>	<b>14273</b>

**3 Flow = 133 mL/Min      3.46 ppm      3.44 ppm      2.24 ppm      1.74 ppm**

**Time: 07:30**

**Peak Areas, mv-sec**

2749	2295	1139	5166
2668	2461	1022	4984
2689	2285	1136	5151
<b>Average Area</b>	<b>2702</b>	<b>1099</b>	<b>5100</b>

# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3 2**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

H <sub>2</sub> S	1	2	3		
Time	06:01	07:13	07:30		
Concentration, ppm	10.8	5.77	3.46		
Area, mv-sec	23503	7892	2702		
Calc. Conc., ppm	10.6	5.97	3.40		
% Error	-1.5	3.5	-1.9 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9001	2.4228	0.9986	2	0.076

MeSH	1	2	3		
Time	06:01	07:13	07:30		
Concentration, ppm	10.7	5.73	3.44		
Area, mv-sec	22223	7020	2347		
Calc. Conc., ppm	10.6	5.89	3.38		
% Error	-1.3	2.9	-1.5 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9758	2.3243	0.9991	2	0.095

DMS	1	2	3		
Time	06:01	07:13	07:30		
Concentration, ppm	6.97	3.73	2.24		
Area, mv-sec	10282	2964	1099		
Calc. Conc., ppm	6.98	3.72	2.25		
% Error	0.2	-0.5	0.3 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9707	2.3484	>0.9999	2	0.091

DMDS	1	2	3		
Time	06:01	07:13	07:30		
Concentration, ppm	5.43	2.91	1.74		
Area, mv-sec	43924	14273	5100		
Calc. Conc., ppm	5.38	2.97	1.72		
% Error	-0.9	2.1	-1.2 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8936	3.2593	0.9995	2	0.027

# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent #2**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Ambient Temperature: 72°C      Barometric Pressure: 29.60 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	461	458	299	233
Ret. Time, sec	25.0	35.0	63.0	132.0

1 Flow = 44.4 mL/Min      10.4 ppm      10.3 ppm      6.72 ppm      5.23 ppm

Time: 16:34

Peak Areas, mv-sec

	23321	20338	9959	43670
	24380	21799	10647	46630
	25056	22227	10285	45442
<u>Average Area</u>	<b>24252</b>	<b>21454</b> ✓	<b>10297</b>	<b>45247</b>

2 Flow = 77.4 mL/Min      5.96 ppm      5.92 ppm      3.86 ppm      3.01 ppm

Time: 16:51

Peak Areas, mv-sec

	9796	7866	3569	17108
	9812	7920	3556	17604
	9831	7352	3254	15792
<u>Average Area</u>	<b>9813</b>	<b>7713</b>	<b>3460</b> ✓	<b>16834</b>

3 Flow = 130 mL/Min      3.56 ppm      3.53 ppm      2.30 ppm      1.79 ppm

Time: 17:05

Peak Areas, mv-sec

	3510	2899	1228	5869
	3467	2681	1272	6176
	3570	2800	1253	6307
<u>Average Area</u>	<b>3516</b>	<b>2793</b>	<b>1251</b>	<b>6117</b> ✓



# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 2**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

H <sub>2</sub> S	1	2	3		
Time	16:34	16:51	17:05		
Concentration, ppm	10.4	5.96	3.56		
Area, mv-sec	24252	9813	3516		
Calc. Conc., ppm	10.2	6.18	3.49		
% Error	-1.7	3.6	-1.8 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8007	2.5680	0.9984	2	0.055

MeSH	1	2	3		
Time	16:34	16:51	17:05		
Concentration, ppm	10.3	5.92	3.53		
Area, mv-sec	21454	7713	2793		
Calc. Conc., ppm	10.3	5.99	3.51		
% Error	-0.6	1.2	-0.6 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9025	2.4083	0.9998	2	0.078

DMS	1	2	3		
Time	16:34	16:51	17:05		
Concentration, ppm	6.72	3.86	2.30		
Area, mv-sec	10297	3460	1251		
Calc. Conc., ppm	6.72	3.86	2.30 ✓		
% Error	-0.0	0.1	-0.0		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9679	2.3846	>0.9999	2	0.087

DMDS	1	2	3		
Time	16:34	16:51	17:05		
Concentration, ppm	5.23	3.01	1.79		
Area, mv-sec	45247	16834	6117		
Calc. Conc., ppm	5.19	3.06	1.78		
% Error	-0.8	1.7	-0.9 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8669	3.3201	0.9996	2	0.024

# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, SC**

Project Number: **15730.001.008**

Source: **Paper Machine Vent # 2**

Method **16**

Operator: **VD**

Date: **23 Jun 2021**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Molecular Weight	34.08	48.11	62.14	94.20
Retention Time, sec	25.0	35.0	63.0	132.0
Peak Detection Window, sec	10.0	10.0	10.0	10.0
Minimum Peak Area, mv-sec	2	2	2	2
Minimum Peak Height, mv	1	1	1	1
Beginning Peak Width, sec	1.0	1.0	3.0	3.0
Ending Peak Width, sec	2.0	3.0	5.0	5.0
Permeation Device ID	T-51831	33-50536	89-50725	89-53405
Permeation Rate, ng/min	642 ✓	901 ✓	758 ✓	895 ✓
Permeation Rate, nL/min*	461	458	299	233

**Barometric Pressure:** 29.60 in. Hg      **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460 + T_a) / T_s] \times (P_s / P_b)$$

Where:

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**PR<sub>ng</sub>** = Permeation Rate by weight, ng/min

**V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole

**W<sub>mol</sub>** = Molecular Weight of compound

**T<sub>a</sub>** = Ambient Temperature, °F

**T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)

**P<sub>s</sub>** = Standard Pressure = 29.92 in Hg

**P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 642 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.60) \\ = 461 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

**C** = Concentration, ppmv

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**F<sub>d</sub>** = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3<sup>2</sup>**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

File: E:\6-24-21.trs  
Program Version: 2.0, built 15 May 2017 File Version: 2.0  
Computer: JWS-PROGRAMMING Trailer: 271

Analog Input Device: Keithley KUSB-3108 GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: GC-8A Serial No. C10494419420SA  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 100	Primary: 3'
Air	30	60	Detector: 120	Secondary:
Carrier	50	30		Sample Loop: 6" unlined

## Injection Cycle

Total Length: 180 sec Sampling Time: 160 sec Load/Backflush Time: 85 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 5 mv-sec Minimum peak height 5 mv above baseline

## Dynacalibrator

Chamber Temperature 130.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.60 in. Hg

# RUN DATA

Number 7

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine Vent 3/2**

Method **16**  
 Calibration **1**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
<b>Post test drift</b>									
17:22	13670	7.97	<2	<0.095	<2	<0.091	<2	<0.027	7.97
17:23	13643	7.96	<2	<0.095	<2	<0.091	<2	<0.027	7.96
17:25	13246	7.84	<2	<0.095	<2	<0.091	<2	<0.027	7.84
<b>Average</b>		<b>7.92</b>		<b>&lt;0.095</b>		<b>&lt;0.091</b>		<b>&lt;0.027</b>	<b>7.92</b> ✓

# RUN DATA

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 2**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM vent 2 Run 1</b>				
14:37:42	6760	20.2	-18	0.2
14:37:57	6760	20.2	-18	0.2
14:38:12	6759	20.2	-19	0.2
14:38:27	6762	20.2	-20	0.2
14:38:42	6761	20.2	-19	0.2
14:38:57	6759	20.2	-20	0.2
14:39:12	6760	20.2	-20	0.2
14:39:27	6760	20.2	-19	0.2
14:39:42	6758	20.2	-20	0.2
14:39:57	6761	20.2	-20	0.2
14:40:12	6760	20.2	-19	0.2
14:40:27	6759	20.2	-19	0.2
14:40:42	6759	20.2	-20	0.2
14:40:57	6760	20.2	-20	0.2
<b>Avg</b>	<b>6760</b>	<b>20.2</b>	<b>-19</b>	<b>0.2</b>

# RUN DATA

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 2**

Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
15:28:17	6773	20.2	-35	0.2
<b>PM Vent 2 Run 2</b>				
15:28:32	6773	20.2	-35	0.2
15:28:47	6774	20.2	-34	0.2
15:29:02	6774	20.2	-35	0.2
15:29:17	6773	20.2	-35	0.2
15:29:32	6775	20.2	-34	0.2
15:29:47	6774	20.2	-35	0.2
15:30:02	6774	20.2	-35	0.2
15:30:17	6774	20.2	-35	0.2
15:30:32	6773	20.2	-35	0.2
15:30:47	6775	20.2	-35	0.2
15:31:02	6774	20.2	-35	0.2
15:31:17	6774	20.2	-35	0.2
15:31:32	6775	20.2	-35	0.2
15:31:47	6775	20.2	-35	0.2
15:32:02	6775	20.2	-35	0.2
15:32:17	6775	20.2	-35	0.2
15:32:32	6775	20.2	-36	0.2
15:32:47	6773	20.2	-36	0.2
15:33:02	6773	20.2	-35	0.2
15:33:17	6775	20.2	-34	0.2
15:33:32	6774	20.2	-35	0.2
15:33:47	6773	20.2	-35	0.2
15:34:02	6774	20.2	-35	0.2
15:34:17	6773	20.2	-32	0.2
15:34:32	6768	20.2	-29	0.2
<b>Avg</b>	<b>6774</b>	<b>20.2</b>	<b>-35</b>	<b>0.2</b>

# RUN DATA

Number 6

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine vent 2**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM vent 2 Run 3</b>				
16:40:11	6779	20.2	-34	0.2
16:40:26	6778	20.2	-34	0.2
16:40:41	6778	20.2	-32	0.2
16:40:56	6776	20.2	-32	0.2
16:41:11	6777	20.2	-32	0.2
16:41:26	6778	20.2	-32	0.2
16:41:41	6777	20.2	-32	0.2
16:41:56	6777	20.2	-31	0.2
16:42:11	6777	20.2	-31	0.2
16:42:26	6778	20.2	-32	0.2
16:42:41	6778	20.2	-33	0.2
16:42:56	6779	20.2	-32	0.2
16:43:11	6778	20.2	-31	0.2
16:43:26	6780	20.2	-32	0.2
16:43:41	6778	20.2	-30	0.2
16:43:56	6777	20.2	-29	0.2
16:44:11	6777	20.2	-31	0.2
16:44:26	6777	20.2	-31	0.2
16:44:41	6777	20.2	-32	0.2
<b>Avg</b>	<b>6778</b>	<b>20.2</b>	<b>-32</b>	<b>0.2</b>



# CALIBRATION DATA

Number 1

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine vent 2**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

Start Time: 10:02

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	13
10.1 ✓	SG9168283BAL	3292
19.5 ✓	CC454190	6577

Curve Coefficients

Slope	Intercept	Corr. Coeff.
336.5 ✓	-26 ✓	0.9998 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	-68
10.2 ✓	SG9168283BAL	3027
20.4 ✓	CC454190	6279

Curve Coefficients

Slope	Intercept	Corr. Coeff.
311.1 ✓	-90 ✓	0.9999 ✓

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 2**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 10:02

**O<sub>2</sub>**

Method: EPA 3A  
Span Conc. 19.5 %

**Slope 336.5                      Intercept -25.8**

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	13	0.1	0.1	0.5 ✓	Pass
10.1	3292	9.9	-0.2	-1.0 ✓	Pass
19.5	6577	19.6	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.4 %

**Slope 311.1                      Intercept -90.1**

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-68	0.1	0.1	0.5 ✓	Pass
10.2	3027	10.0	-0.2	-1.0 ✓	Pass
20.4	6279	20.5	0.1	0.5 ✓	Pass

*✓*

# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 2**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

**File:** C:\Users\Trailer 271\Documents\New Indy\6-24-21.cem  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** DESKTOP-GQ0I9UV **Trailer:** 271  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>20.0</b>
Span Concentration, %	<b>19.5</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.4</b>



## VENT 3

New Indy  
Catawba, SC

15730.001.008  
No. 3 Hood Exhaust  
Paper Machine Vent 3

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
Date	6/24/21 ✓	6/24/21 ✓	6/24/21 ✓	---
Time Began	937 ✓	1042 ✓	1145 ✓	---
Time Ended	1037 ✓	1142 ✓	1245 ✓	---
Volumetric Flow Rate, (Qs), DSCFM	5.45E+04 ✓	5.30E+04 ✓	5.51E+04 ✓	5.42E+04
BWS	0.210 ✓	0.214 ✓	0.196 ✓	0.207
% Oxygen	20.2 ✓	20.2 ✓	20.2 ✓	20.2
<hr/>				
<b>Total Reduced Sulfur</b> (TRS MW)= 34.08				
Concentration, ppm	0.81 ✓	0.69 ✓	0.73 ✓	0.74
Emission Rate, lb/hr	0.23	0.19	0.21	0.21

*AM*

New Indy  
Catawba, SC

15730.001.008  
No. 3 Hood Exhaust

### Paper Machine Vent 3

#### ISOKINETIC CALCULATIONS

Run Number	1	2	3	Mean
Date	6/24/21 ✓	6/24/21 ✓	6/24/21 ✓	---
Time Began	937 ✓	1042 ✓	1145 ✓	---
Time Ended	1029 ✓	1136 ✓	1236 ✓	---

#### INPUT DATA

Sampling Time, min	(Theta)	48.0 ✓	48 ✓	48 ✓	48
Stack Diameter, in.	(Dia.)	55.88 ✓	55.88 ✓	55.88 ✓	55.88
Barometric Pressure, in. Hg	(Pb)	29.70 ✓	29.70 ✓	29.70 ✓	29.70
Static Pressure, in. H2O	(Pg)	-1.00 ✓	-1.00 ✓	-1.00 ✓	-1.00
Pitot Tube Coefficient	(Cp)	0.84 ✓	0.84 ✓	0.84 ✓	0.84
Meter Correction Factor	(Y)	1.0030 ✓	1.0030 ✓	1.0030 ✓	1.0030
Orifice Calibration Value	(Delta H@)	1.8000 ✓	1.8000 ✓	1.8000 ✓	1.8000
Nozzle Diameter, in.	(Dn)	0.250 ✓	0.250 ✓	0.250 ✓	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	30.544 ✓	30.347 ✓	30.732 ✓	30.541
Meter Temperature, °F	(Tm)	76.5 ✓	81.6 ✓	87.1 ✓	81.7
Meter Temperature, °R	(Tm-R)	536.5	541.6	547.1	541.7
Meter Orifice Pressure, in. H2O	(Delta H)	1.300 ✓	1.300 ✓	1.300 ✓	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> )avg	1.140 ✓	1.140 ✓	1.140 ✓	1.140
Volume H2O Collected, mL	(Vlc)	170.0 ✓	170.6 ✓	153.2 ✓	164.6
CO2 Concentration, %	(CO2)	0.2 ✓	0.2 ✓	0.2 ✓	0.2
O2 Concentration, %	(O2)	20.2 ✓	20.2 ✓	20.2 ✓	20.2
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> )avg	1.282 ✓	1.254 ✓	1.273 ✓	1.270
Stack Temperature, °F	(Ts)	185.0 ✓	186.8 ✓	182.1 ✓	184.6
Stack Temperature, °R	(Ts-R)	645.0	646.8	642.1	644.6
Moisture Fraction (at Saturation)	(BWS)	0.576 ✓	0.599 ✓	0.541 ✓	0.572

#### CALCULATED DATA

Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	17.03 ✓	17.03 ✓	17.03 ✓	17.03
Stack Pressure, in. Hg	(Ps)	29.63	29.63	29.63	29.63
Meter Pressure, in. Hg	(Pm)	29.80	29.80	29.80	29.80
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	30.013	29.539	29.613	29.721
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	8.002	8.030	7.211	7.748
Moisture Fraction (Measured)	(BWS)	0.210	0.214	0.196	0.207
Moisture Fraction (lower sat/meas)	(BWS)	0.210	0.214	0.196	0.207
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	28.84	28.84	28.84	28.84
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	26.56	26.52	26.72	26.60
Average Stack Gas Velocity, ft/sec	(Vs)	83.37	81.68	82.34	82.46
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	85180	83452	84121	84251
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	54489	53016	55059	54188
Calibration check	(Yqa)	1.0150	1.0264	1.0187	1.020
Percent difference from Y					1.70%

*Handwritten signature*



No. 3 Hood Exhaust

Isokinetic Field Data

Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 3 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 1  
 Date: 6/24/21  
 Test Personnel: JEM/BB  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.500  
 Probe ID/Length: PR-66 6'  
 Liner Material: 65  
 Pitot ID/Coeff.: P77 0.84  
 Thermo ID: A023  
 Nozzle ID/Diams.: .250 in.

Ambient Temp.: 68 °F  
 Baro. Pressure\*: 29.70 in. Hg  
 Static Pressure: -1.0 in. H<sub>2</sub>O  
 Impinger Gain: 104.8 mL  
 Silica Gel Gain: 5.5 g

Stack Area: 17.03 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A

Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	0.006	0.020
Pitot	13"	6"
	Good	Good

Filter ID: N/A  
 Sample ID: R-1

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	-DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
0		0937			544.900									
A-1	3		1.8	1.3	546.8	186	N/A	76	253	248	N/A	64	3	
2	6		2.0	1.3	548.7	186		75	256	246		51	3	
3	9		2.0	1.3	550.7	186		75	255	245		47	3	
4	12		2.0	1.3	552.5	186		75	252	246		48	3	
5	15		1.4	1.3	559.4	186		75	252	246		49	3	
6	18		1.2	1.3	556.398	186		76	251	247		51	3	
7	21		1.3	1.3	558.299	185		76	256	245		52	3	
8	24		1.2	1.3	560.2	185		76	254	249		53	3	
B-1	27		1.7	1.3	562.1	180		77	252	246		57	3	
2	30		1.7	1.3	564.1	186		77	249	245		55	3	
3	33		1.9	1.3	566.0	186		77	249	244		54	3	
4	36		1.8	1.3	567.9	186		77	250	245		54	3	
5	39		1.8	1.3	569.9	186		78	252	246		55	3	
6	42		1.8	1.3	571.9	185		78	254	244		54	3	
7	45		1.5	1.3	573.5	185		78	251	247		56	3	
8	48	10:29	1.4	1.3	575.444	184		78	249	246		56	3	
*Barometric Pressure is at port elevation			Avg √Δp	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>	O <sub>2</sub> /CO <sub>2</sub> by Orsat Fyrite M3A		Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-sd</sub> scf
			1.2823	1.3000	30.544	185	76.5	249/256	244/249	64	64	64	3	
			1.636	1.1402										



Integrated Air Services

Flue Gas Composition  
 Oxygen, %  
 Carbon Dioxide, %  
 Moisture, %

Thermocouple Check  
 Meter Temp., °F  
 Ref. Temp., °F  
 Result

Leak Check, Pre-run  
 Post-run

15730.001.008  
 Paper Machine, #1-2 CDE  
 Emission Report

JEM



No. 3 Hood Exhaust

**Isokinetic Field Data**

**Method: EPA 4, Moisture**

Client New Indy Console ID A223 Ambient Temp. 73 °F  
 Location/Plant Catawba, SC Meter Corr., Y 1.003 Baro. Pressure\* 29.70 in. Hg  
 Source No. 3 Hood Exhaust Console ΔH@ 1.600 Static Pressure -1.0 in. H<sub>2</sub>O  
 Sample Location Roost Probe ID/Length PABC-6' Impinger Gain 163.4 mL  
 W. O. Number 15730.001.008 Liner Material SS Silica Gel Gain 7.2 g  
 Run Number 2 Pitot ID/Coeff. P77 Thermo ID A223 Stack Area 17.03 ft<sup>2</sup>  
 Date 4/24/21 Thermo ID A223 Stack Area 17.03 ft<sup>2</sup>  
 Test Personnel BEARBE Nozzle ID/Diams. .250 in. Total Traverse Points 16  
 Sample Time 48 min. Avg. Nozzle Diam. .250 in. Total Traverse Points 16

K Factor N/A  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	0.054	1.002
Pitot	Good	Good

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
A-1	3		1.6	1.3	576.747	186	N/A	80	250	239	58NA	58	3	
2	6		1.8	1.3	578.7	188		80	251	243		57	3	
3	9		1.9	1.3	580.5	188		80	256	242		56	3	
4	12		1.9	1.3	582.4	188		81	251	243		56	3	
5	15		1.7	1.3	584.2	188		81	261	244		56	3	
6	18		1.6	1.3	586.1	189		81	251	242		56	3	
7	21		1.6	1.3	588.1	189		81	252	244		57	3	
8	24		1.6	1.3	590.0	189		82	252	242		57	3	
B-1	27		1.8	1.3	591.9	189		82	250	239		59	3	
2	30		2.0	1.3	593.9	186		82	249	241		58	3	
3	33		2.0	1.3	595.8	189		82	253	244		59	3	
4	36		2.0	1.3	597.6	187		82	252	242		60	3	
5	39		1.1	1.3	599.5	185		81	253	241		62	3	
6	42		1.2	1.3	601.3	185		83	254	241		64	3	
7	45		1.3	1.3	603.2	185		84	253	240		62	3	
8	48	14:36	1.2	1.3	605.1	184		84	253	243		57	3	
8	48	14:36	1.2	1.3	607.094	179		84	253	243		64	3	
*Barometric Pressure is at port elevation					Total Volume	Avg T <sub>m</sub>	Avg T <sub>s</sub>	Avg T <sub>o</sub>	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub> scf
					30.347	186.8	186.8	249/250	239/244	239/244	64	3		

Flue Gas Composition: Oxygen, % 1.587 ✓ Carbon Dioxide, % 1.1402 ✓ Moisture, % 1.1402 ✓  
 O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A 81.6 ✓  
 Leak Check, Pre-run 81.6 ✓ Post-run 81.6 ✓  
 Thermocouple Check: Meter Temp., °F 64 % Isokinetic 64  
 Ref. Temp., °F 64 Calculated by 64 QC by 64



Integrated Air Services



start DGM: 607.665

# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 3 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/24/21  
 Test Personnel: BEA/DE  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PRLC-6'  
 Liner Material: SS  
 Pitot ID/Coeff.: P77  
 Thermo ID: A023  
 Nozzle ID/Diams.: 1.250 in.  
 Avg. Nozzle Diam.: 1.250 in.

Ambient Temp.: 75 °F  
 Baro. Pressure\*: 29.70 in. Hg  
 Static Pressure: -1.0 in. H<sub>2</sub>O  
 Impinger Gain: 146.8 mL  
 Silica Gel Gain: 6.4 g

K Factor: N/A  
 Leak Checks: Good 1000

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	.003	.000
Pitot	12"	6"


Filter ID: N/A  
 Sample ID: RA-3

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP. (°F)	DGM INLET TEMP. (°F)	DGM OUTLET TEMP. (°F)	PROBE TEMP. (°F)	FILTER BOX TEMP. (°F)	FILTER EXIT TEMP. (°F)	IMPINGER EXIT TEMP. (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
A-1	0	11:45			607.633	180	N/A	85	250	209	N/A	60	3	
2	3		1.6	1.3	609.9	183		85	249	242		56	2	
3	6		1.8	1.3	613.6	183		85	250	247		54	2	
4	9		1.9	1.3	615.5	183		86	249	246		53	2	
5	12		1.8	1.3	617.4	183		86	253	247		54	2	
6	15		1.6	1.3	619.3	183		86	252	244		55	2	
7	18		1.6	1.3	621.2	183		87	251	243		55	2	
8	21		1.5	1.3	623.1	182		88	251	244		54	2	
B-1	24		1.7	1.3	625.0	179		88	249	245		57	2	
2	27		1.7	1.3	626.9	183		88	252	245		54	2	
3	30		1.9	1.3	628.8	183		88	252	248		54	2	
4	33		1.9	1.3	630.7	183		89	254	245		55	2	
5	36		1.8	1.3	632.5	183		89	254	249		56	2	
6	39		1.2	1.3	634.5	182		89	250	247		57	2	
7	42		1.2	1.3	636.4	183		89	253	244		57	2	
8	45		1.1	1.3	638.3	177		90	254	244		58	2	
8	48	12:26			607.633	182.1	87.1	249	244	244		60	3	
*Barometric Pressure is at port elevation			Avg v <sub>sp</sub>	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>o</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub> scf
			1.2730	1.300	20.732	182.1	87.1	249/254	244/244	209/249	244/244	60	3	

Flue Gas Composition  
 Oxygen, %  
 Carbon Dioxide, %  
 Moisture, %

Thermocouple Check  
 Meter Temp., °F  
 Ref. Temp., °F  
 Result

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run  
 Post-run



Integrated Air Services



# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 3 Hood Exhaust  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/24/21 Recovery Date 6/24/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp. Total	Silica Gel grams	Total
	1	2	3			
Final	653.6	821.4	642.9		875.4	
Initial	726.0	789.5	637.9		869.9	
Gain	127.6 ✓	31.9 ✓	5 ✓	164.5 ✓	5.5 ✓	170.0

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 2 Sample Date 6/24/21 Recovery Date 6/24/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp. Total	Silica Gel grams	Total
	1	2	3			
Final	909.6	668.0	556.8		916.6	
Initial	767.3	649.7	554.0		909.4	
Gain	142.3 ✓	18.3 ✓	2.8 ✓	163.4 ✓	7.2 ✓	170.6

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 3 Sample Date 6/24/21 Recovery Date 6/24/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp. Total	Silica Gel grams	Total
	1	2	3			
Final	880.1	841.3	645		866.1	
Initial	754.1	822.2	643.3		859.7	
Gain	126 ✓	19.1 ✓	1.7 ✓	146.8 ✓	6.4 ✓	153.2

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Check COC for Sample IDs of Media Blanks

②

# Sample and Velocity Traverse Point Data Sheet - Method 1

15730.001.008  
 Paper, #3 Paper Machine,  
 #2-3 SDTVs, & #1-2 CBs  
 Emission Report

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 3 Hood Exhaust

Operator VD / LF  
 Date 15-Jun-21  
 W.O. Number 15730.001.008

**Duct Type**  Circular  Rectangular Duct Indicate appropriate type  
**Traverse Type**  Particulate Traverse  Velocity Traverse


Distance from far wall to outside of port (in.) = C	56.000
Port Depth (in.) = D	0.125
Depth of Duct, diameter (in.) = C-D	55.875
Area of Duct (ft <sup>2</sup> )	17.03
Total Traverse Points	16
Total Traverse Points per Port	8

**Rectangular Ducts Only**

Width of Duct, rectangular duct only (in.)	
Total Ports (rectangular duct only)	

Traverse Point Locations			
Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	3.2	2	2
2	10.5	6	6
3	19.4	11	11
4	32.3	18	18
5	67.7	38	38
6	80.6	45	45
7	89.5	50	50
8	96.8	54	54
9			
10			
11			
12			

Flow Disturbances	
Upstream - A (ft)	7.000
Downstream - B (ft)	25.0
Upstream - A (duct diameters)	1.50
Downstream - B (duct diameters)	5.37



Equivalent Diameter =  $(2 * L * W) / (L + W)$

Traverse Point Location Percent of Stack - Circular												
Number of Traverse Points												
	1	2	3	4	5	6	7	8	9	10	11	12
T	1	14.6		6.7	4.4	3.2		2.6		2.1		
r	2	85.4		25	14.6	10.5		8.2		6.7		
a	3		75	29.6	19.4	14.6		11.8				
v	4			93.3	70.4	32.3		22.6		17.7		
e	5				85.4	67.7		34.2		25		
r	6					95.6		80.6		65.8		35.6
s	7							89.5		77.4		64.4
s	8									96.8		85.4
a	9											91.8
e	10											97.4
i	11											93.3
n	12											97.9


Traverse Point Location Percent of Stack - Rectangular												
Number of Traverse Points												
	1	2	3	4	5	6	7	8	9	10	11	12
T	1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
r	2	75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
a	3		83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
v	4			87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
e	5				90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
r	6					91.7	78.6	68.8	61.1	55.0	50.0	45.8
s	7						92.9	81.3	72.2	65.0	59.1	54.2
a	8							93.8	83.3	75.0	68.2	62.5
e	9								94.4	85.0	77.3	70.8
i	10									95.0	86.4	79.2
n	11										95.5	87.5
t	12											95.8

Rectangular Stack Points & Matrix  
 9 - 3 x 3  
 12 - 4 x 3  
 16 - 4 x 4  
 20 - 5 x 4  
 25 - 5 x 5  
 30 - 6 x 5  
 36 - 6 x 6  
 42 - 7 x 6  
 49 - 7 x 7

Port Diam. (in) = 4  
 Number of Ports = 2

Tape Measure I.D. # JM-07





**NOTES:**

1. ALL DIMENSIONS UNLESS OTHERWISE NOTED.

2. ALL DIMENSIONS TO FACE UNLESS NOTED OTHERWISE.

3. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

4. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

5. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

6. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

7. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

8. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

9. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

10. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

**LEGEND:**

1. ALL DIMENSIONS UNLESS OTHERWISE NOTED.

2. ALL DIMENSIONS TO FACE UNLESS NOTED OTHERWISE.

3. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

4. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

5. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

6. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

7. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

8. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

9. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

10. ALL DIMENSIONS TO CENTERLINE UNLESS NOTED OTHERWISE.

**PROJECT INFORMATION:** 2023.2 - Project Columbia

**DATE:** 4/27/2020 *Shawky, Sadek*

**PROJECT:** PULP DRYER, #3 PAPER MACHINE, #2-3 SDTVs, & #1-2 CBs

**CLIENT:** [Redacted]

**DESIGNER:** [Redacted]

**CHECKER:** [Redacted]

**APPROVER:** [Redacted]

**SCALE:** AS SHOWN

**PROJECT NO.:** 19-168-151

**ENERGUIN AIR INC.**  
 ISSUED CERTIFIED EQUIPMENT TAGS  
 10000 W. 100th Ave., Suite 100  
 Denver, CO 80231  
 Phone: 303.440.1111  
 Email: info@energuin.com

**ENERGUIN AIR INC.**  
 ISSUED CERTIFIED EQUIPMENT TAGS  
 10000 W. 100th Ave., Suite 100  
 Denver, CO 80231  
 Phone: 303.440.1111  
 Email: info@energuin.com

**ENERGUIN AIR INC.**  
 ISSUED CERTIFIED EQUIPMENT TAGS  
 10000 W. 100th Ave., Suite 100  
 Denver, CO 80231  
 Phone: 303.440.1111  
 Email: info@energuin.com

**ENERGUIN AIR INC.**  
 ISSUED CERTIFIED EQUIPMENT TAGS  
 10000 W. 100th Ave., Suite 100  
 Denver, CO 80231  
 Phone: 303.440.1111  
 Email: info@energuin.com

**ENERGUIN AIR INC.**  
 ISSUED CERTIFIED EQUIPMENT TAGS  
 10000 W. 100th Ave., Suite 100  
 Denver, CO 80231  
 Phone: 303.440.1111  
 Email: info@energuin.com

**RECEIVED Reference# 218002**  
 By Vendor: [Redacted] at 10:28 AM, Apr 29, 2020

NO.	DATE	BY	REVISION
1	11-14	1	ISSUE FOR CONSTRUCTION
2	11-14	1	ISSUE FOR CONSTRUCTION
3	11-14	1	ISSUE FOR CONSTRUCTION
4	11-14	1	ISSUE FOR CONSTRUCTION
5	11-14	1	ISSUE FOR CONSTRUCTION
6	11-14	1	ISSUE FOR CONSTRUCTION
7	11-14	1	ISSUE FOR CONSTRUCTION
8	11-14	1	ISSUE FOR CONSTRUCTION
9	11-14	1	ISSUE FOR CONSTRUCTION
10	11-14	1	ISSUE FOR CONSTRUCTION

NO.	DATE	BY	REVISION
1	11-14	1	ISSUE FOR CONSTRUCTION
2	11-14	1	ISSUE FOR CONSTRUCTION
3	11-14	1	ISSUE FOR CONSTRUCTION
4	11-14	1	ISSUE FOR CONSTRUCTION
5	11-14	1	ISSUE FOR CONSTRUCTION
6	11-14	1	ISSUE FOR CONSTRUCTION
7	11-14	1	ISSUE FOR CONSTRUCTION
8	11-14	1	ISSUE FOR CONSTRUCTION
9	11-14	1	ISSUE FOR CONSTRUCTION
10	11-14	1	ISSUE FOR CONSTRUCTION

NO.	DATE	BY	REVISION
1	11-14	1	ISSUE FOR CONSTRUCTION
2	11-14	1	ISSUE FOR CONSTRUCTION
3	11-14	1	ISSUE FOR CONSTRUCTION
4	11-14	1	ISSUE FOR CONSTRUCTION
5	11-14	1	ISSUE FOR CONSTRUCTION
6	11-14	1	ISSUE FOR CONSTRUCTION
7	11-14	1	ISSUE FOR CONSTRUCTION
8	11-14	1	ISSUE FOR CONSTRUCTION
9	11-14	1	ISSUE FOR CONSTRUCTION
10	11-14	1	ISSUE FOR CONSTRUCTION

NO.	DATE	BY	REVISION
1	11-14	1	ISSUE FOR CONSTRUCTION
2	11-14	1	ISSUE FOR CONSTRUCTION
3	11-14	1	ISSUE FOR CONSTRUCTION
4	11-14	1	ISSUE FOR CONSTRUCTION
5	11-14	1	ISSUE FOR CONSTRUCTION
6	11-14	1	ISSUE FOR CONSTRUCTION
7	11-14	1	ISSUE FOR CONSTRUCTION
8	11-14	1	ISSUE FOR CONSTRUCTION
9	11-14	1	ISSUE FOR CONSTRUCTION
10	11-14	1	ISSUE FOR CONSTRUCTION

NO.	DATE	BY	REVISION
1	11-14	1	ISSUE FOR CONSTRUCTION
2	11-14	1	ISSUE FOR CONSTRUCTION
3	11-14	1	ISSUE FOR CONSTRUCTION
4	11-14	1	ISSUE FOR CONSTRUCTION
5	11-14	1	ISSUE FOR CONSTRUCTION
6	11-14	1	ISSUE FOR CONSTRUCTION
7	11-14	1	ISSUE FOR CONSTRUCTION
8	11-14	1	ISSUE FOR CONSTRUCTION
9	11-14	1	ISSUE FOR CONSTRUCTION
10	11-14	1	ISSUE FOR CONSTRUCTION

NO.	DATE	BY	REVISION
1	11-14	1	ISSUE FOR CONSTRUCTION
2	11-14	1	ISSUE FOR CONSTRUCTION
3	11-14	1	ISSUE FOR CONSTRUCTION
4	11-14	1	ISSUE FOR CONSTRUCTION
5	11-14	1	ISSUE FOR CONSTRUCTION
6	11-14	1	ISSUE FOR CONSTRUCTION
7	11-14	1	ISSUE FOR CONSTRUCTION
8	11-14	1	ISSUE FOR CONSTRUCTION
9	11-14	1	ISSUE FOR CONSTRUCTION
10	11-14	1	ISSUE FOR CONSTRUCTION

NO.	DATE	BY	REVISION
1	11-14	1	ISSUE FOR CONSTRUCTION
2	11-14	1	ISSUE FOR CONSTRUCTION
3	11-14	1	ISSUE FOR CONSTRUCTION
4	11-14	1	ISSUE FOR CONSTRUCTION
5	11-14	1	ISSUE FOR CONSTRUCTION
6	11-14	1	ISSUE FOR CONSTRUCTION
7	11-14	1	ISSUE FOR CONSTRUCTION
8	11-14	1	ISSUE FOR CONSTRUCTION
9	11-14	1	ISSUE FOR CONSTRUCTION
10	11-14	1	ISSUE FOR CONSTRUCTION

NO.	DATE	BY	REVISION
1	11-14	1	ISSUE FOR CONSTRUCTION
2	11-14	1	ISSUE FOR CONSTRUCTION
3	11-14	1	ISSUE FOR CONSTRUCTION
4	11-14	1	ISSUE FOR CONSTRUCTION
5	11-14	1	ISSUE FOR CONSTRUCTION
6	11-14	1	ISSUE FOR CONSTRUCTION
7	11-14	1	ISSUE FOR CONSTRUCTION
8	11-14	1	ISSUE FOR CONSTRUCTION
9	11-14	1	ISSUE FOR CONSTRUCTION
10	11-14	1	ISSUE FOR CONSTRUCTION

NO.	DATE	BY	REVISION
1	11-14	1	ISSUE FOR CONSTRUCTION
2	11-14	1	ISSUE FOR CONSTRUCTION
3	11-14	1	ISSUE FOR CONSTRUCTION
4	11-14	1	ISSUE FOR CONSTRUCTION
5	11-14	1	ISSUE FOR CONSTRUCTION
6	11-14	1	ISSUE FOR CONSTRUCTION
7	11-14	1	ISSUE FOR CONSTRUCTION
8	11-14	1	ISSUE FOR CONSTRUCTION
9	11-14	1	ISSUE FOR CONSTRUCTION
10	11-14	1	ISSUE FOR CONSTRUCTION

NO.	DATE	BY	REVISION
1	11-14	1	ISSUE FOR CONSTRUCTION
2	11-14	1	ISSUE FOR CONSTRUCTION
3	11-14	1	ISSUE FOR CONSTRUCTION
4	11-14	1	ISSUE FOR CONSTRUCTION
5	11-14	1	ISSUE FOR CONSTRUCTION
6	11-14	1	ISSUE FOR CONSTRUCTION
7	11-14	1	ISSUE FOR CONSTRUCTION
8	11-14	1	ISSUE FOR CONSTRUCTION
9	11-14	1	ISSUE FOR CONSTRUCTION
10	11-14	1	ISSUE FOR CONSTRUCTION

NO.	DATE	BY	REVISION
1	11-14	1	ISSUE FOR CONSTRUCTION
2	11-14	1	ISSUE FOR CONSTRUCTION
3	11-14	1	ISSUE FOR CONSTRUCTION
4	11-14	1	ISSUE FOR CONSTRUCTION
5	11-14	1	ISSUE FOR CONSTRUCTION
6	11-14	1	ISSUE FOR CONSTRUCTION
7	11-14	1	ISSUE FOR CONSTRUCTION
8	11-14	1	ISSUE FOR CONSTRUCTION
9	11-14	1	ISSUE FOR CONSTRUCTION
10	11-14	1	ISSUE FOR CONSTRUCTION

# RUN SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

**Start Time 09:37    End Time 10:37**

---

**Average Measured TRS Conc.**    0.79 ppm  
**Recovery No. 2**    97.2 %  
**TRS Corrected for Recovery**    0.81 ppm ✓

*✓ JKH*



# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

Start Time 10:42    End Time 11:42

---

Average Measured TRS Conc.    0.67 ppm  
Recovery No. 2    97.2 %  
TRS Corrected for Recovery    0.69 ppm ✓

*✓*



# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

**Start Time 11:45    End Time 12:45**

---

**Average Measured TRS Conc.    0.71 ppm**  
**Recovery No. 2    97.2 %**  
**TRS Corrected for Recovery    0.73 ppm ✓**

*JWH*

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
09:37	61	0.46	<2	<0.095	<2	<0.091	<2	<0.027	0.46
09:40	19	0.25	<2	<0.095	<2	<0.091	<2	<0.027	0.25
09:43	47	0.40	30	0.37	<2	<0.091	<2	<0.027	0.78
09:46	11	0.19	<2	<0.095	<2	<0.091	<2	<0.027	0.19
09:49	40	0.37	<2	<0.095	<2	<0.091	10	0.06	0.50
09:52	7	0.15	22	0.32	<2	<0.091	75	0.19	0.84
09:55	23	0.28	11	0.22	17	0.27	46	0.14	1.06
09:58	113	0.64	<2	<0.095	<2	<0.091	47	0.15	0.93
10:01	20	0.26	<2	<0.095	<2	<0.091	91	0.21	0.67
10:04	<2	<0.076	34	0.40	<2	<0.091	38	0.13	0.66
10:07	49	0.41	18	0.29	<2	<0.091	143	0.26	1.22
10:10	24	0.29	8	0.19	27	0.34	143	0.26	1.34
10:13	<2	<0.076	<2	<0.095	6	0.15	109	0.23	0.61
10:16	46	0.40	5	0.15	<2	<0.091	<2	<0.027	0.55
10:19	31	0.32	30	0.37	87	0.62	<2	<0.027	1.31
10:22	133	0.70	38	0.42	<2	<0.091	<2	<0.027	1.11
10:25	8	0.16	33	0.39	<2	<0.091	52	0.15	0.85
10:28	<2	<0.076	10	0.22	13	0.23	26	0.11	0.66
10:31	<2	<0.076	10	0.21	13	0.24	47	0.15	0.73
10:34	9	0.17	13	0.24	96	0.65	<2	<0.027	1.06
<b>Average</b>		<b>0.27</b>		<b>0.19</b>		<b>0.13</b>		<b>0.10</b>	<b>0.79</b>

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
10:42	52	0.43	25	0.34	<2	<0.091	<2	<0.027	0.77
10:45	44	0.39	63	0.54	<2	<0.091	<2	<0.027	0.93
10:48	12	0.20	<2	<0.095	5	0.15	<2	<0.027	0.35
10:51	21	0.26	<2	<0.095	<2	<0.091	<2	<0.027	0.26
10:54	18	0.25	<2	<0.095	<2	<0.091	<2	<0.027	0.25
10:57	81	0.54	15	0.26	10	0.20	<2	<0.027	1.00
11:00	14	0.21	46	0.46	22	0.31	<2	<0.027	0.99
11:03	<2	<0.076	<2	<0.095	<2	<0.091	<2	<0.027	-
11:06	13	0.20	36	0.41	33	0.38	<2	<0.027	0.99
11:09	<2	<0.076	<2	<0.095	<2	<0.091	<2	<0.027	-
11:12	139	0.71	17	0.28	<2	<0.091	<2	<0.027	0.99
11:15	6	0.13	<2	<0.095	38	0.41	<2	<0.027	0.54
11:18	22	0.27	6	0.17	<2	<0.091	<2	<0.027	0.44
11:21	30	0.32	24	0.33	<2	<0.091	<2	<0.027	0.65
11:24	55	0.44	10	0.21	57	0.50	<2	<0.027	1.15
11:27	<2	<0.076	19	0.29	<2	<0.091	<2	<0.027	0.29
11:30	12	0.20	15	0.26	102	0.67	<2	<0.027	1.14
11:33	22	0.27	7	0.18	12	0.23	<2	<0.027	0.69
11:36	37	0.36	40	0.43	88	0.62	41	0.14	1.68
11:39	14	0.21	<2	<0.095	8	0.18	<2	<0.027	0.39
<b>Average</b>		<b>0.27</b>		<b>0.21</b>		<b>0.18</b>		<b>&lt;0.027</b>	<b>0.67</b>

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
11:45	<2	<0.076	7	0.18	20	0.30	16	0.08	0.64
11:48	<2	<0.076	21	0.31	20	0.30	67	0.17	0.96
11:51	25	0.29	<2	<0.095	8	0.18	<2	<0.027	0.47
11:54	24	0.28	<2	<0.095	<2	<0.091	<2	<0.027	0.28
11:57	6	0.14	10	0.22	<2	<0.091	<2	<0.027	0.36
12:00	128	0.68	<2	<0.095	<2	<0.091	<2	<0.027	0.68
12:03	53	0.43	37	0.42	<2	<0.091	<2	<0.027	0.85
12:06	42	0.38	10	0.21	7	0.17	101	0.22	1.19
12:09	52	0.43	20	0.30	<2	<0.091	<2	<0.027	0.73
12:12	77	0.52	<2	<0.095	23	0.32	<2	<0.027	0.84
12:15	18	0.24	14	0.26	<2	<0.091	<2	<0.027	0.50
12:18	12	0.20	<2	<0.095	<2	<0.091	<2	<0.027	0.20
12:21	6	0.14	<2	<0.095	<2	<0.091	<2	<0.027	0.14
12:24	18	0.24	<2	<0.095	<2	<0.091	106	0.22	0.69
12:27	20	0.26	<2	<0.095	38	0.41	47	0.15	0.96
12:30	29	0.31	56	0.51	<2	<0.091	<2	<0.027	0.82
12:33	27	0.30	27	0.35	<2	<0.091	<2	<0.027	0.66
12:36	30	0.32	37	0.41	37	0.40	<2	<0.027	1.13
12:39	59	0.45	<2	<0.095	52	0.48	61	0.17	1.27
12:42	38	0.36	35	0.40	<2	<0.091	<2	<0.027	0.77
<b>Average</b>		<b>0.30</b>		<b>0.18</b>		<b>0.13</b>		<b>0.05</b>	<b>0.71</b>

# RECOVERY DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

## Before Run 1

Start Time 07:42    End Time 07:59

---

### Recovery Gas to Probe, Time 07:42

Peak Areas, mv-sec			Average	ppm
12673	11981	12277	12311	7.54

---

### Recovery Gas to GC, Time 07:54

Peak Areas, mv-sec			Average	ppm
13351	13392	13952	13565	7.94

---

Recovery 95.0%

---

*VD*

# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

After Run 3    Before Run 4  
Start Time 12:45    End Time 12:55

---

Recovery Gas to Probe, Time 12:45

Peak Areas, mv-sec			Average	ppm
12908	13446	13416	13257	7.84

---

Recovery Gas to GC, Time 12:51

Peak Areas, mv-sec			Average	ppm
13746	14196	14064	14002	8.07

---

Recovery 97.2%

---

*1/20/21*

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

**Ambient Temperature: 72°C**

**Barometric Pressure: 29.60 in. Hg**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	461	458	299	233
Ret. Time, sec	25.0	35.0	63.0	132.0

**1 Flow = 42.9 mL/Min      10.8 ppm      10.7 ppm      6.97 ppm      5.43 ppm**

**Time: 06:01**

**Peak Areas, mv-sec**

23635	22744	10268	43754
23397	21865	10275	43943
23478	22059	10303	44074
<b>Average Area</b>	<b>23503</b>	<b>10282</b>	<b>43924</b>

**2 Flow = 80.0 mL/Min      5.77 ppm      5.73 ppm      3.73 ppm      2.91 ppm**

**Time: 07:13**

**Peak Areas, mv-sec**

8086	7277	3039	14674
7612	6821	2896	13428
7977	6961	2956	14718
<b>Average Area</b>	<b>7892</b>	<b>2964</b>	<b>14273</b>

**3 Flow = 133 mL/Min      3.46 ppm      3.44 ppm      2.24 ppm      1.74 ppm**

**Time: 07:30**

**Peak Areas, mv-sec**

2749	2295	1139	5166
2668	2461	1022	4984
2689	2285	1136	5151
<b>Average Area</b>	<b>2702</b>	<b>1099</b>	<b>5100</b>

*VD*



# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

H <sub>2</sub> S	1	2	3		
Time	06:01	07:13	07:30		
Concentration, ppm	10.8	5.77	3.46		
Area, mv-sec	23503	7892	2702		
Calc. Conc., ppm	10.6	5.97	3.40		
% Error	-1.5	3.5	-1.9 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9001	2.4228	0.9986	2	0.076

MeSH	1	2	3		
Time	06:01	07:13	07:30		
Concentration, ppm	10.7	5.73	3.44		
Area, mv-sec	22223	7020	2347		
Calc. Conc., ppm	10.6	5.89	3.38		
% Error	-1.3	2.9	-1.5 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9758	2.3243	0.9991	2	0.095

DMS	1	2	3		
Time	06:01	07:13	07:30		
Concentration, ppm	6.97	3.73	2.24		
Area, mv-sec	10282	2964	1099		
Calc. Conc., ppm	6.98	3.72	2.25		
% Error	0.2	-0.5	0.3 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9707	2.3484	>0.9999	2	0.091

DMDS	1	2	3		
Time	06:01	07:13	07:30		
Concentration, ppm	5.43	2.91	1.74		
Area, mv-sec	43924	14273	5100		
Calc. Conc., ppm	5.38	2.97	1.72		
% Error	-0.9	2.1	-1.2 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8936	3.2593	0.9995	2	0.027

✓ JH

# CALIBRATION DATA

Number 2

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine Vent 3**

Method **16**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

**Ambient Temperature: 72°C**

**Barometric Pressure: 29.60 in. Hg**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	461	458	299	233
Ret. Time, sec	25.0	35.0	63.0	132.0

**1 Flow = 44.4 mL/Min      10.4 ppm      10.3 ppm      6.72 ppm      5.23 ppm**

**Time: 16:34**

**Peak Areas, mv-sec**

	23321	20338	9959	43670
	24380	21799	10647	46630
	25056	22227	10285	45442
<b>Average Area</b>	<b>24252</b>	<b>21454</b>	<b>10297</b>	<b>45247</b>

**2 Flow = 77.4 mL/Min      5.96 ppm      5.92 ppm      3.86 ppm      3.01 ppm**

**Time: 16:51**

**Peak Areas, mv-sec**

	9796	7866	3569	17108
	9812	7920	3556	17604
	9831	7352	3254	15792
<b>Average Area</b>	<b>9813</b>	<b>7713</b>	<b>3460</b>	<b>16834</b>

**3 Flow = 130 mL/Min      3.56 ppm      3.53 ppm      2.30 ppm      1.79 ppm**

**Time: 17:05**

**Peak Areas, mv-sec**

	3510	2899	1228	5869
	3467	2681	1272	6176
	3570	2800	1253	6307
<b>Average Area</b>	<b>3516</b>	<b>2793</b>	<b>1251</b>	<b>6117</b>

*Wdh*

# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Method **16**

H <sub>2</sub> S	1	2	3			
Time	16:34	16:51	17:05			
Concentration, ppm	10.4	5.96	3.56			
Area, mv-sec	24252	9813	3516			
Calc. Conc., ppm	10.2	6.18	3.49			
% Error	-1.7	3.6	-1.8	✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.8007	2.5680	0.9984	2	0.055	

MeSH	1	2	3			
Time	16:34	16:51	17:05			
Concentration, ppm	10.3	5.92	3.53			
Area, mv-sec	21454	7713	2793			
Calc. Conc., ppm	10.3	5.99	3.51			
% Error	-0.6	1.2	-0.6	✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.9025	2.4083	0.9998	2	0.078	

DMS	1	2	3			
Time	16:34	16:51	17:05			
Concentration, ppm	6.72	3.86	2.30			
Area, mv-sec	10297	3460	1251			
Calc. Conc., ppm	6.72	3.86	2.30			
% Error	-0.0	0.1	-0.0	✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.9679	2.3846	>0.9999	2	0.087	

DMDS	1	2	3			
Time	16:34	16:51	17:05			
Concentration, ppm	5.23	3.01	1.79			
Area, mv-sec	45247	16834	6117			
Calc. Conc., ppm	5.19	3.06	1.78			
% Error	-0.8	1.7	-0.9	✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.8669	3.3201	0.9996	2	0.024	

✓ JWH

# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Molecular Weight	34.08	48.11	62.14	94.20
Retention Time, sec	25.0	35.0	63.0	132.0
Peak Detection Window, sec	10.0	10.0	10.0	10.0
Minimum Peak Area, mv-sec	2	2	2	2
Minimum Peak Height, mv	1	1	1	1
Beginning Peak Width, sec	1.0	1.0	3.0	3.0
Ending Peak Width, sec	2.0	3.0	5.0	5.0
Permeation Device ID	T-51831	33-50536	89-50725	89-53405
Permeation Rate, ng/min	642 ✓	901 ✓	758 ✓	895 ✓
Permeation Rate, nL/min*	461	458	299	233

**Barometric Pressure:** 29.60 in. Hg      **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**PR<sub>ng</sub>** = Permeation Rate by weight, ng/min

**V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole

**W<sub>mol</sub>** = Molecular Weight of compound

**T<sub>a</sub>** = Ambient Temperature, °F

**T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)

**P<sub>s</sub>** = Standard Pressure = 29.92 in Hg

**P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 642 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.60) = 461 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

**C** = Concentration, ppmv

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**F<sub>d</sub>** = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

File: E:\6-24-21.trs  
Program Version: 2.0, built 15 May 2017 File Version: 2.0  
Computer: JWS-PROGRAMMING Trailer: 271

Analog Input Device: Keithley KUSB-3108 GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: GC-8A Serial No. C10494419420SA  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 100	Primary: 3'
Air	30	60	Detector: 120	Secondary:
Carrier	50	30		Sample Loop: 6" unlined

## Injection Cycle

Total Length: 180 sec Sampling Time: 160 sec Load/Backflush Time: 85 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 5 mv-sec Minimum peak height 5 mv above baseline

## Dynacalibrator

Chamber Temperature 130.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.60 in. Hg

# RUN DATA

Number 7

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 3**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
<b>Post test drift</b>									
17:22	13670	7.97	<2	<0.095	<2	<0.091	<2	<0.027	7.97
17:23	13643	7.96	<2	<0.095	<2	<0.091	<2	<0.027	7.96
17:25	13246	7.84	<2	<0.095	<2	<0.091	<2	<0.027	7.84
<b>Average</b>		<b>7.92</b>		<b>&lt;0.095</b>		<b>&lt;0.091</b>		<b>&lt;0.027</b>	<b>7.92</b>

# RUN DATA

Number 1

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine vent 2<sup>3</sup>**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM vent 3 Run 1</b>				
11:07:35	6776	20.2	-35	0.2
11:07:50	6778	20.2	-35	0.2
11:08:05	6777	20.2	-35	0.2
11:08:20	6778	20.2	-36	0.2
11:08:35	6776	20.2	-35	0.2
11:08:50	6777	20.2	-34	0.2
11:09:05	6779	20.2	-35	0.2
11:09:20	6778	20.2	-34	0.2
11:09:35	6778	20.2	-33	0.2
11:09:50	6779	20.2	-33	0.2
11:10:05	6776	20.2	-33	0.2
11:10:20	6780	20.2	-33	0.2
11:10:35	6776	20.2	-33	0.2
11:10:50	6777	20.2	-32	0.2
11:11:05	6780	20.2	-32	0.2
11:11:20	6776	20.2	-33	0.2
<b>Avg</b>	<b>6778</b>	<b>20.2</b>	<b>-34</b>	<b>0.2</b>



# RUN DATA

Number 2

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine vent 2**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

Calibration 1

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM 3 Run 2</b>				
11:48:17	6776	20.2	-35	0.2
11:48:32	6776	20.2	-35	0.2
11:48:47	6775	20.2	-35	0.2
11:49:02	6779	20.2	-35	0.2
11:49:17	6778	20.2	-35	0.2
11:49:32	6776	20.2	-34	0.2
11:49:47	6778	20.2	-35	0.2
11:50:02	6779	20.2	-35	0.2
11:50:17	6777	20.2	-35	0.2
11:50:32	6777	20.2	-36	0.2
11:50:47	6777	20.2	-34	0.2
11:51:02	6777	20.2	-35	0.2
11:51:17	6777	20.2	-35	0.2
11:51:32	6778	20.2	-34	0.2
11:51:47	6778	20.2	-35	0.2
11:52:02	6779	20.2	-35	0.2
11:52:17	6776	20.2	-35	0.2
11:52:32	6778	20.2	-36	0.2
11:52:47	6777	20.2	-34	0.2
11:53:02	6777	20.2	-35	0.2
11:53:17	6779	20.2	-35	0.2
11:53:32	6778	20.2	-35	0.2
11:53:47	6776	20.2	-34	0.2
<b>Avg</b>	<b>6777</b>	<b>20.2</b>	<b>-35</b>	<b>0.2</b>

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 2 3**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Calibration 1

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM 3 Run 3</b>				
13:11:54	6772	20.2	-32	0.2
13:12:09	6774	20.2	-31	0.2
13:12:24	6774	20.2	-32	0.2
13:12:39	6774	20.2	-33	0.2
13:12:54	6775	20.2	-34	0.2
13:13:09	6774	20.2	-31	0.2
13:13:24	6774	20.2	-32	0.2
13:13:39	6774	20.2	-34	0.2
13:13:54	6772	20.2	-33	0.2
13:14:09	6773	20.2	-33	0.2
13:14:24	6774	20.2	-33	0.2
13:14:39	6773	20.2	-33	0.2
13:14:54	6773	20.2	-33	0.2
13:15:09	6774	20.2	-33	0.2
13:15:24	6773	20.2	-34	0.2
13:15:39	6775	20.2	-34	0.2
13:15:54	6773	20.2	-35	0.2
13:16:09	6774	20.2	-35	0.2
13:16:24	6774	20.2	-35	0.2
13:16:39	6774	20.2	-34	0.2
13:16:54	6773	20.2	-35	0.2
<b>Avg</b>	<b>6774</b>	<b>20.2</b>	<b>-33</b>	<b>0.2</b>

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 2** 3

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 10:02

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	13
10.1	SG9168283BAL	3292
19.5	CC454190	6577

Curve Coefficients

Slope	Intercept	Corr. Coeff.
336.5	-26	0.9998

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	-68
10.2	SG9168283BAL	3027
20.4	CC454190	6279

Curve Coefficients

Slope	Intercept	Corr. Coeff.
311.1	-90	0.9999

✓

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 23**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 10:02

**O<sub>2</sub>**

Method: EPA 3A

Span Conc. 19.5 %

Slope 336.5                      Intercept -25.8

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	13	0.1	0.1	0.5 ✓	Pass
10.1	3292	9.9	-0.2	-1.0 ✓	Pass
19.5	6577	19.6	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.4 %

Slope 311.1                      Intercept -90.1

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-68	0.1	0.1	0.5 ✓	Pass
10.2	3027	10.0	-0.2	-1.0 ✓	Pass
20.4	6279	20.5	0.1	0.5 ✓	Pass



# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 2<sup>m</sup>**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

File: K:\15730 New Indy\001 Catawba SC\008\Data\CEMS data\6-24-21.cem

Program Version: 2.2, built 3 Jul 2020 File Version: 2.04

Computer: DESKTOP-GQ0I9UV Trailer: 271

Analog Input Device: Keithley KUSB-3108

---

## Channel 1

Analyte	O <sub>2</sub>
Method	EPA 3A, Using Bias
Analyzer Make, Model & Serial No.	CAI 600 SN E07015-M
Full-Scale Output, mv	10000
Analyzer Range, %	20.0
Span Concentration, %	19.5

## Channel 2

Analyte	CO <sub>2</sub>
Method	EPA 3A, Using Bias
Analyzer Make, Model & Serial No.	CAI 600 SN E07015-M
Full-Scale Output, mv	10000
Analyzer Range, %	25.0
Span Concentration, %	20.4



## VENT 4

New Indy  
Catawba, SC

15730.001.008  
No. 4 Hood Exhaust  
Paper Machine Vent 4

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
Date	6/25/21 ✓	6/25/21 ✓	6/25/21 ✓	---
Time Began	1135 ✓	1240 ✓	1345 ✓	---
Time Ended	1235 ✓	1340 ✓	1445 ✓	---
Volumetric Flow Rate, (Qs), DSCFM	3.32E+04 ✓	3.47E+04 ✓	3.31E+04 ✓	3.37E+04
BWS	0.269 ✓	0.268 ✓	0.263 ✓	0.267
% Oxygen	20.2 ✓	20.2 ✓	20.2 ✓	20.2
<hr/>				
<b>Total Reduced Sulfur</b>	<b>(TRS MW)= 34.08</b>			
Concentration, ppm	0.56 ✓	0.53 ✓	0.62 ✓	0.57
Emission Rate, lb/hr	0.10	0.10	0.11	0.10

A.3 ✓



New Indy  
Catawba, SC

15730.001.008  
No. 4 Hood Exhaust

### Paper Machine Vent 4

#### ISOKINETIC CALCULATIONS

Run Number		1	2	3	Mean
Date		6/25/21 ✓	6/25/21 ✓	6/25/21 ✓	---
Time Began		1135 ✓	1240 ✓	1345 ✓	---
Time Ended		1227 ✓	1334 ✓	1437 ✓	---
INPUT DATA					
Sampling Time, min	(Theta)	48.0 ✓	48 ✓	48 ✓	48
Stack Diameter, in.	(Dia.)	56.13 ✓	56.13 ✓	56.13 ✓	56.13
Barometric Pressure, in. Hg	(Pb)	29.68 ✓	29.68 ✓	29.68 ✓	29.68
Static Pressure, in. H2O	(Pg)	-0.49 ✓	-0.49 ✓	-0.49 ✓	-0.49
Pitot Tube Coefficient	(Cp)	0.84 ✓	0.84 ✓	0.84 ✓	0.84
Meter Correction Factor	(Y)	1.0030 ✓	1.0030 ✓	1.0030 ✓	1.0030
Orifice Calibration Value	(Delta H@)	1.8000 ✓	1.8000 ✓	1.8000 ✓	1.8000
Nozzle Diameter, in.	(Dn)	0.250 ✓	0.250 ✓	0.250 ✓	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	29.932 ✓	30.405 ✓	30.432 ✓	30.256
Meter Temperature, °F	(Tm)	84.1 ✓	86.3 ✓	85.2 ✓	85.2
Meter Temperature, °R	(Tm-R)	544.1	546.3	545.2	545.2
Meter Orifice Pressure, in. H2O	(Delta H)	1.300 ✓	1.300 ✓	1.300 ✓	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> avg)	1.140 ✓	1.140 ✓	1.140 ✓	1.140
Volume H2O Collected, mL	(Vlc)	226.5 ✓	228.6 ✓	223.0 ✓	226.0
CO2 Concentration, %	(CO2)	0.2 ✓	0.2 ✓	0.2 ✓	0.2
O2 Concentration, %	(O2)	20.2 ✓	20.2 ✓	20.2 ✓	20.2
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> avg)	0.831 ✓	0.869 ✓	0.824 ✓	0.841
Stack Temperature, °F	(Ts)	193.1 ✓	193.6 ✓	194.1 ✓	193.6
Stack Temperature, °R	(Ts-R)	653.1	653.6	654.1	653.6
Moisture Fraction (at Saturation)	(BWS)	0.685 ✓	0.693 ✓	0.700 ✓	0.693
CALCULATED DATA					
Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	17.18 ✓	17.18 ✓	17.18 ✓	17.18
Stack Pressure, in. Hg	(Ps)	29.64	29.64	29.64	29.64
Meter Pressure, in. Hg	(Pm)	29.78	29.78	29.78	29.78
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	28.981	29.321	29.406	29.236
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	10.661	10.760	10.497	10.639
Moisture Fraction (Measured)	(BWS)	0.269	0.268	0.263	0.267
Moisture Fraction (lower sat/meas)	(BWS)	0.269	0.268	0.263	0.267
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	28.84	28.84	28.84	28.84
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	25.92	25.93	25.99	25.95
Average Stack Gas Velocity, ft/sec	(Vs)	54.99	57.54	54.52	55.68
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	56682	59312	56198	57397
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	33178	34714	33109	33667
Calibration check	(Yqa)	1.0434	1.0293	1.0273	1.033
Percent difference from Y					3.02%

✓

# Isokinetic Field Data

## Method: EPA 4, Moisture

Bare Pressure 29.68

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 4 Hood Exhaust  
 Sample Location: Reop  
 W. O. Number: 15730.001.008  
 Run Number: 1  
 Date: 6/25/21  
 Test Personnel: BSA/BZ  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PR6C-6'  
 Liner Material: 55  
 Pitot ID/Coeff.: P77 0.84  
 Thermo ID: A023  
 Nozzle ID/Diams.: \_\_\_\_\_  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp. 75 °F  
 Baro. Pressure\* 29.68 in. Hg  
 Static Pressure -.49 in. H<sub>2</sub>O  
 Impinger Gain 218.9 mL  
 Silica Gel Gain 7.6 g  
 Stack Area 17.18 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor N/A

### Leak Checks

	Initial	Final
Volume, ft <sup>3</sup>	<u>0.000</u>	<u>0.000</u>
@ Vac., in. Hg	<u>12"</u>	<u>6"</u>
Pitot	<u>Good</u>	<u>Good</u>

Filter ID: N/A

Sample ID: Run1

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
0	11:35				821.800									
A-1	3		.78	1.3	823.6	193	N/A	82	243	251	N/A	63	3	
2	6		.73	1.3	825.4	193		82	243	252		63	3	
3	9		.72	1.3	827.2	193		83	242	255		54	3	
4	12		.54	1.3	829.1	193		84	241	253		50	3	
5	15		.68	1.3	831.0	193		84	241	250		50	3	
6	18		.70	1.3	832.9	193		83	240	250		50	3	
7	21		.67	1.3	834.8	193		84	241	251		50	3	
8	24		.60	1.3	836.7	191		85	242	254		50	3	
B-1	27		.77	1.3	838.6	193		84	241	255		56	3	
2	30		.79	1.3	840.4	193		86	241	254		51	3	
3	33		.70	1.3	842.3	193		85	243	251		49	3	
4	36		.68	1.3	844.2	193		85	242	255		49	3	
5	39		.69	1.3	846.1	195		85	242	251		49	3	
6	42		.70	1.3	848.0	195		85	243	254		50	3	
7	45		.66	1.3	849.8	193		85	241	253		50	3	
8	48	12:27	.65	1.3	851.732	193		85	242	251		51	3	
*Barometric Pressure is at port elevation			Avg V <sub>ap</sub>	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-sth</sub> scf
			1.8306	1.300	29.932	193.1	84.1	246/243	250/255			63	3	

Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 Result \_\_\_\_\_

Leak Check, Pre-run \_\_\_\_\_  
 Post-run \_\_\_\_\_  
 O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A \_\_\_\_\_  
 Leak Check, Pre-run \_\_\_\_\_  
 Post-run \_\_\_\_\_

Flue Gas Composition  
 Oxygen, % 20.2  
 Carbon Dioxide, % 0.2  
 Moisture, % \_\_\_\_\_

Comments: \_\_\_\_\_

15730.001.008  
 Philp Dyer, #3 Paper Machine,  
 #2-3 SDTVs, & #1-2 CBs  
 Emission Report



Integrated Air Services



# Isokinetic Field Data

# Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 4 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 2  
 Date: 6/9/21  
 Test Personnel: BEA/BC  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PR6C-6  
 Liner Material: PS  
 Pitot ID/Coeff.: P77 0.84  
 Thermo ID: A023  
 Nozzle ID/Diams.: \_\_\_\_\_  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp. 79 °F  
 Baro. Pressure\* 29.68 in. Hg  
 Static Pressure -.49 in. H<sub>2</sub>O  
 Impinger Gain 220.9 mL  
 Silica Gel Gain 7.7 g  
 Stack Area 17.18 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor N/A  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	<u>0.000</u>	<u>0.000</u>
Pitot	<u>12"</u>	<u>5"</u>
	<u>Good</u>	<u>Good</u>

Filter ID: N/A  
 Sample ID: R012


TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS	
0		<u>12:40</u>			<u>857.900</u>										
A-1	3		<u>.84</u>	<u>1.3</u>	<u>853.9</u>	<u>192</u>	<u>N/A</u>	<u>86</u>	<u>293</u>	<u>256</u>	<u>N/A</u>	<u>65</u>	<u>2</u>		
2	6		<u>.84</u>	<u>1.3</u>	<u>855.8</u>	<u>193</u>		<u>86</u>	<u>242</u>	<u>255</u>		<u>64</u>	<u>2</u>		
3	9		<u>.85</u>	<u>1.3</u>	<u>857.7</u>	<u>194</u>		<u>87</u>	<u>241</u>	<u>255</u>		<u>61</u>	<u>2</u>		
4	12		<u>.74</u>	<u>1.3</u>	<u>859.5</u>	<u>194</u>		<u>86</u>	<u>242</u>	<u>257</u>		<u>61</u>	<u>2</u>		
5	15		<u>.76</u>	<u>1.3</u>	<u>861.4</u>	<u>194</u>		<u>85</u>	<u>241</u>	<u>251</u>		<u>61</u>	<u>2</u>		
6	18		<u>.74</u>	<u>1.3</u>	<u>863.3</u>	<u>194</u>		<u>86</u>	<u>242</u>	<u>255</u>		<u>61</u>	<u>2</u>		
7	21		<u>.73</u>	<u>1.3</u>	<u>865.2</u>	<u>194</u>		<u>86</u>	<u>242</u>	<u>256</u>		<u>63</u>	<u>2</u>		
8	24		<u>.66</u>	<u>1.3</u>	<u>867.1</u>	<u>193</u>		<u>87</u>	<u>242</u>	<u>252</u>		<u>65</u>	<u>2</u>		
B-1	27		<u>.81</u>	<u>1.3</u>	<u>869.0</u>	<u>194</u>		<u>87</u>	<u>243</u>	<u>254</u>		<u>64</u>	<u>2</u>		
2	30		<u>.84</u>	<u>1.3</u>	<u>870.9</u>	<u>194</u>		<u>87</u>	<u>239</u>	<u>257</u>		<u>62</u>	<u>2</u>		
3	33		<u>.79</u>	<u>1.3</u>	<u>872.7</u>	<u>194</u>		<u>87</u>	<u>242</u>	<u>258</u>		<u>61</u>	<u>2</u>		
4	36		<u>.67</u>	<u>1.3</u>	<u>874.7</u>	<u>194</u>		<u>86</u>	<u>241</u>	<u>256</u>		<u>61</u>	<u>2</u>		
5	39		<u>.71</u>	<u>1.3</u>	<u>876.6</u>	<u>194</u>		<u>86</u>	<u>243</u>	<u>248</u>		<u>61</u>	<u>2</u>		
6	42		<u>.73</u>	<u>1.3</u>	<u>878.5</u>	<u>194</u>		<u>86</u>	<u>241</u>	<u>251</u>		<u>62</u>	<u>2</u>		
7	45		<u>.72</u>	<u>1.3</u>	<u>880.4</u>	<u>193</u>		<u>86</u>	<u>242</u>	<u>251</u>		<u>63</u>	<u>2</u>		
8	48	<u>13:34</u>	<u>.67</u>	<u>1.3</u>	<u>882.305</u>	<u>193</u>		<u>87</u>	<u>242</u>	<u>254</u>		<u>64</u>	<u>2</u>		
*Barometric Pressure is at port elevation			Avg Δp	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>i</sub>	Avg T <sub>o</sub>	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub> scf	
			<u>.8689</u>	<u>1.300</u>	<u>30.905</u>	<u>193.6</u>	<u>86.3</u>	<u>231/243</u>	<u>248/258</u>	<u>65</u>					

Flue Gas Composition  
 Oxygen, % 20.2  
 Carbon Dioxide, % 0.2  
 Moisture, % \_\_\_\_\_

Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 Result \_\_\_\_\_

Q<sub>s</sub>, dscfm \_\_\_\_\_  
 % Isokinetic \_\_\_\_\_  
 Calculated by \_\_\_\_\_  
 QC by WCS

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run \_\_\_\_\_  
 Post-run \_\_\_\_\_



Integrated Air Services



# Isokinetic Field Data

# Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 4 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/25/21  
 Test Personnel: BZA / BL  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PR6C-6'  
 Liner Material: SS  
 Pitot ID/Coeff.: P77 0.84  
 Thermo ID: A023  
 Nozzle ID/Diams.:  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp. 79 °F  
 Baro. Pressure\* 27.66 in. Hg  
 Static Pressure -.49 in. H<sub>2</sub>O  
 Impinger Gain 217.3 mL  
 Silica Gel Gain 6.7 g  
 Stack Area 17.16 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	0.604	0.001
Pitot	12"	5"
	Good	Good

Filter ID: N/A  
 Sample ID: Run 3

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS	
															Avg V <sub>sp</sub>
0	13:45				882.557										
A-1	3		.81	1.3	884.5	195	N/A	86	243	256	N/A	63	3		
2	6		.80	1.3	886.4	195		86	239	255		62	3		
3	9		.76	1.3	888.2	195		85	241	254		57	3		
4	12		.54	1.3	890.1	194		85	240	254		55	3		
5	15		.50	1.3	892.0	194		85	242	252		55	3		
6	18		.71	1.3	893.9	194		84	239	254		54	3		
7	21		.67	1.3	895.8	194		84	240	253		54	3		
8	24		.67	1.3	897.7	194		84	240	251		54	3		
B-1	27		.80	1.3	899.6	194		85	242	252		57	3		
2	30		.76	1.3	901.6	194		86	243	253		55	3		
3	33		.70	1.3	903.5	194		86	241	252		55	3		
4	36		.68	1.3	905.4	194		86	240	252		56	3		
5	39		.63	1.3	907.2	194		86	243	252		57	3		
6	42		.58	1.3	909.1	194		85	240	252		58	3		
7	45		.65	1.3	911.0	194		85	240	252		59	3		
8	48		.65	1.3	912.8	193		85	240	254		59	3		
			Avg V <sub>sp</sub>	Avg ΔH	Avg T <sub>s</sub>	Avg T <sub>m</sub>				Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub> scf
			.8239	1.300	194.1	85.2			239/244	251/258		63	3		
			Flue Gas Composition			O <sub>2</sub> /CO <sub>2</sub> by Orsat Fyrite M3A			Thermocouple Check			Q <sub>s</sub> , dscfm			
			Oxygen, %			20.2			Leak Check, Pre-run			% Isokinetic			
			Carbon Dioxide, %			0.2			Post-run			Calculated by			
			Moisture, %						Result			QC by			

\*Barometric Pressure is at port elevation



15730.001.008  
 Pulp Dryer, #3 Paper Machine,  
 #2-3 SDTVs, & #1-2 CBs  
 Emission Report

Sample time 48  
 DGM reading: 912.989



# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 4 Hood Exhaust  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID Run 1 Filter ID N/A Analyst BA

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	954.7	723.6	555.9		896.5	
Initial	766.9	690.8	557.6		888.9	
Gain	187.8 ✓	32.8 ✓	-1.7 ✓	218.9	7.6 ✓	226.5

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 2 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID Run 2 Filter ID N/A Analyst BA

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	940.9	839.8	658.5		859.8	
Initial	763.2	802.2	652.9		852.1	
Gain	177.7 ✓	37.6 ✓	5.6 ✓	220.9	7.7 ✓	228.6

Impinger Color Clear Labeled?   
 Silica Gel Condition good Sealed?

Run No. 3 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID Run 3 Filter ID N/A Analyst BA

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	949.0	718.9	553.8		901.0	
Initial	762.9	684.6	556.9		895.3	
Gain	186.1 ✓	34.3 ✓	-3.1 ✓	217.3	5.7 ✓	223

Impinger Color Clear Labeled?   
 Silica Gel Condition good Sealed?

Check COC for Sample IDs of Media Blanks



# Sample and Velocity Traverse Point Data Sheet - Method 1

15730.001.008  
 Philip Meyer, #3 Paper Machine,  
 #2-3 SDTVs, & #1-2 CBs  
 Emission Report

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 4 Hood Exhaust

Operator VD / LF  
 Date 15-Jun-21  
 W.O. Number 15730.001.008

**Duct Type**  Circular  Rectangular Duct Indicate appropriate type  
**Traverse Type**  Particulate Traverse  Velocity Traverse

Distance from far wall to outside of port (in.) = C	<b>56.250</b>
Port Depth (in.) = D	<b>0.125</b>
Depth of Duct, diameter (in.) = C-D	<b>56.125</b>
Area of Duct (ft <sup>2</sup> )	<b>17.18</b>
Total Traverse Points	<b>16</b>
Total Traverse Points per Port	<b>8</b>



**Rectangular Ducts Only**

Width of Duct, rectangular duct only (in.)

Total Ports (rectangular duct only)

Traverse Point Locations			
Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	3.2	2	2
2	10.5	6	6
3	19.4	11	11
4	32.3	18	18 1/2
5	67.7	38	38
6	80.6	45	45 1/2
7	89.5	50	50 1/2
8	96.8	54 1/2	54 1/2
9			
10			
11			
12			

Flow Disturbances	
Upstream - A (ft)	<b>5.670</b>
Downstream - B (ft)	<b>25.0</b>
Upstream - A (duct diameters)	<b>1.21</b>
Downstream - B (duct diameters)	<b>5.35</b>



Equivalent Diameter =  $(2 * L * W) / (L + W)$

		Traverse Point Location Percent of Stack -Circular											
		Number of Traverse Points											
		1	2	3	4	5	6	7	8	9	10	11	12
T r a v e r s e P o i n t	1		14.6		6.7		4.4		3.2		2.6		2.1
	2		85.4		25		14.6		10.5		8.2		6.7
	3			75		29.6		19.4		14.6		11.8	
	4				93.3		70.4		32.3		22.6		17.7
	5					85.4		67.7		34.2		25	
	6						95.6		80.6		65.8		35.6
	7							89.5		77.4		64.4	
	8								96.8		85.4		75
	9									91.8		82.3	
	10										97.4		88.2
	11											93.3	
	12												97.9

		Traverse Point Location Percent of Stack -Rectangular											
		Number of Traverse Points											
		1	2	3	4	5	6	7	8	9	10	11	12
T r a v e r s e P o i n t	1		25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
	2		75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
	3			83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
	4				87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
	5					90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
	6						91.7	78.6	68.8	61.1	55.0	50.0	45.8
	7							92.9	81.3	72.2	65.0	59.1	54.2
	8								93.8	83.3	75.0	68.2	62.5
	9									94.4	85.0	77.3	70.8
	10										95.0	86.4	79.2
	11											95.5	87.5
	12												95.8

- Rectangular Stack Points & Matrix**
- 9 - 3 x 3
  - 12 - 4 x 3
  - 16 - 4 x 4
  - 20 - 5 x 4
  - 25 - 5 x 5
  - 30 - 6 x 5
  - 36 - 6 x 6
  - 42 - 7 x 6
  - 49 - 7 x 7

Port Diam. (in) = 4  
 Number of Ports = 2

Tape Measure I.D. # TM-07







# RUN SUMMARY

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1** 4

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**Start Time 11:35    End Time 12:35**

---

**Average Measured TRS Conc.**    0.56 ppm  
**Recovery No. 3**    98.5 % ✓  
**TRS Corrected for Recovery**    0.56 ppm ✓

✓

# RUN SUMMARY

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1** 4

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

Start Time 12:40    End Time 13:40

---

Average Measured TRS Conc.    0.52 ppm  
Recovery No. 3                    98.5 % ✓  
TRS Corrected for Recovery       0.53 ppm /

12/21

# RUN SUMMARY

Number 6

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1** *4*

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**Start Time 13:45    End Time 14:45**

---

**Average Measured TRS Conc.**    0.61 ppm  
**Recovery No. 3**                    98.5 % */*  
**TRS Corrected for Recovery**    0.62 ppm */*

*JCH*

# RUN DATA

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1** *4*

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
<b>PM Vent 4 Run 1</b>									
11:35	25	0.27	<2	<0.08	<2	<0.07	50	0.14	0.55
11:38	<2	<0.07	<2	<0.08	8	0.15	<2	<0.02	0.15
11:41	<2	<0.07	145	0.77	<2	<0.07	<2	<0.02	0.77
11:44	26	0.27	26	0.31	<2	<0.07	<2	<0.02	0.59
11:47	38	0.34	23	0.30	27	0.28	<2	<0.02	0.92
11:50	43	0.36	27	0.32	<2	<0.07	14	0.07	0.82
11:53	41	0.35	<2	<0.08	28	0.29	<2	<0.02	0.64
11:56	36	0.33	4	0.11	<2	<0.07	<2	<0.02	0.44
11:59	37	0.33	<2	<0.08	27	0.28	49	0.13	0.88
12:02	<2	<0.07	11	0.20	13	0.19	11	0.06	0.51
12:05	<2	<0.07	<2	<0.08	<2	<0.07	16	0.07	0.15
12:08	63	0.44	13	0.22	34	0.32	<2	<0.02	0.98
12:11	30	0.29	7	0.16	57	0.42	<2	<0.02	0.88
12:14	<2	<0.07	<2	<0.08	<2	<0.07	<2	<0.02	-
12:17	29	0.29	18	0.26	<2	<0.07	<2	<0.02	0.55
12:20	<2	<0.07	<2	<0.08	<2	<0.07	<2	<0.02	-
12:23	8	0.14	35	0.37	<2	<0.07	<2	<0.02	0.51
12:26	14	0.20	<2	<0.08	17	0.22	35	0.11	0.65
12:29	<2	<0.07	4	0.12	18	0.23	<2	<0.02	0.36
12:32	58	0.42	7	0.16	12	0.19	<2	<0.02	0.77
<b>Average</b>		<b>0.20</b>		<b>0.17</b>		<b>0.13</b>		<b>0.03</b>	<b>0.56</b>

# RUN DATA

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent # 4**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
<b>PM vent 4 Run 2</b>									
12:40	8	0.15	<2	<0.08	24	0.27	<2	<0.02	0.42
12:43	11	0.18	41	0.40	<2	<0.07	25	0.09	0.76
12:46	97	0.55	<2	<0.08	<2	<0.07	<2	<0.02	0.55
12:49	19	0.23	<2	<0.08	<2	<0.07	<2	<0.02	0.23
12:52	<2	<0.07	<2	<0.08	51	0.40	<2	<0.02	0.40
12:55	13	0.19	<2	<0.08	18	0.23	<2	<0.02	0.42
12:58	<2	<0.07	7	0.15	56	0.42	<2	<0.02	0.58
13:01	7	0.14	<2	<0.08	<2	<0.07	28	0.10	0.34
13:04	<2	<0.07	<2	<0.08	14	0.20	35	0.11	0.43
13:07	68	0.46	9	0.18	10	0.17	<2	<0.02	0.81
13:10	6	0.12	<2	<0.08	25	0.27	14	0.07	0.53
13:13	20	0.24	26	0.31	<2	<0.07	<2	<0.02	0.56
13:16	10	0.16	35	0.37	61	0.44	17	0.08	1.12
13:19	23	0.26	<2	<0.08	<2	<0.07	<2	<0.02	0.26
13:22	<2	<0.07	<2	<0.08	12	0.18	23	0.09	0.36
13:25	44	0.37	45	0.42	5	0.12	<2	<0.02	0.90
13:28	80	0.50	<2	<0.08	<2	<0.07	<2	<0.02	0.50
13:31	<2	<0.07	<2	<0.08	27	0.29	<2	<0.02	0.29
13:34	<2	<0.07	14	0.23	<2	<0.07	14	0.07	0.36
13:37	<2	<0.07	17	0.25	10	0.17	33	0.11	0.64
<b>Average</b>		<b>0.18</b>		<b>0.12</b>		<b>0.16</b>		<b>0.04</b>	<b>0.52</b>

# RUN DATA

Number 6

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1<sup>4</sup>**

Method **16**  
Calibration **1**

*Run 3*

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
13:45	13	0.19	<2	<0.08	<2	<0.07	22	0.09	0.37
13:48	11	0.18	<2	<0.08	33	0.32	<2	<0.02	0.49
13:51	10	0.17	13	0.22	<2	<0.07	11	0.06	0.50
13:54	13	0.19	<2	<0.08	<2	<0.07	<2	<0.02	0.19
13:57	30	0.30	<2	<0.08	<2	<0.07	34	0.11	0.52
14:00	117	0.61	<2	<0.08	10	0.17	14	0.07	0.91
14:03	26	0.28	<2	<0.08	65	0.46	<2	<0.02	0.73
14:06	37	0.33	9	0.18	<2	<0.07	7	0.05	0.61
14:09	27	0.28	<2	<0.08	21	0.25	<2	<0.02	0.53
14:12	5	0.12	15	0.24	<2	<0.07	<2	<0.02	0.36
14:15	5	0.12	14	0.22	26	0.28	16	0.07	0.77
14:18	25	0.27	8	0.17	29	0.30	<2	<0.02	0.73
14:21	49	0.38	<2	<0.08	<2	<0.07	<2	<0.02	0.38
14:24	51	0.39	6	0.15	<2	<0.07	12	0.06	0.67
14:27	119	0.62	<2	<0.08	<2	<0.07	<2	<0.02	0.62
14:30	56	0.41	13	0.22	10	0.17	23	0.09	0.98
14:33	59	0.42	31	0.35	<2	<0.07	<2	<0.02	0.77
14:36	40	0.35	<2	<0.08	4	0.11	<2	<0.02	0.45
14:39	23	0.26	11	0.20	92	0.55	<2	<0.02	1.00
14:42	30	0.30	33	0.36	<2	<0.07	<2	<0.02	0.65
<b>Average</b>		<b>0.31</b>		<b>0.11</b>		<b>0.13</b>		<b>0.03</b>	<b>0.61</b>



# RUN DATA

Number 14

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine Vent # 4**

Method **16**  
 Calibration **1**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
<b>Calibration drift check</b>									
20:16	14345	7.84	<2	<0.08	<2	<0.07	<2	<0.02	7.84
20:19	14713	7.94	<2	<0.08	<2	<0.07	<2	<0.02	7.94
20:22	14122	7.77	<2	<0.08	<2	<0.07	<2	<0.02	7.77
<b>Average</b>		<b>7.85</b>		<b>&lt;0.08</b>		<b>&lt;0.07</b>		<b>&lt;0.02</b>	<b>7.85</b>

# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 14**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

After Run 3    Before Run 4  
Start Time 11:06    End Time 11:15

## Recovery Gas to Probe, Time 11:06

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
13991	13801	13923	13905	7.71

## Recovery Gas to GC, Time 11:12

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
14345	14801	14524	14556	7.90

Recovery 97.6%

*VDH*

# RECOVERY DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent # 4**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

**After Run 6 Before Run 10**  
**Start Time 14:45 End Time 14:58**

## Recovery Gas to Probe, Time 14:45

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
14557	13955	14506	14339	7.83

## Recovery Gas to GC, Time 14:54

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
15125	14482	14672	14759	7.95

**Recovery 98.5%**

*VD*

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent # 4**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Ambient Temperature: 72°C Barometric Pressure: 29.70 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	460	457	298	232
Ret. Time, sec	25.0	35.0	63.0	132.0

1 Flow = 42.9 mL/Min 10.7 ppm 10.7 ppm 6.95 ppm 5.41 ppm

Time: 06:02

Peak Areas, mv-sec

25099	20594	10407	44232
24750	21533	10445	46016
25597	21979	10703	45950

Average Area

25149	21369	10519	45399
-------	-------	-------	-------

2 Flow = 82.8 mL/Min 5.56 ppm 5.52 ppm 3.60 ppm 2.80 ppm

Time: 06:53

Peak Areas, mv-sec

7926	6406	2923	14068
7950	6306	2884	13591
8444	6460	2990	14698

Average Area

8107	6390	2932	14119
------	------	------	-------

3 Flow = 130 mL/Min 3.54 ppm 3.52 ppm 2.29 ppm 1.79 ppm

Time: 07:08

Peak Areas, mv-sec

3069	2599	1371	5786
3064	2578	1331	5729
3088	2512	1340	5842

Average Area

3074	2563	1347	5786
------	------	------	------

*VD*

# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 14**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Method 16

H <sub>2</sub> S	1	2	3		
Time	06:02	06:53	07:08		
Concentration, ppm	10.7	5.56	3.54		
Area, mv-sec	25149	8107	3074		
Calc. Conc., ppm	10.6	5.79	3.46		
% Error	-1.6	4.2	-2.4		
<u>Calibration Curve</u>	<u>Slope</u>	<u>Intercept</u>	<u>Corr. Coeff.</u>	<u>Min. Area</u>	<u>Det. Lim.</u>
	1.8847	2.4717	0.9980	2	0.07

MeSH	1	2	3		
Time	06:02	06:53	07:08		
Concentration, ppm	10.7	5.52	3.52		
Area, mv-sec	21369	6390	2563		
Calc. Conc., ppm	10.6	5.62	3.48		
% Error	-0.7	1.8	-1.1		
<u>Calibration Curve</u>	<u>Slope</u>	<u>Intercept</u>	<u>Corr. Coeff.</u>	<u>Min. Area</u>	<u>Det. Lim.</u>
	1.9089	2.3742	0.9996	2	0.08

DMS	1	2	3		
Time	06:02	06:53	07:08		
Concentration, ppm	6.95	3.60	2.29		
Area, mv-sec	10519	2932	1347		
Calc. Conc., ppm	7.00	3.53	2.32		
% Error	0.8	-2.0	1.2		
<u>Calibration Curve</u>	<u>Slope</u>	<u>Intercept</u>	<u>Corr. Coeff.</u>	<u>Min. Area</u>	<u>Det. Lim.</u>
	1.8617	2.4483	0.9995	2	0.07

DMDS	1	2	3		
Time	06:02	06:53	07:08		
Concentration, ppm	5.41	2.80	1.79		
Area, mv-sec	45399	14119	5786		
Calc. Conc., ppm	5.37	2.86	1.77		
% Error	-0.8	2.0	-1.2		
<u>Calibration Curve</u>	<u>Slope</u>	<u>Intercept</u>	<u>Corr. Coeff.</u>	<u>Min. Area</u>	<u>Det. Lim.</u>
	1.8537	3.3043	0.9995	2	0.02

JKH

# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1 4**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

H <sub>2</sub> S	1	2	3		
Time	19:32	19:43	19:59		
Concentration, ppm	10.5	6.99	3.74		
Area, mv-sec	24392	13907	4527		
Calc. Conc., ppm	10.3	7.29	3.68		
% Error	-2.5	4.3	-1.6		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.6380	2.7299	0.9976	2	0.03

MeSH	1	2	3		
Time	19:32	19:43	19:59		
Concentration, ppm	10.5	6.95	3.71		
Area, mv-sec	23509	12131	3753		
Calc. Conc., ppm	10.3	7.11	3.68		
% Error	-1.4	2.4	-0.9		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.7779	2.5690	0.9992	2	0.05

DMS	1	2	3		
Time	19:32	19:43	19:59		
Concentration, ppm	6.82	4.53	2.42		
Area, mv-sec	10516	5246	1551		
Calc. Conc., ppm	6.73	4.63	2.40		
% Error	-1.3	2.2	-0.9		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8539	2.4865	0.9993	2	0.07

DMDS	1	2	3		
Time	19:32	19:43	19:59		
Concentration, ppm	5.31	3.53	1.88		
Area, mv-sec	48003	24800	7538		
Calc. Conc., ppm	5.23	3.62	1.86		
% Error	-1.6	2.7	-1.0		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.7949	3.3916	0.9990	2	0.02

✓

# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent #4**

Method 16

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

**Ambient Temperature: 72°C**

**Barometric Pressure: 29.70 in. Hg**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	460	457	298	232
Ret. Time, sec	25.0	35.0	63.0	132.0

**1 Flow = 43.6 mL/Min      10.5 ppm      10.5 ppm      6.82 ppm      5.31 ppm**

**Time: 19:32**

**Peak Areas, mv-sec**

	23668	22380	10086	46114
	24884	23771	10653	47622
	24624	24375	10810	50274
<b>Average Area</b>	<b>24392</b>	<b>23509</b>	<b>10516</b>	<b>48003</b>

**2 Flow = 65.8 mL/Min      6.99 ppm      6.95 ppm      4.53 ppm      3.53 ppm**

**Time: 19:43**

**Peak Areas, mv-sec**

	14069	11744	5164	24545
	13746	12537	5293	24899
	13905	12112	5280	24958
<b>Average Area</b>	<b>13907</b>	<b>12131</b>	<b>5246</b>	<b>24800</b>

**3 Flow = 123 mL/Min      3.74 ppm      3.71 ppm      2.42 ppm      1.88 ppm**

**Time: 19:59**

**Peak Areas, mv-sec**

	4288	3691	1547	7409
	4623	3823	1561	7662
	4672	3745	1545	7541
<b>Average Area</b>	<b>4527</b>	<b>3753</b>	<b>1551</b>	<b>7538</b>

*10/24*



# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1 4**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
<b>Molecular Weight</b>	34.08	48.11	62.14	94.20
<b>Retention Time, sec</b>	25.0	35.0	63.0	132.0
<b>Peak Detection Window, sec</b>	10.0	10.0	10.0	10.0
<b>Minimum Peak Area, mv-sec</b>	2	2	2	2
<b>Minimum Peak Height, mv</b>	1	1	1	1
<b>Beginning Peak Width, sec</b>	1.0	1.0	3.0	3.0
<b>Ending Peak Width, sec</b>	2.0	3.0	5.0	5.0
<b>Permeation Device ID</b>	T-51831	33-50536	89-50725	89-53405
<b>Permeation Rate, ng/min</b>	642 ✓	901 ✓	758	895 ✓
<b>Permeation Rate, nL/min*</b>	460	457	298	232

**Barometric Pressure:** 29.70 in. Hg    **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- PR<sub>ng</sub>** = Permeation Rate by weight, ng/min
- V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole
- W<sub>mol</sub>** = Molecular Weight of compound
- T<sub>a</sub>** = Ambient Temperature, °F
- T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)
- P<sub>s</sub>** = Standard Pressure = 29.92 in Hg
- P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 642 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.70) = 460 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

- C** = Concentration, ppmv
- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- F<sub>d</sub>** = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1/4**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

File: E:\6-25-21.trs  
Program Version: 2.0, built 21 Feb 2015    File Version: 2.0  
Computer: JWS-PROGRAMMING    Trailer: 271

Analog Input Device: Keithley KUSB-3108    GC Channel: 16

Sampling Rate: 0.050 sec.    Data Interval: 0.5 sec.

Gas Chromatograph: GC-8A    Serial No. C10494419420SA  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 100	Primary: 3'
Air	30	60	Detector: 120	Secondary:
Carrier	50	30		Sample Loop: 6" unlined

## Injection Cycle

Total Length: 180 sec    Sampling Time: 160 sec    Load/Backflush Time: 85 sec

## Default Integration Parameters

Signal Threshold 0.67 mv    Peak detection window ±10 sec  
Minimum peak area 5 mv-sec    Minimum peak height 5 mv above baseline

## Dynacalibrator

Chamber Temperature 130.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.70 in. Hg

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 4**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM vent 4 Run 1</b>				
12:46:45	6775	20.2	34	0.2
12:47:00	6777	20.2	34	0.2
12:47:15	6777	20.2	34	0.2
12:47:30	6775	20.2	35	0.2
12:47:45	6775	20.2	34	0.2
12:48:00	6777	20.2	34	0.2
12:48:15	6776	20.2	34	0.2
12:48:30	6778	20.2	35	0.2
12:48:45	6775	20.2	32	0.2
12:49:00	6776	20.2	31	0.2
12:49:15	6780	20.2	30	0.2
12:49:30	6775	20.2	31	0.2
12:49:45	6774	20.2	34	0.2
12:50:00	6777	20.2	32	0.2
12:50:15	6778	20.2	33	0.2
12:50:30	6776	20.2	32	0.2
12:50:45	6776	20.2	33	0.2
12:51:00	6776	20.2	32	0.2
12:51:15	6776	20.2	32	0.2
12:51:30	6776	20.2	31	0.2
12:51:45	6774	20.2	31	0.2
<b>Avg</b>	<b>6776</b>	<b>20.2</b>	<b>33</b>	<b>0.2</b>

---

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 4**

Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM vent 4 Run 2</b>				
13:48:57	6773	20.2	34	0.2
13:49:12	6775	20.2	33	0.2
13:49:27	6775	20.2	34	0.2
13:49:42	6776	20.2	34	0.2
13:49:57	6774	20.2	34	0.2
13:50:12	6777	20.2	34	0.2
13:50:27	6775	20.2	33	0.2
13:50:42	6774	20.2	34	0.2
13:50:57	6776	20.2	34	0.2
13:51:12	6775	20.2	34	0.2
13:51:27	6774	20.2	34	0.2
13:51:42	6776	20.2	34	0.2
13:51:57	6773	20.2	34	0.2
13:52:12	6775	20.2	34	0.2
13:52:27	6766	20.2	35	0.2
13:52:42	6772	20.2	34	0.2
13:52:57	6775	20.2	34	0.2
13:53:12	6774	20.2	35	0.2
13:53:27	6774	20.2	34	0.2
13:53:42	6775	20.2	35	0.2
13:53:57	6775	20.2	34	0.2
13:54:12	6775	20.2	34	0.2
13:54:27	6773	20.2	35	0.2
13:54:42	6774	20.2	34	0.2
<b>Avg</b>	<b>6774</b>	<b>20.2</b>	<b>34</b>	<b>0.2</b>

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 4**

Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM vent 4 Run 3</b>				
15:01:47	6759	20.2	52	0.2
15:02:02	6759	20.2	51	0.2
15:02:17	6761	20.2	50	0.2
15:02:32	6759	20.2	49	0.2
15:02:47	6758	20.2	51	0.2
15:03:02	6761	20.2	51	0.2
15:03:17	6760	20.2	51	0.2
15:03:32	6760	20.2	53	0.2
15:03:47	6759	20.2	52	0.2
15:04:02	6758	20.2	51	0.2
15:04:17	6759	20.2	51	0.2
15:04:32	6761	20.2	52	0.2
15:04:47	6758	20.2	53	0.2
15:05:02	6759	20.2	52	0.2
15:05:17	6759	20.2	52	0.2
15:05:32	6760	20.2	52	0.2
15:05:47	6760	20.2	51	0.2
15:06:02	6759	20.2	52	0.2
15:06:17	6759	20.2	52	0.2
15:06:32	6759	20.2	52	0.2
15:06:47	6759	20.2	52	0.2
<b>Avg</b>	<b>6759</b>	<b>20.2</b>	<b>52</b>	<b>0.2</b>

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 4**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 08:20

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	8
10.1 ✓	SG9168283BAL	3287
19.5	CC454190	6576

Curve Coefficients

Slope	Intercept	Corr. Coeff.
336.7	-31 ✓	0.9998 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	5
10.2 ✓	SG9168283BAL	3276
20.4 ✓	CC454190	6722

Curve Coefficients

Slope	Intercept	Corr. Coeff.
329.3	-20 ✓	0.9999 ✓

✓

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 4**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 08:20

**O<sub>2</sub>**

Method: EPA 3A  
Span Conc. 19.5 %

Slope 336.7                      Intercept -31.5

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	8	0.1	0.1	0.5 ✓	Pass
10.1	3287	9.9	-0.2	-1.0 ✓	Pass
19.5	6576	19.6	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.4 %

Slope 329.3                      Intercept -19.9

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	5	0.1	0.1	0.5 ✓	Pass
10.2	3276	10.0	-0.2	-1.0 ✓	Pass
20.4	6722	20.5	0.1	0.5 ✓	Pass

*AW*



# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 4**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**File:** C:\Users\Trailer 271\Documents\New Indy\6-25-21b.cem  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** DESKTOP-GQ0I9UV **Trailer:** 271  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>20.0</b>
Span Concentration, %	<b>19.5</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.4</b>



## APPENDIX D

---

### VENT 6

New Indy  
Catawba, SC

15730.001.008  
No. 6 Hood Exhaust  
Paper Machine Vent 6

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
Date	6/25/21 ✓	6/25/21 ✓	6/25/21 ✓	---
Time Began	1555 ✓	1715 ✓	1820 ✓	---
Time Ended	1655 ✓	1816 ✓	1920 ✓	---
Volumetric Flow Rate, (Qs), DSCFM	4.18E+04 ✓	4.18E+04 ✓	4.21E+04 ✓	4.19E+04
BWS	0.254 ✓	0.264 ✓	0.219 ✓	0.245
% Oxygen	20.2 ✓	20.2 ✓	20.2 ✓	20.2

---

<b>Total Reduced Sulfur</b>	(TRS MW)=	34.08			
Concentration, ppm		0.57 ✓	0.59 ✓	0.59 ✓	0.58
Emission Rate, lb/hr		0.13	0.13	0.13	0.13

---

*AM*

New Indy  
Catawba, SC

15730.001.008  
No. 6 Hood Exhaust

**Paper Machine Vent 6**

**ISOKINETIC CALCULATIONS**

Run Number	1	2	3	Mean
Date	6/25/21 ✓	6/25/21 ✓	6/25/21 ✓	---
Time Began	1555 ✓	1715 ✓	1820 ✓	---
Time Ended	1659 ✓	1808 ✓	1914 ✓	---

**INPUT DATA**

Sampling Time, min	(Theta)	48.0 ✓	48 ✓	48 ✓	48
Stack Diameter, in.	(Dia.)	52 ✓	52 ✓	52 ✓	52
Barometric Pressure, in. Hg	(Pb)	29.68 ✓	29.68 ✓	29.68 ✓	29.68
Static Pressure, in. H2O	(Pg)	-0.75 ✓	-0.75 ✓	-0.75 ✓	-0.75
Pitot Tube Coefficient	(Cp)	0.84 ✓	0.84 ✓	0.84 ✓	0.84
Meter Correction Factor	(Y)	1.0030 ✓	1.0030 ✓	1.0030 ✓	1.0030
Orifice Calibration Value	(Delta H@)	1.8000 ✓	1.8000 ✓	1.8000 ✓	1.8000
Nozzle Diameter, in.	(Dn)	0.250 ✓	0.250 ✓	0.250 ✓	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	30.737 ✓	31.150 ✓	31.398 ✓	31.095
Meter Temperature, °F	(Tm)	87.9 ✓	92.5 ✓	91.9 ✓	90.8
Meter Temperature, °R	(Tm-R)	547.9	552.5	551.9	550.8
Meter Orifice Pressure, in. H2O	(Delta H)	1.300 ✓	1.300 ✓	1.300 ✓	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> )avg	1.140 ✓	1.140 ✓	1.140 ✓	1.140
Volume H2O Collected, mL	(Vlc)	213.5 ✓	226.0 ✓	178.5 ✓	206.0
CO2 Concentration, %	(CO2)	0.2 ✓	0.2 ✓	0.2 ✓	0.2
O2 Concentration, %	(O2)	20.2 ✓	20.2 ✓	20.2 ✓	20.2
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> )avg	1.196 ✓	1.210 ✓	1.158 ✓	1.188
Stack Temperature, °F	(Ts)	191.3 ✓	191.2 ✓	190.3 ✓	190.9
Stack Temperature, °R	(Ts-R)	651.3	651.2	650.3	650.9
Moisture Fraction (at Saturation)	(BWS)	0.660	0.659	0.646	0.655

**CALCULATED DATA**

Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	14.75 ✓	14.75 ✓	14.75 ✓	14.75
Stack Pressure, in. Hg	(Ps)	29.62	29.62	29.62	29.62
Meter Pressure, in. Hg	(Pm)	29.78	29.78	29.78	29.78
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	29.554	29.702	29.971	29.742
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	10.049	10.638	8.402	9.696
Moisture Fraction (Measured)	(BWS)	0.254	0.264	0.219	0.245
Moisture Fraction (lower sat/meas)	(BWS)	0.254	0.264	0.219	0.245
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	28.84	28.84	28.84	28.84
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	26.09	25.98	26.47	26.18
Average Stack Gas Velocity, ft/sec	(Vs)	78.85	79.90	75.73	78.16
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	69772	70706	67009	69162
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	41777	41778	42058	41871
Calibration check	(Yqa)	1.0196	1.0103	1.0018	1.011
Percent difference from Y					0.76%

*AM*



No. 6 Hood Exhaust

**Isokinetic Field Data**

**Method: EPA 4, Moisture**

Client New Indy  
 Location/Plant Catawba, SC  
 Source Roof  
 Sample Location Roof  
 W. O. Number 15730.001.008  
 Run Number 1  
 Date 6/25/21  
 Test Personnel BEA/BE  
 Sample Time 48 min.

Console ID A023  
 Meter Corr., Y 1.003  
 Console ΔH@ 1.800  
 Probe ID/Length PR6C-6'  
 Liner Material SS  
 Pitot ID/Coeff. P77 0.84  
 Thermo ID A023  
 Nozzle ID/Diams. \_\_\_\_\_  
 Avg. Nozzle Diam. .250 in. Total Traverse Points 16

Ambient Temp. 81 °F  
 Baro. Pressure\* 29.688 in. Hg  
 Static Pressure -7.5 in. H<sub>2</sub>O  
 Impinger Gain 204.7 mL  
 Silica Gel Gain 8.8 g  
 Stack Area 19.75 ft<sup>2</sup>  
 Filter ID N/A  
 Sample ID Run 1

K Factor N/A  
 Leak Checks  
 Volume, ft<sup>3</sup> 0.002 Initial 0.002 Final 0.000  
 @ Vac., in. Hg 12" 5"  
 Pitot Good Good

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
0		15:65			913.394									
A-1	3		1.7	1.3	915.1	189	N/A	87	243	252	N/A	65	2	
2	6		1.4	1.3	917.0	192		87	243	254		62	2	
3	9		1.2	1.3	919.0	192		87	242	250		56	2	
4	12		1.4	1.3	920.9	193		87	242	253		56	2	
5	15		1.5	1.3	922.8	192		87	241	256		58	2	
6	18		1.4	1.3	924.7	192		87	244	249		60	2	
7	21		1.6	1.3	926.7	192		87	245	254		61	2	
8	24		1.6	1.3	928.6	191		88	241	253		61	2	
B-1	27		1.2	1.3	930.5	189		88	241	250		66	2	
2	30		1.1	1.3	932.5	190		88	240	251		64	2	
3	33		1.1	1.3	934.4	191		88	243	253		66	2	
4	36		1.4	1.3	936.3	191		89	241	256		64	2	
5	39		1.5	1.3	938.2	191		89	242	247		61	2	
6	42		1.7	1.3	940.2	193		89	240	247		61	2	
7	45		1.6	1.3	942.1	192		90	243	257		61	2	
8	48	16:59	1.6	1.3	944.081	191		89	242	295		59	2	
			Avg. V <sub>ap</sub>	Avg. ΔH	Total Volume	Avg. T <sub>s</sub>	Avg. T <sub>m</sub>		Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-sth</sub> scf
			1.4375	1.300	30.737	191.3	87.5		240/245	245/257		66	2	

\*Barometric Pressure is at port elevation

Flue Gas Composition  
 Oxygen, % 20.6  
 Carbon Dioxide, % 0.2  
 Moisture, % \_\_\_\_\_

O<sub>2</sub>/CO<sub>2</sub> by Orsat M3A  
 Leak Check, Pre-run \_\_\_\_\_  
 Post-run \_\_\_\_\_

Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 Result \_\_\_\_\_

Q<sub>s</sub>, dscfm \_\_\_\_\_  
 % Isokinetic \_\_\_\_\_  
 Calculated by \_\_\_\_\_  
 QC by GA



Comments \_\_\_\_\_

Integrated Air Services



*No. 6 Hood Exhaust*

**Isokinetic Field Data**

**Method: EPA 4, Moisture**

Client New Indy  
 Location/Plant Catawba, SC  
 Source 6 Hood Exhaust  
 Sample Location 15730.001.008  
 W. O. Number 2  
 Run Number 6175/121  
 Date 03/13/21  
 Test Personnel BJA/BZ  
 Sample Time 48 min.

Console ID A623  
 Meter Corr., Y 1.003  
 Console ΔH@ 1.800  
 Probe ID/Length PR6C-6'  
 Liner Material SS  
 Pitot ID/Coeff. P77 0.84  
 Thermo ID A623  
 Nozzle ID/Diams. .250 in.

Ambient Temp. 82 °F  
 Baro. Pressure\* 27.68 in. Hg  
 Static Pressure -.75 in. H<sub>2</sub>O  
 Impinger Gain 218.6 mL  
 Silica Gel Gain 7.4 g  
 Stack Area 14.75 ft<sup>2</sup>  
 Total Traverse Points 16

K Factor N/A  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	<u>12"</u>	<u>6"</u>
Pitot	<u>Good</u>	<u>Good</u>

Filter ID N/A  
 Sample ID run 2

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
A-1	0	17:15	1.3	1.3	945.194	191	N/A	90	245	249	N/A	65	39	
2	3		1.2	1.3	947.1	171		91	241	255		65	39	
3	6		1.2	1.3	949.0	191		91	244	255		65	39	
4	9		1.1	1.3	951.0	191		91	243	250		63	4	
5	12		1.5	1.3	953.0	191		92	242	254		64	4	
6	15		1.5	1.3	954.8	192		92	244	256		64	4	
7	18		1.7	1.3	956.8	192		93	240	246		65	4	
8	21		1.7	1.3	958.7	192		93	241	249		65	4	
B-1	24		1.7	1.3	960.6	190		92	292	257		67	4	
2	27		1.5	1.3	962.6	192		93	244	246		61	4	
3	30		1.5	1.3	964.5	192		93	243	251		69	4	
4	33		1.5	1.3	966.5	192		94	244	256		57	4	
5	36		1.6	1.3	968.4	191		93	243	255		55	4	
6	39		1.5	1.3	970.3	191		94	244	273		54	4	
7	42		1.5	1.3	972.3	191		94	244	245		55	4	
8	45		1.6	1.3	974.2	190		94	244	293		55	4	
8	48	18:08	1.6	1.3	976.294	190		94	291	293		55	4	
*Barometric Pressure is at port elevation			Avg V <sub>Δp</sub>	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>	O <sub>2</sub> /CO <sub>2</sub>	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub> scf
			1.2097	1.300	31.15	191.2	92.5	24/245	243/257	243/257	243/257	67	4	

Flue Gas Composition  
 Oxygen, % 20.2  
 Carbon Dioxide, % 0.2  
 Moisture, %

Thermocouple Check  
 Meter Temp., °F 87  
 Ref. Temp., °F 87  
 Result

Isokinetic  
 Calculated by   
 QC by





No. 4 Hood Exhaust

**Isokinetic Field Data**

**Method: EPA 4, Moisture**

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: 6-No. 4 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/25/21  
 Test Personnel: DEA/DE  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PR6C-6"  
 Liner Material: 53  
 Pitot ID/Coeff.: RR6C-6" 0.84 P77  
 Thermo ID: A023  
 Nozzle ID/Diams.: 7.50 in.  
 Avg. Nozzle Diam.: 7.50 in.  
 Total Traverse Points: 16

Ambient Temp. 82 °F  
 Baro. Pressure\* 27.68 in. Hg  
 Static Pressure -7.5 in. H<sub>2</sub>O  
 Impinger Gain 170.9 mL  
 Silica Gel Gain 7.6 g  
 Stack Area 14.75 ft<sup>2</sup>

K Factor N/A  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	<u>0.002</u>	<u>0.000</u>
Pitot	<u>12"</u>	<u>5"</u>
	<u>Good</u>	<u>Good</u>

Filter ID: N/A  
 Sample ID: RUM 3

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
A-1	0	18:20	1.6	1.3	976.578	191	N/A	92	243	295	N/A	66	2	
2	3		1.6	1.3	978.7	191		92	243	295		59	2	
3	6		1.6	1.3	980.7	191		92	245	298		55	2	
4	9		1.5	1.3	982.7	191		72	244	252		52	2	
5	12		1.6	1.3	984.6	191		93	246	245		53	2	
6	15		1.6	1.3	986.6	191		72	245	251		53	2	
7	18		1.5	1.3	988.5	191		92	245	256		53	2	
8	21		1.6	1.3	990.4	191		92	241	258		53	2	
B-1	24		1.6	1.3	992.3	190		72	241	249		53	2	
2	27		1.2	1.3	994.3	188		92	287	250		57	2	
3	30		1.3	1.3	996.2	189		92	242	250		54	2	
4	33		1.3	1.3	998.1	189		92	240	246		53	2	
5	36		.71	1.3	1000.1	190		92	242	251		54	2	
6	39		.70	1.3	1002.0	190		91	246	250		55	2	
7	42		.68	1.3	1003.9	190		92	241	251		54	2	
8	45		1.7	1.3	1005.9	191		91	241	249		55	2	
8	48	19:14	1.7	1.3	1007.976	191		91	242	244		56	2	
			Avg √Δp	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub> scf
			1.1579	1.300	31.398	190.3	91.9	237/246	244/258	244/258	244/258	66	2	
			1.368	1.1402										

\*Barometric Pressure is at port elevation  
 Thermocouple Check: Meter Temp, °F 66 Max Temp 66 V<sub>m-std</sub> scf 2  
 Ref. Temp, °F 66 Calculated by QC by [Signature]

Flue Gas Composition: O<sub>2</sub>/CO<sub>2</sub> by Orsat 20.2 Fyrite M3A  
 Leak Check, Pre-run 0.2 Post-run 0.2  
 Oxygen, % 20.2  
 Carbon Dioxide, % 0.2  
 Moisture, % 0.2

**WESTON SOLUTIONS**  
 Integrated Air Services

Comments: \_\_\_\_\_  
 Result: \_\_\_\_\_



# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 3 Hood Exhaust  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEARBE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	881.3	878.9	671.8		868.6	
Initial	753.7	815.1	658.5	✓	859.8	
Gain	127.6 ✓	63.8 ✓	13.3 ✓		8.8 ✓	213.5 ✓

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 2 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEARBE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	945.2	711.1	558.6		908.4	
Initial	775.7	666.8	553.8	✓	901.0	
Gain	169.5 ✓	44.3 ✓	4.8 ✓		7.4 ✓	226 ✓

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 3 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEARBE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	857.8	783.2	637.4		873.4	
Initial	714.5	759.7	633.3	✓	865.8	
Gain	143.3 ✓	23.5 ✓	4.1 ✓		7.6 ✓	178.5 ✓

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Check COC for Sample IDs of Media Blanks

# Sample and Velocity Traverse Point Data Sheet - Method 1

15730.001.008  
 Equip. #3 Paper Machine,  
 #2-3 SDTV's, & #1-2 CB's  
 Emission Report

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 6 Hood Exhaust

Operator VD / LF  
 Date 15-Jun-21  
 W.O. Number 15730.001.008

**Duct Type**  Circular  Rectangular Duct Indicate appropriate type  
**Traverse Type**  Particulate Traverse  Velocity Traverse



Distance from far wall to outside of port (in.) = C	52.125
Port Depth (in.) = D	0.125
Depth of Duct, diameter (in.) = C-D	52
Area of Duct (ft <sup>2</sup> )	14.75
Total Traverse Points	16
Total Traverse Points per Port	8

**Rectangular Ducts Only**

Width of Duct, rectangular duct only (in.)	
Total Ports (rectangular duct only)	

Traverse Point Locations			
Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	3.2	1 1/2	2
2	10.5	5 1/2	5 1/2
3	19.4	10	10
4	32.3	17	17
5	67.7	35	35 1/2
6	80.6	42	42
7	89.5	46 1/2	46 1/2
8	96.8	50 1/2	50 1/2
9			
10			
11			
12			

Flow Disturbances	
Upstream - A (ft)	4.330
Downstream - B (ft)	25.0
Upstream - A (duct diameters)	1.00
Downstream - B (duct diameters)	5.77



Equivalent Diameter =  $(2 * L * W) / (L + W)$

**Traverse Point Location Percent of Stack -Circular**  
 Number of Traverse Points

		1	2	3	4	5	6	7	8	9	10	11	12
T r a v e r s e P o i n t	1		14.6		6.7		4.4		3.2		2.6		2.1
	2		85.4		25		14.6		10.5		8.2		6.7
	3			75		29.6		19.4		14.6		11.8	
	4				93.3		70.4		32.3		22.6		17.7
	5					85.4		67.7		34.2		25	
	6						95.6		80.6		65.8		35.6
	7							89.5		77.4		64.4	
	8								96.8		85.4		75
	9									91.8		82.3	
	10										97.4		88.2
	11											93.3	
	12												97.9

**Traverse Point Location Percent of Stack -Rectangular**  
 Number of Traverse Points


		1	2	3	4	5	6	7	8	9	10	11	12
T r a v e r s e P o i n t	1		25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
	2		75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
	3			83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
	4				87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
	5					90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
	6						91.7	78.6	68.8	61.1	55.0	50.0	45.8
	7							92.9	81.3	72.2	65.0	59.1	54.2
	8								93.8	83.3	75.0	68.2	62.5
	9									94.4	85.0	77.3	70.8
	10										95.0	86.4	79.2
	11											95.5	87.5
	12												95.8

- Rectangular Stack Points & Matrix**
- 9 - 3 x 3
  - 12 - 4 x 3
  - 16 - 4 x 4
  - 20 - 5 x 4
  - 25 - 5 x 5
  - 30 - 6 x 5
  - 36 - 6 x 6
  - 42 - 7 x 6
  - 49 - 7 x 7

Port Diam. (in) = 4  
 Number of Ports = 2

Tape Measure I.D. # TM-07





# RUN SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** *ALP*

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**Start Time 15:55    End Time 16:55**

---

**Average Measured TRS Conc.**    0.56 ppm ✓  
**Recovery No. 5**    98.2 % -  
**TRS Corrected for Recovery**    0.57 ppm ✓



# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** *16*

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**Start Time 17:15    End Time 18:16**

---

**Average Measured TRS Conc.    0.58 ppm**  
**Recovery No. 5    98.2 %**  
**TRS Corrected for Recovery    0.59 ppm** ✓

# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 1** *CP*

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**Start Time 18:20    End Time 19:20**

---

**Average Measured TRS Conc.    0.57 ppm**  
**Recovery No. 5    98.2 %**  
**TRS Corrected for Recovery    0.59 ppm ✓**



# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** *14*

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
15:55	46	0.37	26	0.31	<2	<0.07	15	0.07	0.83
15:58	<2	<0.07	14	0.23	16	0.21	<2	<0.02	0.44
16:01	21	0.25	<2	<0.08	<2	<0.07	19	0.08	0.41
16:04	111	0.59	<2	<0.08	39	0.35	<2	<0.02	0.94
16:07	<2	<0.07	<2	<0.08	14	0.20	37	0.12	0.43
16:10	<2	<0.07	15	0.23	95	0.56	<2	<0.02	0.79
16:13	23	0.26	<2	<0.08	11	0.18	3	0.03	0.49
16:16	7	0.14	<2	<0.08	<2	<0.07	<2	<0.02	0.14
16:19	<2	<0.07	<2	<0.08	9	0.16	<2	<0.02	0.16
16:22	43	0.36	24	0.30	39	0.35	<2	<0.02	1.00
16:25	<2	<0.07	<2	<0.08	25	0.27	54	0.14	0.56
16:28	<2	<0.07	<2	<0.08	28	0.29	<2	<0.02	0.29
16:31	21	0.25	<2	<0.08	20	0.24	50	0.14	0.76
16:34	9	0.16	18	0.26	<2	<0.07	<2	<0.02	0.41
16:37	42	0.35	<2	<0.08	74	0.49	26	0.10	1.04
16:40	<2	<0.07	<2	<0.08	17	0.22	19	0.08	0.38
16:43	41	0.35	<2	<0.08	13	0.19	23	0.09	0.72
16:46	21	0.25	<2	<0.08	<2	<0.07	32	0.11	0.46
16:49	29	0.29	<2	<0.08	7	0.14	<2	<0.02	0.43
16:52	<2	<0.07	<2	<0.08	63	0.45	8	0.05	0.55

**Average**                      **0.18**                      **<0.08**                      **0.22**                      **0.05**                      **0.56**

*SH*

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** *16*

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
17:15	<2	<0.07	21	0.28	16	0.22	16	0.07	0.65
17:18	14	0.19	49	0.44	<2	<0.07	<2	<0.02	0.63
17:21	9	0.16	61	0.49	41	0.36	19	0.08	1.17
17:24	<2	<0.07	4	0.12	14	0.20	18	0.08	0.47
17:27	<2	<0.07	<2	<0.08	<2	<0.07	<2	<0.02	-
17:30	<2	<0.07	<2	<0.08	14	0.20	6	0.04	0.29
17:33	10	0.16	<2	<0.08	<2	<0.07	<2	<0.02	0.16
17:36	5	0.12	31	0.34	<2	<0.07	27	0.10	0.66
17:39	9	0.15	6	0.15	<2	<0.07	<2	<0.02	0.30
17:42	38	0.34	<2	<0.08	<2	<0.07	<2	<0.02	0.34
17:45	21	0.24	35	0.37	19	0.23	<2	<0.02	0.85
17:48	21	0.25	10	0.19	<2	<0.07	30	0.10	0.64
17:52	63	0.44	<2	<0.08	<2	<0.07	<2	<0.02	0.44
17:55	4	0.10	<2	<0.08	37	0.34	24	0.09	0.62
17:58	19	0.23	61	0.49	12	0.19	<2	<0.02	0.91
18:01	52	0.40	39	0.39	<2	<0.07	20	0.08	0.95
18:04	15	0.21	49	0.44	<2	<0.07	<2	<0.02	0.65
18:07	89	0.53	<2	<0.08	37	0.34	<2	<0.02	0.86
18:10	51	0.39	<2	<0.08	<2	<0.07	70	0.16	0.72
18:13	10	0.17	<2	<0.08	<2	<0.07	16	0.07	0.32

**Average**                      **0.20**                      **0.18**                      **0.10**                      **0.04**                      **0.58** ✓

*dy*

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** *76*

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
18:20	8	0.14	<2	<0.08	10	0.17	30	0.10	0.52
18:23	<2	<0.07	22	0.29	<2	<0.07	<2	<0.02	0.29
18:26	10	0.16	<2	<0.08	27	0.28	19	0.08	0.61
18:29	9	0.16	<2	<0.08	11	0.18	40	0.12	0.57
18:32	8	0.15	<2	<0.08	<2	<0.07	45	0.13	0.40
18:35	33	0.31	14	0.23	27	0.28	19	0.08	0.98
18:38	17	0.22	<2	<0.08	<2	<0.07	<2	<0.02	0.22
18:41	8	0.15	15	0.24	31	0.30	111	0.21	1.11
18:44	<2	<0.07	7	0.16	29	0.30	33	0.11	0.67
18:47	14	0.20	<2	<0.08	23	0.26	36	0.11	0.69
18:50	31	0.30	<2	<0.08	<2	<0.07	17	0.08	0.46
18:53	<2	<0.07	<2	<0.08	51	0.40	14	0.07	0.54
18:56	8	0.15	<2	<0.08	22	0.25	9	0.05	0.51
18:59	12	0.18	<2	<0.08	11	0.18	29	0.10	0.56
19:02	56	0.41	8	0.17	<2	<0.07	<2	<0.02	0.58
19:05	68	0.46	13	0.22	4	0.10	<2	<0.02	0.78
19:08	<2	<0.07	<2	<0.08	<2	<0.07	<2	<0.02	-
19:11	97	0.55	<2	<0.08	<2	<0.07	72	0.17	0.89
19:14	42	0.35	<2	<0.08	20	0.24	<2	<0.02	0.59
19:17	14	0.20	13	0.22	6	0.12	<2	<0.02	0.54
<b>Average</b>		<b>0.20</b>		<b>&lt;0.08</b>		<b>0.15</b>		<b>0.07</b>	<b>0.5755</b> ✓

*5/8*

# RUN DATA

Number 14

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine Vent #16**

Method **16**  
 Calibration **1**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
<b>Calibration drift check</b>									
20:16	14345	7.84	<2	<0.08	<2	<0.07	<2	<0.02	7.84
20:19	14713	7.94	<2	<0.08	<2	<0.07	<2	<0.02	7.94
20:22	14122	7.77	<2	<0.08	<2	<0.07	<2	<0.02	7.77
<b>Average</b>		<b>7.85</b>		<b>&lt;0.08</b>		<b>&lt;0.07</b>		<b>&lt;0.02</b>	<b>7.85</b>

*SV*

# RECOVERY DATA

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** ✓

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

After Run 10    Before Run 11  
Start Time 15:41    End Time 15:52

---

Recovery Gas to Probe, Time 15:41

Peak Areas, mv-sec			Average	ppm
13485	14713	15050	14416	7.86

---

Recovery Gas to GC, Time 15:48

Peak Areas, mv-sec			Average	ppm
15015	14984	15595	15198	8.08

---

Recovery 97.2% ✓

---

✓

# RECOVERY DATA

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent #6**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

After Run 13    Before Run 14  
Start Time 19:19    End Time 19:29

---

Recovery Gas to Probe, Time 19:19

Peak Areas, mv-sec			Average	ppm
13784	14634	14808	14409	7.85

---

Recovery Gas to GC, Time 19:26

Peak Areas, mv-sec			Average	ppm
14826	14809	15121	14918	8.00

---

Recovery 98.2% ✓

---

54



# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent #6**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Ambient Temperature: 72°C

Barometric Pressure: 29.70 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	460	457	298	232
Ret. Time, sec	25.0	35.0	63.0	132.0

1 Flow = 42.9 mL/Min	10.7 ppm	10.7 ppm	6.95 ppm	5.41 ppm
<b>Time: 06:02</b>		<b>Peak Areas, mv-sec</b>		
	25099	20594	10407	44232
	24750	21533	10445	46016
	25597	21979	10703	45950
<b>Average Area</b>	<b>25149</b>	<b>21369</b>	<b>10519 ✓</b>	<b>45399</b>
2 Flow = 82.8 mL/Min	5.56 ppm	5.52 ppm	3.60 ppm	2.80 ppm
<b>Time: 06:53</b>		<b>Peak Areas, mv-sec</b>		
	7926	6406	2923	14068
	7950	6306	2884	13591
	8444	6460	2990	14698
<b>Average Area</b>	<b>8107</b>	<b>6390 ✓</b>	<b>2932</b>	<b>14119</b>
3 Flow = 130 mL/Min	3.54 ppm	3.52 ppm	2.29 ppm	1.79 ppm
<b>Time: 07:08</b>		<b>Peak Areas, mv-sec</b>		
	3069	2599	1371	5786
	3064	2578	1331	5729
	3088	2512	1340	5842
<b>Average Area</b>	<b>3074 ✓</b>	<b>2563</b>	<b>1347</b>	<b>5786</b>

SH

# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent #6**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

H <sub>2</sub> S	1	2	3			
Time	06:02	06:53	07:08			
Concentration, ppm	10.7	5.56	3.54			
Area, mv-sec	25149	8107	3074			
Calc. Conc., ppm	10.6	5.79	3.46			
% Error	-1.6	4.2	-2.4 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.8847	2.4717	0.9980	2	0.07	

MeSH	1	2	3			
Time	06:02	06:53	07:08			
Concentration, ppm	10.7	5.52	3.52			
Area, mv-sec	21369	6390	2563			
Calc. Conc., ppm	10.6	5.62	3.48			
% Error	-0.7	1.8	-1.1 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.9089	2.3742	0.9996	2	0.08	

DMS	1	2	3			
Time	06:02	06:53	07:08			
Concentration, ppm	6.95	3.60	2.29			
Area, mv-sec	10519	2932	1347			
Calc. Conc., ppm	7.00	3.53	2.32			
% Error	0.8	-2.0	1.2 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.8617	2.4483	0.9995	2	0.07	

DMDS	1	2	3			
Time	06:02	06:53	07:08			
Concentration, ppm	5.41	2.80	1.79			
Area, mv-sec	45399	14119	5786			
Calc. Conc., ppm	5.37	2.86	1.77			
% Error	-0.8	2.0	-1.2 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.8537	3.3043	0.9995	2	0.02	

# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent #6**

Method 16

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Ambient Temperature: 72°C

Barometric Pressure: 29.70 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	460	457	298	232
Ret. Time, sec	25.0	35.0	63.0	132.0

1 Flow = 43.6 mL/Min      10.5 ppm      10.5 ppm      6.82 ppm      5.31 ppm

Time: 19:32

Peak Areas, mv-sec

	23668	22380	10086	46114
	24884	23771	10653	47622
	24624	24375	10810	50274
<u>Average Area</u>	<b>24392</b> ✓	<b>23509</b>	<b>10516</b>	<b>48003</b>

2 Flow = 65.8 mL/Min      6.99 ppm      6.95 ppm      4.53 ppm      3.53 ppm

Time: 19:43

Peak Areas, mv-sec

	14069	11744	5164	24545
	13746	12537	5293	24899
	13905	12112	5280	24958
<u>Average Area</u>	<b>13907</b>	<b>12131</b> ✓	<b>5246</b>	<b>24800</b>

3 Flow = 123 mL/Min      3.74 ppm      3.71 ppm      2.42 ppm      1.88 ppm

Time: 19:59

Peak Areas, mv-sec

	4288	3691	1547	7409
	4623	3823	1561	7662
	4672	3745	1545	7541
<u>Average Area</u>	<b>4527</b>	<b>3753</b>	<b>1551</b> ✓	<b>7538</b>

54

# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** *ALC*

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

H <sub>2</sub> S	1	2	3		
Time	19:32	19:43	19:59		
Concentration, ppm	10.5	6.99	3.74		
Area, mv-sec	24392	13907	4527		
Calc. Conc., ppm	10.3	7.29	3.68		
% Error	-2.5	4.3	-1.6		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.6380	2.7299	0.9976	2	0.03

MeSH	1	2	3		
Time	19:32	19:43	19:59		
Concentration, ppm	10.5	6.95	3.71		
Area, mv-sec	23509	12131	3753		
Calc. Conc., ppm	10.3	7.11	3.68		
% Error	-1.4	2.4	-0.9		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.7779	2.5690	0.9992	2	0.05

DMS	1	2	3		
Time	19:32	19:43	19:59		
Concentration, ppm	6.82	4.53	2.42		
Area, mv-sec	10516	5246	1551		
Calc. Conc., ppm	6.73	4.63	2.40		
% Error	-1.3	2.2	-0.9		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8539	2.4865	0.9993	2	0.07

DMDS	1	2	3		
Time	19:32	19:43	19:59		
Concentration, ppm	5.31	3.53	1.88		
Area, mv-sec	48003	24800	7538		
Calc. Conc., ppm	5.23	3.62	1.86		
% Error	-1.6	2.7	-1.0		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.7949	3.3916	0.9990	2	0.02

574

# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** *file*

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
<b>Molecular Weight</b>	34.08	48.11	62.14	94.20
<b>Retention Time, sec</b>	25.0	35.0	63.0	132.0
<b>Peak Detection Window, sec</b>	10.0	10.0	10.0	10.0
<b>Minimum Peak Area, mv-sec</b>	2	2	2	2
<b>Minimum Peak Height, mv</b>	1	1	1	1
<b>Beginning Peak Width, sec</b>	1.0	1.0	3.0	3.0
<b>Ending Peak Width, sec</b>	2.0	3.0	5.0	5.0
<b>Permeation Device ID</b>	T-51831	33-50536	89-50725	89-53405
<b>Permeation Rate, ng/min</b>	642 ✓	901 ✓	758 ✓	895 ✓
<b>Permeation Rate, nL/min*</b>	460	457	298	232

**Barometric Pressure:** 29.70 in. Hg    **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**PR<sub>ng</sub>** = Permeation Rate by weight, ng/min

**V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole

**W<sub>mol</sub>** = Molecular Weight of compound

**T<sub>a</sub>** = Ambient Temperature, °F

**T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)

**P<sub>s</sub>** = Standard Pressure = 29.92 in Hg

**P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 642 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.70) \\ = 460 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

**C** = Concentration, ppmv

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**F<sub>d</sub>** = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** *1 Ce*

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun, 2021**

File: E:\6-25-21.trs  
Program Version: 2.0, built 21 Feb 2015 File Version: 2.0  
Computer: JWS-PROGRAMMING Trailer: 271

Analog Input Device: Keithley KUSB-3108 GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: GC-8A Serial No. C10494419420SA  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 100	Primary: 3'
Air	30	60	Detector: 120	Secondary:
Carrier	50	30		Sample Loop: 6" unlined

## Injection Cycle

Total Length: 180 sec Sampling Time: 160 sec Load/Backflush Time: 85 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 5 mv-sec Minimum peak height 5 mv above baseline

## Dynacalibrator

Chamber Temperature 130.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.70 in. Hg



# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 6**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM vent 6 Run 1</b>				
17:56:59	6779	20.2	34	0.2
17:57:14	6779	20.2	35	0.2
17:57:29	6780	20.2	34	0.2
17:57:44	6781	20.2	34	0.2
17:57:59	6779	20.2	35	0.2
17:58:14	6781	20.2	35	0.2
17:58:29	6781	20.2	34	0.2
17:58:44	6778	20.2	35	0.2
17:58:59	6780	20.2	34	0.2
17:59:14	6780	20.2	36	0.2
17:59:29	6780	20.2	34	0.2
17:59:44	6779	20.2	36	0.2
17:59:59	6779	20.2	37	0.2
18:00:14	6780	20.2	36	0.2
18:00:29	6779	20.2	37	0.2
18:00:44	6781	20.2	37	0.2
18:00:59	6780	20.2	38	0.2
18:01:14	6779	20.2	37	0.2
18:01:29	6781	20.2	37	0.2
18:01:44	6779	20.2	37	0.2
18:01:59	6778	20.2	36	0.2
18:02:14	6779	20.2	38	0.2
18:02:29	6774	20.2	41	0.2
18:02:44	6772	20.2	41	0.2
18:02:59	6771	20.2	41	0.2
<b>Avg</b>	<b>6779</b>	<b>20.2</b>	<b>36</b>	<b>0.2</b>

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 6**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM vent 6 Run 2</b>				
18:28:22	6777	20.2	34	0.2
18:28:37	6778	20.2	35	0.2
18:28:52	6775	20.2	33	0.2
18:29:07	6778	20.2	33	0.2
18:29:22	6778	20.2	35	0.2
18:29:37	6779	20.2	35	0.2
18:29:52	6778	20.2	34	0.2
18:30:07	6777	20.2	32	0.2
18:30:22	6779	20.2	34	0.2
18:30:37	6778	20.2	35	0.2
18:30:52	6778	20.2	34	0.2
18:31:07	6778	20.2	33	0.2
18:31:22	6779	20.2	34	0.2
18:31:37	6778	20.2	34	0.2
<b>Avg</b>	<b>6778</b>	<b>20.2</b>	<b>34</b>	<b>0.2</b>

# RUN DATA

Number 3

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine vent 6**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>PM vent 6 Run 3</b>				
19:27:17	6777	20.2	34	0.2
19:27:32	6777	20.2	37	0.2
19:27:47	6777	20.2	34	0.2
19:28:02	6778	20.2	34	0.2
19:28:17	6777	20.2	34	0.2
19:28:32	6777	20.2	36	0.2
19:28:47	6778	20.2	36	0.2
19:29:02	6779	20.2	37	0.2
19:29:17	6777	20.2	38	0.2
19:29:32	6777	20.2	37	0.2
19:29:47	6777	20.2	37	0.2
19:30:02	6777	20.2	35	0.2
19:30:17	6777	20.2	36	0.2
19:30:32	6779	20.2	34	0.2
19:30:47	6778	20.2	33	0.2
<b>Avg</b>	<b>6777</b>	<b>20.2</b>	<b>35</b>	<b>0.2</b>

# RUN DATA

Number 4

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine vent 6**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **25 Jun 2021**

Calibration 1

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
19:44:04	3363	10.1	3207	9.8
19:44:19	3314	9.9	3241	9.9
19:44:34	3314	9.9	3247	9.9
<b>SG9168283BAL 10.12 - O2 10.16 - CO2</b>				
19:44:49	3313	9.9	3246	9.9
19:45:04	3311	9.9	3247	9.9
19:45:19	3312	9.9	3250	9.9
19:45:34	3312	9.9	3248	9.9
19:45:49	3311	9.9	3249	9.9
19:46:04	3311	9.9	3249	9.9
19:46:19	3312	9.9	3251	9.9
19:46:34	3311	9.9	3251	9.9
19:46:49	3311	9.9	3250	9.9
19:47:04	3310	9.9	3248	9.9
19:47:19	3311	9.9	3248	9.9
<b>Avg</b>	<b>3315</b>	<b>9.9</b>	<b>3245</b>	<b>9.9</b>

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 6**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 08:20

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	8
10.1 ✓	SG9168283BAL	3287
19.5 ✓	CC454190	6576

Curve Coefficients

Slope	Intercept	Corr. Coeff.
336.7 ✓	-31 ✓	0.9998 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	5
10.2 ✓	SG9168283BAL	3276
20.4 ✓	CC454190	6722

Curve Coefficients

Slope	Intercept	Corr. Coeff.
329.3 ✓	-20 ✓	0.9999 ✓

*Handwritten signature*

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 6**

Calibration 1

Project Number: **15730.001.008**

Operator: **VD**

Date: **25 Jun 2021**

Start Time: 08:20

**O<sub>2</sub>**

Method: EPA 3A

Span Conc. 19.5 %

Slope 336.7

Intercept -31.5

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	8	0.1	0.1	0.5 ✓	Pass
10.1	3287	9.9	-0.2	-1.0 ✓	Pass
19.5	6576	19.6	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.4 %

Slope 329.3

Intercept -19.9

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	5	0.1	0.1	0.5 ✓	Pass
10.2	3276	10.0	-0.2	-1.0 ✓	Pass
20.4	6722	20.5	0.1	0.5 ✓	Pass

✓

# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 6**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**File:** C:\Users\Trailer 271\Documents\New Indy\6-25-21c.cem  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** DESKTOP-GQ0I9UV **Trailer:** 271  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>20.0</b>
Span Concentration, %	<b>19.5</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.4</b>





## VENT 7

New Indy  
 Catawba, SC

15730.001.008  
 No. 7 Hood Exhaust  
 Paper Machine Vent 7

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
Date	6/26/21 ✓	6/26/21 ✓	6/26/21 ✓	---
Time Began	945 ✓	1050 ✓	1155 ✓	---
Time Ended	1046 ✓	1150 ✓	1255 ✓	---
Volumetric Flow Rate, (Qs), DSCFM	6.40E+04 ✓	6.42E+04 ✓	6.52E+04 ✓	6.45E+04
BWS	0.261 ✓	0.242 ✓	0.254 ✓	0.252
% Oxygen	20.2 ✓	20.2 ✓	20.2 ✓	20.2

---

<b>Total Reduced Sulfur</b>	(TRS MW)=	34.08				
Concentration, ppm			0.42 ✓	0.43 ✓	0.52 ✓	0.46
Emission Rate, lb/hr			0.14 ✓	0.15 ✓	0.18 ✓	0.16

---

*As for SH ✓*

New Indy  
Catawba, SC

15730.001.008  
No. 7 Hood Exhaust

### Paper Machine Vent 7

#### ISOKINETIC CALCULATIONS

Run Number		1	2	3	Mean
Date		6/26/21 ✓	6/26/21 ✓	6/26/21 ✓	---
Time Began		945 ✓	1050 ✓	1155 ✓	---
Time Ended		1037 ✓	1145 ✓	1249 ✓	---
INPUT DATA					
Sampling Time, min	(Theta)	48.0 ✓	48 ✓	48 ✓	48
Stack Diameter, in.	(Dia.)	66 ✓	66 ✓	66 ✓	66
Barometric Pressure, in. Hg	(Pb)	29.68 ✓	29.68 ✓	29.68 ✓	29.68
Static Pressure, in. H2O	(Pg)	-0.30 ✓	-0.30 ✓	-0.30 ✓	-0.30
Pitot Tube Coefficient	(Cp)	0.84 ✓	0.84 ✓	0.84 ✓	0.84
Meter Correction Factor	(Y)	1.0030 ✓	1.0030 ✓	1.0030 ✓	1.0030
Orifice Calibration Value	(Delta H@)	1.8000 ✓	1.8000 ✓	1.8000 ✓	1.8000
Nozzle Diameter, in.	(Dn)	0.250 ✓	0.250 ✓	0.250 ✓	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	30.393 ✓	30.677 ✓	30.480 ✓	30.517
Meter Temperature, °F	(Tm)	79.3 ✓	86.1 ✓	92.1 ✓	85.8
Meter Temperature, °R	(Tm-R)	539.3 ✓	546.1 ✓	552.1 ✓	545.8
Meter Orifice Pressure, in. H2O	(Delta H)	1.300 ✓	1.300 ✓	1.300 ✓	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> avg)	1.140 ✓	1.140 ✓	1.140 ✓	1.140
Volume H2O Collected, mL	(Vlc)	223.0 ✓	201.0 ✓	210.4 ✓	211.5
CO2 Concentration, %	(CO2)	0.2 ✓	0.1 ✓	0.2 ✓	0.2
O2 Concentration, %	(O2)	20.2 ✓	20.2 ✓	20.2 ✓	20.2
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> avg)	1.144 ✓	1.122 ✓	1.157 ✓	1.141
Stack Temperature, °F	(Ts)	187.7 ✓	188.2 ✓	189.9 ✓	188.6
Stack Temperature, °R	(Ts-R)	647.7 ✓	648.2 ✓	649.9 ✓	648.6
Moisture Fraction (at Saturation)	(BWS)	0.610 ✓	0.617 ✓	0.640 ✓	0.622
CALCULATED DATA					
Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04 ✓	3.41E-04 ✓	3.41E-04 ✓	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	23.76 ✓	23.76 ✓	23.76 ✓	23.76
Stack Pressure, in. Hg	(Ps)	29.66 ✓	29.66 ✓	29.66 ✓	29.66
Meter Pressure, in. Hg	(Pm)	29.78 ✓	29.78 ✓	29.78 ✓	29.78
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	29.690 ✓	29.594 ✓	29.084 ✓	29.456
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	10.497 ✓	9.461 ✓	9.904 ✓	9.954
Moisture Fraction (Measured)	(BWS)	0.261 ✓	0.242 ✓	0.254 ✓	0.252
Moisture Fraction (lower sat/meas)	(BWS)	0.261 ✓	0.242 ✓	0.254 ✓	0.252
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	28.84 ✓	28.82 ✓	28.84 ✓	28.83
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	26.01 ✓	26.20 ✓	26.09 ✓	26.10
Average Stack Gas Velocity, ft/sec	(Vs)	75.29 ✓	73.59 ✓	76.12 ✓	75.00
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	107321 ✓	104899 ✓	108506 ✓	106908
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	64044 ✓	64155 ✓	65159 ✓	64452
Calibration check	(Yqa)	1.0230 ✓	1.0202 ✓	1.0322 ✓	1.025
Percent difference from Y					2.21%

AB for SH ✓



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 7 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 1  
 Date: 6/26/21  
 Test Personnel: BSA/BL  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PR6C-6'  
 Liner Material: 55  
 Pitot ID/Coeff.: 0.77  
 Thermo ID: A023  
 Nozzle ID/Diams.: 0.250 in.

Ambient Temp. 73 °F  
 Baro. Pressure: 29.68 in. Hg  
 Static Pressure: 0.30 in. H<sub>2</sub>O  
 Impinger Gain: 214.7 mL  
 Silica Gel Gain: 8.1 g  
 Stack Area: 23.76 ft<sup>2</sup>

K Factor: N/A  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	0.001	0.000
Pitot	12"	5"
	Good	Good

Filter ID: N/A  
 Sample ID: RUN1


Total Traverse Points: 16

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
A-1	0	09:45	1.2	1.3	8.360	190	N/A	76	246	252	N/A	61	3	
2	3		1.2	1.3	10.5	190		77	245	251		51	3	
3	6		1.3	1.3	12.2	190		77	244	254		51	3	
4	9		1.3	1.3	14.0	189		78	245	250		51	3	
5	12		1.1	1.3	15.9	189		78	248	253		51	3	
6	15		1.1	1.3	17.7	189		79	244	252		53	3	
7	18		1.3	1.3	19.6	188		79	242	254		54	3	
8	21		1.2	1.3	21.5	188		79	243	255		55	5	
B-1	24		1.5	1.3	23.4	186		79	242	252		59	3	
2	27		1.5	1.3	25.3	187		80	247	252		58	3	
3	30		1.4	1.3	27.2	187		80	245	255		60	3	
4	33		1.5	1.3	29.2	187		80	245	252		62	3	
5	36		1.5	1.3	31.1	187		81	247	254		62	3	
6	39		1.4	1.3	33.0	187		81	245	255		64	3	
7	42		1.3	1.3	34.9	187		82	243	254		64	3	
8	45		1.2	1.3	36.8	187		82	246	256		64	3	
8	48	10:57	1.2	1.3	38.743	182		82	246	256		64	3	
			Avg V <sub>ap</sub> : 1.144	Avg ΔH: 1.300	Total Volume: 30.393	Avg T <sub>m</sub> : 187.7		79.3	242/248	250/256		66	3	

\*Barometric Pressure is at port elevation

Flue Gas Composition  
 Oxygen, %: 20.2  
 Carbon Dioxide, %: 0.2  
 Moisture, %: \_\_\_\_\_

Thermocouple Check  
 Meter Temp., °F: 192 % Isokinetic  
 Ref. Temp., °F: 191.6 Calculated by  
 Result: 95% QC by \_\_\_\_\_



Integrated Air Services



# Isokinetic Field Data

# Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 7 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 2  
 Date: 6/26/21  
 Test Personnel: BFA/Bc  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PR6C-6'  
 Liner Material: SS  
 Pitot ID/Coeff.: P77 0.84  
 Thermo ID: A023  
 Nozzle ID/Diams.: \_\_\_\_\_  
 Avg. Nozzle Diam.: 2.50 in.

Ambient Temp. 75 °F  
 Baro. Pressure\* 29.68 in. Hg  
 Static Pressure -.30 in. H<sub>2</sub>O  
 Impinger Gain: 125.0 mL  
 Silica Gel Gain: 6.0 g  
 Stack Area 23.76 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	<u>0.004</u>	<u>0.000</u>
Pitot	<u>12"</u>	<u>5"</u>
	<u>Good</u>	<u>Good</u>

Filter ID: N/A  
 Sample ID: Run 2

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant,time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
A-1	0	10:50			39.009									
	3		1.1	1.3	40.9	188	N/A	82	247	253	N/A	67	2	
	6		1.1	1.3	42.8	188		83	246	253		62	2	
	9		1.1	1.3	44.7	188		83	247	253		57	2	
	12		1.1	1.3	46.7	189		86	245	253		56	2	
	15		1.1	1.3	48.6	188		85	243	253		56	2	
	18		1.3	1.3	50.5	188		85	242	251		56	2	
	21		1.2	1.3	52.4	189		86	242	252		54	2	
	24		1.3	1.3	54.4	188		86	243	255		55	2	
B-1	27		1.5	1.3	56.3	187		88	244	253		61	2	
	30		1.4	1.3	58.2	188		87	247	253		56	2	
	33		1.5	1.3	60.1	188		87	248	253		55	2	
	36		1.4	1.3	62.0	188		86	245	252		56	2	
	39		1.3	1.3	63.9	188		88	247	251		58	2	
	42		1.2	1.3	65.8	189		87	244	253		56	2	
	45		1.3	1.3	67.7	189		89	246	254		57	2	
	48	11:45	1.3	1.3	69.686	188		87	243	253		58	2	
*Barometric Pressure is at port elevation					Total Volume									
					1.720	1.360	186.2	86.1	242/248	251/255		67	2	
					1.2625	1.1902								

Flue Gas Composition  
 Oxygen, % 20.2  
 Carbon Dioxide, % 0.1  
 Moisture, % \_\_\_\_\_

Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 Result \_\_\_\_\_

Leak Check, Pre-run \_\_\_\_\_  
 Post-run \_\_\_\_\_

QC by [Signature]



Integrated Air Services



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 7 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/14/21  
 Test Personnel: BEAT BE  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.603  
 Console ΔH@: 1.800  
 Probe ID/Length: PR6C-6'  
 Liner Material: SS  
 Pitot ID/Coeff.: P77 0.84  
 Thermo ID: A023  
 Nozzle ID/Diams.: \_\_\_\_\_  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp. 79 °F  
 Baro. Pressure\* 29.68 in. Hg  
 Static Pressure -.30 in. H<sub>2</sub>O  
 Impinger Gain 202.2 mL  
 Silica Gel Gain 8.2 g  
 Stack Area 23.76 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A  
 Leak Checks: \_\_\_\_\_

	Initial	Final
Volume, ft <sup>3</sup>	<u>0.000</u>	<u>0.000</u>
@ Vac., in. Hg	<u>12"</u>	<u>5"</u>
Pitot	<u>Good</u>	<u>Good</u>

Filter ID: N/A  
 Sample ID: Run 3

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
A-1	0	11:55	1.1	1.3	70.079	189	N/A	91	245	252	N/A	67	3	
2	3		1.2	1.3	71.9	191		91	245	251		58	3	
3	6		1.2	1.3	73.8	191		91	247	250		56	3	
4	9		1.3	1.3	75.7	192		92	244	253		56	3	
5	12		1.1	1.3	77.6	190		92	243	252		56	3	
6	15		1.1	1.3	79.5	190		94	243	252		57	3	
7	18		1.4	1.3	81.4	190		93	241	253		57	3	
8	21		1.4	1.3	83.2	190		92	241	253		58	3	
B-1	24		1.6	1.3	85.1	187		92	241	256		57	3	
2	27		1.5	1.3	87.1	190		92	246	252		62	3	
3	30		1.5	1.3	89.0	190		93	242	252		62	3	
4	33		1.6	1.3	91.0	190		93	245	252		64	3	
5	36		1.5	1.3	93.0	191		92	247	253		66	3	
6	39		1.5	1.3	94.8	191		92	240	251		67	3	
7	42		1.4	1.3	96.7	190		91	243	251		66	3	
8	45		1.1	1.3	98.6	185		92	245	251		66	3	
8	48	12:49	1.1	1.3	100.559	185		92	245	251		66	3	
			Avg Δp	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>		Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub> scf
			<u>1.565</u>	<u>1.300</u>	<u>30.48</u>	<u>185.5</u>	<u>92.1</u>		<u>240/247</u>	<u>250/256</u>	<u>250/256</u>	<u>67</u>	<u>3</u>	

\*Barometric Pressure is at port elevation



Integrated Air Services

Flue Gas Composition  
 Oxygen, % 20.2  
 Carbon Dioxide, % 0.2  
 Moisture, % \_\_\_\_\_

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run \_\_\_\_\_  
 Post-run \_\_\_\_\_

Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 Result \_\_\_\_\_

QC by BEAT  
 Pulverizer, # \_\_\_\_\_  
 #2-3 Sifts & #1-2 CBs  
 Emission Report



# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 7 Hood Exhaust  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/26/21 Recovery Date 6/26/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	928.4	700.8	562.9		916.6	
Initial	774.4	669.3	538.5		908.5	
Gain	154 ✓	31.5 ✓	24.4 ✓	214.9	8.1 ✓	223 ✓

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 2 Sample Date 6/26/21 Recovery Date 6/26/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	900.8	808.5	640.8		879.4	
Initial	734.5	783.2	637.4		873.4	
Gain	166.3 ✓	25.3 ✓	3.4 ✓	195 ✓	6 ✓	201 ✓

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 3 Sample Date 6/26/21 Recovery Date 6/26/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	931.4	727.2	569.3		924.8	
Initial	780.9	681.9	562.9		916.6	
Gain	150.5 ✓	45.3 ✓	6.4 ✓	202.2 ✓	8.2 ✓	210.4 ✓

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Check COC for Sample IDs of Media Blanks

*BEA*





# Sample and Velocity Traverse Point Data Sheet - Method 1

15730.001.008  
 Pulp Dryer, #3 Paper Machine,  
 #2-3 SDTVs, & #1-2 CBs  
 Emission Report

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 7 Hood Exhaust

Operator VD / LF  
 Date 15-Jun-21  
 W.O. Number 15730.001.008

**Duct Type**  Circular  Rectangular Duct Indicate appropriate type  
**Traverse Type**  Particulate Traverse  Velocity Traverse

Distance from far wall to outside of port (in.) = C	66.125
Port Depth (in.) = D	0.125
Depth of Duct, diameter (in.) = C-D	66
Area of Duct (ft <sup>2</sup> )	23.76
Total Traverse Points	16
Total Traverse Points per Port	8

**Rectangular Ducts Only**



Width of Duct, rectangular duct only (in.)	
Total Ports (rectangular duct only)	

**Traverse Point Locations**

Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	3.2	2	2
2	10.5	7	7
3	19.4	13	13
4	32.3	21 1/2	21 1/2
5	67.7	44 1/2	45
6	80.6	53	53 1/2
7	89.5	59	59
8	96.8	64	64
9			
10			
11			
12			

**Flow Disturbances**

Upstream - A (ft)	5.625
Downstream - B (ft)	25.0
Upstream - A (duct diameters)	1.02
Downstream - B (duct diameters)	4.55



Equivalent Diameter =  $(2 * L * W) / (L + W)$

**Traverse Point Location Percent of Stack -Circular**  
 Number of Traverse Points

	1	2	3	4	5	6	7	8	9	10	11	12
T	1	14.6	6.7	4.4	3.2	2.6						
r	2	85.4	25	14.6	10.5	8.2	6.7					
a	3		75	29.6	19.4	14.6	11.8					
v	4			93.3	70.4	32.3	22.6	17.7				
e	5				85.4	67.7	34.2	25				
e	6					95.6	80.6	65.8	35.6			
r	7						89.5	77.4	64.4			
s	8							96.8	85.4	75		
s	9								91.8	82.3		
a	10									97.4	88.2	
e	11										93.3	
t	12											97.9

**Traverse Point Location Percent of Stack -Rectangular**  
 Number of Traverse Points

	1	2	3	4	5	6	7	8	9	10	11	12
T	1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
r	2	75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
a	3		83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
v	4			87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
e	5				90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
r	6					91.7	78.6	68.8	61.1	55.0	50.0	45.8
s	7						92.9	81.3	72.2	65.0	59.1	54.2
a	8							93.8	83.3	75.0	68.2	62.5
e	9								94.4	85.0	77.3	70.8
t	10									95.0	86.4	79.2
	11										95.5	87.5
	12											95.8

**Rectangular Stack Points & Matrix**  
 9 - 3 x 3  
 12 - 4 x 3  
 16 - 4 x 4  
 20 - 5 x 4  
 25 - 5 x 5  
 30 - 6 x 5  
 36 - 6 x 6  
 42 - 7 x 6  
 49 - 7 x 7

Port Diam. (in) = 4  
 Number of Ports = 2

Tape Measure I.D. # TM-01





# RUN SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

**Start Time 09:45    End Time 10:46**

---

**Average Measured TRS Conc.    0.39 ppm ✓**  
**Recovery No. 2    93.9 % ✓**  
**TRS Corrected for Recovery    0.42 ppm ✓**

# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

**Start Time 10:50    End Time 11:50**

---

**Average Measured TRS Conc.**    0.40 ppm ✓  
**Recovery No. 2**    93.9 %  
**TRS Corrected for Recovery**    0.43 ppm ✓

# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun.2021**

---

**Start Time 11:55    End Time 12:55**

---

**Average Measured TRS Conc.**    0.49 ppm ✓  
**Recovery No. 2**    93.9 %  
**TRS Corrected for Recovery**    0.52 ppm ✓

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
09:45	17	0.11	<2	<0.05	15	0.14	16	0.04	0.34
09:48	26	0.14	6	0.08	10	0.11	<2	<0.02	0.34
09:51	27	0.14	8	0.09	39	0.24	5	0.02	0.53
09:54	9	0.07	6	0.08	39	0.25	<2	<0.02	0.40
09:57	26	0.14	7	0.09	<2	<0.05	<2	<0.02	0.23
10:00	29	0.15	12	0.12	52	0.29	27	0.06	0.68
10:03	<2	<0.04	<2	<0.05	43	0.26	117	0.14	0.55
10:06	32	0.16	<2	<0.05	32	0.22	10	0.03	0.45
10:09	<2	<0.04	<2	<0.05	54	0.29	<2	<0.02	0.29
10:12	36	0.17	14	0.13	21	0.17	<2	<0.02	0.47
10:15	70	0.26	<2	<0.05	21	0.17	45	0.08	0.59
10:18	5	0.05	<2	<0.05	<2	<0.05	34	0.07	0.19
10:22	<2	<0.04	<2	<0.05	<2	<0.05	32	0.07	0.13
10:25	<2	<0.04	<2	<0.05	64	0.33	<2	<0.02	0.33
10:28	7	0.07	<2	<0.05	43	0.26	42	0.08	0.48
10:31	4	0.05	33	0.22	<2	<0.05	<2	<0.02	0.26
10:34	<2	<0.04	18	0.15	22	0.17	<2	<0.02	0.33
10:37	22	0.13	8	0.10	24	0.19	<2	<0.02	0.41
10:40	24	0.14	17	0.15	16	0.15	5	0.02	0.48
10:43	<2	<0.04	13	0.13	12	0.12	26	0.06	0.37

**Average**                      **0.09**                      **0.07**                      **0.17**                      **0.03**                      **0.39**

584



# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
10:50	34	0.17	41	0.25	38	0.24	21	0.05	0.76
10:53	13	0.09	<2	<0.05	<2	<0.05	<2	<0.02	0.09
10:56	8	0.07	15	0.14	15	0.14	25	0.06	0.46
10:59	<2	<0.04	<2	<0.05	30	0.21	<2	<0.02	0.21
11:02	48	0.21	41	0.25	9	0.10	<2	<0.02	0.55
11:05	<2	<0.04	<2	<0.05	18	0.16	92	0.12	0.41
11:08	9	0.08	21	0.17	46	0.27	<2	<0.02	0.51
11:11	5	0.05	7	0.09	<2	<0.05	41	0.08	0.30
11:14	41	0.19	33	0.22	<2	<0.05	29	0.06	0.53
11:17	<2	<0.04	<2	<0.05	17	0.15	55	0.09	0.33
11:20	<2	<0.04	<2	<0.05	33	0.22	<2	<0.02	0.22
11:23	23	0.13	<2	<0.05	<2	<0.05	10	0.03	0.20
11:26	<2	<0.04	16	0.14	24	0.18	27	0.06	0.45
11:29	5	0.05	<2	<0.05	<2	<0.05	7	0.03	0.11
11:32	57	0.23	10	0.11	30	0.21	17	0.05	0.64
11:35	<2	<0.04	92	0.39	<2	<0.05	<2	<0.02	0.39
11:38	11	0.09	<2	<0.05	<2	<0.05	26	0.06	0.20
11:41	<2	<0.04	33	0.22	28	0.20	13	0.04	0.49
11:44	13	0.09	23	0.18	90	0.40	38	0.07	0.81
11:47	20	0.12	<2	<0.05	25	0.19	18	0.05	0.40

**Average**                      **0.08**                      **0.11**                      **0.13**                      **0.04**                      **0.40** ✓

5/4

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
11:55	<2	<0.04	44	0.26	<2	<0.05	<2	<0.02	0.26
11:58	42	0.19	5	0.07	17	0.15	21	0.05	0.52
12:01	14	0.10	34	0.22	<2	<0.05	<2	<0.02	0.32
12:04	68	0.25	<2	<0.05	7	0.09	16	0.04	0.43
12:07	57	0.23	33	0.22	19	0.16	<2	<0.02	0.61
12:10	<2	<0.04	18	0.15	72	0.35	<2	<0.02	0.50
12:13	18	0.11	<2	<0.05	18	0.16	<2	<0.02	0.27
12:16	68	0.25	<2	<0.05	191	0.61	<2	<0.02	0.86
12:19	40	0.18	<2	<0.05	11	0.12	22	0.05	0.41
12:22	16	0.11	10	0.11	16	0.15	<2	<0.02	0.36
12:25	<2	<0.04	19	0.16	<2	<0.05	<2	<0.02	0.16
12:28	23	0.13	83	0.37	26	0.19	<2	<0.02	0.69
12:31	76	0.27	<2	<0.05	69	0.34	<2	<0.02	0.61
12:34	12	0.09	20	0.16	15	0.14	26	0.06	0.51
12:37	46	0.20	33	0.22	72	0.35	12	0.04	0.84
12:40	62	0.24	62	0.31	26	0.19	9	0.03	0.81
12:43	<2	<0.04	<2	<0.05	12	0.12	13	0.04	0.20
12:46	87	0.30	28	0.20	<2	<0.05	39	0.07	0.64
12:49	53	0.22	4	0.07	<2	<0.05	<2	<0.02	0.29
12:52	10	0.08	51	0.28	12	0.12	11	0.04	0.55

**Average**                      **0.15**                      **0.14**                      **0.16**                      **0.02**                      **0.49** ✓

SH

# RECOVERY DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

## Before Run 1

Start Time 08:19    End Time 08:31

### Recovery Gas to Probe, Time 08:19

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
15757	15082	15526	15455	6.94

### Recovery Gas to GC, Time 08:27

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
17789	17071	17094	17318	7.43

Recovery 93.3% ↗

HS

# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

**After Run 3    Before Run 4**  
**Start Time 12:55    End Time 13:09**

## Recovery Gas to Probe, Time 12:55

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
16925	16900	17033	16953	7.34

## Recovery Gas to GC, Time 13:06

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
18883	18581	18955	18807	7.82

**Recovery 93.9%** ✓

SH

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

**Ambient Temperature: 72°C**

**Barometric Pressure: 29.70 in. Hg**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	460	457	298	232
Ret. Time, sec	25.0	35.0	63.0	132.0

**1** Flow = **48.0 mL/Min**      **9.58 ppm**      **9.52 ppm**      **6.20 ppm**      **4.83 ppm**

**Time: 07:01**      **Peak Areas, mv-sec**

25119	23385	10987	48706
25616	23496	10706	47186
25021	22672	10690	48066
<b>Average Area</b>	<b>25252</b>	<b>23184 ✓</b>	<b>10794</b>

**2** Flow = **81.6 mL/Min**      **5.64 ppm**      **5.60 ppm**      **3.65 ppm**      **2.84 ppm**

**Time: 07:34**      **Peak Areas, mv-sec**

11971	9531	4072	19617
11666	9535	4189	19344
11820	9242	4068	20012
<b>Average Area</b>	<b>11819</b>	<b>9436</b>	<b>4110 ✓</b>

**3** Flow = **151 mL/Min**      **3.05 ppm**      **3.02 ppm**      **1.97 ppm**      **1.54 ppm**

**Time: 07:49**      **Peak Areas, mv-sec**

3892	3195	1507	6761
3898	3136	1468	6767
3818	3182	1462	6752
<b>Average Area</b>	<b>3869 ✓</b>	<b>3171</b>	<b>1479</b>

sty

# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

H <sub>2</sub> S	1	2	3		
Time	07:01	07:34	07:49		
Concentration, ppm	9.58	5.64	3.05		
Area, mv-sec	25252	11819	3869		
Calc. Conc., ppm	9.36	5.89	2.98		
% Error	-2.4	4.5	-2.0 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.6414	2.8084	0.9978	2	0.04

MeSH	1	2	3		
Time	07:01	07:34	07:49		
Concentration, ppm	9.52	5.60	3.02		
Area, mv-sec	23184	9436	3171		
Calc. Conc., ppm	9.47	5.65	3.01		
% Error	-0.5	0.9	-0.4 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.7368	2.6693	0.9999	2	0.05

DMS	1	2	3		
Time	07:01	07:34	07:49		
Concentration, ppm	6.20	3.65	1.97		
Area, mv-sec	10794	4110	1479		
Calc. Conc., ppm	6.26	3.59	1.99		
% Error	0.9	-1.7	0.8 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.7325	2.6531	0.9997	2	0.05

DMDS	1	2	3		
Time	07:01	07:34	07:49		
Concentration, ppm	4.83	2.84	1.54		
Area, mv-sec	47986	19658	6760		
Calc. Conc., ppm	4.82	2.86	1.53		
% Error	-0.3	0.6	-0.3 ✓		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.7107	3.5133	>0.9999	2	0.02

dy



# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Analyte	Ambient Temperature: 72°C	Barometric Pressure: 29.70 in. Hg		
Perm. Device ID	<b>H<sub>2</sub>S</b>	<b>MeSH</b>	<b>DMS</b>	<b>DMDS</b>
Perm. Rate, nL/min	T-51831	33-50536	89-50725	89-53405
Ret. Time, sec	460	457	298	232
	25.0	35.0	63.0	132.0

1 Flow = 48.0 mL/Min	9.58 ppm	9.52 ppm	6.20 ppm	4.83 ppm
<b>Time: 16:36</b>	<b>Peak Areas, mv-sec</b>			
	26011	25303	11444	51862
	26531	26149	12036	53970
	27302	26754	12114	53372
<b>Average Area</b>	<b>26615</b>	<b>26069</b>	<b>11864 ✓</b>	<b>53068</b>

2 Flow = 88.9 mL/Min	5.17 ppm	5.14 ppm	3.35 ppm	2.61 ppm
<b>Time: 16:50</b>	<b>Peak Areas, mv-sec</b>			
	9447	7596	3066	16100
	9456	7369	3124	14977
	9570	7546	3109	14905
<b>Average Area</b>	<b>9491</b>	<b>7504 ✓</b>	<b>3100</b>	<b>15327</b>

3 Flow = 133 mL/Min	3.45 ppm	3.43 ppm	2.23 ppm	1.74 ppm
<b>Time: 17:14</b>	<b>Peak Areas, mv-sec</b>			
	4013	3384	1323	6743
	4015	3427	1344	6741
	3979	3463	1344	6769
<b>Average Area</b>	<b>4002</b>	<b>3425</b>	<b>1337 ✓</b>	<b>6751</b>

SH

# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

H <sub>2</sub> S	1	2	3			
Time	16:36	16:50	17:14			
Concentration, ppm	9.58	5.17	3.45			
Area, mv-sec	26615	9491	4002			
Calc. Conc., ppm	9.43	5.38	3.37			
% Error	-1.6	4.1	-2.4 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.8396	2.6323	0.9977	2	0.05	

MeSH	1	2	3			
Time	16:36	16:50	17:14			
Concentration, ppm	9.52	5.14	3.43			
Area, mv-sec	26069	7504	3425			
Calc. Conc., ppm	9.54	5.10	3.44			
% Error	0.3	-0.7	0.4 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.9895	2.4671	0.9999	2	0.08	

DMS	1	2	3			
Time	16:36	16:50	17:14			
Concentration, ppm	6.20	3.35	2.23			
Area, mv-sec	11864	3100	1337			
Calc. Conc., ppm	6.22	3.32	2.24			
% Error	0.3	-0.8	0.5 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	2.1400	2.3753	0.9999	2	0.11	

DMDS	1	2	3			
Time	16:36	16:50	17:14			
Concentration, ppm	4.83	2.61	1.74			
Area, mv-sec	53068	15327	6751			
Calc. Conc., ppm	4.83	2.61	1.74			
% Error	-0.0	0.1	-0.0 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	2.0180	3.3447	>0.9999	2	0.03	

5x

# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Analyte Molecular Weight	H <sub>2</sub> S 34.08	MeSH 48.11	DMS 62.14	DMDS 94.20
Retention Time, sec	25.0	35.0	63.0	132.0
Peak Detection Window, sec	10.0	10.0	10.0	10.0
Minimum Peak Area, mv-sec	2	2	2	2
Minimum Peak Height, mv	1	1	1	1
Beginning Peak Width, sec	1.0	1.0	3.0	3.0
Ending Peak Width, sec	2.0	3.0	5.0	5.0
Permeation Device ID	T-51831 ✓	33-50536 ✓	89-50725 ✓	89-53405 ✓
Permeation Rate, ng/min	642 ✓	901 ✓	758 ✓	895 ✓
Permeation Rate, nL/min*	460	457	298	232

**Barometric Pressure:** 29.70 in. Hg    **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**PR<sub>ng</sub>** = Permeation Rate by weight, ng/min

**V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole

**W<sub>mol</sub>** = Molecular Weight of compound

**T<sub>a</sub>** = Ambient Temperature, °F

**T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)

**P<sub>s</sub>** = Standard Pressure = 29.92 in Hg

**P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 642 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.70) \\ = 460 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

**C** = Concentration, ppmv

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**F<sub>d</sub>** = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

File: E:\6-26-21.trs  
Program Version: 2.0, built 21 Feb 2015 File Version: 2.0  
Computer: JWS-PROGRAMMING Trailer: 271

Analog Input Device: Keithley KUSB-3108 GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: GC-8A Serial No. C10494419420SA  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 100	Primary: 3'
Air	30	60	Detector: 120	Secondary:
Carrier	50	30		Sample Loop: 6" unlined

## Injection Cycle

Total Length: 180 sec Sampling Time: 160 sec Load/Backflush Time: 85 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 5 mv-sec Minimum peak height 5 mv above baseline

## Dynacalibrator

Chamber Temperature 130.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.70 in. Hg

# RUN DATA

Number 7

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine Vent 7**

Method **16**  
 Calibration **1**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **26 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
17:44	18765	7.81	<2	<0.05	<2	<0.05	<2	<0.02	7.81
17:47	19416	7.97	<2	<0.05	<2	<0.05	<2	<0.02	7.97
17:50	18473	7.73	<2	<0.05	<2	<0.05	<2	<0.02	7.73
17:53	18357	7.70	<2	<0.05	<2	<0.05	<2	<0.02	7.70
<b>Average</b>		<b>7.80</b>		<b>&lt;0.05</b>		<b>&lt;0.05</b>		<b>&lt;0.02</b>	<b>7.80</b>

SK

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 7**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
10:49:55	6772	20.2	-2	0.2
10:50:10	6774	20.2	-2	0.2
10:50:25	6773	20.2	-3	0.2
10:50:40	6772	20.2	-2	0.2
10:50:55	6773	20.2	-2	0.2
10:51:10	6773	20.2	-3	0.2
10:51:25	6774	20.2	-2	0.2
10:51:40	6771	20.2	-2	0.2
10:51:55	6771	20.2	-2	0.2
10:52:10	6774	20.2	-3	0.2
10:52:25	6773	20.2	-2	0.2
10:52:40	6772	20.2	-2	0.2
10:52:55	6773	20.2	-3	0.2
10:53:10	6774	20.2	-2	0.2
10:53:25	6774	20.2	-2	0.2
10:53:40	6773	20.2	-2	0.2
10:53:55	6774	20.2	-3	0.2
10:54:10	6773	20.2	-3	0.2
<b>Avg</b>	<b>6773</b>	<b>20.2</b>	<b>-2</b>	<b>0.2</b>



# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 7**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
12:01:12	6774	20.2	-2	0.2
12:01:27	6773	20.2	-4	0.1
12:01:42	6773	20.2	-3	0.2
12:01:57	6772	20.2	-4	0.1
12:02:12	6773	20.2	-5	0.1
12:02:27	6772	20.2	-4	0.1
12:02:42	6773	20.2	-5	0.1
12:02:57	6772	20.2	-5	0.1
12:03:12	6772	20.2	-5	0.1
12:03:27	6772	20.2	-5	0.1
12:03:42	6772	20.2	-5	0.1
12:03:57	6772	20.2	-4	0.1
12:04:12	6772	20.2	-5	0.1
12:04:27	6773	20.2	-4	0.1
12:04:42	6773	20.2	-5	0.1
12:04:57	6771	20.2	-5	0.1
12:05:12	6772	20.2	-6	0.1
<b>Avg</b>	<b>6772</b>	<b>20.2</b>	<b>-4</b>	<b>0.1</b>

# RUN DATA

## Number 3

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine vent 7**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **26 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
13:04:58	6768	20.2	-3	0.2
13:05:13	6768	20.2	-3	0.2
13:05:28	6767	20.2	-2	0.2
13:05:43	6768	20.2	-3	0.2
13:05:58	6768	20.2	-2	0.2
13:06:13	6768	20.2	-2	0.2
13:06:28	6768	20.2	-4	0.1
13:06:43	6768	20.2	-3	0.2
13:06:58	6769	20.2	-3	0.2
13:07:13	6768	20.2	-3	0.2
13:07:28	6769	20.2	-4	0.1
13:07:43	6770	20.2	-5	0.1
13:07:58	6767	20.2	-3	0.2
13:08:13	6767	20.2	-2	0.2
13:08:28	6769	20.2	-2	0.2
13:08:43	6768	20.2	-4	0.1
13:08:58	6768	20.2	-3	0.2
<b>Avgs</b>	<b>6768</b>	<b>20.2</b>	<b>-3</b>	<b>0.2</b>

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 7**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Start Time: 08:07

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	8
10.1 ✓	SG9168283BAL	3293
19.5	CC454190	6574

Curve Coefficients

Slope	Intercept	Corr. Coeff.
336.6	-29 ✓	0.9998 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	-32
10.2 ✓	SG9168283BAL	3417
20.4 ✓	CC454190	7035

Curve Coefficients

Slope	Intercept	Corr. Coeff.
346.4 ✓	-56 ✓	0.9999 ✓

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 7**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Start Time: 08:07

**O<sub>2</sub>**

Method: EPA 3A  
Span Conc. 19.5 %

**Slope** 336.6                      **Intercept** -29.2

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	8	0.1	0.1	0.5 ✓	Pass
10.1	3293	9.9	-0.2	-1.0 ✓	Pass
19.5	6574	19.6	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.4 %

**Slope** 346.4                      **Intercept** -55.6

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-32	0.1	0.1	0.5 ✓	Pass
10.2	3417	10.0	-0.2	-1.0 ✓	Pass
20.4	7035	20.5	0.1	0.5 ✓	Pass

*W*

# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 7**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

**File:** C:\Users\Trailer 271\Documents\New Indy\6-26-21.cem  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** DESKTOP-GQ0I9UV **Trailer:** 271  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>20.0</b>
Span Concentration, %	<b>19.5</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.4</b>



## VENT 8

New Indy  
Catawba, SC

15730.001.008  
No. 8 Hood Exhaust  
Paper Machine Vent 8

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
Date	6/26/21 ✓	6/26/21 ✓	6/26/21 ✓	---
Time Began	1315 ✓	1420 ✓	1525 ✓	---
Time Ended	1415 ✓	1520 ✓	1625 ✓	---
Volumetric Flow Rate, (Qs), DSCFM	6.31E+04 ✓	6.57E+04 ✓	6.27E+04 ✓	6.38E+04
BWS	0.238 ✓	0.230 ✓	0.230 ✓	0.233
% Oxygen	20.2 ✓	20.2 ✓	20.2 ✓	20.2

---

<b>Total Reduced Sulfur</b>	(TRS MW)=	34.08				
Concentration, ppm			0.59 ✓	0.51 ✓	0.56 ✓	0.55
Emission Rate, lb/hr			0.20	0.18	0.19	0.19

---

*AB for SHL*



New Indy  
Catawba, SC

15730.001.008  
No. 8 Hood Exhaust

### Paper Machine Vent 8

#### ISOKINETIC CALCULATIONS

Run Number		1	2	3	Mean
Date		6/26/21	6/26/21	6/26/21	---
Time Began		1315	1420	1525	---
Time Ended		1405	1510	1615	---
INPUT DATA					
Sampling Time, min	(Theta)	48.0	48	48	48
Stack Diameter, in.	(Dia.)	66	66	66	66
Barometric Pressure, in. Hg	(Pb)	29.68	29.68	29.68	29.68
Static Pressure, in. H2O	(Pg)	-0.71	-0.71	-0.71	-0.71
Pitot Tube Coefficient	(Cp)	0.84	0.84	0.84	0.84
Meter Correction Factor	(Y)	1.0030	1.0030	1.0030	1.0030
Orifice Calibration Value	(Delta H@)	1.8000	1.8000	1.8000	1.8000
Nozzle Diameter, in.	(Dn)	0.250	0.250	0.250	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	30.745	30.782	30.346	30.624
Meter Temperature, °F	(Tm)	94.9	96.0	92.1	94.3
Meter Temperature, °R	(Tm-R)	554.9	556.0	552.1	554.3
Meter Orifice Pressure, in. H2O	(Delta H)	1.300	1.300	1.300	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> )avg	1.140	1.140	1.140	1.140
Volume H2O Collected, mL	(Vlc)	194.0	184.6	184.1	187.6
CO2 Concentration, %	(CO2)	0.1	0.1	0.1	0.1
O2 Concentration, %	(O2)	20.2	20.2	20.2	20.2
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> )avg	1.096	1.130	1.079	1.102
Stack Temperature, °F	(Ts)	183.6	184.2	184.0	183.9
Stack Temperature, °R	(Ts-R)	643.6	644.2	644.0	643.9
Moisture Fraction (at Saturation)	(BWS)	0.559	0.566	0.564	0.563
CALCULATED DATA					
Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	23.76	23.76	23.76	23.76
Stack Pressure, in. Hg	(Ps)	29.63	29.63	29.63	29.63
Meter Pressure, in. Hg	(Pm)	29.78	29.78	29.78	29.78
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	29.189	29.166	28.958	29.105
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	9.132	8.689	8.666	8.829
Moisture Fraction (Measured)	(BWS)	0.238	0.230	0.230	0.233
Moisture Fraction (lower sat/meas)	(BWS)	0.238	0.230	0.230	0.233
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	28.82	28.82	28.82	28.82
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	26.24	26.34	26.33	26.31
Average Stack Gas Velocity, ft/sec	(Vs)	71.60	73.73	70.40	71.91
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	102063	105108	100356	102509
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	63130	65700	62685	63838
Calibration check	(Yqa)	1.0261	1.0259	1.0370	1.030
Percent difference from Y					2.66%

APB for SH ✓

static pressure: -.71

# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 8 Hood Exhaust  
 Sample Location: Level  
 W. O. Number: 15730.001.008  
 Run Number: 1  
 Date: 6/26/21  
 Test Personnel: BJA/Bc  
 Sample Time: 48 min.

Console ID: MA023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.000  
 Probe ID/Length: PRC-6'  
 Liner Material: SS  
 Pitot ID/Coeff.: 977  
 Thermo ID: MA023  
 Nozzle ID/Diams.: .250 in.

Ambient Temp.: 81 °F  
 Baro. Pressure\*: 29.68 in. Hg  
 Static Pressure: 20 in. H<sub>2</sub>O  
 Impinger Gain: 178.7 ml  
 Silica Gel Gain: 15.9 g  
 Stack Area: 23.76 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	<u>0.000</u>	<u>0.000</u>
Pitot	<u>12"</u>	<u>5"</u>
	<u>Good</u>	<u>Good</u>

Filter ID: N/A  
 Sample ID: Run1

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
0		13:15			100.831									
A-1	3		1.2	1.3	102.7	183	N/A	92	245	253	N/A	67	2	
2	6		1.1	1.3	104.6	183		92	244	254		59	2	
3	9		1.2	1.3	106.5	183		93	244	252		56	2	
4	12		.97	1.3	108.4	184		92	244	257		55	2	
5	15		.98	1.3	110.3	184		94	245	253		56	2	
6	18		.96	1.3	112.2	185		94	244	266		56	2	
7	21		1.1	1.3	114.1	183		94	241	253		58	2	
8	24		1.0	1.3	116.0	182		95	240	251		58	2	
B-1	27		1.2	1.3	117.9	182		96	241	251		61	2	
2	30		1.4	1.3	119.8	183		96	244	253		57	2	
3	33		1.3	1.3	121.8	184		96	242	252		56	2	
4	36		1.4	1.3	123.7	185		97	245	254		55	2	
5	39		1.5	1.3	125.6	184		97	245	252		56	2	
6	42		1.3	1.3	127.5	183		97	241	259		58	2	
7	45		1.3	1.3	129.5	185		97	243	251		59	2	
8	48	14:05	1.3	1.3	131.576	185		96	247	252		60	2	
*Barometric Pressure is at port elevation.					Total Volume	Avg T <sub>m</sub>	Avg T <sub>m</sub>	Avg T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Vac	V <sub>m-std</sub> scf
					30.745	183.6	94.9	240/247	251/266	67	2	2	2	2

Flue Gas Composition  
 Oxygen, %: 20.2  
 Carbon Dioxide, %: 0.1  
 Moisture, %: 23.9

Thermocouple Check  
 Meter Temp., °F: \_\_\_\_\_  
 Ref. Temp., °F: \_\_\_\_\_  
 Result: \_\_\_\_\_

Leak Check, Pre-run: \_\_\_\_\_  
 Post-run: \_\_\_\_\_

15730.001.008  
 Pump Dryer, #3 Paper Machine,  
 #2-3 S# TV# & #1-2 CB#  
 Emission Report

WESTON SOLUTIONS  
 Integrated Air Services  
 MA-1206  
 Completed 2006  
 1.0959  
 1.2068



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 8 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 2  
 Date: 6/26/21  
 Test Personnel: DA/Bc  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PR6C-6'  
 Line Material: 55  
 Pitot ID/Coeff.: P77  
 Thermo ID: A023  
 Nozzle ID/Diams.: .250 in.

Ambient Temp: 84 °F  
 Baro. Pressure\*: 29.68 in. Hg  
 Static Pressure: -71 in. H<sub>2</sub>O  
 Impinger Gain: 179.5 mL  
 Silica Gel Gain: 5.1 g  
 Stack Area: 23.76 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A  
 Leak Checks: Good

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	0.000	0.000
Pitot	12"	5"

Filter ID: N/A  
 Sample ID: RUN2


TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)		ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM TEMP (°F)		PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
			Δp	ΔH				DGM INLET	DGM OUTLET						
0		14:20				131.774									
A-1	3		1.1	1.3	1.3	133.7	183	N/A	96	293	253	N/A	65	3	
2	6		1.2	1.3	1.3	135.6	184		97	243	252		60	3	
3	9		1.2	1.3	1.3	137.5	183		96	241	253		58	3	
4	12		1.1	1.3	1.3	139.4	183		96	245	254		56	3	
5	15		1.2	1.3	1.3	141.3	186		96	244	255		55	3	
6	18		1.3	1.3	1.3	143.2	185		98	241	254		56	3	
7	21		1.1	1.3	1.3	145.1	185		96	242	255		54	3	
8	24		1.1	1.3	1.3	147.0	185		95	244	251		53	3	
B-1	27		1.5	1.3	1.3	149.0	183		95	244	253		57	3	
2	30		1.4	1.3	1.3	150.9	184		96	243	253		52	3	
3	33		1.4	1.3	1.3	152.9	184		97	245	252		52	3	
4	36		1.3	1.3	1.3	154.8	184		97	246	252		53	3	
5	39		1.5	1.3	1.3	156.7	185		95	243	252		54	3	
6	42		1.4	1.3	1.3	158.7	185		96	244	254		55	3	
7	45		1.6	1.3	1.3	160.6	184		95	248	252		56	3	
8	48	15:10	1.2	1.3	1.3	162.556	184		95	244	253		55	3	
*Barometric Pressure is at port elevation			Avg Δp	Avg ΔH	Avg T <sub>s</sub>	Total Volume		Avg T <sub>m</sub>			Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std.</sub>
			1.301	1.300	184.2	30.782		96.0			241/248	251/255	65	3	

Flue Gas Composition: O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A: 96.0  
 Leak Check, Pre-run: 241/248 Post-run: 251/255  
 Oxygen, %: 96.0  
 Carbon Dioxide, %: 0.0  
 Moisture, %: 0.0

Thermocouple Check: Meter Temp., °F: 65 Isokinetic: 3  
 Ref. Temp., °F: 65 Calculated by: QC by

Comments: 1.2812  
 Avg ΔH: 1.1402

15730.001.008  
 Pulp Dryer, #3 Paper Machine,  
 #2-3 SOTVs & #1-2 CBs  
 Emission Report



Integrated Air Services



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 8 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/26/21  
 Test Personnel: BA/BC  
 Sample Time: 48 min.

Console ID: AP23  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: PRLC-6'  
 Liner Material: 53  
 Pitot ID/Coeff.: 0.777 0.84  
 Thermo ID: AP23  
 Nozzle ID/Diams.: 0.250 in.  
 Avg. Nozzle Diam.: 0.250 in.

Ambient Temp.: 86 °F  
 Baro. Pressure\*: 29.48 in. Hg  
 Static Pressure: 0.71 in. H<sub>2</sub>O  
 Impinger Gain: 178 mL  
 Silica Gel Gain: 6.1 g  
 Stack Area: 23.76 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A  
 Leak Checks: N/A  
 Initial: 0.002 by Final  
 @ Vac., in. Hg: 12"  
 Pitot: Good  
 Filter ID: N/A  
 Sample ID: Run 3

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
0	0	15:25			162.998									
A-1	3		1.0	1.3	164.9	184	N/A	91	242	253	N/A	67	2	
2	6		1.1	1.3	166.7	184		90	242	252		58	2	
3	9		1.0	1.3	168.6	183		90	244	253		55	2	
4	12		1.1	1.3	170.5	183		89	245	251		53	2	
5	15		1.2	1.3	172.4	185		89	248	255		51	2	
6	18		1.1	1.3	174.3	185		90	243	252		51	2	
7	21		1.1	1.3	176.1	185		90	244	253		52	2	
8	24		1.1	1.3	178.0	185		92	245	262		53	2	
B-1	27		1.2	1.3	179.8	184		93	243	254		58	2	
2	30		1.4	1.3	181.8	184		94	246	252		53	2	
3	33		1.3	1.3	183.7	184		94	246	251		52	2	
4	36		1.4	1.3	185.6	184		93	245	251		52	2	
5	39		1.2	1.3	187.5	184		94	246	254		53	2	
6	42		1.2	1.3	189.5	184		96	245	253		53	2	
7	45		1.2	1.3	191.4	183		94	244	253		54	2	
8	48	16:15	1.1	1.3	193.344	183		94	242	251		54	2	
*Barometric Pressure is at port elevation					Avg V <sub>ap</sub>	Avg ΔH	Total Volume	Avg T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub> SCF
					1.079	1.300	30.346	92.06	242/248	251/254	251/254	67	2	
					1.168	1.1402								

Flue Gas Composition

Oxygen, %: 20.2

Carbon Dioxide, %: 0.1

Moisture, %: \_\_\_\_\_

Thermocouple Check

Meter Temp., °F: \_\_\_\_\_

Ref. Temp., °F: \_\_\_\_\_

Result: \_\_\_\_\_

15730.001.008

Pulp Dryer, #3 Paper Machine,

#2-3 S... & #1-2 CBs

Emission Report

Integrated Air Services



# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 8 Hood Exhaust  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/26/21 Recovery Date 6/26/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	915.9	833.3	643.6		844.7	
Initial	764.9	808.4	640.8		829.4	
Gain	151 ✓	24.9 ✓	2.8 ✓		15.3 ✓	194

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 2 Sample Date 6/26/21 Recovery Date 6/26/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	936.5	704.6	554.8		929.9	
Initial	780.3	682.5	553.6		924.8	
Gain	156.2 ✓	22.1 ✓	1.2 ✓	179.5	5.1 ✓	184.6 ✓

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 3 Sample Date 6/26/21 Recovery Date 6/26/21  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	907.5	830.8	633.4		890.8	
Initial	773.4	789.5	630.8		884.7	
Gain	134.1 ✓	41.3 ✓	2.6 ✓	178	6.1 ✓	184.1 ✓

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Check COC for Sample IDs of Media Blanks

*Handwritten initials/signature*



Integrated Air Services

# Sample and Velocity Traverse Point Data Sheet - Method 1

15730.001.008  
 Pulp Mill, #3 Paper Machine,  
 #2-3 SDTVs, & #1-2 CBs  
 Emission Report

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 8 Hood Exhaust

Operator VD / LF  
 Date 15-Jun-21  
 W.O. Number 15730.001.008

**Duct Type**  Circular  Rectangular Duct Indicate appropriate type  
**Traverse Type**  Particulate Traverse  Velocity Traverse



Distance from far wall to outside of port (in.) = C	<b>66.125</b>
Port Depth (in.) = D	<b>0.125</b>
Depth of Duct, diameter (in.) = C-D	<b>66</b>
Area of Duct (ft <sup>2</sup> )	<b>23.76</b>
Total Traverse Points	<b>16</b>
Total Traverse Points per Port	<b>8</b>

**Rectangular Ducts Only**

Width of Duct, rectangular duct only (in.)	
Total Ports (rectangular duct only)	

Traverse Point Locations			
Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	3.2	2	2
2	10.5	7	7
3	19.4	13	13
4	32.3	21 1/2	21 1/2
5	67.7	44 1/2	45
6	80.6	53	53 1/2
7	89.5	59	59
8	96.8	64	64
9			
10			
11			
12			

Flow Disturbances	
Upstream - A (ft)	<b>5.5</b>
Downstream - B (ft)	<b>25.0</b>
Upstream - A (duct diameters)	<b>1.00</b>
Downstream - B (duct diameters)	<b>4.55</b>



Equivalent Diameter =  $(2 * L * W) / (L + W)$

Traverse Point Location Percent of Stack -Circular												
Number of Traverse Points												
	1	2	3	4	5	6	7	8	9	10	11	12
T	1	14.6	6.7	4.4	3.2	2.6						
r	2	85.4	25	14.6	10.5	8.2	6.7					
a	3		75	29.6	19.4	14.6	11.8					
v	4			93.3	70.4	32.3	22.6	17.7				
e	5				85.4	67.7	34.2	25				
e	6					95.6	80.6	65.8	35.6			
r	7						89.5	77.4	64.4			
s	8							96.8	85.4	75		
a	9								91.8	82.3		
e	10									97.4	88.2	
i	11										93.3	
n	12											97.9

Traverse Point Location Percent of Stack -Rectangular												
Number of Traverse Points												
	1	2	3	4	5	6	7	8	9	10	11	12
T	1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
r	2	75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
a	3		83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
v	4			87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
e	5				90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
r	6					91.7	78.6	68.8	61.1	55.0	50.0	45.8
s	7						92.9	81.3	72.2	65.0	59.1	54.2
a	8							93.8	83.3	75.0	68.2	62.5
e	9								94.4	85.0	77.3	70.8
i	10									95.0	86.4	79.2
n	11										95.5	87.5
t	12											95.8

**Rectangular Stack Points & Matrix**  
 9 - 3 x 3  
 12 - 4 x 3  
 16 - 4 x 4  
 20 - 5 x 4  
 25 - 5 x 5  
 30 - 6 x 5  
 36 - 6 x 6  
 42 - 7 x 6  
 49 - 7 x 7

Port Diam. (in) = 4  
 Number of Ports = 2

Tape Measure I.D. # TM-07









# RUN SUMMARY

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7/8**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

**Start Time 13:15    End Time 14:15**

---

**Average Measured TRS Conc.    0.54 ppm ✓**  
**Recovery No. 3    91.1 % ✓**  
**TRS Corrected for Recovery    0.59 ppm ✓**

SH

# RUN SUMMARY

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent #8**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

Start Time 14:20    End Time 15:20

---

Average Measured TRS Conc.    0.46 ppm ✓  
Recovery No. 3    91.1 % ✓  
TRS Corrected for Recovery    0.51 ppm ✓

SH

# RUN SUMMARY

Number 6

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 78**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

Start Time 15:25    End Time 16:25

---

Average Measured TRS Conc.    0.51 ppm ✓  
Recovery No. 3                    91.1 % ✓  
TRS Corrected for Recovery      0.56 ppm ✓

SK

# RUN DATA

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** *7 8*

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
<b>PM vent 8 Run 1</b>									
13:15	49	0.21	28	0.20	31	0.21	38	0.07	0.77
13:18	202	0.49	<2	<0.05	55	0.30	<2	<0.02	0.79
13:21	<2	<0.04	<2	<0.05	<2	<0.05	22	0.05	0.11
13:24	<2	<0.04	27	0.19	10	0.11	43	0.08	0.47
13:27	96	0.31	<2	<0.05	8	0.10	48	0.08	0.58
13:30	57	0.23	32	0.22	18	0.16	35	0.07	0.74
13:33	<2	<0.04	<2	<0.05	67	0.33	<2	<0.02	0.33
13:36	<2	<0.04	<2	<0.05	23	0.18	<2	<0.02	0.18
13:39	25	0.14	36	0.23	44	0.26	<2	<0.02	0.63
13:42	<2	<0.04	<2	<0.05	22	0.17	<2	<0.02	0.17
13:45	7	0.06	<2	<0.05	23	0.18	<2	<0.02	0.24
13:48	<2	<0.04	69	0.33	54	0.29	98	0.13	0.88
13:51	<2	<0.04	<2	<0.05	46	0.27	14	0.04	0.35
13:54	9	0.07	<2	<0.05	14	0.14	47	0.08	0.38
13:57	9	0.07	113	0.44	12	0.12	<2	<0.02	0.64
14:00	54	0.22	49	0.27	24	0.18	35	0.07	0.82
14:03	<2	<0.04	<2	<0.05	<2	<0.05	16	0.04	0.09
14:06	7	0.07	<2	<0.05	123	0.47	<2	<0.02	0.54
14:09	10	0.08	<2	<0.05	142	0.51	19	0.05	0.69
14:12	52	0.22	29	0.20	334	0.84	19	0.05	1.36
<b>Average</b>		<b>0.11</b>		<b>0.10</b>		<b>0.24</b>		<b>0.04</b>	<b>0.54</b> ✓

*5x*

# RUN DATA

Number *82*

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** *78*

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
14:20	15	0.10	<2	<0.05	24	0.19	<2	<0.02	0.29
14:23	58	0.23	15	0.14	31	0.21	20	0.05	0.68
14:26	31	0.16	11	0.11	<2	<0.05	<2	<0.02	0.27
14:29	13	0.09	<2	<0.05	31	0.22	53	0.09	0.49
14:32	15	0.10	<2	<0.05	30	0.21	<2	<0.02	0.31
14:35	16	0.10	11	0.11	<2	<0.05	<2	<0.02	0.22
14:38	<2	<0.04	<2	<0.05	71	0.34	<2	<0.02	0.34
14:41	<2	<0.04	<2	<0.05	81	0.37	47	0.08	0.54
14:44	13	0.09	17	0.15	<2	<0.05	56	0.09	0.42
14:47	<2	<0.04	16	0.15	94	0.41	58	0.10	0.74
14:50	14	0.10	53	0.28	6	0.08	30	0.07	0.60
14:53	<2	<0.04	91	0.39	34	0.23	<2	<0.02	0.62
14:56	9	0.08	59	0.30	17	0.15	34	0.07	0.67
14:59	<2	<0.04	31	0.21	19	0.16	106	0.13	0.64
15:02	<2	<0.04	40	0.24	<2	<0.05	<2	<0.02	0.24
15:05	9	0.07	<2	<0.05	56	0.30	23	0.05	0.48
15:08	15	0.10	<2	<0.05	<2	<0.05	29	0.06	0.23
15:11	64	0.24	<2	<0.05	91	0.40	<2	<0.02	0.64
15:14	<2	<0.04	<2	<0.05	59	0.31	25	0.06	0.43
15:17	15	0.10	14	0.13	9	0.11	10	0.03	0.41
<b>Average</b>		<b>0.08</b>		<b>0.11</b>		<b>0.18</b>		<b>0.04</b>	<b>0.46</b> ✓

*82*

# RUN DATA

Number *β* 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 78**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
15:25	<2	<0.04	11	0.12	<2	<0.05	18	0.05	0.21
15:28	67	0.25	7	0.09	11	0.12	<2	<0.02	0.46
15:31	44	0.20	11	0.12	13	0.13	<2	<0.02	0.44
15:34	<2	<0.04	<2	<0.05	13	0.13	27	0.06	0.25
15:37	17	0.11	5	0.07	23	0.18	78	0.11	0.59
15:40	25	0.14	74	0.35	22	0.18	17	0.05	0.75
15:43	29	0.15	9	0.10	10	0.11	<2	<0.02	0.36
15:46	83	0.29	<2	<0.05	9	0.11	94	0.13	0.65
15:49	7	0.07	12	0.12	4	0.07	37	0.07	0.40
15:52	<2	<0.04	71	0.34	<2	<0.05	22	0.05	0.45
15:55	10	0.08	29	0.20	24	0.18	67	0.10	0.67
15:58	14	0.10	25	0.18	<2	<0.05	12	0.04	0.36
16:01	21	0.13	15	0.14	28	0.20	9	0.03	0.53
16:04	<2	<0.04	35	0.23	14	0.14	<2	<0.02	0.36
16:07	8	0.07	<2	<0.05	21	0.17	<2	<0.02	0.24
16:10	14	0.10	11	0.12	135	0.50	81	0.12	0.94
16:13	67	0.25	<2	<0.05	<2	<0.05	29	0.06	0.38
16:16	14	0.10	25	0.18	249	0.71	<2	<0.02	0.99
16:19	16	0.10	38	0.24	84	0.38	<2	<0.02	0.72
16:22	<2	<0.04	121	0.46	<2	<0.05	<2	<0.02	0.46
<b>Average</b>		<b>0.11</b>		<b>0.15</b>		<b>0.16</b>		<b>0.04</b>	<b>0.51</b> ✓

*54*



# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 78**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

**After Run 3    Before Run 4**  
**Start Time 12:55    End Time 13:09**

## Recovery Gas to Probe, Time 12:55

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
16925	16900	17033	16953	7.34

## Recovery Gas to GC, Time 13:06

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
18883	18581	18955	18807	7.82

**Recovery 93.9%** ✓

84

# RECOVERY DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent** f y

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

After Run 6 Before Run 7  
Start Time 16:25 End Time 16:35

## Recovery Gas to Probe, Time 16:25

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
15588	15927	16534	16016	7.09

## Recovery Gas to GC, Time 16:31

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
18437	18819	18738	18664	7.78

Recovery 91.1% ✓

54

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

**Ambient Temperature: 72°C**

**Barometric Pressure: 29.70 in. Hg**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	460	457	298	232
Ret. Time, sec	25.0	35.0	63.0	132.0

**1 Flow = 48.0 mL/Min      9.58 ppm      9.52 ppm      6.20 ppm      4.83 ppm**

**Time: 07:01      Peak Areas, mv-sec**

	25119	23385	10987	48706
	25616	23496	10706	47186
	25021	22672	10690	48066
<b>Average Area</b>	<b>25252</b>	<b>23184</b>	<b>10794</b>	<b>47986</b>

**2 Flow = 81.6 mL/Min      5.64 ppm      5.60 ppm      3.65 ppm      2.84 ppm**

**Time: 07:34      Peak Areas, mv-sec**

	11971	9531	4072	19617
	11666	9535	4189	19344
	11820	9242	4068	20012
<b>Average Area</b>	<b>11819</b>	<b>9436</b>	<b>4110</b>	<b>19658</b>

**3 Flow = 151 mL/Min      3.05 ppm      3.02 ppm      1.97 ppm      1.54 ppm**

**Time: 07:49      Peak Areas, mv-sec**

	3892	3195	1507	6761
	3898	3136	1468	6767
	3818	3182	1462	6752
<b>Average Area</b>	<b>3869</b>	<b>3171</b>	<b>1479</b>	<b>6760</b>

SK

# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

<b>H<sub>2</sub>S</b>	<b>1</b>	<b>2</b>	<b>3</b>			
Time	07:01	07:34	07:49			
Concentration, ppm	9.58	5.64	3.05			
Area, mv-sec	25252	11819	3869			
Calc. Conc., ppm	9.36	5.89	2.98			
% Error	-2.4	4.5	-2.0 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.6414	2.8084	0.9978	2	0.04	

<b>MeSH</b>	<b>1</b>	<b>2</b>	<b>3</b>			
Time	07:01	07:34	07:49			
Concentration, ppm	9.52	5.60	3.02			
Area, mv-sec	23184	9436	3171			
Calc. Conc., ppm	9.47	5.65	3.01			
% Error	-0.5	0.9	-0.4 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.7368	2.6693	0.9999	2	0.05	

<b>DMS</b>	<b>1</b>	<b>2</b>	<b>3</b>			
Time	07:01	07:34	07:49			
Concentration, ppm	6.20	3.65	1.97			
Area, mv-sec	10794	4110	1479			
Calc. Conc., ppm	6.26	3.59	1.99			
% Error	0.9	-1.7	0.8 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.7325	2.6531	0.9997	2	0.05	

<b>DMDS</b>	<b>1</b>	<b>2</b>	<b>3</b>			
Time	07:01	07:34	07:49			
Concentration, ppm	4.83	2.84	1.54			
Area, mv-sec	47986	19658	6760			
Calc. Conc., ppm	4.82	2.86	1.53			
% Error	-0.3	0.6	-0.3 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.7107	3.5133	>0.9999	2	0.02	

# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

**Ambient Temperature: 72°C**

**Barometric Pressure: 29.70 in. Hg**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	460	457	298	232
Ret. Time, sec	25.0	35.0	63.0	132.0

**1 Flow = 48.0 mL/Min      9.58 ppm      9.52 ppm      6.20 ppm      4.83 ppm**

**Time: 16:36      Peak Areas, mv-sec**

26011	25303	11444	51862
26531	26149	12036	53970
27302	26754	12114	53372
<b>Average Area</b>	<b>26615</b>	<b>11864</b> ✓	<b>53068</b>

**2 Flow = 88.9 mL/Min      5.17 ppm      5.14 ppm      3.35 ppm      2.61 ppm**

**Time: 16:50      Peak Areas, mv-sec**

9447	7596	3066	16100
9456	7369	3124	14977
9570	7546	3109	14905
<b>Average Area</b>	<b>9491</b>	<b>7504</b> ✓	<b>15327</b>

**3 Flow = 133 mL/Min      3.45 ppm      3.43 ppm      2.23 ppm      1.74 ppm**

**Time: 17:14      Peak Areas, mv-sec**

4013	3384	1323	6743
4015	3427	1344	6741
3979	3463	1344	6769
<b>Average Area</b>	<b>4002</b> ✓	<b>3425</b>	<b>6751</b>

KS

# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

H <sub>2</sub> S	1	2	3			
Time	16:36	16:50	17:14			
Concentration, ppm	9.58	5.17	3.45			
Area, mv-sec	26615	9491	4002			
Calc. Conc., ppm	9.43	5.38	3.37			
% Error	-1.6	4.1	-2.4 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.8396	2.6323	0.9977	2	0.05	

MeSH	1	2	3			
Time	16:36	16:50	17:14			
Concentration, ppm	9.52	5.14	3.43			
Area, mv-sec	26069	7504	3425			
Calc. Conc., ppm	9.54	5.10	3.44			
% Error	0.3	-0.7	0.4 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.9895	2.4671	0.9999	2	0.08	

DMS	1	2	3			
Time	16:36	16:50	17:14			
Concentration, ppm	6.20	3.35	2.23			
Area, mv-sec	11864	3100	1337			
Calc. Conc., ppm	6.22	3.32	2.24			
% Error	0.3	-0.8	0.5 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	2.1400	2.3753	0.9999	2	0.11	

DMDS	1	2	3			
Time	16:36	16:50	17:14			
Concentration, ppm	4.83	2.61	1.74			
Area, mv-sec	53068	15327	6751			
Calc. Conc., ppm	4.83	2.61	1.74 ✓			
% Error	-0.0	0.1	-0.0 ✓			
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	2.0180	3.3447	>0.9999	2	0.03	

5/4



# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
<b>Molecular Weight</b>	34.08	48.11	62.14	94.20
<b>Retention Time, sec</b>	25.0	35.0	63.0	132.0
<b>Peak Detection Window, sec</b>	10.0	10.0	10.0	10.0
<b>Minimum Peak Area, mv-sec</b>	2	2	2	2
<b>Minimum Peak Height, mv</b>	1	1	1	1
<b>Beginning Peak Width, sec</b>	1.0	1.0	3.0	3.0
<b>Ending Peak Width, sec</b>	2.0	3.0	5.0	5.0
<b>Permeation Device ID</b>	T-51831	33-50536	89-50725	89-53405
<b>Permeation Rate, ng/min</b>	642 ✓	901 ✓	758 ✓	895 ✓
<b>Permeation Rate, nL/min*</b>	460	457	298	232

**Barometric Pressure:** 29.70 in. Hg     **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- PR<sub>ng</sub>** = Permeation Rate by weight, ng/min
- V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole
- W<sub>mol</sub>** = Molecular Weight of compound
- T<sub>a</sub>** = Ambient Temperature, °F
- T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)
- P<sub>s</sub>** = Standard Pressure = 29.92 in Hg
- P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 642 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.70) = 460 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

- C** = Concentration, ppmv
- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- F<sub>d</sub>** = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

File: E:\6-26-21.trs  
Program Version: 2.0, built 21 Feb 2015 File Version: 2.0  
Computer: JWS-PROGRAMMING Trailer: 271

Analog Input Device: Keithley KUSB-3108 GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: GC-8A Serial No. C10494419420SA  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 100	Primary: 3'
Air	30	60	Detector: 120	Secondary:
Carrier	50	30		Sample Loop: 6" unlined

## Injection Cycle

Total Length: 180 sec Sampling Time: 160 sec Load/Backflush Time: 85 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 5 mv-sec Minimum peak height 5 mv above baseline

## Dynacalibrator

Chamber Temperature 130.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.70 in. Hg

# RUN DATA

Number 7

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vent 7**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
17:44	18765	7.81	<2	<0.05	<2	<0.05	<2	<0.02	7.81
17:47	19416	7.97	<2	<0.05	<2	<0.05	<2	<0.02	7.97
17:50	18473	7.73	<2	<0.05	<2	<0.05	<2	<0.02	7.73
17:53	18357	7.70	<2	<0.05	<2	<0.05	<2	<0.02	7.70
<b>Average</b>		<b>7.80</b>		<b>&lt;0.05</b>		<b>&lt;0.05</b>		<b>&lt;0.02</b>	<b>7.80</b>

SH

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 8**

Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
14:21:27	6775	20.2	-11	0.1
14:21:42	6776	20.2	-11	0.1
14:21:57	6776	20.2	-11	0.1
14:22:12	6777	20.2	-11	0.1
14:22:27	6777	20.2	-11	0.1
14:22:42	6777	20.2	-12	0.1
14:22:57	6777	20.2	-11	0.1
14:23:12	6776	20.2	-11	0.1
14:23:27	6778	20.2	-12	0.1
14:23:42	6777	20.2	-10	0.1
14:23:57	6777	20.2	-10	0.1
14:24:12	6777	20.2	-11	0.1
14:24:27	6778	20.2	-11	0.1
14:24:42	6777	20.2	-11	0.1
14:24:57	6777	20.2	-10	0.1
14:25:12	6778	20.2	-9	0.1
14:25:27	6778	20.2	-11	0.1
14:25:42	6778	20.2	-10	0.1
<b>Avg</b>	<b>6777</b>	<b>20.2</b>	<b>-11</b>	<b>0.1</b>

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 8**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
15:30:53	6776	20.2	-11	0.1
15:31:08	6777	20.2	-10	0.1
15:31:23	6777	20.2	-11	0.1
15:31:38	6776	20.2	-10	0.1
15:31:53	6777	20.2	-11	0.1
15:32:08	6778	20.2	-11	0.1
15:32:23	6775	20.2	-11	0.1
15:32:38	6777	20.2	-12	0.1
15:32:53	6777	20.2	-12	0.1
15:33:08	6777	20.2	-14	0.1
15:33:23	6776	20.2	-13	0.1
15:33:38	6777	20.2	-14	0.1
15:33:53	6777	20.2	-16	0.1
15:34:08	6776	20.2	-13	0.1
15:34:23	6777	20.2	-13	0.1
15:34:38	6778	20.2	-14	0.1
15:34:53	6777	20.2	-12	0.1
<b>Avg</b>	<b>6777</b>	<b>20.2</b>	<b>-12</b>	<b>0.1</b>

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 8**

Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
16:29:58	6779	20.2	-9	0.1
16:30:13	6778	20.2	-8	0.1
16:30:28	6778	20.2	-7	0.1
16:30:43	6779	20.2	-7	0.1
16:30:58	6780	20.2	-8	0.1
16:31:13	6780	20.2	-8	0.1
16:31:28	6778	20.2	-8	0.1
16:31:43	6779	20.2	-7	0.1
16:31:58	6778	20.2	-8	0.1
16:32:13	6779	20.2	-7	0.1
16:32:28	6779	20.2	-8	0.1
16:32:43	6781	20.2	-8	0.1
16:32:58	6778	20.2	-8	0.1
16:33:13	6777	20.2	-8	0.1
16:33:28	6780	20.2	-7	0.1
16:33:43	6779	20.2	-9	0.1
16:33:58	6779	20.2	-8	0.1
16:34:13	6779	20.2	-8	0.1
16:34:28	6780	20.2	-8	0.1
16:34:43	6779	20.2	-8	0.1
16:34:58	6779	20.2	-8	0.1
16:35:13	6778	20.2	-7	0.1
16:35:28	6780	20.2	-9	0.1
16:35:43	6780	20.2	-9	0.1
16:35:58	6779	20.2	-8	0.1
<b>Avg</b>	<b>6779</b>	<b>20.2</b>	<b>-8</b>	<b>0.1</b>



# RUN DATA

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 8**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
16:38:22	3393	10.2	3339	9.8
16:38:37	3316	9.9	3407	10.0
16:38:52	3315	9.9	3412	10.0
<b>SG9168283BAL</b>		<b>O2=10.12</b>		<b>CO2= 10.16</b>
16:39:07	3312	9.9	3413	10.0
16:39:22	3312	9.9	3416	10.0
16:39:37	3311	9.9	3418	10.0
16:39:52	3310	9.9	3416	10.0
16:40:07	3311	9.9	3417	10.0
16:40:22	3311	9.9	3417	10.0
16:40:37	3309	9.9	3417	10.0
16:40:52	3311	9.9	3418	10.0
16:41:07	3309	9.9	3418	10.0
16:41:22	3310	9.9	3418	10.0
16:41:37	3310	9.9	3417	10.0
16:41:52	3311	9.9	3417	10.0
16:42:07	3311	9.9	3418	10.0
16:42:22	3312	9.9	3416	10.0
16:42:37	3313	9.9	3416	10.0
16:42:52	3315	9.9	3413	10.0
16:43:07	3317	9.9	3411	10.0
16:43:22	3316	9.9	3410	10.0
16:43:37	3321	10.0	3407	10.0
16:43:52	3334	10.0	3395	10.0
16:44:07	3363	10.1	3365	9.9
<b>Avg</b>	<b>3319</b>	<b>9.9</b>	<b>3409</b>	<b>10.0</b>

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 8**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Start Time: 08:07

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	8
10.1 ✓	SG9168283BAL	3293
19.5 ✓	CC454190	6574

Curve Coefficients

Slope	Intercept	Corr. Coeff.
336.6 ✓	-29 ✓	0.9998 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	-32
10.2 ✓	SG9168283BAL	3417
20.4 ✓	CC454190	7035

Curve Coefficients

Slope	Intercept	Corr. Coeff.
346.4 ✓	-56 ✓	0.9999 ✓

✓

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 8**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Start Time: 08:07

**O<sub>2</sub>**

Method: EPA 3A

Span Conc. 19.5 %

Slope 336.6

Intercept -29.2

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	8	0.1	0.1	0.5 ✓	Pass
10.1	3293	9.9	-0.2	-1.0 ✓	Pass
19.5	6574	19.6	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.4 %

Slope 346.4

Intercept -55.6

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-32	0.1	0.1	0.5 ✓	Pass
10.2	3417	10.0	-0.2	-1.0 ✓	Pass
20.4	7035	20.5	0.1	0.5 ✓	Pass

*✓*

# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vent 8**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

---

**File:** C:\Users\Trailer 271\Documents\New Indy\6-26-21b.cem  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** DESKTOP-GQ0I9UV **Trailer:** 271  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>20.0</b>
Span Concentration, %	<b>19.5</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.4</b>



**VENT 1  
(VOIDED DATA)**

# RUN SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

Start Time 15:00    End Time 16:00

---

Average Measured TRS Conc.    0.67 ppm ✓  
Recovery No. 2    98.7 % ✓  
TRS Corrected for Recovery    0.68 ppm ✓

✓

# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

Start Time 16:02    End Time 17:02

---

Average Measured TRS Conc.    0.91 ppm ✓  
Recovery No. 2    98.7 % ✓  
TRS Corrected for Recovery    0.92 ppm ✓

*Handwritten mark*



# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

Start Time 17:04    End Time 18:04

---

Average Measured TRS Conc.    0.92 ppm ✓  
Recovery No. 2    98.7 % ✓  
TRS Corrected for Recovery    0.93 ppm ✓

N

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**

Operator: **VD**

Date: **23 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
15:00	15	0.28	13	0.32	<2	<0.12	<2	<0.037	0.60
15:03	132	0.83	<2	<0.13	<2	<0.12	<2	<0.037	0.83
15:06	11	0.24	18	0.37	<2	<0.12	<2	<0.037	0.61
15:09	38	0.45	67	0.69	<2	<0.12	<2	<0.037	1.14
15:12	69	0.60	5	0.21	<2	<0.12	<2	<0.037	0.81
15:15	16	0.29	39	0.53	<2	<0.12	<2	<0.037	0.82
15:18	10	0.23	<2	<0.13	<2	<0.12	<2	<0.037	0.23
15:21	7	0.19	<2	<0.13	<2	<0.12	<2	<0.037	0.19
15:24	10	0.23	23	0.42	<2	<0.12	<2	<0.037	0.64
15:27	52	0.52	19	0.37	<2	<0.12	<2	<0.037	0.90
15:30	18	0.31	29	0.47	<2	<0.12	<2	<0.037	0.77
15:33	13	0.27	21	0.39	<2	<0.12	<2	<0.037	0.66
15:36	50	0.51	31	0.48	<2	<0.12	<2	<0.037	0.99
15:39	9	0.23	<2	<0.13	<2	<0.12	<2	<0.037	0.23
15:42	5	0.16	19	0.38	<2	<0.12	<2	<0.037	0.54
15:45	24	0.36	6	0.21	<2	<0.12	<2	<0.037	0.57
15:48	30	0.40	<2	<0.13	<2	<0.12	<2	<0.037	0.40
15:51	<2	<0.10	<2	<0.13	<2	<0.12	<2	<0.037	-
15:54	17	0.30	167	1.07	<2	<0.12	<2	<0.037	1.37
15:57	44	0.48	52	0.61	<2	<0.12	<2	<0.037	1.09

**Average**                      **0.34**                      **0.33**                      **<0.12**                      **<0.037**                      **0.67** ✓

*M*

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
16:02	17	0.30	<2	<0.13	<2	<0.12	<2	<0.037	0.30
16:05	<2	<0.10	<2	<0.13	<2	<0.12	<2	<0.037	-
16:08	7	0.19	<2	<0.13	<2	<0.12	<2	<0.037	0.19
16:11	113	0.77	<2	<0.13	194	1.05	<2	<0.037	1.82
16:14	<2	<0.10	12	0.31	<2	<0.12	42	0.17	0.65
16:17	9	0.22	13	0.32	5	0.18	<2	<0.037	0.72
16:20	11	0.24	<2	<0.13	<2	<0.12	45	0.18	0.59
16:23	35	0.43	4	0.19	81	0.69	8	0.07	1.46
16:26	37	0.44	6	0.22	20	0.35	75	0.23	1.47
16:29	16	0.29	<2	<0.13	<2	<0.12	18	0.11	0.51
16:32	5	0.16	10	0.28	96	0.75	<2	<0.037	1.20
16:35	<2	<0.10	77	0.74	<2	<0.12	19	0.12	0.97
16:38	46	0.49	<2	<0.13	<2	<0.12	11	0.08	0.66
16:41	<2	<0.10	31	0.48	45	0.52	34	0.15	1.31
16:44	21	0.34	21	0.39	63	0.61	16	0.10	1.55
16:47	21	0.34	36	0.51	6	0.20	87	0.24	1.54
16:50	6	0.19	26	0.44	<2	<0.12	45	0.18	0.98
16:53	13	0.26	<2	<0.13	<2	<0.12	11	0.09	0.43
16:56	15	0.28	<2	<0.13	13	0.28	54	0.19	0.95
16:59	79	0.64	4	0.18	<2	<0.12	<2	<0.037	0.82
<b>Average</b>		<b>0.28</b>		<b>0.20</b>		<b>0.23</b>		<b>0.10</b>	<b>0.91</b> ✓

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
17:04	59	0.56	<2	<0.13	<2	<0.12	<2	<0.037	0.56
17:07	24	0.36	20	0.39	39	0.48	<2	<0.037	1.23
17:10	22	0.34	16	0.35	34	0.45	<2	<0.037	1.15
17:13	25	0.36	31	0.48	<2	<0.12	27	0.14	1.11
17:16	27	0.38	13	0.32	<2	<0.12	<2	<0.037	0.69
17:19	66	0.59	<2	<0.13	<2	<0.12	<2	<0.037	0.59
17:22	10	0.23	33	0.50	<2	<0.12	46	0.18	1.08
17:25	<2	<0.10	<2	<0.13	19	0.35	<2	<0.037	0.35
17:28	<2	<0.10	8	0.26	57	0.58	<2	<0.037	0.84
17:31	4	0.14	37	0.52	23	0.38	<2	<0.037	1.04
17:34	46	0.49	<2	<0.13	72	0.65	<2	<0.037	1.14
17:37	5	0.17	5	0.20	53	0.56	20	0.12	1.17
17:40	<2	<0.10	16	0.35	59	0.59	10	0.08	1.11
17:43	44	0.48	20	0.39	32	0.44	16	0.11	1.53
17:46	17	0.30	<2	<0.13	26	0.40	27	0.14	0.98
17:49	24	0.36	<2	<0.13	<2	<0.12	99	0.26	0.88
17:52	<2	<0.10	13	0.32	12	0.28	<2	<0.037	0.60
17:55	15	0.28	4	0.18	10	0.25	24	0.13	0.96
17:58	26	0.37	5	0.20	21	0.36	36	0.16	1.25
18:01	<2	<0.10	<2	<0.13	<2	<0.12	16	0.10	0.21
<b>Average</b>		<b>0.27</b>		<b>0.22</b>		<b>0.29</b>		<b>0.07</b>	<b>0.92</b>

# RECOVERY DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

## Before Run 1

Start Time 08:11    End Time 08:31

---

### Recovery Gas to Probe, Time 08:11

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
10815	11212	10554	10860	7.38

---

### Recovery Gas to GC, Time 08:26

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
12058	12718	12683	12486	7.91

---

Recovery 93.3% ✓

---

# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

After Run 3

Start Time 18:08    End Time 18:27

## Recovery Gas to Probe, Time 18:08

Peak Areas, mv-sec			Average	ppm
13435	13768	13995	13733 ✓	8.29

## Recovery Gas to GC, Time 18:22

Peak Areas, mv-sec			Average	ppm
13868	14119	14335	14107 ✓	8.41

Recovery 98.7% /

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

Ambient Temperature: 72°C

Barometric Pressure: 29.30 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51831	33-50536	89-50725	89-53405
Perm. Rate, nL/min	466	463	302	235
Ret. Time, sec	25.0	35.0	63.0	132.0

**1** Flow = **42.9** mL/Min      **10.9** ppm      **10.8** ppm      **7.04** ppm      **5.48** ppm

Time: **06:01**

Peak Areas, mv-sec

	23855	22293	10526	42673
	23215	21931	9998	42671
	22458	20868	9790	39883
<u>Average Area</u>	<b>23176</b> ✓	<b>21697</b> ✓	<b>10105</b> ✓	<b>41742</b> ✓

**2** Flow = **73.0** mL/Min      **6.39** ppm      **6.34** ppm      **4.13** ppm      **3.22** ppm

Time: **07:11**

Peak Areas, mv-sec

	8465	7583	3422	15009
	8597	7440	3304	15088
	8224	7258	3241	15119
<u>Average Area</u>	<b>8429</b> ✓	<b>7427</b> ✓	<b>3322</b> ✓	<b>15072</b> ✓

**3** Flow = **160** mL/Min      **2.91** ppm      **2.89** ppm      **1.89** ppm      **1.47** ppm

Time: **07:27**

Peak Areas, mv-sec

	1616	1350	665	3068
	1680	1357	629	2997
	1609	1367	669	3070
<u>Average Area</u>	<b>1635</b> ✓	<b>1358</b> ✓	<b>655</b> ✓	<b>3045</b> ✓



# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

H <sub>2</sub> S	1	2	3		
Time	06:01	07:11	07:27		
Concentration, ppm	10.9	6.39	2.91		
Area, mv-sec	23176	8429	1635		
Calc. Conc., ppm	10.7	6.51	2.89		
% Error	-1.2	2.0	-0.8		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	2.0185	2.2831	0.9997	2	0.10

MeSH	1	2	3		
Time	06:01	07:11	07:27		
Concentration, ppm	10.8	6.34	2.89		
Area, mv-sec	21697	7427	1358		
Calc. Conc., ppm	10.7	6.44	2.88		
% Error	-0.9	1.5	-0.6		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	2.1084	2.1655	0.9998	2	0.13

DMS	1	2	3		
Time	06:01	07:11	07:27		
Concentration, ppm	7.04	4.13	1.89		
Area, mv-sec	10105	3322	655		
Calc. Conc., ppm	7.05	4.13	1.89		
% Error	0.1	-0.2	0.1		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	2.0770	2.2430	>0.9999	2	0.12

DMDS	1	2	3		
Time	06:01	07:11	07:27		
Concentration, ppm	5.48	3.22	1.47		
Area, mv-sec	41742	15072	3045		
Calc. Conc., ppm	5.44	3.26	1.46		
% Error	-0.8	1.3	-0.5		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9911	3.1557	0.9999	2	0.037

# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

Analyte Molecular Weight	H <sub>2</sub> S 34.08	MeSH 48.11	DMS 62.14	DMDS 94.20
Retention Time, sec	25.0	35.0	63.0	132.0
Peak Detection Window, sec	15.0	15.0	10.0	10.0
Minimum Peak Area, mv-sec	2	2	2	2
Minimum Peak Height, mv	1	1	1	1
Beginning Peak Width, sec	1.0	1.0	3.0	3.0
Ending Peak Width, sec	2.0	3.0	5.0	5.0
Permeation Device ID	T-51831	33-50536	89-50725	89-53405
Permeation Rate, ng/min	642 ✓	901	✓758	✓895 ✓
Permeation Rate, nL/min*	461	458	299	233

**Barometric Pressure:** 29.60 in. Hg     **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

- $PR_{nl}$  = Permeation Rate by volume, nL/min
- $PR_{ng}$  = Permeation Rate by weight, ng/min
- $V_{mol}$  = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole
- $W_{mol}$  = Molecular Weight of compound
- $T_a$  = Ambient Temperature, °F
- $T_s$  = Standard Temperature = 492°R (32 °F)
- $P_s$  = Standard Pressure = 29.92 in Hg
- $P_b$  = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 642 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.60) = 461 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

- $C$  = Concentration, ppmv
- $PR_{nl}$  = Permeation Rate by volume, nL/min
- $F_d$  = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine Vents**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

File: E:\New Indy\6-23-21.trs  
Program Version: 2.0, built 15 May 2017 File Version: 2.0  
Computer: JWS-PROGRAMMING Trailer: 271

Analog Input Device: Keithley KUSB-3108 GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: GC-8A Serial No. C10494419420SA  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 100	Primary: 3'
Air	30	60	Detector: 120	Secondary:
Carrier	50	30		Sample Loop: 6" unlined

## Injection Cycle

Total Length: 180 sec Sampling Time: 160 sec Load/Backflush Time: 85 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 2 mv-sec Minimum peak height 1 mv above baseline

## Dynacalibrator

Chamber Temperature 130.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.60 in. Hg

# Isokinetic Field Data

# Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 1 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/23/21  
 Test Personnel: BEA/BE  
 Sample Time: 48 min.

Console ID: A-23  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.805  
 Probe ID/Length: PL66-6'  
 Liner Material: SS  
 Pitot ID/Coeff: P77  
 Thermo ID: A-23  
 Nozzle ID/Diams.: 1/4"  
 Avg. Nozzle Diam.: -250 in.

Ambient Temp.: 84 °F  
 Baro. Pressure\*: 29.58 in. Hg  
 Static Pressure: -.01 in. H<sub>2</sub>O  
 Impinger Gain: 150.4 mL  
 Silica Gel Gain: 7.5 g  
 Stack Area: 13.64 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A

Leak Checks	
Initial	Final
Volume, ft <sup>3</sup>	0.007
@ Vac., in. Hg	14"
Pitot	Good

Filter ID: N/A  
 Sample ID: 23

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
0		16:04			513.550									
A-1	3		.04	1.3	515.6	173	M/A	89	253	261	M/A	59	3	
2	6		.03	1.3	517.4	174		89	256	263		53	3	
3	9		.04	1.3	519.3	174		88	256	263		54	3	
4	12		.04	1.3	521.8	174		89	253	264		51	3	
5	15		.04	1.3	523.2	172		89	253	268		52	3	
6	18		.04	1.3	525.1	172		88	252	267		53	3	
7	21		.03	1.3	526.9	172		90	252	268		54	3	
8	24		.03	1.3	528.8	171		90	253	267		55	3	
B-1	27		.04	1.3	530.8	169		90	249	267		57	3	
2	30		.04	1.3	532.8	172		90	250	264		66	3	
3	33		.04	1.3	534.7	173		90	251	264		57	3	
4	36		.03	1.3	536.7	173		90	252	261		57	3	
5	39		.02	1.3	538.6	173		90	251	266		58	3	
6	42		.03	1.3	540.5	173		89	253	267		58	3	
7	45		.03	1.3	542.5	173		90	252	267		59	3	
8	48	16:54	.04	1.3	544.528	173		90	253	266		58	3	
*Barometric Pressure is at port elevation			Avg Vap	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub>
			.085	1.300	30.978	172.56	89.4	249/256	261/268	266	266	59	3	3

15730.001.008  
 Pulp Dr. Paper Machine,  
 #2-3 SD TVs & #1-2 CBs  
 Emission Report

Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 Result \_\_\_\_\_

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run \_\_\_\_\_  
 Post-run \_\_\_\_\_

Flue Gas Composition  
 Oxygen, % \_\_\_\_\_  
 Carbon Dioxide, % \_\_\_\_\_  
 Moisture, % \_\_\_\_\_

Comments \_\_\_\_\_  
 QC by \_\_\_\_\_





# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 1 Hood Exhaust  
 Sample Location: Roof  
 W. O. Number: 15730.001.008  
 Run Number: 1  
 Date: 6/23/21  
 Test Personnel: BEA/BE  
 Sample Time: 48 min.

Console ID: A023  
 Meter Corr., Y: 1.003  
 Console ΔH@: 1.800  
 Probe ID/Length: 6'  
 Liner Material: 8'  
 Pitot ID/Coeff.: 0.84  
 Thermo ID: A023  
 Nozzle ID/Diams.: .250 in.

Ambient Temp.: 81 °F  
 Baro. Pressure\*: 29.58 in. Hg  
 Static Pressure: -0.01 in. H<sub>2</sub>O  
 Impinger Gain: 125.8 mL  
 Silica Gel Gain: 8.1 g  
 Stack Area: 1364 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: N/A

### Leak Checks

	Initial	Final
Volume, ft <sup>3</sup>	<u>0.006</u>	<u>0.000</u>
@ Vac., in. Hg	<u>12</u>	<u>5</u>
Pitot	<u>Good</u>	

Filter ID: N/A  
 Sample ID: Run 1

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
0		<u>15:00</u>			<u>450.550</u>									
A-1	3		<u>.04</u>	<u>1.3</u>	<u>452.6</u>	<u>185</u>	<u>N/A</u>	<u>89</u>	<u>253</u>	<u>260</u>	<u>N/A</u>	<u>56</u>	<u>3</u>	
2	6		<u>.04</u>	<u>1.3</u>	<u>454.5</u>	<u>187</u>		<u>89</u>	<u>266</u>	<u>261</u>		<u>56</u>	<u>3</u>	
3	9		<u>.05</u>	<u>1.3</u>	<u>456.4</u>	<u>190</u>		<u>90</u>	<u>261</u>	<u>244</u>		<u>53</u>	<u>3</u>	
4	12		<u>.04</u>	<u>1.3</u>	<u>458.2</u>	<u>190</u>		<u>90</u>	<u>264</u>	<u>263</u>		<u>54</u>	<u>3</u>	
5	15		<u>.03</u>	<u>1.3</u>	<u>460.1</u>	<u>179</u>		<u>91</u>	<u>253</u>	<u>244</u>		<u>54</u>	<u>3</u>	
6	18		<u>.03</u>	<u>1.3</u>	<u>462.0</u>	<u>180</u>		<u>92</u>	<u>251</u>	<u>262</u>		<u>54</u>	<u>3</u>	
7	21		<u>.03</u>	<u>1.3</u>	<u>464.0</u>	<u>179</u>		<u>92</u>	<u>256</u>	<u>268</u>		<u>56</u>	<u>3</u>	
8	24		<u>.02</u>	<u>1.3</u>	<u>466.0</u>	<u>175</u>		<u>93</u>	<u>254</u>	<u>267</u>		<u>57</u>	<u>3</u>	
B-1	27		<u>.05</u>	<u>1.3</u>	<u>467.9</u>	<u>177</u>		<u>94</u>	<u>253</u>	<u>264</u>		<u>60</u>	<u>3</u>	
2	30		<u>.04</u>	<u>1.3</u>	<u>469.8</u>	<u>180</u>		<u>94</u>	<u>252</u>	<u>264</u>		<u>60</u>	<u>3</u>	
3	33		<u>.04</u>	<u>1.3</u>	<u>471.8</u>	<u>180</u>		<u>95</u>	<u>255</u>	<u>265</u>		<u>59</u>	<u>3</u>	
4	36		<u>.03</u>	<u>1.3</u>	<u>473.7</u>	<u>181</u>		<u>96</u>	<u>254</u>	<u>266</u>		<u>59</u>	<u>3</u>	
5	39		<u>.04</u>	<u>1.3</u>	<u>475.8</u>	<u>181</u>		<u>96</u>	<u>256</u>	<u>266</u>		<u>61</u>	<u>3</u>	
6	42		<u>.04</u>	<u>1.3</u>	<u>477.7</u>	<u>177</u>		<u>96</u>	<u>251</u>	<u>265</u>		<u>63</u>	<u>3</u>	
7	45		<u>.03</u>	<u>1.3</u>	<u>479.8</u>	<u>176</u>		<u>95</u>	<u>253</u>	<u>266</u>		<u>63</u>	<u>3</u>	
8	48		<u>.03</u>	<u>1.3</u>	<u>481.733</u>	<u>173</u>		<u>95</u>	<u>255</u>	<u>264</u>		<u>64</u>	<u>3</u>	
			Avg. ΔP	Avg. ΔH	Total Volume	Avg. T <sub>s</sub>	Avg. T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std.</sub> scf
			<u>.1892</u>	<u>1.3000</u>	<u>31.183</u>	<u>180.6</u>	<u>92.9</u>	<u>251/266</u>	<u>260/268</u>	<u>260/268</u>	<u>264</u>	<u>64</u>	<u>3</u>	<u>3</u>

\*Barometric Pressure is at port elevation  
 Flue Gas Composition:  
 Oxygen, %  
 Carbon Dioxide, %  
 Moisture, %  
 O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run  
 Post-run  
 Thermocouple Check  
 Meter Temp., °F  
 Ref. Temp., °F  
 % Isokinetic  
 Calculated by  
 QC by





# Isokinetic Field Data

## Method: EPA 4, Moisture

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 1 Hood Exhaust  
 Sample Location Roof  
 W. O. Number 15730.001.008  
 Run Number 2  
 Date 6/23/21  
 Test Personnel BEA/BE  
 Sample Time 48 min.

Console ID A623  
 Meter Corr., Y 1.003  
 Console ΔH@ 1.8000  
 Probe ID/Length PR-6C 6'  
 Liner Material SS  
 Pitot ID/Coeff. 0.84  
 Thermo ID A623  
 Nozzle ID/Diams. 0.250 in.

Ambient Temp. 81 °F  
 Baro. Pressure\* 29.55 in. Hg  
 Static Pressure -0.1 in. H<sub>2</sub>O  
 Impinger Gain 160.8 mL  
 Silica Gel Gain 11.1 g  
 Stack Area 13.64 ft<sup>2</sup>  
 Total Traverse Points 16

K Factor N/A  
 Leak Checks  
 Volume, ft<sup>3</sup> Initial Final  
 @ Vac., in. Hg 0.002 0.002  
 Pitot 12" 7  
Good Good  
 Filter ID N/A  
 Sample ID EW-7

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
0	0	1602			481.900									
A-1	3		.04	1.3	483.8	173	N/A	91	254	260	N/A	65	3	
2	6		.05	1.3	485.8	179		90	252	263		63	3	
3	9		.04	1.3	487.6	177		90	255	260		62	3	
4	12		.05	1.3	489.5	177		88	252	265		60	3	
5	15		.04	1.3	491.6	176		88	254	265		60	3	
6	18		.04	1.3	493.2	176		87	257	264		66	3	
7	21		.02	1.3	495.5	174		88	254	265		66	3	
8	24		.02	1.3	497.4	162		88	254	263		67	3	
B-1	27		.04	1.3	499.3	170		89	253	266		64	3	
2	30		.03	1.3	501.2	175		89	255	265		65	3	
3	33		.03	1.3	503.1	175		90	254	266		63	3	
4	36		.03	1.3	505.1	175		89	252	265		63	3	
5	39		.04	1.3	507.1	174		89	252	266		63	3	
6	42		.04	1.3	509.0	172		90	253	265		63	3	
7	45		.03	1.3	511.0	172		89	253	266		64	3	
8	48	1652	.03	1.3	512.981	172		89	252	265		65	3	
*Barometric Pressure is at port elevation			Avg. ΔP	Avg. ΔH	Total Volume	Avg. T <sub>s</sub>	Avg. T <sub>m</sub>			Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std.</sub> scf
			.1873	1.3000	31,081	173.7	89.0			252/257	260/266	67	3	
			.03563	1.1402										


Flue Gas Composition  
 Oxygen, % \_\_\_\_\_  
 Carbon Dioxide, % \_\_\_\_\_  
 Moisture, % \_\_\_\_\_

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run \_\_\_\_\_  
 Post-run \_\_\_\_\_

Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 Result \_\_\_\_\_

QC by \_\_\_\_\_

15730.001.008  
 Pump Driver, #8 Paper Machine,  
 #2-3 SUTVs & #1-2 CBs  
 Emission Report



WESTON SOLUTIONS  
 Integrated Air Services



# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 1 Hood Exhaust  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date \_\_\_\_\_ Recovery Date \_\_\_\_\_  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Contents	<u>H<sub>2</sub>O</u>	<u>H<sub>2</sub>O</u>	<u>Empty</u>			
Final	<u>848.6</u>	<u>661.6</u>	<u>550.0</u>		<u>901.6</u>	
Initial	<u>752.4</u>	<u>635.8</u>	<u>546.2</u>	✓	<u>893.5</u>	
Gain	<u>96.2</u> ✓	<u>25.8</u> ✓	<u>3.8</u> ✓	<u>125.8</u>	<u>8.1</u>	<u>133.9</u>

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 2 Sample Date \_\_\_\_\_ Recovery Date \_\_\_\_\_  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Contents	<u>H<sub>2</sub>O</u>	<u>H<sub>2</sub>O</u>	<u>Empty</u>			
Final	<u>850.8</u>	<u>849.2</u>	<u>637.9</u>		<u>868.9</u>	
Initial	<u>745.0</u>	<u>804.1</u>	<u>628.0</u>		<u>857.8</u>	
Gain	<u>105.8</u> ✓	<u>45.1</u> ✓	<u>9.9</u> ✓		<u>11.1</u>	<u>171.9</u>

Impinger Color Clear Labeled?   
 Silica Gel Condition Good Sealed?

Run No. 3 Sample Date \_\_\_\_\_ Recovery Date \_\_\_\_\_  
 Sample ID \_\_\_\_\_ Filter ID N/A Analyst BEA/BE

	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Contents	<u>H<sub>2</sub>O</u>	<u>H<sub>2</sub>O</u>	<u>Empty</u>			
Final	<u>913.3</u>	<u>647.2</u>	<u>554.0</u>		<u>909.1</u>	
Initial	<u>784.0</u>	<u>630.1</u>	<u>550.0</u>	✓	<u>901.6</u>	
Gain	<u>129.3</u> ✓	<u>17.1</u> ✓	<u>4.0</u> ✓	<u>150.4</u>	<u>7.5</u>	<u>157.9</u>

Impinger Color \_\_\_\_\_ Labeled?   
 Silica Gel Condition \_\_\_\_\_ Sealed?

Check COC for Sample IDs of Media Blanks



SAMI Hot Box

Nozzle Box

Ratchet Strap

Cooler + Water

	Delta P	Angle <del>Temp</del>	Temp
1.	.02	7	<del>184</del> 284 184
2.	.00	0	<del>280</del> 190
3.	.00	0	280 192
4.	.00	0	192
5.	-.02	6	193
6.	-.02	6	192
7.	.04	12	190
8.	.05	14	194
9.	.02	7	194
10.	.04	12	193
11.	.05	15	193
12.	.00	0	

450.135  
 .550

# RUN DATA

Number 1

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **Paper Machine vents**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
<b>Paper Machine Vent 1 Run 1</b>				
16:35:26	6778	20.2	0	0.2
16:35:41	6781	20.2	-2	0.2
16:35:56	6780	20.2	-2	0.2
16:36:11	6781	20.2	-1	0.2
16:36:26	6782	20.2	-4	0.2
16:36:41	6782	20.2	-3	0.2
16:36:56	6782	20.2	-5	0.2
16:37:11	6785	20.2	-4	0.2
16:37:26	6782	20.2	-4	0.2
16:37:41	6783	20.2	-4	0.2
16:37:56	6783	20.2	-5	0.2
16:38:11	6782	20.2	-2	0.2
16:38:26	6783	20.2	-4	0.2
16:38:41	6783	20.2	-3	0.2
16:38:56	6781	20.2	-2	0.2
<b>Avg</b>	<b>6782</b>	<b>20.2</b>	<b>-3</b>	<b>0.2</b>

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vents**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
19:02:02	6782	20.2	-4	0.2
<b>Paper Machine Vent 1 Run 2</b>				
19:02:17	6781	20.2	-5	0.2
19:02:32	6778	20.2	-6	0.2
19:02:47	6781	20.2	-4	0.2
19:03:02	6782	20.2	-5	0.2
19:03:17	6781	20.2	-1	0.2
19:03:32	6781	20.2	-3	0.2
19:03:47	6780	20.2	-3	0.2
19:04:02	6780	20.2	-5	0.2
19:04:17	6781	20.2	-5	0.2
19:04:32	6777	20.2	-4	0.2
19:04:47	6781	20.2	-5	0.2
19:05:02	6780	20.2	-2	0.2
19:05:17	6780	20.2	-3	0.2
19:05:32	6778	20.2	-1	0.2
19:05:47	6762	20.2	12	0.2
<b>Avg</b>	<b>6779</b>	<b>20.2</b>	<b>-3</b>	<b>0.2</b>

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vents**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
19:06:16	6780	20.2	-1	0.2
<b>Paper Machine Vent 1 Run 3</b>				
19:06:31	6780	20.2	-2	0.2
19:06:46	6781	20.2	-2	0.2
19:07:01	6780	20.2	-2	0.2
19:07:16	6781	20.2	-2	0.2
19:07:31	6782	20.2	-2	0.2
19:07:46	6781	20.2	-2	0.2
19:08:01	6781	20.2	-2	0.2
19:08:16	6780	20.2	-3	0.2
19:08:31	6779	20.2	1	0.2
19:08:46	6780	20.2	1	0.2
19:09:01	6782	20.2	-0	0.2
19:09:16	6781	20.2	-0	0.2
19:09:31	6780	20.2	1	0.2
19:09:46	6781	20.2	2	0.2
19:10:01	6781	20.2	4	0.2
19:10:16	6781	20.2	1	0.2
19:10:31	6781	20.2	-1	0.2
19:10:46	6781	20.2	1	0.2
19:11:01	6779	20.2	1	0.2
19:11:16	6780	20.2	2	0.2
<b>Avg</b>	<b>6781</b>	<b>20.2</b>	<b>-0</b>	<b>0.2</b>

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vents**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 13:37

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	46
10.1 ✓	SG9168283BAL	3296
19.5 ✓	CC454190	6582

Curve Coefficients

Slope	Intercept	Corr. Coeff.
335.0	3 ✓	0.9997 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	-36
10.2 ✓	SG9168283BAL	3110
20.4 ✓	CC454190	6430

Curve Coefficients

Slope	Intercept	Corr. Coeff.
317.0	-61 ✓	0.9999 ✓

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vents**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 13:37

**O<sub>2</sub>**

Method: EPA 3A

Span Conc. 19.5 %

Slope 335.0

Intercept 2.5

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	46	0.1	0.1	0.5 ✓	Pass
10.1	3296	9.8	-0.3	-1.5 ✓	Pass
19.5	6582	19.6	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.4 %

Slope 317.0

Intercept -60.9

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-36	0.1	0.1	0.5 ✓	Pass
10.2	3110	10.0	-0.2	-1.0 ✓	Pass
20.4	6430	20.5	0.1	0.5 ✓	Pass

# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **Paper Machine vents**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

**File:** C:\Users\Trailer 271\Documents\New Indy\6-23-21.cem  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** DESKTOP-GQ0I9UV **Trailer:** 271  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>20.0</b>
Span Concentration, %	<b>19.5</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>CAI 600 SN E07015-M</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.4</b>





**APPENDIX E**  
**FIELD DATA – NO. 2 AND 3**  
**SMELT DISSOLVING TANK VENTS**

---

New Indy  
Catawba, SC

15730.001.008  
No. 2 & 3 SDTV

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
Date	6/27/21 ✓	6/27/21 ✓	6/27/21 ✓	---
Time Began	1100 ✓	1222 ✓	1344 ✓	---
Time Ended	1210 ✓	1331 ✓	1454 ✓	---
Volumetric Flow Rate, (Qs), DSCFM	2.60E+04 ✓	2.61E+04 ✓	2.54E+04 ✓	2.58E+04
BWS	0.392 ✓	0.412 ✓	0.409 ✓	0.404
% Oxygen	20.1 ✓	20.0 ✓	20.3 ✓	20.1
<hr/>				
<b>Total Reduced Sulfur</b> (TRS MW)=	34.08			
Concentration, ppm	7.36 ✓	9.23 ✓	8.20 ✓	8.26
Emission Rate, lb/hr	1.02	1.28	1.10	1.13
<hr/>				

AA for SH ✓

New Indy  
Catawba, SC

15730.001.008  
No. 2 & 3 SDTV

ISOKINETIC CALCULATIONS

Run Number		1	2	3	Mean
Date		6/27/21	6/27/21	6/27/21	---
Time Began		1100	1222	1344	---
Time Ended		1208	1332	1451	---
INPUT DATA					
Sampling Time, min	(Theta)	64.0	64	64	64
Stack Diameter, in.	(Dia.)	71	71	71	71
Barometric Pressure, in. Hg	(Pb)	29.40	29.40	29.40	29.40
Static Pressure, in. H2O	(Pg)	-0.16	-0.16	-0.16	-0.16
Pitot Tube Coefficient	(Cp)	0.84	0.84	0.84	0.84
Meter Correction Factor	(Y)	1.0000	1.0000	1.0000	1.0000
Orifice Calibration Value	(Delta H@)	2.0490	2.0490	2.0490	2.0490
Nozzle Diameter, in.	(Dn)	0.250	0.250	0.250	0.250
Meter Volume, ft^3	(Vm)	39.637	39.229	39.027	39.298
Meter Temperature, °F	(Tm)	103.3	101.8	98.8	101.3
Meter Temperature, °R	(Tm-R)	563.3	561.8	558.8	561.3
Meter Orifice Pressure, in. H2O	(Delta H)	1.300	1.300	1.300	1.300
Ave Sq Rt Orifice Press, (in. H2O)^½	((Delta H)½)avg	1.140	1.140	1.140	1.140
Volume H2O Collected, mL	(Vlc)	519.8	541.0	558.9	539.9
CO2 Concentration, %	(CO2)	0.0	0.0	0.0	0.0
O2 Concentration, %	(O2)	20.1	20.0	20.3	20.1
Ave Sq Rt Velo Head, (in. H2O)^½	((Delta P)½)avg	0.469	0.486	0.469	0.475
Stack Temperature, °F	(Ts)	167.5	170.1	169.4	169.0
Stack Temperature, °R	(Ts-R)	627.5	630.1	629.4	629.0
Moisture Fraction (at Saturation)	(BWS)	0.392	0.416	0.409	0.406
CALCULATED DATA					
Nozzle Area, ft²	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft²	(As)	27.49	27.49	27.49	27.49
Stack Pressure, in. Hg	(Ps)	29.39	29.39	29.39	29.39
Meter Pressure, in. Hg	(Pm)	29.50	29.50	29.50	29.50
Standard Meter Volume, ft³	(Vmstd)	36.615	36.331	36.342	36.429
Standard Water Volume, ft³	(Vwstd)	24.467	25.465	26.307	25.413
Moisture Fraction (Measured)	(BWS)	0.401	0.412	0.420	0.411
Moisture Fraction (lower sat/meas)	(BWS)	0.392	0.412	0.409	0.404
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	28.80	28.80	28.81	28.81
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	24.57	24.35	24.39	24.44
Average Stack Gas Velocity, ft/sec	(Vs)	31.40	32.72	31.59	31.90
Stack Gas Flow, actual, ft³/min	(Qa)	51795	53982	52110	52629
Stack Gas Flow, Std, ft³/min	(Qs)	26017	26110	25364	25830
Calibration check	(Yqa)	1.0072	1.0165	1.0187	1.014
Percent difference from Y					1.41%

AB for SHV

# Isokinetic Field Data

## Method: EPA 4, Moisture

Client New Indy  
 Location/Plant Catawba, SC  
 Source SDTV  
 Sample Location Stack outlet  
 W. O. Number 15730.001.008  
 Run Number 1  
 Date 6/27/21  
 Test Personnel ATC/CL/BE  
 Sample Time 64 min.

Console ID A025  
 Meter Corr., Y 1.000  
 Console ΔH@ 2.044  
 Probe ID/Length 118L  
 Liner Material 81  
 Pitot ID/Coeff. 0.84  
 Thermo ID A025  
 Nozzle ID/Diams. .250 in.  
 Avg. Nozzle Diam. .250 in.

Ambient Temp. 96 °F  
 Baro. Pressure 29.50 in. Hg  
 Static Pressure -1.16 in. H<sub>2</sub>O  
 Impinger Gain 509.5 mL  
 Silica Gel Gain 10.3 g  
 Stack Area 27.44 ft<sup>2</sup>  
 Total Traverse Points 16

K Factor NA

Leak Checks	
Initial	Final
Volume, ft <sup>3</sup>	.005
@ Vac., in. Hg	8
Pitot	1,000

Filter ID NK  
 Sample ID Run 1

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
A-1 B	4	11:00	.17	1.3	991.700	166		102	260	265		67	2.5	
2	8		.18	1.3	996.6	164		102	264	261		66	2.5	
3	12		.19	1.3	998.7	164		103	265	260		66	2.5	
4	16		.20	1.3	1001.7	163		104	265	262		65	3	
5	20		.24	1.3	1004.1	164		104	264	262		65	3	
6	24		.26	1.3	1006.6	166		104	263	268		63	3	
7	28		.24	1.3	1008.1	164		104	262	267		61	3	
8	32	11:32	.22	1.3	1011.5	167		103	264	265		60	3	
A-1 A	36	11:36	.21	1.3	1014.1	169		103	263	263		65	3	
2	40		.23	1.3	1017.1	164		103	265	262		58	3	
3	44		.23	1.3	1018.9	169		103	247	267		58	3	
4	48		.23	1.3	1021.3	170		103	252	265		59	4	
5	52		.24	1.3	1023.9	170		104	252	264		58	4	End volume
6	56		.24	1.3	1026.5	171		103	253	261		59	4	
7	60		.22	1.3	1028.8	170		103	254	265		63	4	
8	64	12:08	.23	1.3	1031.9	164		104	252	263		61	4	

\*Barometric Pressure is at port elevation  
 Avg V<sub>ap</sub> 4.68  
 Avg ΔH 1.3  
 Total Volume 40.6779  
 Avg T<sub>s</sub> 167.5  
 Avg T<sub>m</sub> 103.25  
 Min/Max 247/265  
 Min/Max 264/268  
 Min/Max 262/268  
 Max Temp 67  
 Max Vac 4  
 V<sub>m-std</sub> scf  
 Q<sub>s</sub> dscfm  
 Thermocouple Check  
 Meter Temp., °F  
 Ref. Temp., °F  
 % Isokinetic  
 Calculated by AN  
 QC by AN



DW SCDFEL  
6/27



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: SDTV  
 Sample Location: Stack 6  
 W. O. Number: 15730.001.008  
 Run Number: 2  
 Date: 6/27/21  
 Test Personnel: ARR/CL/BE  
 Sample Time: 64 min.

Console ID: A025  
 Meter Corr., Y: 1,000  
 Console ΔH@: 2.049  
 Probe ID/Length: PR8L 4'  
 Liner Material: 35  
 Pitot ID/Coeff: 0.84  
 Thermo ID: A025  
 Nozzle ID/Diams.: 256, 256, 250  
 Avg. Nozzle Diam.: 250 in.

Ambient Temp.: 80 °F  
 Baro. Pressure: 29.46 in. Hg  
 Static Pressure: -16 in. H<sub>2</sub>O  
 Impinger Gain: 526.5 mL  
 Silica Gel Gain: 14.5 g  
 Stack Area: 27.44 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: NA  
 Leak Checks: Initial: NA, Final: NA  
 Volume, ft<sup>3</sup>: 1,005  
 @ Vac., in. Hg: 8  
 Pitot: 1,000

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
	0	12:22			31.660									
A-1	4		.22	1.3	33.8	167	104	296	262	262	66	3		
2	8		.23	1.3	36.5	170	104	248	263	263	57	3		
3	12		.23	1.3	34.0	173	104	249	264	264	55	3		
4	16		.25	1.3	42.1	170	104	250	265	265	55	3.5		
5	20		.25	1.3	44.3	172	105	251	264	264	56	3.5		
6	24		.25	1.3	46.5	173	105	250	263	263	58	3.5		
7	28		.27	1.3	44.6	175	105	251	267	267	61	4		
8	32	12:54	.25	1.3	51.3	173	104	250	266	266	65	4		
B-1	36	13:00	.20	1.3	53.7	170	106	238	265	265	64	4		
2	40		.20	1.3	56.3	170	101	258	264	264	63	4		
3	44		.20	1.3	58.7	171	106	254	268	268	63	4		
4	48		.23	1.3	61.1	168	96	260	267	267	63	4		
5	52		.25	1.3	63.8	169	97	258	266	266	64	4.5		
6	56		.26	1.3	65.9	167	98	254	265	265	64	4.5		
7	60		.25	1.3	68.4	167	101	234	264	264	65	5		
8	64	13:32	.24	1.3	70.829	167	101	258	264	264	66	5		
*Barometric Pressure is at port elevation			Avg ΔP	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac		
			1.485	1.3	39.224	176.12	101.81	246.234	262.268	262.268	66	5		

Filter ID: NA  
 Sample ID: RWA2

Thermocouple Check  
 Meter Temp., °F: \_\_\_\_\_  
 Ref. Temp., °F: \_\_\_\_\_  
 Result: \_\_\_\_\_

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run: \_\_\_\_\_  
 Post-run: \_\_\_\_\_

Flue Gas Composition  
 Oxygen, %: \_\_\_\_\_  
 Carbon Dioxide, %: \_\_\_\_\_  
 Moisture, %: \_\_\_\_\_

Comments: 0.170

15730.001.008  
 Pulp Dryer #3 Paper Machine,  
 #2-350's, & #1-2 CBs  
 Emission Report



Integrated Air Services  
 DW SCDHEC  
 6/27



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: SDTV  
 Sample Location: STARK OUTLET  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/27/12  
 Test Personnel: ATR/LL/BE  
 Sample Time: 64 min.

Console ID: A035  
 Meter Corr., Y: 1.006  
 Console ΔH@: 2.644  
 Probe ID/Length: PR8L 81  
 Liner Material: SS  
 Pitot ID/Coeff.: P320 0.84  
 Thermo ID: A025  
 Nozzle ID/Diams.: .250 in.  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp.: 45 °F  
 Baro. Pressure\*: 29.40 in. Hg  
 Static Pressure: -16 in. H<sub>2</sub>O  
 Impinger Gain: 548.9 ml  
 Silica Gel Gain: 163 g  
 Stack Area: 27.44 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: NA  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	1007	1003
Pitot	8	0
	1003	1003

Filter ID: NA  
 Sample ID: Run 3

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TFMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
	0	13:44			71.100									
A-1	4		.19	1.3	73.8	167		98	256	257		64	4	
2	8		.19	1.3	76.2	170		94	257	254		62	4	
3	12		.20	1.3	78.9	170		97	256	261		55	4	
4	16		.22	1.3	81.6	176		97	257	260		56	4	
5	20		.23	1.3	83.2	170		98	256	266		56	4	
6	24		.23	1.3	85.7	169		98	255	261		58	4	
7	28		.24	1.3	88.5	169		97	254	260		58	4	
8	32	14:16	.23	1.3	90.6	170		98	253	261		60	4.5	
B-1	36	14:19	.23	1.3	93.3	169		94	254	262		65	4.5	
2	40		.22	1.3	95.5	169		94	255	263		61	4.5	
3	44		.22	1.3	98.9	169		101	256	262		60	4.5	
4	48		.24	1.3	100.4	176		100	257	261		64	4.5	
5	52		.23	1.3	102.9	170		101	258	262		64	5	
6	56		.22	1.3	105.1	171		100	256	263		64	5	
7	60		.22	1.3	107.8	169		99	255	264		65	5.5	
8	64	14:51	.22	1.3	110.127	169		94	256	263		65	5.5	
			Avg V <sub>ap</sub>	Avg ΔH	Total Volume	Avg T <sub>stack</sub>	Avg T <sub>dgm</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	
			.4644	1.3	39.027	169.484	99.25	253/258	257/264	257/264	257/264	65	5.5	
			.2206	1.190										

\*Barometric Pressure is at port elevation

Flue Gas Composition: Oxygen, %  
 Carbon Dioxide, %  
 Moisture, %

Thermocouple Check: Meter Temp., °F  
 Ref. Temp., °F

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run  
 Post-run

V<sub>m-std</sub> scf  
 Q<sub>s</sub> dscfm  
 % Isokinetic  
 Calculated by  
 QC by

15730.001.008  
 Pulp Dryer Paper Machine,  
 #2-3  
 Emission Report

WESTON SOLUTIONS  
 Integrated Air Services

Comments

312



# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source SDTV  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/27/21 Recovery Date 6/27/21  
 Sample ID Run 1 Filter ID NA Analyst ATR

	Impingers				Imp.Total	Silica Gel grams	Total
	1	2	3	4			
Contents	<u>DI</u>	<u>DI</u>	<u>empty</u>	<u>empty</u>			
Final	<u>918.4</u>	<u>1622.6</u>	<u>707.8</u>	<u>608.2</u>		<u>933.3</u>	
Initial	<u>711.1</u>	<u>783.9</u>	<u>646.4</u>	<u>665.6</u>	✓	<u>923.0</u>	
Gain	<u>207.3</u> ✓	<u>238.7</u> ✓	<u>60.4</u> ✓	<u>2.6</u> ✓	<u>509.5</u>	<u>10.3</u>	<u>519.8</u>

Impinger Color clear Labeled? ✓  
 Silica Gel Condition used Sealed? ✓

Run No. 2 Sample Date 6/27/21 Recovery Date 6/27/21  
 Sample ID Run 2 Filter ID NA Analyst ATR

	Impingers				Imp.Total	Silica Gel grams	Total
	1	2	3	4			
Contents	<u>DI</u>	<u>DI</u>	<u>empty</u>	<u>empty</u>			
Final	<u>981.4</u>	<u>1014.7</u>	<u>730.6</u>	<u>668.6</u>		<u>855.7</u>	
Initial	<u>774.0</u>	<u>779.7</u>	<u>649.9</u>	<u>665.2</u>	✓	<u>841.2</u>	
Gain	<u>207.4</u> ✓	<u>235</u> ✓	<u>80.7</u> ✓	<u>3.4</u> ✓	<u>526.5</u>	<u>14.5</u>	<u>541</u> ✓

Impinger Color clear Labeled? ✓  
 Silica Gel Condition used Sealed? ✓

Run No. 3 Sample Date 6/27/21 Recovery Date 6/27/21  
 Sample ID Run 3 Filter ID NA Analyst ATR

	Impingers				Imp.Total	Silica Gel grams	Total
	1	2	3	4			
Contents	<u>DI</u>	<u>DI</u>	<u>empty</u>	<u>empty</u>			
Final	<u>923.0</u>	<u>973.1</u>	<u>714.3</u>	<u>595.9</u>	<u>AB 613W</u>	<u>909.6</u>	
Initial	<u>663.4</u>	<u>758.0</u>	<u>643.0</u>	<u>593.3</u>	<u>548.6</u>	<u>899.3</u>	
Gain	<u>259.6</u> ✓	<u>215.1</u> ✓	<u>71.3</u> ✓	<u>2.6</u> ✓	<u>548.6</u>	<u>10.3</u>	<u>558.9</u>

Impinger Color clear Labeled? ✓  
 Silica Gel Condition used Sealed? ✓

Check COC for Sample IDs of Media Blanks





# Sample and Velocity Traverse Points - Method 1

Client New-Indy Source SDTV 2 & 3  
 Location/Plant Catawba, SC W.O. Number 15730.001.001  
 Operator JWS/JW Date 3/27/2019

Duct Type  Circular  Rectangular  
 Traverse Type  Particulate Traverse  Velocity Traverse  Stratification Traverse

Depth, far wall to outside of port (in) = C	77.75
Port Depth (in) = D	6.75
Depth of Duct, diameter (in) = C - D	71
Area of Duct (ft <sup>2</sup> )	27.49
Number of Ports	2
Traverse Points per Port	8
Total Traverse Points	16



**Rectangular Ducts Only**

Width of Duct (in)	
Equivalent Diameter (in)	

Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	3.2	2.3	9.0
2	10.5	7.4	14.2
3	19.4	13.8	20.5
4	32.3	22.9	29.7
5	67.7	48.1	54.8
6	80.6	57.2	64.0
7	89.5	63.6	70.3
8	96.8	68.7	75.5

**Flow Disturbances**

Upstream - A (ft)	10
Downstream - B (ft)	38
Upstream - A (duct diameters)	1.7
Downstream - B (duct diameters)	6.4



**Traverse Point Location % of Stack - Circular**

Traverse Point	Number of Traverse Points											
	1	2	3	4	5	6	7	8	9	10	11	12
1		14.6		6.7		4.4		3.2		2.8		2.1
2		85.4		25.0		14.6		10.5		8.2		6.7
3			75.0		29.6		19.4		14.6		11.8	
4			93.3		70.4		32.3		22.6		17.7	
5				85.4		67.7		34.2		25.0		
6				95.6		80.6		65.8		35.8		
7					89.5		77.4		64.4			
8						96.8		85.4		75.0		
9							91.8		82.3			
10								97.4		88.2		
11									93.3			
12										97.9		

**Traverse Point Location % of Stack - Rectangular**

Traverse Point	Number of Traverse Points											
	1	2	3	4	5	6	7	8	9	10	11	12
1		25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
2		75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
3			83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
4				87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
5					90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
6						91.7	78.8	68.8	61.1	55.0	50.0	45.8
7							92.9	81.3	72.2	65.0	59.1	54.2
8								93.8	83.3	75.0	68.2	62.5
9									94.4	85.0	77.3	70.8
10										95.0	88.4	79.2
11											95.5	87.5
12												95.8

**Rectangular Stack Points & Matrix**

- 9 - 3 x 3
- 12 - 4 x 3
- 16 - 4 x 4
- 20 - 5 x 4
- 25 - 5 x 5
- 30 - 6 x 5
- 36 - 6 x 6
- 42 - 7 x 6
- 49 - 7 x 7

Tape measure ID \_\_\_\_\_

# RUN SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

---

**Start Time 11:00    End Time 12:10**

---

**Average Measured TRS Conc.**    6.76 ppm ✓  
**Recovery No. 2**    91.9 % ✓  
**TRS Corrected for Recovery**    7.36 ppm ✓

✓

# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

---

Start Time 12:22    End Time 13:31

---

Average Measured TRS Conc.	8.48 ppm	✓
Recovery No. 2	91.9 %	✓
TRS Corrected for Recovery	9.23 ppm	✓

✓

# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

---

**Start Time 13:44    End Time 14:54**

---

**Average Measured TRS Conc.**    7.54 ppm ✓  
**Recovery No. 2**    91.9 %  
**TRS Corrected for Recovery**    8.20 ppm ✓

✓

# RUN DATA

Number 1

Client: **New Indy**  
 Location: **Catawba, NC**  
 Source: **2 & 3 SDTV**

Method **16**  
 Calibration **1**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **27 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
11:00	9746	6.75	79	0.83	<2	<0.078	3	0.04	7.67
11:03	10033	6.85	101	0.95	<2	<0.078	5	0.06	7.92
11:06	9112	6.51	107	0.97	<2	<0.078	3	0.05	7.58
11:09	7501	5.87	115	1.01	<2	<0.078	5	0.06	6.99
11:12	5842	5.14	115	1.01	<2	<0.078	5	0.06	6.27
11:15	5372	4.91	117	1.02	3	0.09	5	0.06	6.14
11:18	4418	4.43	105	0.96	2	0.08	5	0.06	5.59
11:21	4580	4.51	110	0.99	<2	<0.078	3	0.04	5.59
11:24	4551	4.50	111	0.99	<2	<0.078	5	0.06	5.61
11:27	4210	4.31	99	0.94	3	0.09	3	0.05	5.43
<b>Paused for Port Change</b>									
11:40	4222	4.32	107	0.97	<2	<0.078	4	0.05	5.40
11:43	5768	5.10	113	1.01	<2	<0.078	4	0.05	6.22
11:46	5698	5.07	122	1.04	7	0.16	6	0.07	6.40
11:49	6812	5.57	138	1.12	<2	<0.078	5	0.06	6.81
11:52	7585	5.90	155	1.19	<2	<0.078	6	0.06	7.21
11:55	8396	6.23	162	1.21	<2	<0.078	5	0.06	7.56
11:58	8694	6.35	166	1.23	<2	<0.078	6	0.06	7.70
12:01	9023	6.47	173	1.25	<2	<0.078	6	0.06	7.86
12:04	9097	6.50	169	1.24	<2	<0.078	7	0.07	7.89
12:07	7770	5.98	165	1.23	<2	<0.078	6	0.06	7.33
<b>Average</b>		<b>5.56</b>	<b>1.06</b>		<b>&lt;0.078</b>		<b>0.06</b>		<b>6.76</b> ✓

*rv*

# RUN DATA

Number 2

15730.001.008  
Pulp Dryer, #3 Paper Machine,  
#2-3 SDTVs, & #1-2 CBs  
Emission Report

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
12:22	5222	4.84	150	1.17	2	0.09	5	0.06	6.21
12:25	7380	5.82	164	1.22	3	0.09	5	0.06	7.24
12:28	8350	6.21	193	1.33	3	0.10	3	0.05	7.73
12:31	11724	7.44	192	1.32	4	0.11	5	0.06	8.99
12:34	13839	8.13	213	1.40	5	0.12	7	0.07	9.79
12:37	13568	8.04	206	1.37	3	0.10	7	0.07	9.66
12:40	10733	7.10	199	1.35	4	0.11	6	0.07	8.69
12:43	10057	6.86	192	1.32	3	0.10	4	0.05	8.39
12:46	13409	7.99	207	1.38	4	0.12	7	0.07	9.63
12:49	13864	8.14	220	1.42	4	0.12	7	0.07	9.82
<b>Paused for Port Change</b>									
13:01	18795	9.57	181	1.28	3	0.10	7	0.07	11.1
13:04	16648	8.97	173	1.25	4	0.12	6	0.06	10.5
13:07	14072	8.20	190	1.32	3	0.10	6	0.06	9.75
13:10	10289	6.94	155	1.18	4	0.11	4	0.05	8.34
13:13	9917	6.81	167	1.23	3	0.10	7	0.07	8.28
13:16	9314	6.58	170	1.24	<2	<0.078	4	0.05	7.93
13:19	7425	5.84	158	1.20	4	0.12	5	0.06	7.27
13:22	6575	5.47	152	1.17	4	0.11	2	0.04	6.83
13:25	6676	5.51	153	1.17	3	0.10	5	0.06	6.91
13:28	6242	5.32	149	1.16	<2	<0.078	5	0.06	6.60
<b>Average</b>		<b>6.99</b>		<b>1.28</b>		<b>0.10</b>		<b>0.06</b>	<b>8.48</b>



# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
13:44	6773	5.56	145	1.14	3	0.09	5	0.06	6.91
13:47	7079	5.69	149	1.16	<2	<0.078	5	0.06	6.97
13:50	8284	6.19	161	1.21	<2	<0.078	5	0.06	7.52
13:53	9347	6.60	157	1.19	3	0.10	5	0.06	8.00
13:56	11430	7.34	154	1.18	<2	<0.078	4	0.05	8.62
13:59	11137	7.24	81	0.84	3	0.09	6	0.06	8.30
14:02	9753	6.75	84	0.86	3	0.09	5	0.06	7.82
14:05	12285	7.63	74	0.80	2	0.08	6	0.06	8.64
14:08	10527	7.03	77	0.82	3	0.10	4	0.06	8.06
14:11	10419	6.99	72	0.80	<2	<0.078	4	0.05	7.89
<b>Paused for Port Change</b>									
14:24	4752	4.60	52	0.67	<2	<0.078	2	0.04	5.35
14:27	6627	5.49	51	0.66	<2	<0.078	5	0.06	6.27
14:30	7671	5.94	56	0.69	3	0.10	4	0.05	6.84
14:33	7875	6.02	111	0.99	<2	<0.078	5	0.06	7.13
14:36	9158	6.53	60	0.72	3	0.10	4	0.05	7.45
14:39	9894	6.80	134	1.10	<2	<0.078	5	0.06	8.01
14:42	9132	6.52	118	1.03	2	0.09	5	0.06	7.75
14:45	8684	6.34	114	1.01	5	0.13	4	0.06	7.60
14:48	8526	6.28	124	1.05	2	0.08	6	0.06	7.54
14:51	10818	7.13	68	0.77	<2	<0.078	7	0.07	8.05
<b>Average</b>		<b>6.43</b>	<b>0.94</b>		<b>&lt;0.078</b>		<b>0.06</b>		<b>7.54</b> ✓

AV

# RUN DATA

Number 0

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS	
	area	ppm	area	ppm	area	ppm	area	ppm	ppm	
			<b>CC416806 7.257 ppm</b> ✓							
16:31	12652	7.69	<2	<0.12	<2	<0.078	<2	<0.036	7.69	
16:34	13142	7.85	<2	<0.12	<2	<0.078	<2	<0.036	7.85	
16:37	13429	7.94	<2	<0.12	<2	<0.078	<2	<0.036	7.94	
<b>Average</b>		<b>7.83</b>		<b>&lt;0.12</b>		<b>&lt;0.078</b>		<b>&lt;0.036</b>	<b>7.83</b> ✓	

✓

# RECOVERY DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

---

## Before Run 1

Start Time 09:25    End Time 09:39

---

### Recovery Gas to Probe, Time 09:25

Peak Areas, mv-sec			Average	ppm
11108	11283	11482	11291 ✓	7.30

---

### Recovery Gas to GC, Time 09:37

Peak Areas, mv-sec			Average	ppm
13285	13216	13267	13256 ✓	7.95

---

Recovery 91.8% ✓

---

*M*

# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

---

**After Run 3    Before Run 4**  
**Start Time 14:56    End Time 15:17**

---

**Recovery Gas to Probe, Time 14:56**

<b>Peak Areas, mv-sec</b>			<b>Average</b>	<b>ppm</b>
11388	11667	11619	11558 ✓	7.39

---

**Recovery Gas to GC, Time 15:13**

<b>Peak Areas, mv-sec</b>			<b>Average</b>	<b>ppm</b>
13585	13587	13493	13555 ✓	8.04

---

**Recovery 91.9% ✓**

---

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Project Number: **15730.001.008**

Operator: **VD**

Date: **26 Jun 2021**

Method **16**

Ambient Temperature: 72°C

Barometric Pressure: 29.70 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51828	33-53274	89-53332	89-53266
Perm. Rate, nL/min	346	363	470	238
Ret. Time, sec	16.0	22.5	48.0	127.0

**1** Flow = 37.1 mL/Min      **9.32 ppm**      **9.79 ppm**      **12.7 ppm**      **6.41 ppm**

**Time: 07:00**

**Peak Areas, mv-sec**

17531	8727	27825	33485	
17951	8703	27443	33712	
18066	8758	27669	33342	
<b>Average Area</b>	<b>17849</b> ✓	<b>8730</b> ✓	<b>27646</b> ✓	<b>33513</b> ✓

**2** Flow = 78.5 mL/Min      **4.41 ppm**      **4.63 ppm**      **5.99 ppm**      **3.03 ppm**

**Time: 08:24**

**Peak Areas, mv-sec**

4366	2153	6888	8191	
4464	2149	6729	8050	
4361	2131	6827	8110	
<b>Average Area</b>	<b>4397</b> ✓	<b>2145</b> ✓	<b>6815</b> ✓	<b>8117</b> ✓

**3** Flow = 172 mL/Min      **2.01 ppm**      **2.11 ppm**      **2.73 ppm**      **1.38 ppm**

**Time: 08:47**

**Peak Areas, mv-sec**

1026	464	1561	1864	
980	466	1558	1873	
996	463	1569	1872	
<b>Average Area</b>	<b>1001</b> ✓	<b>464</b> ✓	<b>1563</b> ✓	<b>1870</b> ✓

*M*

# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Method **16**

H <sub>2</sub> S	1	2	3		
Time	07:00	08:24	08:47		
Concentration, ppm	9.32	4.41	2.01		
Area, mv-sec	17849	4397	1001		
Calc. Conc., ppm	9.31	4.42	2.01		
% Error	-0.1	0.2	-0.1		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8784	2.4316	>0.9999	2	0.073

MeSH	1	2	3		
Time	07:00	08:24	08:47		
Concentration, ppm	9.79	4.63	2.11		
Area, mv-sec	8730	2145	464		
Calc. Conc., ppm	9.74	4.68	2.10		
% Error	-0.5	1.0	-0.5		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9131	2.0496	0.9999	2	0.12

DMS	1	2	3		
Time	07:00	08:24	08:47		
Concentration, ppm	12.7	5.99	2.73		
Area, mv-sec	27646	6815	1563		
Calc. Conc., ppm	12.7	6.00	2.73		
% Error	-0.1	0.1	-0.1		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8729	2.3765	>0.9999	2	0.078

DMDS	1	2	3		
Time	07:00	08:24	08:47		
Concentration, ppm	6.41	3.03	1.38		
Area, mv-sec	33513	8117	1870		
Calc. Conc., ppm	6.42	3.02	1.38		
% Error	0.1	-0.3	0.1		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8815	3.0064	>0.9999	2	0.036

2



# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

Method **16**

Ambient Temperature: 72°C

Barometric Pressure: 29.45 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51828	33-53274	89-53332	89-53266
Perm. Rate, nL/min	349	366	474	240
Ret. Time, sec	16.0	22.5	48.0	127.0

1 Flow = 35.7 mL/Min      9.77 ppm      10.3 ppm      13.3 ppm      6.71 ppm

Time: 15:25

Peak Areas, mv-sec

	19473	9508	30148	36336
	19160	9600	30169	36878
	19488	9629	30467	36382
<u>Average Area</u>	<b>19374</b> ✓	<b>9579</b> ✓	<b>30261</b> ✓	<b>36532</b> ✓

2 Flow = 76.0 mL/Min      4.59 ppm      4.82 ppm      6.24 ppm      3.15 ppm

Time: 15:41

Peak Areas, mv-sec

	4986	2412	7781	9320
	5080	2405	7724	9106
	5033	2355	7680	9257
<u>Average Area</u>	<b>5033</b> ✓	<b>2391</b> ✓	<b>7728</b> ✓	<b>9228</b> ✓

3 Flow = 170 mL/Min      2.06 ppm      2.16 ppm      2.80 ppm      1.41 ppm

Time: 16:10

Peak Areas, mv-sec

	1092	517	1666	1995
	1079	522	1692	1998
	1108	504	1661	1964
<u>Average Area</u>	<b>1093</b> ✓	<b>514</b> ✓	<b>1673</b> ✓	<b>1986</b> ✓

*M*

# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

Method **16**

## H<sub>2</sub>S

**1**

**2**

**3**

<b>Time</b>	15:25	15:41	16:10		
<b>Concentration, ppm</b>	9.77	4.59	2.06		
<b>Area, mv-sec</b>	19374	5033	1093		
<b>Calc. Conc., ppm</b>	9.68	4.67	2.04		
<b>% Error</b>	-0.9	1.7	-0.8		
<b>Calibration Curve</b>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8461	2.4668	0.9998	2	0.067

## MeSH

**1**

**2**

**3**

<b>Time</b>	15:25	15:41	16:10		
<b>Concentration, ppm</b>	10.3	4.82	2.16		
<b>Area, mv-sec</b>	9579	2391	514		
<b>Calc. Conc., ppm</b>	10.2	4.87	2.15		
<b>% Error</b>	-0.6	1.1	-0.5		
<b>Calibration Curve</b>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8776	2.0870	0.9999	2	0.11

## DMS

**1**

**2**

**3**

<b>Time</b>	15:25	15:41	16:10		
<b>Concentration, ppm</b>	13.3	6.24	2.80		
<b>Area, mv-sec</b>	30261	7728	1673		
<b>Calc. Conc., ppm</b>	13.2	6.33	2.78		
<b>% Error</b>	-0.7	1.4	-0.7		
<b>Calibration Curve</b>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8592	2.3984	0.9999	2	0.074

## DMDS

**1**

**2**

**3**

<b>Time</b>	15:25	15:41	16:10		
<b>Concentration, ppm</b>	6.71	3.15	1.41		
<b>Area, mv-sec</b>	36532	9228	1986		
<b>Calc. Conc., ppm</b>	6.67	3.20	1.41		
<b>% Error</b>	-0.7	1.3	-0.6		
<b>Calibration Curve</b>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8700	3.0217	0.9999	2	0.035

*Handwritten mark*

# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

Method **16**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
<b>Molecular Weight</b>	34.08	48.11	62.14	94.20
<b>Retention Time, sec</b>	16.0	22.5	48.0	127.0
<b>Peak Detection Window, sec</b>	3.0	7.0	10.0	10.0
<b>Minimum Peak Area, mv-sec</b>	2	2	2	2
<b>Minimum Peak Height, mv</b>	1	1	1	1
<b>Beginning Peak Width, sec</b>	1.0	1.0	2.0	3.0
<b>Ending Peak Width, sec</b>	2.0	6.0	4.0	5.0
<b>Permeation Device ID</b>	T-51828	33-53274	89-53332	89-53266
<b>Permeation Rate, ng/min</b>	483 ✓	716 ✓	1197	918 ✓
<b>Permeation Rate, nL/min*</b>	349	366	474	240

**Barometric Pressure:** 29.45 in. Hg    **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- PR<sub>ng</sub>** = Permeation Rate by weight, ng/min
- V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole
- W<sub>mol</sub>** = Molecular Weight of compound
- T<sub>a</sub>** = Ambient Temperature, °F
- T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)
- P<sub>s</sub>** = Standard Pressure = 29.92 in Hg
- P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 483 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.45) = 349 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

- C** = Concentration, ppmv
- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- F<sub>d</sub>** = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

15730.001.008  
Pulp Dryer, #3 Paper Machine,  
#2-3 SDTVs, & #1-2 CBs  
Emission Report

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **2 & 3 SDTV**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **26 Jun 2021**

File: C:\Data\210627 New Indy Catawba SDTV.trs  
Program Version: 2.0, built 15 May 2017 File Version: 2.0  
Computer: WLT5 Trailer: 281

Analog Input Device: MCC USB-1608G GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: Shimadzu GC8-A Serial No. C10493615061  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min	Column: 140	Primary: Carbopack
H <sub>2</sub>	30	50	Detector: 140	Secondary: N/A
Air	30	60		Sample Loop: 4"
Carrier	50	30		

## Injection Cycle

Total Length: 180 sec Sampling Time: 170 sec Load/Backflush Time: 80 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 2 mv-sec Minimum peak height 1 mv above baseline

## Dynacalibrator

Chamber Temperature 50.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.45 in. Hg

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **2 &3 SDTV**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

Calibration **1**

---

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
12:12:06	6857	20.1	-5	0.0
12:12:16	6859	20.1	-5	0.0
12:12:26	6858	20.1	-7	0.0
12:12:36	6858	20.1	-8	0.0
12:12:46	6858	20.1	-8	0.0
12:12:56	6859	20.1	-8	0.0
12:13:06	6859	20.1	-6	0.0
12:13:16	6858	20.1	-5	0.0
12:13:26	6859	20.1	-5	0.0
12:13:36	6859	20.1	-5	0.0
12:13:46	6858	20.1	-6	0.0
12:13:56	6856	20.1	-7	0.0
<b>Avg</b>	<b>6858</b>	<b>20.1</b>	<b>-6</b>	<b>0.0</b>

---

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **2 &3 SDTV**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

Calibration 1

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
13:35:44	6803	20.0	-5	0.0
13:35:54	6804	20.0	-5	0.0
13:36:04	6804	20.0	-6	0.0
13:36:14	6802	20.0	-8	0.0
13:36:24	6803	20.0	-8	0.0
13:36:34	6804	20.0	-8	0.0
13:36:44	6803	20.0	-6	0.0
13:36:54	6805	20.0	-5	0.0
13:37:04	6802	20.0	-5	0.0
13:37:14	6803	20.0	-5	0.0
13:37:24	6807	20.0	-5	0.0
13:37:34	6946	20.4	-8	0.0
<b>Avg</b>	<b>6816</b>	<b>20.0</b>	<b>-6</b>	<b>0.0</b>



# RUN DATA

Number 3

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **2 &3 SDTV**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **27 Jun 2021**

Calibration 1

Time	O <sub>2</sub>		CO <sub>2</sub>	
	mv	%	mv	%
14:57:38	6920	20.3	-8	0.0
14:57:48	6922	20.3	-6	0.0
14:57:58	6921	20.3	-5	0.0
14:58:08	6920	20.3	-6	0.0
14:58:18	6920	20.3	-5	0.0
14:58:28	6919	20.3	-7	0.0
14:58:38	6918	20.3	-8	0.0
14:58:48	6920	20.3	-8	0.0
14:58:58	6920	20.3	-8	0.0
14:59:08	6918	20.3	-6	0.0
14:59:18	6918	20.3	-5	0.0
14:59:28	6920	20.3	-5	0.0
<b>Avgs</b>	<b>6920</b>	<b>20.3</b>	<b>-6</b>	<b>0.0</b>

# CALIBRATION DATA

Number 1

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **2 & 3 SDTV**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **27 Jun 2021**

Start Time: 10:20

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	-2
10.1 ✓	XC013544B	3438
20.2 ✓	CC275468	6897

Curve Coefficients

Slope	Intercept	Corr. Coeff.
340.9	-7 ✓	>0.9999 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero ✓	-	-8
10.2 ✓	XC013544B	4174
20.3 ✓	CC275468	8060

Curve Coefficients

Slope	Intercept	Corr. Coeff.
398.0	38 ✓	0.9998 ✓

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **2 & 3 SDTV**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

Calibration 1

Start Time: 10:20

**O<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.2 %

Slope 340.9

Intercept -7.4

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-2	0.0	0.0	0.0 ✓	Pass
10.1	3438	10.1	0.0	0.0 ✓	Pass
20.2	6897	20.3	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.3 %

Slope 398.0

Intercept 37.9

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-8	-0.1	-0.1	-0.5 ✓	Pass
10.2	4174	10.4	0.2	1.0 ✓	Pass
20.3	8060	20.2	-0.1	-0.5 ✓	Pass

*W*

# CALIBRATION ERROR DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **2 & 3 SDTV**

Project Number: **15730.001.008**

Operator: **VD**

Date: **27 Jun 2021**

Calibration 1

Start Time: 15:13

**O<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.2 %

Slope 340.9

Intercept -7.4

Standard %	Response mv	Result %	Difference %	Error %	Status
Zero	-2	0.0	0.0	0.0 ✓	Pass
10.1	3438	10.1	0.0	0.0 ✓	Pass
20.2	6897	20.3	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.3 %

Slope 398.0

Intercept 37.9

Standard %	Response mv	Result %	Difference %	Error %	Status
Zero	-8	-0.1	-0.1	-0.5 ✓	Pass
10.2	4174	10.4	0.2	1.0 ✓	Pass
20.3	8060	20.2	-0.1	-0.5 ✓	Pass

✓

# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **2 &3 SDTV**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **27 Jun 2021**

---

**File:** C:\Data\210627 New Indy Catawba SDTV.com  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** WSAUBCHEMLABGC1 **Trailer:** 281  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T802 s/n: 172</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.2</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T802 s/n: 172</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.3</b>



**APPENDIX F**  
**FIELD DATA – NO. 1 AND 2**  
**COMBINATION BOILERS**

---



**No. 1 COMBINATION BOILER  
(CONDITION 1: NCG AND SOG GASES)**



New Indy  
Catawba, SC

15730.001.008  
No. 1 Combination Boiler  
Condition 1: NCGs & SOGs

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
<b>Date</b>	6/23/21 ✓	6/23/21 ✓	6/23/21 ✓	---
<b>Time Began</b>	1158 ✓	1400 ✓	1541 ✓	---
<b>Time Ended</b>	1258 ✓	1500 ✓	1641 ✓	---
<b>Volumetric Flow Rate, (Qs), DSCFM</b>	1.35E+05 ✓	1.31E+05 ✓	1.33E+05 ✓	1.33E+05
<b>BWS</b>	0.174 ✓	0.177 ✓	0.160 ✓	0.170
<b>% Oxygen</b>	12.1 ✓	11.4 ✓	12.0 ✓	11.8
<hr/>				
<b>Sulfur Dioxide</b>	MW= 64.06			
Concentration, ppm	195.0 ✓	278.0 ✓	344.0 ✓	272.3
Emission Rate, lb/hr	262.7	362.5	457.4	360.9
<hr/>				
<b>Total Reduced Sulfur</b>	(TRS MW)= 34.08			
Concentration, ppm	0.78 ✓	0.71 ✓	0.70 ✓	0.73
Emission Rate, lb/hr	0.56	0.49	0.50	0.52
<hr/>				

New Indy  
Catawba, SC

15730.001.008  
No. 1 Combination Boiler

**Condition 1: NCGs & SOGs**

**ISOKINETIC CALCULATIONS**

Run Number	1	2	3	Mean
Date	6/23/21 ✓	6/23/21 ✓	6/23/21 ✓	---
Time Began	1158 ✓	1400 ✓	1541 ✓	---
Time Ended	1326 ✓	1525 ✓	1710 ✓	---

**INPUT DATA**

Sampling Time, min	(Theta)	64.0 ✓	64 ✓	64 ✓	64
Stack Diameter, in.	(Dia.)	120.00 ✓	120.00 ✓	120.00 ✓	120.00
Barometric Pressure, in. Hg	(Pb)	29.45 ✓	29.45 ✓	29.45 ✓	29.45
Static Pressure, in. H2O	(Pg)	-0.64 ✓	-0.66 ✓	-0.65 ✓	-0.65
Pitot Tube Coefficient	(Cp)	0.84 ✓	0.84 ✓	0.84 ✓	0.84
Meter Correction Factor	(Y)	0.9880 ✓	0.9880 ✓	0.9880 ✓	0.9880
Orifice Calibration Value	(Delta H@)	1.7320 ✓	1.7320 ✓	1.7320 ✓	1.7320
Nozzle Diameter, in.	(Dn)	0.250 ✓	0.250 ✓	0.250 ✓	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	41.974 ✓	42.371 ✓	42.570 ✓	42.305
Meter Temperature, °F	(Tm)	88.0 ✓	92.5 ✓	97.3 ✓	92.6
Meter Temperature, °R	(Tm-R)	548.0	552.5	557.3	552.6
Meter Orifice Pressure, in. H2O	(Delta H)	1.300 ✓	1.300 ✓	1.300 ✓	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> )avg	1.140 ✓	1.140 ✓	1.140 ✓	1.140
Volume H2O Collected, mL	(Vlc)	176.5 ✓	179.9 ✓	159.3 ✓	171.9
CO2 Concentration, %	(CO2)	7.8 ✓	8.4 ✓	7.7 ✓	8.0
O2 Concentration, %	(O2)	12.1 ✓	11.4 ✓	12.0 ✓	11.8
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> )avg	0.786 ✓	0.765 ✓	0.765 ✓	0.772
Stack Temperature, °F	(Ts)	414.6 ✓	418.3 ✓	415.3 ✓	416.1
Stack Temperature, °R	(Ts-R)	874.6	878.3	875.3	876.1

**CALCULATED DATA**

Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	78.54 ✓	78.54 ✓	78.54 ✓	78.54
Stack Pressure, in. Hg	(Ps)	29.40	29.40	29.40	29.40
Meter Pressure, in. Hg	(Pm)	29.55	29.55	29.55	29.55
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	39.441	39.490	39.333	39.421
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	8.308	8.468	7.498	8.091
Moisture Fraction (Measured)	(BWS)	0.174	0.177	0.160	0.170
Moisture Fraction (lower sat/meas)	(BWS)	0.174	0.177	0.160	0.170
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	29.73	29.80	29.71	29.75
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	27.69	27.72	27.84	27.75
Average Stack Gas Velocity, ft/sec	(Vs)	58.52	57.06	56.84	57.47
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	275752	268902	267850	270835
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	135073	130750	133309	133044

Calibration check	(Yqa)	1.0034	0.9969	0.9980	0.999
Percent difference from Y					1.16%



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 1 Combination Boiler  
 Sample Location Stack outlet  
 W. O. Number 15730.001.008  
 Run Number 1  
 Date 6/23/21  
 Test Personnel AR/LL  
 Sample Time 64 min.

Console ID A010  
 Meter Corr., Y 1.98  
 Console ΔH@ 1.732  
 Probe ID/Length PR5B/5'  
 Liner Material SS  
 Pitot ID/Coeff. P172 0.84  
 Thermo ID A010  
 Nozzle ID/Diams. .250 in.  
 Avg. Nozzle Diam. .250 in.

Ambient Temp. 80 °F  
 Baro. Pressure\* 29.45 in. Hg  
 Static Pressure -64 in. H<sub>2</sub>O  
 Impinger Gain 160.5 mL  
 Silica Gel Gain 16 g

Stack Area 78.54 ft<sup>2</sup>  
 Total Traverse Points 16

K Factor NA  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	.012	.005
Pitot	1.0	.6
	.000	.000

Filter ID NA  
 Sample ID Run 4 NCG + SOG

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp* (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS		
															0	4
A-1 D	0	11:58		1.3	834.900	418		234	234	244		67	1			
2	4		.75	1.3	841.9	417	88	88	235	245		65	1			
3	8		.70	1.3	845.3	416	88	88	236	249		64	1.5			
4	12		.67	1.3	848.1	416	89	89	237	248		64	1.5			
4-1 A	16	12:14	.54	1.3	851.7	415	88	88	237	250		65	1.5			
2	20	12:22	.65	1.3	853.3	416	88	88	238	250		65	1.5			
3	24		.54	1.3	855.7	415	88	88	239	250		64	1.5			
4	28		.59	1.3	858.2	415	88	88	240	251		63	1.5			
4	32	12:36	.36	1.3	860.8	412	87	87	241	252		64	1.5			
4-1 B	36	12:44	.61	1.3	863.4	413	88	88	241	251		59	1.5			
2	40	12:44	.63	1.3	866.1	412	88	88	242	250		58	1.5			
3	44	12:44	.66	1.3	868.8	412	88	88	241	251		58	1.5			
4	48	13:00	.47	1.3	871.4	413	89	89	240	252		63	1.5			
4-1 C	52	13:10	.77	1.3	874.2	415	89	89	242	253		61	1.5			
2	56		.75	1.3	876.6	416	86	86	241	252		59	1.5			
3	60	13:26	.71	1.3	879.2	416	87	87	240	252		58	1.5			
4	64	13:36	.57	1.3	881.874	416	87	87	240	252		58	1.5			

\*Barometric Pressure is at port elevation  
 Avg V<sub>sp</sub> 1.786  
 Avg ΔH 1.3  
 Total Volume 411,974  
 Avg T<sub>m</sub> 84  
 Min/Max 234/242  
 Min/Max 244/253  
 O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite MSA  
 Leak Check, Pre-run  
 Post-run  
 Thermocouple Check  
 Meter Temp., °F  
 Ref. Temp., °F  
 Result  
 % Isokinetic  
 Calculated by  
 QC by  
 V<sub>m-std.</sub> scf



Integrated Air Services



# Isokinetic Field Data

## Method: EPA 4, Moisture

Page 1 of 1

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 1 Combination Boiler  
 Sample Location Stack outlet  
 W. O. Number 15730.001.008  
 Run Number 2  
 Date 6/23/21  
 Test Personnel ATL/LL  
 Sample Time 64 min.

Console ID A010  
 Meter Corr., Y .488  
 Console ΔH@ 1.732  
 Probe ID/Length PR33B 1.51  
 Liner Material SS  
 Pitot ID/Coeff. 0.172 0.84  
 Thermo ID A010  
 Nozzle ID/Diams. .250 .250  
 Avg. Nozzle Diam. .250 in.

Ambient Temp. 85 °F  
 Baro. Pressure\* 29.45 in. Hg  
 Static Pressure -.66 in. H<sub>2</sub>O  
 Impinger Gain 108.6 mL  
 Silica Gel Gain 10.6 g  
 Stack Area 78.54 ft<sup>2</sup>  
 Total Traverse Points 16

K Factor NA

### Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	.004	0.003
Pitot	8	5
	.000	.000

Filter ID NA  
 Sample ID Ken 2 NCG 1506

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
A-1 B	0	14:06	.60	1.3	882.000	420		92	234	245		65	1.5	
2	4		.61	1.3	884.1	420		91	235	246		64	1.5	
3	8		.64	1.3	884.4	417		91	236	244		62	1.5	
4	12		.64	1.3	842.6	417		93	236	243		60	1.5	
B-1 A	16	14:16	.66	1.3	845.2	417		92	237	241		62	1.5	
2	20		.53	1.3	897.6	416		92	236	242		60	2.0	
3	24		.45	1.3	900.6	418		91	235	244		57	2.0	
4	28		.36	1.3	903.2	417		92	234	245		58	2.0	
D-1 V	32	14:46	.77	1.3	905.8	420		93	233	250		64	2.0	
2	36		.69	1.3	908.4	420		94	236	256		61	2.0	
3	40		.50	1.3	911.0	418		92	237	254		66	2.0	
4	44		.39	1.3	913.7	415		92	236	252		62	2.0	
D-1 L	48	15:02	.80	1.3	916.4	416		93	232	250		65	2.0	
2	52		.75	1.3	919.1	420		94	235	249		65	2.0	
3	56		.74	1.3	921.8	422		94	233	251		64	2.0	
4	60		.57	1.3	924.371	420		94	234	250		64	2.0	
*Barometric Pressure is at port elevation			Avg Vap	Avg ΔH	Total Volume	Avg T <sub>g</sub>	Avg T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	N <sub>m-stc</sub> scf
			1.76534	1.3	42.371	418.31	92.5	232/238	241/251	241/251	241/251	66	2.0	2.0
			5.9388	1.140										

Thermocouple Check Meter Temp., °F 66 Isokinetic NA  
 Ref. Temp., °F 66 Calculated by NA QC by NA  
 O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A Leak Check, Pre-run NA Post-run NA  
 Flue Gas Composition Oxygen, % NA Carbon Dioxide, % NA Moisture, % NA  
 Comments with NCGs 5065



15730.001.008  
 Pump Dryer, No Paper Machine, #1-3 SB, #1 & #1-2 CBs  
 Data Sheets Version 2. Copyright © 2021 by Weston Solutions, Inc.



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 1 Combination Boiler  
 Sample Location: stack outlet  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/23/21  
 Test Personnel: ATL/LE  
 Sample Time: 64 min.

Console ID: A010  
 Meter Corr., Y: 9.86  
 Console ΔH@: 1.732  
 Probe ID/Length: P153B 5'  
 Liner Material: SS  
 Pitot ID/Coeff.: P172 0.84  
 Thermo ID: A010  
 Nozzle ID/Diams.: 1.250 1.250  
 Avg. Nozzle Diam.: 1.250 in.

Ambient Temp.: 96 °F  
 Baro. Pressure\*: 29.45 in. Hg  
 Static Pressure: 7.65 in. H<sub>2</sub>O  
 Impinger Gain: 1686 mL  
 Silica Gel Gain: 10.6 g  
 Stack Area: 78.54 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: NA  
 Leak Checks: Initial 1.005 Final 1.002  
 @ Vac., in. Hg: 8  
 Pitot: 1.000 1.000  
 Filter ID: NA  
 Sample ID: RUN 23 NCG+SO6

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TFMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
0		15:41			924.700									
A-1 B	4		.59	1.3	927.4	416	95	235	237	237		66	1.5	
2	8		.62	1.3	929.9	416	95	237	254	254		64	1.5	
3	12		.60	1.3	932.8	415	95	238	253	253		63	1.5	
4	16	15:57	.48	1.3	935.3	414	96	239	253	253		64	1.5	
B-1 A	20	16:06	.61	1.3	938.1	412	96	235	255	255		65	1.5	
2	24		.55	1.3	946.1	414	96	236	256	256		63	1.5	
3	28		.50	1.3	943.5	414	97	235	255	255		61	1.5	
4	32	16:22	.35	1.3	946.0	414	97	237	256	256		62	1.5	
Ø-1 D	36	16:29	.74	1.3	948.5	417	94	239	252	252		65	1.5	
2	40		.69	1.3	952.0	416	98	242	257	257		63	1.5	
3	44		.48	1.3	954.3	416	99	238	254	254		63	1.5	
4	48	16:45	.46	1.3	956.6	414	100	237	254	254		64	1.5	
Ø-1 C	52	16:54	.77	1.3	959.2	417	99	240	255	255		66	1.5	
2	56		.75	1.3	962.6	417	98	238	253	253		64	1.5	
3	60		.72	1.3	964.6	419	98	237	253	253		63	1.5	
4	64	17:10	.60	1.3	967.0	413	98	237	253	253		63	3.0	
*Barometric Pressure is at port elevation			Avg V <sub>AP</sub> <u>1.76534</u>	Avg ΔH <u>1.3</u>	Total Volume <u>42.570</u>	Avg T <sub>s</sub> <u>415.85</u>	Avg T <sub>m</sub> <u>97.51</u>	Min/Max <u>235/242</u>	Min/Max <u>251/258</u>	Min/Max <u>251/258</u>	Min/Max <u>66</u>	Max Temp <u>66</u>	Max Vac <u>2.0</u>	V <sub>m-std</sub> <u>scf</u>

Flue Gas Composition: Oxygen, % 50.6; Carbon Dioxide, % 48.6; Moisture, % 0.8

Thermocouple Check: Meter Temp., °F 66; Ref. Temp., °F 66; Result OK

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A: Leak Check, Pre-run 50.6; Post-run 50.6

Comments: 4 NCG

15730.001.008  
 Page Machine, #1-2 CBs  
 Emission Report





# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 1 Combination Boiler  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/23/21 Recovery Date 6/23/21  
 Sample ID Run 1 w/ NCG + SOB Filter ID NA Analyst ATR

	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Contents	DI	DI	empty			
Final	770.1	806.4	643.4		945.5	
Initial	641.1	779.8	638.5		929.5	
Gain	129 ✓	26.6 ✓	4.9 ✓	160.5	16	176.5

Impinger Color clear Labeled?     
 Silica Gel Condition used Sealed?

Run No. 2 Sample Date 6/23/21 Recovery Date 6/23/21  
 Sample ID Run 2 w/ NCG + SOB Filter ID NA Analyst ATR

	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Contents	DI	DI	empty			
Final	914.3	828.2	646.7		933.1	
Initial	770.1	806.4	643.4	169.3	922.5	
Gain	144.2 ✓	21.8 ✓	2.6	168.6	10.6	179.2

Impinger Color clear Labeled?     
 Silica Gel Condition good Sealed?

Run No. 3 Sample Date 6/23/21 Recovery Date 6/23/21  
 Sample ID Run 3 w/ NCG + SOB Filter ID NA Analyst ATR

	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Contents	DI	DI	empty			
Final	874.3	788.9	635.2		801.7	
Initial	763.9	763.8	628.4	✓	789.2	
Gain	110.4 ✓	25.1 ✓	6.3 ✓	146.8	12.5	159.3

Impinger Color clear Labeled?     
 Silica Gel Condition used Sealed?

Check COC for Sample IDs of Media Blanks





# Sample and Velocity Traverse Points - Method 1

Client New Indy  
Location/Plant Catawba, SC  
Operator VD

Source No. 1 Combination Boiler  
W.O. Number 15730.001.008  
Date 6/23/21



Duct Type  Circular  Rectangular  
Traverse Type  Particulate Traverse  Velocity Traverse  Stratification Traverse

Depth, far wall to outside of port (in) = C	127.5
Port Depth (in) = D	7.5
Depth of Duct, diameter (in) = C - D	120
Area of Duct (ft <sup>3</sup> )	78.54
Number of Ports	4
Traverse Points per Port	4
Total Traverse Points	16

<b>Rectangular Ducts Only</b>	
Width of Duct (in)	
Equivalent Diameter (in)	

Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	3.2	3.9	11.4
2	10.5	12.6	20.1
3	19.4	23.3	30.8
4	32.3	38.8	46.3

Flow Disturbances	
Upstream - A (ft)	45
Downstream - B (ft)	32
Upstream - A (duct diameters)	4.5
Downstream - B (duct diameters)	3.2



Traverse Point Location % of Stack - Circular  
Number of Traverse Points

Traverse Point	Number of Traverse Points											
	1	2	3	4	5	6	7	8	9	10	11	12
1	14.6		6.7	4.4		3.2		2.6		2.1		
2		85.4		25.0	14.6	10.5		8.2		6.7		
3			75.0		29.6	19.4		14.6		11.8		
4				93.3		70.4	32.3		22.6	17.7		
5					85.4		67.7		34.2	25.0		
6						95.8		80.6		65.8	35.8	
7							89.5		77.4	64.4		
8								96.8		85.4	75.0	
9									91.8	82.3		
10										97.4	88.2	
11											93.3	
12												97.9

Traverse Point Location % of Stack - Rectangular  
Number of Traverse Points

Traverse Point	Number of Traverse Points											
	1	2	3	4	5	6	7	8	9	10	11	12
1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2	
2		75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
3			83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
4				87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
5					90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
6						91.7	78.6	68.8	61.1	55.0	50.0	45.8
7							92.9	81.3	72.2	65.0	59.1	54.2
8								93.8	83.3	75.0	68.2	62.5
9									94.4	85.0	77.3	70.8
10										95.0	86.4	79.2
11											95.5	87.5
12												95.8

Rectangular Stack Points & Matrix
9 - 3 x 3
12 - 4 x 3
16 - 4 x 4
20 - 5 x 4
25 - 5 x 5
30 - 6 x 5
36 - 6 x 6
42 - 7 x 6
49 - 7 x 7

Tape measure ID \_\_\_\_\_



# RUN SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

**Start Time** 11:58    **End Time** 12:58

---

**Average Measured TRS Conc.**    0.67 ppm ✓  
**Recovery No. 2**                    86.2 % ✓  
**TRS Corrected for Recovery**    0.78 ppm ✓

*mu*

# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

**Start Time 14:00    End Time 15:00**

---

**Average Measured TRS Conc.**    0.61 ppm ✓  
**Recovery No. 2**    86.2 % ✓  
**TRS Corrected for Recovery**    0.71 ppm ✓

*mu*

# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

**Start Time 15:41    End Time 16:41**

---

**Average Measured TRS Conc.**    0.60 ppm ✓  
**Recovery No. 2**    86.2 % ✓  
**TRS Corrected for Recovery**    0.70 ppm ✓

*W*

# RUN DATA

Number 1

15730.001.008  
Pulp Dryer, #3 Paper Machine,  
#2-3 SDTVs, & #1-2 CBs  
Emission Report

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
11:58	4	0.09	37	0.54	<2	<0.16	<2	<0.071	0.64
12:01	3	0.08	35	0.53	<2	<0.16	<2	<0.071	0.61
12:04	3	0.08	35	0.53	<2	<0.16	<2	<0.071	0.62
12:07	3	0.07	36	0.54	<2	<0.16	<2	<0.071	0.61
12:10	3	0.09	37	0.54	<2	<0.16	<2	<0.071	0.63
12:13	3	0.07	37	0.54	<2	<0.16	2	0.08	0.77
12:16	3	0.08	37	0.55	<2	<0.16	<2	<0.071	0.63
12:19	3	0.08	38	0.55	<2	<0.16	<2	<0.071	0.64
12:22	3	0.08	37	0.55	<2	<0.16	<2	<0.071	0.63
12:25	2	0.07	38	0.55	2	0.17	<2	<0.071	0.79
12:28	3	0.08	39	0.56	<2	<0.16	<2	<0.071	0.64
12:31	2	0.07	40	0.57	<2	<0.16	<2	<0.071	0.63
12:34	2	0.07	41	0.58	<2	<0.16	<2	<0.071	0.65
12:37	3	0.07	39	0.56	<2	<0.16	<2	<0.071	0.63
12:40	4	0.09	39	0.56	2	0.17	<2	<0.071	0.82
12:43	3	0.08	40	0.57	2	0.17	<2	<0.071	0.82
12:46	3	0.08	39	0.56	<2	<0.16	<2	<0.071	0.64
12:49	2	0.07	41	0.57	<2	<0.16	2	0.07	0.79
12:52	2	0.07	41	0.57	<2	<0.16	<2	<0.071	0.64
12:55	2	0.07	38	0.55	<2	<0.16	<2	<0.071	0.62
<b>Average</b>		<b>0.08</b>		<b>0.55</b>		<b>&lt;0.16</b>		<b>&lt;0.071</b>	<b>0.67</b> ✓

✓

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
14:00	<2	<0.064	34	0.52	<2	<0.16	<2	<0.071	0.52
14:03	3	0.08	35	0.53	<2	<0.16	<2	<0.071	0.61
14:06	<2	<0.064	34	0.52	<2	<0.16	<2	<0.071	0.52
14:09	3	0.08	36	0.54	<2	<0.16	<2	<0.071	0.62
14:12	4	0.09	36	0.54	<2	<0.16	5	0.12	0.87
14:15	2	0.07	37	0.55	<2	<0.16	<2	<0.071	0.61
14:18	4	0.09	37	0.55	<2	<0.16	<2	<0.071	0.64
14:21	3	0.09	35	0.53	<2	<0.16	<2	<0.071	0.61
14:24	2	0.07	35	0.53	3	0.20	<2	<0.071	0.80
14:27	<2	<0.064	35	0.53	<2	<0.16	3	0.09	0.72
14:30	<2	<0.064	36	0.54	<2	<0.16	<2	<0.071	0.54
14:33	<2	<0.064	35	0.53	<2	<0.16	<2	<0.071	0.53
14:36	3	0.08	37	0.55	<2	<0.16	<2	<0.071	0.62
14:39	<2	<0.064	35	0.53	<2	<0.16	<2	<0.071	0.53
14:42	<2	<0.064	34	0.52	<2	<0.16	<2	<0.071	0.52
14:45	<2	<0.064	36	0.54	<2	<0.16	<2	<0.071	0.54
14:48	<2	<0.064	34	0.52	<2	<0.16	<2	<0.071	0.52
14:51	2	0.07	34	0.52	<2	<0.16	<2	<0.071	0.59
14:54	3	0.08	37	0.55	<2	<0.16	<2	<0.071	0.62
14:57	<2	<0.064	34	0.52	<2	<0.16	3	0.08	0.69
<b>Average</b>		<b>&lt;0.064</b>		<b>0.53</b>		<b>&lt;0.16</b>		<b>&lt;0.071</b>	<b>0.61</b> ✓

✓

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
15:41	3	0.08	32	0.51	<2	<0.16	<2	<0.071	0.58
15:44	<2	<0.064	29	0.48	<2	<0.16	<2	<0.071	0.48
15:47	4	0.09	28	0.47	<2	<0.16	<2	<0.071	0.57
15:50	<2	<0.064	29	0.48	<2	<0.16	<2	<0.071	0.48
15:53	<2	<0.064	31	0.50	3	0.19	<2	<0.071	0.69
15:56	5	0.11	29	0.48	<2	<0.16	<2	<0.071	0.59
15:59	10	0.15	29	0.48	<2	<0.16	<2	<0.071	0.64
16:02	15	0.19	30	0.49	<2	<0.16	<2	<0.071	0.68
16:05	9	0.15	30	0.49	<2	<0.16	3	0.09	0.81
16:08	5	0.11	28	0.47	<2	<0.16	<2	<0.071	0.58
16:11	7	0.13	30	0.49	<2	<0.16	<2	<0.071	0.61
16:14	8	0.14	29	0.48	<2	<0.16	<2	<0.071	0.62
16:17	11	0.17	29	0.48	<2	<0.16	3	0.08	0.82
16:20	3	0.08	30	0.49	<2	<0.16	<2	<0.071	0.58
16:23	<2	<0.064	30	0.49	<2	<0.16	3	0.08	0.65
16:26	3	0.08	30	0.49	<2	<0.16	<2	<0.071	0.56
16:29	<2	<0.064	30	0.49	<2	<0.16	<2	<0.071	0.49
16:32	3	0.08	29	0.48	<2	<0.16	<2	<0.071	0.56
16:35	<2	<0.064	30	0.49	<2	<0.16	<2	<0.071	0.49
16:38	3	0.08	29	0.48	<2	<0.16	<2	<0.071	0.56
<b>Average</b>		<b>0.08</b>		<b>0.49</b>		<b>&lt;0.16</b>		<b>&lt;0.071</b>	<b>0.60</b> ✓

*Handwritten mark*



# RUN DATA

Number 7

Client: **New Indy**  
 Location: **Catawba, NC**  
 Source: **#1 Combination Boiler**

Method **16**  
 Calibration **2**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS	
	area	ppm	area	ppm	area	ppm	area	ppm	ppm	
			CC416806 7.257 ppm ✓							
12:28	14344	7.79	<2	<0.12	<2	<0.077	<2	<0.036	7.79	
12:31	14847	7.94	<2	<0.12	<2	<0.077	<2	<0.036	7.94	
12:34	15003	7.98	<2	<0.12	2	0.09	<2	<0.036	8.07	
<b>Average</b>		<b>7.90</b>	✓	<b>&lt;0.12</b>	✓	<b>&lt;0.077</b>	✓	<b>&lt;0.036</b>	✓ <b>7.93</b>	

*Handwritten mark*

# RECOVERY DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

## Before Run 1

Start Time 08:30    End Time 08:43

### Recovery Gas to Probe, Time 08:30

Peak Areas, mv-sec			Average	ppm
11433	11272	11506	11403 ✓	7.65

### Recovery Gas to GC, Time 08:40

Peak Areas, mv-sec			Average	ppm
13047	13101	13148	13098 ✓	8.26

Recovery 92.6% ✓

# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

**After Run 3    Before Run 4**  
**Start Time 16:45    End Time 17:12**

## Recovery Gas to Probe, Time 16:45

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
10559	10796	10726	10694 ✓	7.38

## Recovery Gas to GC, Time 17:07

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
14018	13986	14003	14002 ✓	8.57

**Recovery 86.2% /**

# RECOVERY DATA

Number 3

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

**After Run 6    Before Run 7**  
**Start Time 23:08    End Time 23:33**

## Recovery Gas to Probe, Time 23:08

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
12008	11871	12366	12082 ✓	7.90

## Recovery Gas to GC, Time 23:30

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
14235	14081	14105	14141 ✓	8.62

**Recovery 91.7% ✓**

✓

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

Method **16**

Ambient Temperature: 72°C

Barometric Pressure: 29.25 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51828	33-53274	89-53332	89-53266
Perm. Rate, nL/min	351	369	477	241
Ret. Time, sec	16.0	22.5	48.0	127.0

1 Flow = 27.4 mL/Min      12.8 ppm      13.5 ppm      17.4 ppm      8.81 ppm

Time: 06:00

Peak Areas, mv-sec

28200	16074	not used	not used
27714	15989	used	used
27544	15970		
<b>Average Area</b>	<b>27819</b> ✓	<b>16011</b> ✓	

2 Flow = 59.5 mL/Min      5.90 ppm      6.20 ppm      8.02 ppm      4.06 ppm

Time: 06:49

Peak Areas, mv-sec

7504	3841	12348	15296
7611	3774	12960	15012
7641	3823	12909	15325
<b>Average Area</b>	<b>7585</b> ✓	<b>3813</b> ✓	<b>12739</b> ✓

3 Flow = 131 mL/Min      2.68 ppm      2.82 ppm      3.64 ppm      1.84 ppm

Time: 07:28

Peak Areas, mv-sec

1734	856	2868	3422
1702	845	2771	3379
1690	846	2788	3411
<b>Average Area</b>	<b>1709</b> ✓	<b>849</b> ✓	<b>2809</b> ✓

4 Flow = 271 mL/Min      1.30 ppm      1.36 ppm      1.76 ppm      0.89 ppm

Time: 07:53

Peak Areas, mv-sec

440	204	681	847
433	209	682	842
472	206	671	834
<b>Average Area</b>	<b>448</b> ✓	<b>206</b> ✓	<b>678</b> ✓

# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

Method **16**

H <sub>2</sub> S	1	2	3	4		
Time	06:00	06:49	07:28	07:53		
Concentration, ppm	12.8	5.90	2.68	1.30		
Area, mv-sec	27819	7585	1709	448		
Calc. Conc., ppm	12.5	6.11	2.68	1.28		
% Error	-2.3	3.5	0.0	-1.2		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.8102	2.4572	0.9997	2	0.064	

MeSH	1	2	3	4		
Time	06:00	06:49	07:28	07:53		
Concentration, ppm	13.5	6.20	2.82	1.36		
Area, mv-sec	16011	3813	849	206		
Calc. Conc., ppm	13.3	6.26	2.84	1.35		
% Error	-0.9	1.0	0.9	-0.9		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.8989	2.0680	0.9999	2	0.12	

DMS	1	2	3		
Time	06:49	07:28	07:53		
Concentration, ppm	8.02	3.64	1.76		
Area, mv-sec	12739	2809	678		
Calc. Conc., ppm	17.6	7.86	3.68		
% Error	119.4	115.7	109.0		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8747	1.7700	0.9997	2	0.16

DMDS	1	2	3		
Time	06:49	07:28	07:53		
Concentration, ppm	4.06	1.84	0.89		
Area, mv-sec	15211	3404	841		
Calc. Conc., ppm	8.91	3.97	1.86		
% Error	119.6	115.3	109.2		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8501	2.4250	0.9997	2	0.071



# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Method **16**

Ambient Temperature: 72°C

Barometric Pressure: 29.25 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51828	33-53274	89-53332	89-53266
Perm. Rate, nL/min	351	369	477	241
Ret. Time, sec	16.0	22.5	48.0	127.0

<b>1</b> Flow = 37.6 mL/Min	<b>9.34</b> ppm	<b>9.81</b> ppm	<b>12.7</b> ppm	<b>6.42</b> ppm
<b>Time: 07:00</b>	<b>Peak Areas, mv-sec</b>			
	19790	9921	31382	38948
	20319	10076	31742	38693
	19852	9986	30214	37936
<b>Average Area</b>	<b>19987</b> ✓	<b>9995</b> ✓	<b>31113</b> ✓	<b>38526</b> ✓
<b>2</b> Flow = 82.8 mL/Min	<b>4.24</b> ppm	<b>4.46</b> ppm	<b>5.77</b> ppm	<b>2.92</b> ppm
<b>Time: 11:03</b>	<b>Peak Areas, mv-sec</b>			
	4788	2266	7435	8918
	4588	2209	7188	8687
	4419	2218	7198	8791
<b>Average Area</b>	<b>4598</b> ✓	<b>2231</b> ✓	<b>7274</b> ✓	<b>8798</b> ✓
<b>3</b> Flow = 180 mL/Min	<b>1.95</b> ppm	<b>2.05</b> ppm	<b>2.66</b> ppm	<b>1.34</b> ppm
<b>Time: 11:47</b>	<b>Peak Areas, mv-sec</b>			
	998	492	1607	1968
	985	496	1607	1963
	982	497	1614	1971
<b>Average Area</b>	<b>988</b> ✓	<b>495</b> ✓	<b>1609</b> ✓	<b>1967</b> ✓

*VD*

# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

H <sub>2</sub> S	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	9.34 ✓	4.24 ✓	1.95 ✓		
Area, mv-sec	19987 ✓	4598 ✓	988 ✓		
Calc. Conc., ppm	9.26	4.31	1.94		
% Error	-0.8	1.6	-0.8		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9212	2.4433	0.9998	2	0.077

MeSH	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	9.81 ✓	4.46 ✓	2.05 ✓		
Area, mv-sec	9995 ✓	2231 ✓	495 ✓		
Calc. Conc., ppm	9.79	4.48	2.05		
% Error	-0.3	0.5	-0.3		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9203	2.0975	>0.9999	2	0.12

DMS	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	12.7 ✓	5.77 ✓	2.66 ✓		
Area, mv-sec	31113 ✓	7274 ✓	1609 ✓		
Calc. Conc., ppm	12.6	5.85	2.64		
% Error	-0.7	1.4	-0.7		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8927	2.4098	0.9999	2	0.077

DMDS	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	6.42 ✓	2.92 ✓	1.34 ✓		
Area, mv-sec	38526 ✓	8798 ✓	1967 ✓		
Calc. Conc., ppm	6.39	2.94	1.34		
% Error	-0.4	0.8	-0.4		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9009	3.0543	>0.9999	2	0.036

*pu*

# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
<b>Molecular Weight</b>	34.08	48.11	62.14	94.20
<b>Retention Time, sec</b>	16.0	22.5	48.0	127.0
<b>Peak Detection Window, sec</b>	3.0	7.0	10.0	10.0
<b>Minimum Peak Area, mv-sec</b>	2	2	2	2
<b>Minimum Peak Height, mv</b>	1	1	1	1
<b>Beginning Peak Width, sec</b>	1.0	1.0	2.0	3.0
<b>Ending Peak Width, sec</b>	2.0	6.0	4.0	5.0
<b>Permeation Device ID</b>	T-51828	33-53274	89-53332	89-53266
<b>Permeation Rate, ng/min</b>	483 ✓	716 ✓	1197 ✓	918 ✓
<b>Permeation Rate, nL/min*</b>	351	369	477	241

**Barometric Pressure:** 29.25 in. Hg    **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- PR<sub>ng</sub>** = Permeation Rate by weight, ng/min
- V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole
- W<sub>mol</sub>** = Molecular Weight of compound
- T<sub>a</sub>** = Ambient Temperature, °F
- T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)
- P<sub>s</sub>** = Standard Pressure = 29.92 in Hg
- P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 483 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.25) = 351 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

- C** = Concentration, ppmv
- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- F<sub>d</sub>** = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

File: C:\Data\210623 New Indy Catawba No. 1 CB.trs  
Program Version: 2.0, built 15 May 2017 File Version: 2.0  
Computer: WLT5 Trailer: 281

Analog Input Device: MCC USB-1608G GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: Shimadzu GC8-A Serial No. C10493615061  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 140	Primary: Carbopack
Air	30	60	Detector: 140	Secondary: N/A
Carrier	50	30		Sample Loop: 4"

## Injection Cycle

Total Length: 180 sec Sampling Time: 170 sec Load/Backflush Time: 80 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 2 mv-sec Minimum peak height 1 mv above baseline

## Dynacalibrator

Chamber Temperature 50.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.25 in. Hg

# RUN SUMMARY

Number 1

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **23 Jun 2021**

Method Conc. Units	O <sub>2</sub> EPA 3A %	CO <sub>2</sub> EPA 3A %	SO <sub>2</sub> EPA 6C ppm
-----------------------	-------------------------------	--------------------------------	----------------------------------

Time: 11:58 to 12:58

### Run Averages

11.9                  7.8                  190

### Pre-run Bias at 10:56

Zero Bias	0.0	0.0	6
Span Bias	10.0	10.1	234
Span Gas	10.1	10.2	242

### Post-run Bias at 13:01

Zero Bias	0.0	0.0	3
Span Bias	10.0	10.2	235
Span Gas	10.1	10.2	242

Run averages corrected for the average of the pre-run and post-run bias

12.1 ✓                  7.8 ✓                  195 ✓

# RUN SUMMARY

Number 2

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **23 Jun 2021**

Method Conc. Units	O <sub>2</sub> EPA 3A %	CO <sub>2</sub> EPA 3A %	SO <sub>2</sub> EPA 6C ppm
-----------------------	-------------------------------	--------------------------------	----------------------------------

Time: 14:00 to 15:00

### Run Averages

11.3                  8.4                  267

### Pre-run Bias at 13:01

Zero Bias	0.0	0.0	3
Span Bias	10.0	10.2	235
Span Gas	10.1	10.2	242

### Post-run Bias at 15:04

Zero Bias	0.0	0.0	5
Span Bias	10.0	10.2	232
Span Gas	10.1	10.2	242

Run averages corrected for the average of the pre-run and post-run bias

11.4 ✓                  8.4 ✓                  278 ✓



# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Method Conc. Units	O <sub>2</sub> EPA 3A %	CO <sub>2</sub> EPA 3A %	SO <sub>2</sub> EPA 6C ppm
-----------------------	-------------------------------	--------------------------------	----------------------------------

Time: 15:41 to 16:41

### Run Averages

11.9            7.7            328

### Pre-run Bias at 15:04

Zero Bias	0.0	0.0	5
Span Bias	10.0	10.2	232
Span Gas	10.1	10.2	242

### Post-run Bias at 16:43

Zero Bias	0.0	0.0	8
Span Bias	10.0	10.1	234
Span Gas	10.1	10.2	242

Run averages corrected for the average of the pre-run and post-run bias

12.0 ✓            7.7 ✓            344 ✓

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
<b>With NCGs &amp; SOGs</b>						
11:59	3900	11.7	3282	8.1	1867	187
12:00	3863	11.6	3222	8.0	1924	193
12:01	3790	11.4	3276	8.1	1958	196
12:02	3761	11.3	3348	8.3	1906	191
12:03	3751	11.3	3375	8.4	2086	209
12:04	3680	11.1	3408	8.4	2212	221
12:05	3691	11.1	3474	8.6	2000	200
12:06	3760	11.3	3448	8.5	1798	180
12:07	3833	11.5	3382	8.4	1847	185
12:08	3834	11.5	3295	8.2	2034	204
12:09	3821	11.5	3293	8.2	1797	180
12:10	3851	11.6	3318	8.2	1571	157
12:11	3980	12.0	3262	8.1	1774	178
12:12	3983	12.0	3137	7.8	2126	213
12:13	3919	11.8	3133	7.8	1792	179
12:14	3885	11.7	3214	8.0	1646	165
12:15	3860	11.6	3254	8.1	1719	172
12:16	3866	11.6	3283	8.1	2175	218
12:17	3926	11.8	3265	8.1	1905	191
12:18	3922	11.8	3213	8.0	1762	176
12:19	3964	11.9	3196	7.9	1725	173
12:20	3881	11.7	3159	7.8	2045	205
12:21	3855	11.6	3258	8.1	1724	173
12:22	3833	11.5	3284	8.1	1640	164
12:23	3786	11.4	3320	8.2	1587	159
12:24	3736	11.2	3393	8.4	1703	171
12:25	3781	11.4	3417	8.5	1742	174
12:26	3832	11.5	3385	8.4	2014	202
12:27	3915	11.8	3304	8.2	2371	237
12:28	3987	12.0	3201	7.9	2116	212
12:29	4032	12.1	3129	7.7	1853	186
12:30	4020	12.1	3071	7.6	1840	184
12:31	4069	12.2	3094	7.7	1730	173
12:32	4170	12.5	3022	7.5	1955	196
12:33	4165	12.5	2923	7.2	2007	201
12:34	4124	12.4	2922	7.2	2005	201
12:35	4074	12.2	2964	7.3	1810	181
12:36	3934	11.8	3074	7.6	1686	169
12:37	4072	12.2	3177	7.9	1563	157
12:38	4120	12.4	3031	7.5	1849	185

# RUN DATA

Number 1

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
12:39	4123	12.4	2977	7.4	1979	198
12:40	4133	12.4	2988	7.4	2012	201
12:41	4185	12.6	2968	7.3	2015	202
12:42	4155	12.5	2913	7.2	2126	213
12:43	4172	12.5	2937	7.3	1950	195
12:44	4138	12.4	2910	7.2	1824	183
12:45	4104	12.3	2957	7.3	1653	166
12:46	4044	12.2	3000	7.4	1704	171
12:47	4064	12.2	3066	7.6	1845	185
12:48	4058	12.2	3025	7.5	2033	204
12:49	4059	12.2	3032	7.5	2065	207
12:50	3992	12.0	3048	7.5	2185	219
12:51	3995	12.0	3098	7.7	1898	190
12:52	3948	11.9	3120	7.7	1851	185
12:53	3920	11.8	3168	7.8	1716	172
12:54	4018	12.1	3188	7.9	1784	179
12:55	4016	12.1	3083	7.6	1767	177
12:56	4035	12.1	3093	7.7	2146	215
12:57	4119	12.4	3045	7.5	2036	204
12:58	3998	12.0	2974	7.4	2112	211
<b>Avg</b>	<b>3958</b>	<b>11.9</b>	<b>3163</b>	<b>7.8</b>	<b>1893</b>	<b>190</b>

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
<b>With NCGs &amp; SOGs</b>						
14:01	3839	11.5	3272	8.1	2531	253
14:02	3807	11.4	3265	8.1	2546	255
14:03	3771	11.3	3316	8.2	2586	259
14:04	3824	11.5	3336	8.3	2244	225
14:05	3869	11.6	3286	8.1	2280	228
14:06	3857	11.6	3237	8.0	2369	237
14:07	3877	11.7	3252	8.1	2484	249
14:08	3817	11.5	3243	8.0	2715	272
14:09	3876	11.6	3274	8.1	2888	289
14:10	3924	11.8	3230	8.0	2684	269
14:11	3921	11.8	3177	7.9	2684	269
14:12	3909	11.7	3190	7.9	2553	255
14:13	3937	11.8	3191	7.9	2517	252
14:14	3899	11.7	3186	7.9	2571	257
14:15	3890	11.7	3216	8.0	2628	263
14:16	3916	11.8	3216	8.0	2624	263
14:17	3953	11.9	3184	7.9	2827	283
14:18	3882	11.7	3161	7.8	2785	279
14:19	3926	11.8	3241	8.0	2595	260
14:20	3954	11.9	3188	7.9	2549	255
14:21	3913	11.8	3179	7.9	2660	266
14:22	3826	11.5	3223	8.0	2581	258
14:23	3841	11.5	3305	8.2	2659	266
14:24	3790	11.4	3301	8.2	2699	270
14:25	3718	11.2	3369	8.3	2726	273
14:26	3711	11.2	3451	8.5	2690	269
14:27	3692	11.1	3459	8.6	2695	270
14:28	3734	11.2	3475	8.6	2680	268
14:29	3804	11.4	3419	8.5	2589	259
14:30	3777	11.4	3364	8.3	2496	250
14:31	3773	11.3	3404	8.4	2606	261
14:32	3757	11.3	3415	8.5	2632	263
14:33	3727	11.2	3442	8.5	2919	292
14:34	3736	11.2	3444	8.5	2571	257
14:35	3781	11.4	3449	8.5	2658	266
14:36	3750	11.3	3409	8.4	2695	270
14:37	3754	11.3	3435	8.5	2600	260
14:38	3764	11.3	3425	8.5	2717	272
14:39	3729	11.2	3411	8.4	2657	266
14:40	3712	11.2	3456	8.6	2841	284

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
14:41	3705	11.1	3477	8.6	2668	267
14:42	3704	11.1	3502	8.7	2632	263
14:43	3614	10.9	3515	8.7	2647	265
14:44	3571	10.7	3595	8.9	2726	273
14:45	3562	10.7	3663	9.1	2741	274
14:46	3616	10.9	3663	9.1	2750	275
14:47	3573	10.7	3607	8.9	2798	280
14:48	3562	10.7	3656	9.1	2813	281
14:49	3547	10.7	3674	9.1	2724	273
14:50	3566	10.7	3677	9.1	2747	275
14:51	3524	10.6	3670	9.1	2747	275
14:52	3546	10.7	3692	9.1	2775	278
14:53	3562	10.7	3665	9.1	2816	282
14:54	3647	11.0	3638	9.0	2834	283
14:55	3675	11.0	3551	8.8	2831	283
14:56	3719	11.2	3517	8.7	2870	287
14:57	3702	11.1	3465	8.6	2874	287
14:58	3633	10.9	3502	8.7	2843	284
14:59	3574	10.7	3585	8.9	2752	275
15:00	3555	10.7	3653	9.0	2685	269
<b>Avg</b>	<b>3752</b>	<b>11.3</b>	<b>3408</b>	<b>8.4</b>	<b>2672</b>	<b>267</b>

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
<b>With NCGs &amp; SOGs</b>						
15:42	4136	12.4	2870	7.1	3026	303
15:43	4071	12.2	2928	7.2	3074	307
15:44	4049	12.2	3004	7.4	3120	312
15:45	4035	12.1	3027	7.5	3280	328
15:46	4047	12.2	3040	7.5	3270	327
15:47	4051	12.2	3019	7.5	3290	329
15:48	4015	12.1	3040	7.5	3264	326
15:49	4082	12.3	3054	7.6	3137	314
15:50	4117	12.4	2977	7.4	3095	310
15:51	4104	12.3	2957	7.3	3214	321
15:52	4135	12.4	2964	7.3	3224	322
15:53	4140	12.4	2932	7.3	3344	334
15:54	4138	12.4	2915	7.2	3399	340
15:55	4106	12.3	2932	7.3	3363	336
15:56	4063	12.2	2994	7.4	3173	317
15:57	4114	12.4	3005	7.4	3187	319
15:58	4132	12.4	2957	7.3	3179	318
15:59	4110	12.3	2944	7.3	3291	329
16:00	4076	12.2	2962	7.3	3350	335
16:01	4024	12.1	2991	7.4	3535	354
16:02	3989	12.0	3045	7.5	3492	349
16:03	3964	11.9	3078	7.6	3329	333
16:04	3894	11.7	3119	7.7	3219	322
16:05	3891	11.7	3203	7.9	3140	314
16:06	3890	11.7	3201	7.9	3140	314
16:07	3924	11.8	3199	7.9	3199	320
16:08	3909	11.7	3164	7.8	3403	340
16:09	3980	12.0	3167	7.8	3447	345
16:10	4005	12.0	3080	7.6	3467	347
16:11	3861	11.6	3083	7.6	3388	339
16:12	3879	11.7	3229	8.0	3208	321
16:13	3969	11.9	3183	7.9	3121	312
16:14	3971	11.9	3125	7.7	3072	307
16:15	3936	11.8	3132	7.8	3222	322
16:16	3807	11.4	3166	7.8	3439	344
16:17	3780	11.4	3260	8.1	3402	340
16:18	3834	11.5	3267	8.1	3296	330
16:19	3881	11.7	3195	7.9	3290	329
16:20	3837	11.5	3164	7.8	3238	324
16:21	3863	11.6	3204	7.9	3166	317



# RUN DATA

Number 3

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
16:22	3910	11.7	3171	7.8	3172	317
16:23	3944	11.9	3114	7.7	3336	334
16:24	3939	11.8	3081	7.6	3447	345
16:25	3907	11.7	3099	7.7	3383	338
16:26	3911	11.8	3120	7.7	3174	317
16:27	3901	11.7	3127	7.7	3171	317
16:28	3942	11.8	3118	7.7	3189	319
16:29	3912	11.8	3090	7.6	3130	313
16:30	3878	11.7	3125	7.7	3413	341
16:31	3870	11.6	3148	7.8	3486	349
16:32	3793	11.4	3185	7.9	3451	345
16:33	3776	11.3	3259	8.1	3293	329
16:34	3811	11.5	3273	8.1	3258	326
16:35	3879	11.7	3232	8.0	3214	321
16:36	3893	11.7	3160	7.8	3237	324
16:37	3862	11.6	3146	7.8	3276	328
16:38	3858	11.6	3180	7.9	3413	341
16:39	3853	11.6	3181	7.9	3370	337
16:40	3856	11.6	3182	7.9	3339	334
16:41	3808	11.4	3190	7.9	3338	334
<b>Avg</b>	<b>3955</b>	<b>11.9</b>	<b>3099</b>	<b>7.7</b>	<b>3276</b>	<b>328</b>

# BIAS

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 08:43

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	4	0.0	0.0	0.0	Pass
Span	10.1	3346	10.1	0.0	0.0	Pass

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	24	0.0	0.0	0.0	Pass
Span	10.2	4072	10.1	-0.1	-0.5	Pass

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	1	80	8	7	1.5	Pass
Span	239	2334	234	-5	-1.1	Pass

*VD*

# BIAS AND CALIBRATION DRIFT

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 10:56

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	9	0.0	0.0	0.0 ✓	Pass
Span	10.1	3325	10.0	-0.1	-0.5 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	9	0.0	0.0 ✓	Pass	
Span	10.1	3325	10.0	-0.1 ✓	Pass	

\*Bias No. 1

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	7	0.0	0.0	0.0 ✓	Pass
Span	10.2	4076	10.1	-0.1	-0.5 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	7	0.0	0.0 ✓	Pass	
Span	10.1	4076	10.1	0.0 ✓	Pass	

\*Bias No. 1

# BIAS AND CALIBRATION DRIFT

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 10:56

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	1	52	6	5	1.1 ✓	Pass
Span	239	2334	234	-5	-1.1 ✓	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	ppm	mv	ppm	%	
Zero	8	52	6	-0.4 ✓	Pass
Span	234	2334	234	0.0 ✓	Pass

\*Bias No. 1

# BIAS AND CALIBRATION DRIFT

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 13:01

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	9	0.0	0.0	0.0 ✓	Pass
Span	10.1	3337	10.0	-0.1	-0.5 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	9	0.0	0.0 ✓	Pass	
Span	10.0	3337	10.0	0.0 ✓	Pass	

\*Bias No. 2

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	17	0.0	0.0	0.0 ✓	Pass
Span	10.2	4108	10.2	0.0	0.0 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	17	0.0	0.0 ✓	Pass	
Span	10.1	4108	10.2	0.1 ✓	Pass	

\*Bias No. 2

# BIAS AND CALIBRATION DRIFT

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 13:01

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

## Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	1	23	3	2	0.4 ✓	Pass
Span	239	2346	235	-4	-0.9 ✓	Pass

## Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	ppm	mv	ppm	%	
Zero	6	23	3	-0.7 ✓	Pass
Span	234	2346	235	0.2 ✓	Pass

\*Bias No. 2

*AK*



# BIAS AND CALIBRATION DRIFT

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 15:04

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	9	0.0	0.0	0.0 ✓	Pass
Span	10.1	3341	10.0	-0.1	-0.5 ✓	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	%	mv	%	%	
Zero	0.0	9	0.0	0.0 ✓	Pass
Span	10.0	3341	10.0	0.0 ✓	Pass

\*Bias No. 3

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	8	0.0	0.0	0.0 ✓	Pass
Span	10.2	4109	10.2	0.0	0.0 ✓	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	%	mv	%	%	
Zero	0.0	8	0.0	0.0 ✓	Pass
Span	10.2	4109	10.2	0.0 ✓	Pass

\*Bias No. 3

# BIAS AND CALIBRATION DRIFT

Number 4

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **23 Jun 2021**

Start Time: 15:04

**SO<sub>2</sub>**

Method: EPA 6C

Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	1	41	5	4	0.9 ✓	Pass
Span	239	2322	232	-7	-1.5 ✓	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status	
Gas	ppm	mv	ppm	%		
Zero	3	41	5	2	0.4 ✓	Pass
Span	235	2322	232	-3	-0.7 ✓	Pass

\*Bias No. 3

# BIAS AND CALIBRATION DRIFT

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 16:43

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	6	0.0	0.0	0.0 ✓	Pass
Span	10.1	3335	10.0	-0.1	-0.5 ✓	Pass

Calibration Drift						Status
Standard	Initial*	Final	Difference	Drift		
Gas	%	mv	%	%	%	
Zero	0.0	6	0.0	0.0	0.0 ✓	Pass
Span	10.0	3335	10.0	0.0	0.0 ✓	Pass

\*Bias No. 4

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	12	0.0	0.0	0.0 ✓	Pass
Span	10.2	4067	10.1	-0.1	-0.5 ✓	Pass

Calibration Drift						Status
Standard	Initial*	Final	Difference	Drift		
Gas	%	mv	%	%	%	
Zero	0.0	12	0.0	0.0	0.0 ✓	Pass
Span	10.2	4067	10.1	-0.1	-0.5 ✓	Pass

\*Bias No. 4

# BIAS AND CALIBRATION DRIFT

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 16:43

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	1	79	8	7	1.5 ✓	Pass
Span	239	2341	234	-5	-1.1 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	ppm	mv	ppm	%		
Zero	5	79	8	3	0.7 ✓	Pass
Span	232	2341	234	2	0.4 ✓	Pass

\*Bias No. 4

*Handwritten mark*

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 08:37

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

### Calibration Results

%	Cylinder ID	Result, mv
Zero ✓	-	3
10.1 ✓	XC013544B	3354
20.2 ✓	CC275468	6750

### Curve Coefficients

Slope	Intercept	Corr. Coeff.
333.3	-7 ✓	>0.9999 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

### Calibration Results

%	Cylinder ID	Result, mv
Zero ✓	-	4
10.2 ✓	XC013544B	4128
20.3 ✓	CC275468	8145

### Curve Coefficients

Slope	Intercept	Corr. Coeff.
401.6	18 ✓	>0.9999 ✓

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 08:37

**SO<sub>2</sub>**

Method: EPA 6C

Calibration Type: Linear Regression

---

Calibration Results

ppm	Cylinder ID	Result, mv
Zero ✓	-	9
242 ✓	CC234516	2392
458 ✓	EB0108003	4596

---

Curve Coefficients

Slope	Intercept ✓	Corr. Coeff. ✓
10.01	-5	0.9999

---

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 08:37

**O<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.2 %

Slope 333.3                      Intercept -6.7

Standard %	Response mv	Result %	Difference %	Error %	Status
Zero	3	0.0	0.0	0.0 ✓	Pass
10.1	3354	10.1	0.0	0.0 ✓	Pass
20.2	6750	20.3	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.3 %

Slope 401.6                      Intercept 18.5

Standard %	Response mv	Result %	Difference %	Error %	Status
Zero	4	0.0	0.0	0.0 ✓	Pass
10.2	4128	10.2	0.0	0.0 ✓	Pass
20.3	8145	20.2	-0.1	-0.5 ✓	Pass

**SO<sub>2</sub>**

Method: EPA 6C  
Span Conc. 458 ppm

Slope 10.01                      Intercept -5

Standard ppm	Response mv	Result ppm	Difference ppm	Error %	Status
Zero	9	1	1	0.2 ✓	Pass
242	2392	239	-3	-0.7 ✓	Pass
458	4596	459	1	0.2 ✓	Pass



# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

**File:** K:\15730 New Indy\001 Catawba SC\008\Data\210623 New Indy Catawba No. 1 CBb.cem  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** WSAUBCHEMLABGC1 **Trailer:** 281  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T802 s/n: 172</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.2</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T802 s/n: 172</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.3</b>

## Channel 5

Analyte	<b>SO<sub>2</sub></b>
Method	<b>EPA 6C, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T100H SN 374</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, ppm	<b>500</b>
Span Concentration, ppm	<b>458</b>



**No. 1 COMBINATION BOILER  
(CONDITION 2: NCG GASES ONLY)**

New Indy  
Catawba, SC

15730.001.008  
No. 1 Combination Boiler  
Condition 2: NCGs only

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
Date	6/23/21 ✓	6/23/21 ✓	6/23/21 ✓	---
Time Began	1824 ✓	2019 ✓	2202 ✓	---
Time Ended	1924 ✓	2119 ✓	2302 ✓	---
Volumetric Flow Rate, (Qs), DSCFM	1.30E+05 ✓	1.31E+05 ✓	1.30E+05 ✓	1.30E+05
BWS	0.164 ✓	0.163 ✓	0.171 ✓	0.166
% Oxygen	11.4 ✓	11.9 ✓	11.6 ✓	11.6

---

Sulfur Dioxide	MW= 64.06				
Concentration, ppm		313.0 ✓	348.0 ✓	349.0 ✓	336.7
Emission Rate, lb/hr		404.4	452.9	450.8	436.1

---

Total Reduced Sulfur	(TRS MW)= 34.08				
Concentration, ppm		0.63 ✓	0.60 ✓	0.67 ✓	0.63
Emission Rate, lb/hr		0.43	0.42	0.46	0.44

---

New Indy  
Catawba, SC

15730.001.008  
No. 1 Combination Boiler

**Condition 2: NCGs only**

**ISOKINETIC CALCULATIONS**

Run Number	1	2	3	Mean
Date	6/23/21 ✓	6/23/21 ✓	6/23/21 ✓	---
Time Began	1824 ✓	2019 ✓	2202 ✓	---
Time Ended	1951 ✓	2145 ✓	2325 ✓	---

**INPUT DATA**

Sampling Time, min	(Theta)	64.0 ✓	64 ✓	64 ✓	64
Stack Diameter, in.	(Dia.)	120.00 ✓	120.00 ✓	120.00 ✓	120.00
Barometric Pressure, in. Hg	(Pb)	29.45 ✓	29.45 ✓	29.45 ✓	29.45
Static Pressure, in. H2O	(Pg)	-0.65 ✓	-0.65 ✓	-0.65 ✓	-0.65
Pitot Tube Coefficient	(Cp)	0.84 ✓	0.84 ✓	0.84 ✓	0.84
Meter Correction Factor	(Y)	0.9880 ✓	0.9880 ✓	0.9880 ✓	0.9880
Orifice Calibration Value	(Delta H@)	1.7320 ✓	1.7320 ✓	1.7320 ✓	1.7320
Nozzle Diameter, in.	(Dn)	0.250 ✓	0.250 ✓	0.250 ✓	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	42.643 ✓	42.125 ✓	41.764 ✓	42.177
Meter Temperature, °F	(Tm)	94.1 ✓	85.2 ✓	77.6 ✓	85.6
Meter Temperature, °R	(Tm-R)	554.1	545.2	537.6	545.6
Meter Orifice Pressure, in. H2O	(Delta H)	1.300 ✓	1.300 ✓	1.300 ✓	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> )avg	1.140 ✓	1.140 ✓	1.140 ✓	1.140
Volume H2O Collected, mL	(Vlc)	165.5 ✓	165.0 ✓	175.8 ✓	168.8
CO2 Concentration, %	(CO2)	8.3 ✓	7.8 ✓	8.1 ✓	8.1
O2 Concentration, %	(O2)	11.4 ✓	11.9 ✓	11.6 ✓	11.6
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> )avg	0.748 ✓	0.750 ✓	0.753 ✓	0.750
Stack Temperature, °F	(Ts)	415.7 ✓	411.3 ✓	415.1 ✓	414.0
Stack Temperature, °R	(Ts-R)	875.7	871.3	875.1	874.0

**CALCULATED DATA**

Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	78.54 ✓	78.54 ✓	78.54 ✓	78.54
Stack Pressure, in. Hg	(Ps)	29.40	29.40	29.40	29.40
Meter Pressure, in. Hg	(Pm)	29.55	29.55	29.55	29.55
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	39.631	39.788	40.006	39.808
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	7.790	7.767	8.275	7.944
Moisture Fraction (Measured)	(BWS)	0.164	0.163	0.171	0.166
Moisture Fraction (lower sat/meas)	(BWS)	0.164	0.163	0.171	0.166
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	29.78	29.72	29.76	29.76
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	27.85	27.81	27.74	27.80
Average Stack Gas Velocity, ft/sec	(Vs)	55.53	55.61	55.97	55.70
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	261702	262033	263755	262497
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	129539	130503	129526	129856
Calibration check	(Yqa)	0.9922	0.9973	0.9983	0.996
Percent difference from Y					0.80%

*AM*



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 1 Combination Boiler  
 Sample Location Stack outlet  
 W. O. Number 15730.001.008  
 Run Number 1  
 Date 6/23/21  
 Test Personnel ATK/LLC  
 Sample Time 64 min.

Console ID A010  
 Meter Corr., Y 988  
 Console ΔH@ 1.732  
 Probe ID/Length PR5B 5  
 Liner Material 35  
 Pitot ID/Coeff. 0.84  
 Thermo ID A010  
 Nozzle ID/Diams. .250, .250, .250  
 Avg. Nozzle Diam. .250 in.

Ambient Temp. 85 °F  
 Baro. Pressure\* 29.45 in. Hg  
 Static Pressure -.65 in. H<sub>2</sub>O  
 Impinger Gain 1500 mL  
 Silica Gel Gain 9.3 g  
 Stack Area 78.54 ft<sup>2</sup>  
 Total Traverse Points 16

K Factor NA  
 Leak Checks  
 Volume, ft<sup>3</sup> 1.004 Initial 1.002 Final  
 @ Vac., in. Hg 8  
 Pitot 1.000 .000

Filter ID NA  
 Sample ID RUN 1 NCGonly

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS	
																0
A-1 B	0	18:24			967.500											
2	4		.59	1.3	970.1	416	95	237	250	250	66	2				
3	8		.60	1.3	972.8	416	95	238	252	252	63	2				
4	12		.61	1.3	975.5	415	95	238	255	255	63	2				
1 A	16	18:40	.55	1.3	978.1	415	95	238	254	254	61	2				
2	20	19:46	.55	1.3	981.0	416	96	237	250	250	64	2.5				
3	24		.49	1.3	983.4	416	96	238	251	251	62	2.5				
4	28		.43	1.3	986.1	415	96	239	252	252	63	2.5				
1 D	32	19:02	.37	1.3	988.8	415	95	240	251	251	64	3.5				
2	36	19:08	.70	1.3	991.5	415	94	235	250	250	66	3.5				
3	40		.69	1.3	994.1	417	94	236	251	251	65	3.5				
4	44		.48	1.3	997.3	417	94	235	250	250	66	2.5				
1 C	48	19:24	.40	1.3	999.5	415	94	236	252	252	65	2.5				
2	52	19:35	.74	1.3	1002.3	417	92	238	255	255	64	2.5				
3	56		.72	1.3	1004.7	416	92	239	256	256	63	2.5				
4	60		.70	1.3	1007.4	416	91	239	257	257	64	2.5				
4	64	19:51	.55	1.3	1016.143	414	91	240	256	256	64	3				
*Barometric Pressure is at port elevation			Avg ΔP	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>i</sub>	Avg T <sub>o</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-stc</sub>	
			1.74	1.3	42.643	415.68	44.06	235/246	250/257	250/257	66	3	66	3	scf	
			5.656	1.146	41.643	411	44.06	235/246	250/257	250/257	66	3	66	3	scf	

Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 % Isokinetic \_\_\_\_\_  
 Calculated by \_\_\_\_\_  
 QC by \_\_\_\_\_

Flue Gas Composition  
 O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A \_\_\_\_\_  
 Leak Check, Pre-run \_\_\_\_\_  
 Post-run \_\_\_\_\_

Oxygen, % \_\_\_\_\_  
 Carbon Dioxide, % \_\_\_\_\_  
 Moisture, % \_\_\_\_\_

15730.001.008  
 Pulp Dryer, Paper Machine,  
 #2-3 SPM, & #1-2 CBs  
 Emission Report



Integrated Air Services



# Isokinetic Field Data

# Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 1 Combination Boiler  
 Sample Location: Stack water  
 W. O. Number: 15730.001.008  
 Run Number: 2  
 Date: 6/23/21  
 Test Personnel: ATR/LL  
 Sample Time: 64 min.

Console ID: AG10  
 Meter Corr., Y: .488  
 Console ΔH@: 1.732  
 Probe ID/Length: PR5B 5'  
 Liner Material: SS  
 Pitot ID/Coeff.: P172 0.84  
 Thermo ID: AG16  
 Nozzle ID/Diams.: .256 .850 .280  
 Avg. Nozzle Diam.: .280 in.

Ambient Temp.: 80 °F  
 Baro. Pressure\*: 29.45 in. Hg  
 Static Pressure: -65 in. H<sub>2</sub>O  
 Impinger Gain: 153 mL  
 Silica Gel Gain: 12 g  
 Stack Area: 78.54 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: NA  
 Leak Checks: Initial NA Final NA  
 Volume, ft<sup>3</sup>: .005  
 @ Vac., in. Hg: 8  
 Pitot: .600  
 Filter ID: NA  
 Sample ID: Run 2 NCG only

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
A-1 B	0	8:19			10,400									
2	4	20:19	.58	1.3	13.0	412	89	236	236	257		65	2	
3	8		.59	1.3	15.9	411	84	237	237	257		64	2	
4	12		.60	1.3	18.4	410	88	238	238	256		61	2	
B-1 A	16	20:35	.46	1.3	21.2	410	88	234	234	255		56	2	
2	20	20:41	.51	1.3	22.4	413	87	238	238	254		57	2	
3	24		.50	1.3	26.6	413	87	239	239	255		55	2	
4	28		.45	1.3	28.9	411	86	239	239	256		56	2	
D-1 D	32	20:57	.36	1.3	31.5	410	86	240	240	255		56	2	
2	36	21:02	.71	1.3	34.3	412	86	236	236	256		62	2	
3	40		.69	1.3	36.9	412	86	235	235	255		59	2	
4	44		.48	1.3	39.5	413	84	236	236	253		58	2	
D-1 C	48	21:18	.39	1.3	42.6	410	83	235	235	254		59	2	
2	52	21:29	.75	1.3	45.1	411	81	236	236	253		59	2	
3	56		.71	1.3	47.5	411	81	235	235	254		60	2	
4	60	21:45	.71	1.3	49.9	412	81	235	235	255		66	2	
4	64	21:48	.53	1.3	52.5	416	81	236	236	256		61	2	

\*Barometric Pressure at port elevation: 7501  
 Avg ΔP: 7501  
 Avg ΔH: 1.3  
 Avg V<sub>ah</sub>: 1.140  
 Total Volume: 42.125  
 Avg T<sub>m</sub>: 85.1  
 Min/Max: 235/240  
 Min/Max: 253/257  
 O<sub>2</sub>: 20.9 by Orsat Fyrite M3A  
 Leak Check, Pre-run: Pass  
 Post-run: Pass  
 Flue Gas Composition: Oxygen, % 20.9; Carbon Dioxide, % 7.1; Moisture, % 71.1  
 Thermocouple Check: Meter Temp., °F 65; Ref. Temp., °F 65  
 O<sub>2</sub>, dscfm: 2  
 % Isokinetic: 2  
 Calculated by: NA  
 QC by: NA



Integrated Air Services



# Isokinetic Field Data

# Method: EPA 4, Moisture

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 1 Combination Boiler  
 Sample Location stack outlet  
 W. O. Number 15730.001.008  
 Run Number 3  
 Date 6/23/21  
 Test Personnel ATL/CL  
 Sample Time 64 min.

Console ID A010  
 Meter Corr., Y 1.488  
 Console ΔH@ 1.732  
 Probe ID/Length PR3B 5'  
 Liner Material 55  
 Pitot ID/Coeff. 0.172  
 Thermo ID A010  
 Nozzle ID/Diams. 0.250 in.  
 Avg. Nozzle Diam. 0.250 in.

Ambient Temp. 75 °F  
 Baro. Pressure\* 29.45 in. Hg  
 Static Pressure -65 in. H<sub>2</sub>O  
 Impinger Gain 166 mL  
 Silica Gel Gain 9.9 g  
 Stack Area 78.54 ft<sup>2</sup>  
 Total Traverse Points 16

K Factor NA  
 Leak Checks  
 Volume, ft<sup>3</sup> Initial Final  
 @ Vac., in. Hg 0.002 0.000  
 Pitot 8 5  
0.000 0.000

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS		
															0	4
φ-1 B	0	22:02			52.900			78	235	255		62	2			
2	4		0.60	1.3	55.5	417	78	235	234	253		59	2			
3	8		0.61	1.3	58.1	416	78	235	235	253		57	2			
4	12		0.59	1.3	60.6	415	78	235	235	254		57	2			
φ-1 A	16	22:18	0.45	1.3	63.3	411	78	235	235	254		57	2			
2	20	22:25	0.57	1.3	65.8	415	78	236	236	253		64	2			
3	24		0.50	1.3	68.3	415	78	237	237	252		58	2			
4	28		0.43	1.3	71.1	416	78	239	239	253		58	2			
φ-1 D	32	22:41	0.39	1.3	73.7	412	77	240	240	253		58	2			
2	36	22:47	0.73	1.3	76.2	417	77	240	240	256		63	2			
3	40		0.70	1.3	79.0	418	78	237	237	255		54	2			
4	44		0.48	1.3	81.6	417	78	238	238	254		54	2			
φ-1 C	48	23:03	0.42	1.3	84.1	416	78	239	239	255		55	2			
2	52	23:09	0.73	1.3	86.7	416	77	240	240	256		60	2			
3	56		0.70	1.3	89.3	415	77	242	242	255		57	2			
4	60		0.68	1.3	92.0	414	76	240	240	256		56	2			
4	64	23:25	0.57	1.3	94.564	412	76	239	239	255		56	2			
*Barometric Pressure is at port elevation			Avg VAP	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac			
			0.75245	1.13	41.764	415.10	77.56	230.42	252.125	255	256	69	2			
			0.57189	1.140												

Filter ID NA  
 Sample ID RUN 3 NCG only  
 O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run \_\_\_\_\_ Post-run \_\_\_\_\_  
 O<sub>2</sub> \_\_\_\_\_ CO<sub>2</sub> \_\_\_\_\_  
 Flue Gas Composition  
 Oxygen, % \_\_\_\_\_  
 Carbon Dioxide, % \_\_\_\_\_  
 Moisture, % \_\_\_\_\_  
 Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 % Isokinetic \_\_\_\_\_  
 Calculated by \_\_\_\_\_  
 QC by \_\_\_\_\_  
 Result \_\_\_\_\_





# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 1 Combination Boiler  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/23/21 Recovery Date 6/23/21  
 Sample ID Run 21 NCG only Filter ID NA Analyst ATR

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	806.1	745.3	651.3		942.4	
Initial	674.8	725.0	646.7	✓	933.1	
Gain	131.3 ✓	20.3 ✓	4.6 ✓	156.2	9.3	165.5

Impinger Color clear Labeled? ✓  
 Silica Gel Condition used Sealed? ✓

Run No. 2 Sample Date 6/23/21 Recovery Date 6/23/21  
 Sample ID Run 2 NCG only Filter ID NA Analyst ATR

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	898.4	751.2	639.3		897.6	
Initial	770	730.7	635.2	✓	885.6	
Gain	128.4 ✓	20.5 ✓	4.1 ✓	153	12	165

Impinger Color clear Labeled? ✓  
 Silica Gel Condition used Sealed? ✓

Run No. 3 Sample Date 6/23/21 Recovery Date 6/23/21  
 Sample ID Run 3 NCG Only Filter ID NA Analyst ATR

Contents	Impingers			Imp.Total	Silica Gel grams	Total
	1	2	3			
Final	843.1	761.2	655.2		841.8	
Initial	696.9	745.3	651.3	✓	882.0	
Gain	146.2 ✓	15.9 ✓	3.9 ✓	166	9.8	175.8

Impinger Color clear Labeled? ✓  
 Silica Gel Condition used Sealed? ✓

Check COC for Sample IDs of Media Blanks

*ATR*



# RUN SUMMARY

Number 4

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

**Start Time 18:24    End Time 19:24**

---

**Average Measured TRS Conc.**    0.58 ppm ✓  
**Recovery No. 3**    91.7 % ✓  
**TRS Corrected for Recovery**    0.63 ppm ✓

*KW*

# RUN SUMMARY

Number 5

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

**Start Time 20:19    End Time 21:19**

---

<b>Average Measured TRS Conc.</b>	<b>0.55 ppm</b> ✓
<b>Recovery No. 3</b>	<b>91.7 %</b> ✓
<b>TRS Corrected for Recovery</b>	<b>0.60 ppm</b> ✓

✓

# RUN SUMMARY

Number 6

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

Start Time 22:02    End Time 23:02

---

Average Measured TRS Conc.    0.61 ppm ✓  
Recovery No. 3                    91.7 % ✓  
TRS Corrected for Recovery    0.67 ppm ✓

*W*

# RUN DATA

Number 4

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
18:24	3	0.07	34	0.52	<2	<0.16	<2	<0.071	0.59
18:27	<2	<0.064	32	0.50	<2	<0.16	<2	<0.071	0.50
18:30	<2	<0.064	32	0.51	<2	<0.16	<2	<0.071	0.51
18:33	<2	<0.064	31	0.49	<2	<0.16	<2	<0.071	0.49
18:36	3	0.07	31	0.50	3	0.21	<2	<0.071	0.78
18:39	<2	<0.064	32	0.51	<2	<0.16	<2	<0.071	0.51
18:42	<2	<0.064	32	0.51	<2	<0.16	<2	<0.071	0.51
18:45	<2	<0.064	33	0.52	<2	<0.16	<2	<0.071	0.52
18:48	<2	<0.064	32	0.50	<2	<0.16	<2	<0.071	0.50
18:51	<2	<0.064	34	0.52	<2	<0.16	4	0.10	0.72
18:54	<2	<0.064	33	0.52	<2	<0.16	<2	<0.071	0.52
18:57	<2	<0.064	34	0.52	<2	<0.16	<2	<0.071	0.52
19:00	2	0.07	36	0.53	<2	<0.16	<2	<0.071	0.60
19:03	<2	<0.064	36	0.54	<2	<0.16	<2	<0.071	0.54
19:06	2	0.06	34	0.53	2	0.18	<2	<0.071	0.77
19:09	3	0.07	35	0.53	<2	<0.16	<2	<0.071	0.60
19:12	<2	<0.064	35	0.53	<2	<0.16	<2	<0.071	0.53
19:15	<2	<0.064	35	0.53	<2	<0.16	<2	<0.071	0.53
19:18	2	0.07	35	0.53	<2	<0.16	2	0.08	0.75
19:21	2	0.07	36	0.54	<2	<0.16	<2	<0.071	0.61
<b>Average</b>		<b>&lt;0.064</b>		<b>0.52</b>		<b>&lt;0.16</b>		<b>&lt;0.071</b>	<b>0.58</b> ✓

# RUN DATA

Number 5

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
20:19	2	0.06	32	0.51	<2	<0.16	<2	<0.071	0.57
20:22	<2	<0.064	29	0.48	<2	<0.16	<2	<0.071	0.48
20:25	<2	<0.064	31	0.50	<2	<0.16	<2	<0.071	0.50
20:28	<2	<0.064	33	0.51	<2	<0.16	<2	<0.071	0.51
20:31	<2	<0.064	33	0.52	<2	<0.16	<2	<0.071	0.52
20:34	<2	<0.064	32	0.51	<2	<0.16	<2	<0.071	0.51
20:37	<2	<0.064	32	0.50	<2	<0.16	<2	<0.071	0.50
20:40	<2	<0.064	33	0.51	<2	<0.16	<2	<0.071	0.51
20:43	<2	<0.064	33	0.52	<2	<0.16	<2	<0.071	0.52
20:46	<2	<0.064	33	0.51	4	0.24	6	0.13	1.01
20:49	<2	<0.064	34	0.52	<2	<0.16	<2	<0.071	0.52
20:52	<2	<0.064	32	0.50	<2	<0.16	<2	<0.071	0.50
20:55	3	0.08	35	0.53	<2	<0.16	<2	<0.071	0.61
20:58	<2	<0.064	34	0.52	<2	<0.16	<2	<0.071	0.52
21:01	<2	<0.064	35	0.53	<2	<0.16	<2	<0.071	0.53
21:04	<2	<0.064	34	0.52	<2	<0.16	<2	<0.071	0.52
21:07	<2	<0.064	36	0.54	<2	<0.16	<2	<0.071	0.54
21:10	<2	<0.064	37	0.54	<2	<0.16	<2	<0.071	0.54
21:13	<2	<0.064	39	0.56	<2	<0.16	<2	<0.071	0.56
21:16	3	0.08	34	0.52	<2	<0.16	<2	<0.071	0.60
<b>Average</b>		<b>&lt;0.064</b>		<b>0.52</b>		<b>&lt;0.16</b>		<b>&lt;0.071</b>	<b>0.55</b> ✓

*Handwritten mark*



# RUN DATA

Number 6

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
22:02	<2	<0.064	31	0.49	<2	<0.16	<2	<0.071	0.49
22:05	<2	<0.064	33	0.52	<2	<0.16	<2	<0.071	0.52
22:08	<2	<0.064	32	0.51	<2	<0.16	<2	<0.071	0.51
22:11	<2	<0.064	31	0.50	<2	<0.16	<2	<0.071	0.50
22:14	2	0.07	33	0.51	<2	<0.16	<2	<0.071	0.58
22:17	<2	<0.064	34	0.52	<2	<0.16	<2	<0.071	0.52
22:20	<2	<0.064	34	0.52	<2	<0.16	<2	<0.071	0.52
22:23	<2	<0.064	36	0.54	2	0.17	<2	<0.071	0.71
22:26	<2	<0.064	35	0.53	5	0.28	<2	<0.071	0.81
22:29	<2	<0.064	33	0.52	<2	<0.16	<2	<0.071	0.52
22:32	<2	<0.064	34	0.52	<2	<0.16	<2	<0.071	0.52
22:35	<2	<0.064	35	0.53	<2	<0.16	<2	<0.071	0.53
22:38	3	0.07	35	0.53	<2	<0.16	<2	<0.071	0.60
22:41	2	0.07	35	0.53	<2	<0.16	2	0.08	0.76
22:44	2	0.07	36	0.54	3	0.19	<2	<0.071	0.80
22:47	<2	<0.064	36	0.53	3	0.19	<2	<0.071	0.72
22:50	<2	<0.064	36	0.54	3	0.20	2	0.07	0.88
22:53	<2	<0.064	36	0.54	<2	<0.16	3	0.09	0.72
22:56	<2	<0.064	37	0.54	<2	<0.16	<2	<0.071	0.54
22:59	<2	<0.064	37	0.55	<2	<0.16	<2	<0.071	0.55
<b>Average</b>		<b>&lt;0.064</b>		<b>0.53</b>		<b>&lt;0.16</b>		<b>&lt;0.071</b>	<b>0.61</b> ✓

*Handwritten signature*

# RUN DATA

Number 7

15730.001.008  
Pulp Dryer, #3 Paper Machine,  
#2-3 SDTVs, & #1-2 CBs  
Emission Report

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **2**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
<b>CC416806 7.257 ppm</b>									
12:28	14344	7.79	<2	<0.12	<2	<0.077	<2	<0.036	7.79
12:31	14847	7.94	<2	<0.12	<2	<0.077	<2	<0.036	7.94
12:34	15003	7.98	<2	<0.12	2	0.09	<2	<0.036	8.07
<b>Average</b>		<b>7.90</b>		<b>&lt;0.12</b>		<b>&lt;0.077</b>		<b>&lt;0.036</b>	<b>7.93</b>

# RECOVERY DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

**Before Run 1**  
**Start Time 08:30    End Time 08:43**

---

**Recovery Gas to Probe, Time 08:30**

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
11433	11272	11506	11403 ✓	7.65

---

**Recovery Gas to GC, Time 08:40**

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
13047	13101	13148	13098 ✓	8.26

---

**Recovery 92.6%** ✓

---

✓

# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

**After Run 3    Before Run 4**  
**Start Time 16:45    End Time 17:12**

## Recovery Gas to Probe, Time 16:45

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
10559	10796	10726	10694	/7.38

## Recovery Gas to GC, Time 17:07

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
14018	13986	14003	14002	/8.57

**Recovery 86.2%** ✓

↗

# RECOVERY DATA

Number 3

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

**After Run 6    Before Run 7**  
**Start Time 23:08    End Time 23:33**

## Recovery Gas to Probe, Time 23:08

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
12008	11871	12366	12082	7.90

## Recovery Gas to GC, Time 23:30

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
14235	14081	14105	14141	8.62

**Recovery 91.7%**

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

Ambient Temperature: 72°C

Barometric Pressure: 29.25 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51828	33-53274	89-53332	89-53266
Perm. Rate, nL/min	351	369	477	241
Ret. Time, sec	16.0	22.5	48.0	127.0

1 Flow = 27.4 mL/Min      12.8 ppm      13.5 ppm      17.4 ppm      8.81 ppm

Time: 06:00

Peak Areas, mv-sec

28200	16074	not used	not used
27714	15989	used	used
27544	15970		
<b>Average Area</b>	<b>27819</b> ✓	<b>16011</b> ✓	

2 Flow = 59.5 mL/Min      5.90 ppm      6.20 ppm      8.02 ppm      4.06 ppm

Time: 06:49

Peak Areas, mv-sec

7504	3841	12348	15296
7611	3774	12960	15012
7641	3823	12909	15325
<b>Average Area</b>	<b>7585</b> ✓	<b>3813</b> ✓	<b>12739</b> ✓

3 Flow = 131 mL/Min      2.68 ppm      2.82 ppm      3.64 ppm      1.84 ppm

Time: 07:28

Peak Areas, mv-sec

1734	856	2868	3422
1702	845	2771	3379
1690	846	2788	3411
<b>Average Area</b>	<b>1709</b> ✓	<b>849</b> ✓	<b>2809</b> ✓

4 Flow = 271 mL/Min      1.30 ppm      1.36 ppm      1.76 ppm      0.89 ppm

Time: 07:53

Peak Areas, mv-sec

440	204	681	847
433	209	682	842
472	206	671	834
<b>Average Area</b>	<b>448</b> ✓	<b>206</b> ✓	<b>678</b> ✓



# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

Method **16**

H <sub>2</sub> S	1	2	3	4		
Time	06:00	06:49	07:28	07:53		
Concentration, ppm	12.8	5.90	2.68	1.30		
Area, mv-sec	27819	7585	1709	448		
Calc. Conc., ppm	12.5	6.11	2.68	1.28		
% Error	-2.3	3.5	0.0	-1.2		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.8102	2.4572	0.9997	2	0.064	

MeSH	1	2	3	4		
Time	06:00	06:49	07:28	07:53		
Concentration, ppm	13.5	6.20	2.82	1.36		
Area, mv-sec	16011	3813	849	206		
Calc. Conc., ppm	13.3	6.26	2.84	1.35		
% Error	-0.9	1.0	0.9	-0.9		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>	
	1.8989	2.0680	0.9999	2	0.12	

DMS	1	2	3		
Time	06:49	07:28	07:53		
Concentration, ppm	8.02	3.64	1.76		
Area, mv-sec	12739	2809	678		
Calc. Conc., ppm	17.6	7.86	3.68		
% Error	119.4	115.7	109.0		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8747	1.7700	0.9997	2	0.16

DMDS	1	2	3		
Time	06:49	07:28	07:53		
Concentration, ppm	4.06	1.84	0.89		
Area, mv-sec	15211	3404	841		
Calc. Conc., ppm	8.91	3.97	1.86		
% Error	119.6	115.3	109.2		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8501	2.4250	0.9997	2	0.071

*Handwritten mark*

# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Ambient Temperature: 72°C

Barometric Pressure: 29.25 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51828	33-53274	89-53332	89-53266
Perm. Rate, nL/min	351	369	477	241
Ret. Time, sec	16.0	22.5	48.0	127.0

**1** Flow = 37.6 mL/Min      **9.34 ppm**      **9.81 ppm**      **12.7 ppm**      **6.42 ppm**

Time: 07:00

Peak Areas, mv-sec

	19790	9921	31382	38948
	20319	10076	31742	38693
	19852	9986	30214	37936
<u>Average Area</u>	<b>19987</b> ✓	<b>9995</b> ✓	<b>31113</b> ✓	<b>38526</b> ✓

**2** Flow = 82.8 mL/Min      **4.24 ppm**      **4.46 ppm**      **5.77 ppm**      **2.92 ppm**

Time: 11:03

Peak Areas, mv-sec

	4788	2266	7435	8918
	4588	2209	7188	8687
	4419	2218	7198	8791
<u>Average Area</u>	<b>4598</b> ✓	<b>2231</b> ✓	<b>7274</b> ✓	<b>8798</b> ✓

**3** Flow = 180 mL/Min      **1.95 ppm**      **2.05 ppm**      **2.66 ppm**      **1.34 ppm**

Time: 11:47

Peak Areas, mv-sec

	998	492	1607	1968
	985	496	1607	1963
	982	497	1614	1971
<u>Average Area</u>	<b>988</b> ✓	<b>495</b> ✓	<b>1609</b> ✓	<b>1967</b> ✓

# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

H <sub>2</sub> S	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	9.34	4.24	1.95		
Area, mv-sec	19987	4598	988		
Calc. Conc., ppm	9.26	4.31	1.94		
% Error	-0.8	1.6	-0.8		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9212	2.4433	0.9998	2	0.077

MeSH	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	9.81	4.46	2.05		
Area, mv-sec	9995	2231	495		
Calc. Conc., ppm	9.79	4.48	2.05		
% Error	-0.3	0.5	-0.3		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9203	2.0975	>0.9999	2	0.12

DMS	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	12.7	5.77	2.66		
Area, mv-sec	31113	7274	1609		
Calc. Conc., ppm	12.6	5.85	2.64		
% Error	-0.7	1.4	-0.7		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8927	2.4098	0.9999	2	0.077

DMDS	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	6.42	2.92	1.34		
Area, mv-sec	38526	8798	1967		
Calc. Conc., ppm	6.39	2.94	1.34		
% Error	-0.4	0.8	-0.4		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9009	3.0543	>0.9999	2	0.036

*M*

# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
<b>Molecular Weight</b>	34.08	48.11	62.14	94.20
<b>Retention Time, sec</b>	16.0	22.5	48.0	127.0
<b>Peak Detection Window, sec</b>	3.0	7.0	10.0	10.0
<b>Minimum Peak Area, mv-sec</b>	2	2	2	2
<b>Minimum Peak Height, mv</b>	1	1	1	1
<b>Beginning Peak Width, sec</b>	1.0	1.0	2.0	3.0
<b>Ending Peak Width, sec</b>	2.0	6.0	4.0	5.0
<b>Permeation Device ID</b>	T-51828	33-53274	89-53332	89-53266
<b>Permeation Rate, ng/min</b>	483	716	1197	918
<b>Permeation Rate, nL/min*</b>	351	369	477	241

**Barometric Pressure:** 29.25 in. Hg    **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**PR<sub>ng</sub>** = Permeation Rate by weight, ng/min

**V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole

**W<sub>mol</sub>** = Molecular Weight of compound

**T<sub>a</sub>** = Ambient Temperature, °F

**T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)

**P<sub>s</sub>** = Standard Pressure = 29.92 in Hg

**P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 483 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.25) = 351 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

**C** = Concentration, ppmv

**PR<sub>nl</sub>** = Permeation Rate by volume, nL/min

**F<sub>d</sub>** = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#1 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **22 Jun 2021**

File: C:\Data\210623 New Indy Catawba No. 1 CB.trs  
Program Version: 2.0, built 15 May 2017 File Version: 2.0  
Computer: WLT5 Trailer: 281

Analog Input Device: MCC USB-1608G GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: Shimadzu GC8-A Serial No. C10493615061  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 140	Primary: Carbopack
Air	30	60	Detector: 140	Secondary: N/A
Carrier	50	30		Sample Loop: 4"

## Injection Cycle

Total Length: 180 sec Sampling Time: 170 sec Load/Backflush Time: 80 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 2 mv-sec Minimum peak height 1 mv above baseline

## Dynacalibrator

Chamber Temperature 50.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.25 in. Hg

# RUN SUMMARY

Number 4

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **23 Jun 2021**

Method Conc. Units	O <sub>2</sub> EPA 3A %	CO <sub>2</sub> EPA 3A %	SO <sub>2</sub> EPA 6C ppm
-----------------------	-------------------------------	--------------------------------	----------------------------------

Time: 18:24 to 19:24

### Run Averages

11.2            8.2            304

### Pre-run Bias at 16:43

Zero Bias	0.0	0.0	8
Span Bias	10.0	10.1	234
Span Gas	10.1	10.2	242

### Post-run Bias at 19:27

Zero Bias	0.0	0.0	7
Span Bias	10.0	10.1	240
Span Gas	10.1	10.2	242

Run averages corrected for the average of the pre-run and post-run bias

11.4 ✓            8.3 ✓            313 ✓

✓

# RUN SUMMARY

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Method Conc. Units	O <sub>2</sub> EPA 3A %	CO <sub>2</sub> EPA 3A %	SO <sub>2</sub> EPA 6C ppm
-----------------------	-------------------------------	--------------------------------	----------------------------------

Time: 20:19 to 21:19

### Run Averages

11.7	7.7	342
------	-----	-----

### Pre-run Bias at 19:27

Zero Bias	0.0	0.0	7
Span Bias	10.0	10.1	240
Span Gas	10.1	10.2	242

### Post-run Bias at 21:26

Zero Bias	0.0	0.0	4
Span Bias	10.0	10.1	240
Span Gas	10.1	10.2	242

Run averages corrected for the average of the pre-run and post-run bias

11.9 ✓	7.8 ✓	348 ✓
--------	-------	-------



# RUN SUMMARY

Number 6

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **23 Jun 2021**

Method Conc. Units	O <sub>2</sub> EPA 3A %	CO <sub>2</sub> EPA 3A %	SO <sub>2</sub> EPA 6C ppm
-----------------------	-------------------------------	--------------------------------	----------------------------------

Time: 22:02 to 23:02

### Run Averages

11.5            8.1            340

### Pre-run Bias at 21:26

Zero Bias	0.0	0.0	4
Span Bias	10.0	10.1	240
Span Gas	10.1	10.2	242

### Post-run Bias at 23:05

Zero Bias	0.0	0.0	3
Span Bias	10.0	10.2	234
Span Gas	10.1	10.2	242

Run averages corrected for the average of the pre-run and post-run bias

11.6 ✓            8.1 ✓            349 ✓

*Handwritten signature*

# RUN DATA

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
<b>With NCGs</b>						
18:25	3619	10.9	3462	8.6	2834	283
18:26	3597	10.8	3490	8.6	2890	289
18:27	3632	10.9	3514	8.7	3019	302
18:28	3736	11.2	3454	8.6	2939	294
18:29	3743	11.2	3343	8.3	2831	283
18:30	3786	11.4	3340	8.3	2799	280
18:31	3778	11.4	3290	8.1	2774	278
18:32	3808	11.4	3289	8.1	2802	280
18:33	3735	11.2	3268	8.1	2860	286
18:34	3656	11.0	3362	8.3	3089	309
18:35	3609	10.8	3449	8.5	3124	312
18:36	3645	11.0	3484	8.6	3073	307
18:37	3785	11.4	3424	8.5	2834	283
18:38	3777	11.4	3290	8.1	2904	290
18:39	3804	11.4	3285	8.1	2907	291
18:40	3718	11.2	3264	8.1	2895	290
18:41	3690	11.1	3351	8.3	3093	309
18:42	3686	11.1	3407	8.4	3117	312
18:43	3696	11.1	3388	8.4	3011	301
18:44	3722	11.2	3371	8.3	3035	304
18:45	3805	11.4	3340	8.3	2989	299
18:46	3854	11.6	3235	8.0	2951	295
18:47	3785	11.4	3209	7.9	2977	298
18:48	3779	11.4	3286	8.1	2943	294
18:49	3850	11.6	3265	8.1	3179	318
18:50	3762	11.3	3224	8.0	3171	317
18:51	3752	11.3	3303	8.2	3078	308
18:52	3743	11.2	3328	8.2	2932	293
18:53	3767	11.3	3329	8.2	2943	294
18:54	3817	11.5	3300	8.2	2907	291
18:55	3971	11.9	3223	8.0	2931	293
18:56	3965	11.9	3060	7.6	3159	316
18:57	3931	11.8	3059	7.6	3147	315
18:58	3776	11.3	3123	7.7	3151	315
18:59	3823	11.5	3263	8.1	2999	300
19:00	3894	11.7	3204	7.9	2846	285
19:01	3840	11.5	3146	7.8	2853	285
19:02	3800	11.4	3212	8.0	2855	286
19:03	3845	11.6	3258	8.1	3066	307
19:04	3895	11.7	3188	7.9	3102	310

# RUN DATA

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
19:05	3903	11.7	3137	7.8	3182	318
19:06	3929	11.8	3117	7.7	3008	301
19:07	3885	11.7	3108	7.7	2900	290
19:08	3825	11.5	3165	7.8	2940	294
19:09	3735	11.2	3242	8.0	2885	289
19:10	3711	11.2	3328	8.2	3079	308
19:11	3631	10.9	3363	8.3	3211	321
19:12	3560	10.7	3452	8.5	3362	336
19:13	3537	10.6	3508	8.7	3482	348
19:14	3508	10.5	3541	8.8	3373	337
19:15	3551	10.7	3564	8.8	3320	332
19:16	3619	10.9	3505	8.7	3287	329
19:17	3665	11.0	3436	8.5	3239	324
19:18	3700	11.1	3387	8.4	3060	306
19:19	3660	11.0	3378	8.4	3177	318
19:20	3705	11.1	3392	8.4	3291	329
19:21	3721	11.2	3370	8.3	3272	327
19:22	3700	11.1	3333	8.3	3148	315
19:23	3610	10.8	3373	8.4	3082	308
19:24	3517	10.6	3499	8.7	3096	310
<b>Avg</b>	<b>3742</b>	<b>11.2</b>	<b>3321</b>	<b>8.2</b>	<b>3040</b>	<b>304</b>

# RUN DATA

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
<b>With NCGs</b>						
20:20	3956	11.9	3038	7.5	3579	358
20:21	3924	11.8	3098	7.7	3395	340
20:22	3929	11.8	3122	7.7	3279	328
20:23	4008	12.0	3112	7.7	3315	332
20:24	4084	12.3	3018	7.5	3351	335
20:25	4065	12.2	2954	7.3	3630	363
20:26	4084	12.3	2958	7.3	3573	357
20:27	4072	12.2	2961	7.3	3514	351
20:28	4153	12.5	2959	7.3	3362	336
20:29	4171	12.5	2872	7.1	3369	337
20:30	4044	12.2	2857	7.1	3410	341
20:31	3988	12.0	2950	7.3	3362	336
20:32	3990	12.0	2998	7.4	3267	327
20:33	3969	11.9	2992	7.4	3560	356
20:34	3943	11.8	3019	7.5	3537	354
20:35	3971	11.9	3035	7.5	3592	359
20:36	3934	11.8	3019	7.5	3468	347
20:37	3991	12.0	3044	7.5	3319	332
20:38	4000	12.0	2989	7.4	3404	340
20:39	3953	11.9	2981	7.4	3454	345
20:40	3971	11.9	3036	7.5	3310	331
20:41	4056	12.2	3000	7.4	3318	332
20:42	4112	12.4	2902	7.2	3348	335
20:43	4009	12.0	2864	7.1	3545	355
20:44	4022	12.1	2939	7.3	3770	377
20:45	4027	12.1	2902	7.2	3729	373
20:46	4034	12.1	2870	7.1	3641	364
20:47	3964	11.9	2843	7.0	3487	349
20:48	3886	11.7	2936	7.3	3469	347
20:49	3797	11.4	3030	7.5	3553	355
20:50	3801	11.4	3109	7.7	3451	345
20:51	3768	11.3	3120	7.7	3428	343
20:52	3639	10.9	3223	8.0	3434	343
20:53	3636	10.9	3370	8.3	3400	340
20:54	3766	11.3	3370	8.3	3361	336
20:55	3847	11.6	3259	8.1	3411	341
20:56	3799	11.4	3185	7.9	3420	342
20:57	3728	11.2	3255	8.1	3504	350
20:58	3684	11.1	3338	8.3	3512	351
20:59	3656	11.0	3394	8.4	3477	348

# RUN DATA

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
21:00	3787	11.4	3427	8.5	3314	331
21:01	3885	11.7	3278	8.1	3325	333
21:02	3882	11.7	3206	7.9	3290	329
21:03	3886	11.7	3198	7.9	3331	333
21:04	3864	11.6	3209	7.9	3355	336
21:05	3808	11.4	3226	8.0	3328	333
21:06	3745	11.3	3295	8.2	3338	334
21:07	3685	11.1	3379	8.4	3344	334
21:08	3694	11.1	3433	8.5	3353	335
21:09	3773	11.3	3427	8.5	3305	331
21:10	3853	11.6	3327	8.2	3342	334
21:11	3950	11.9	3240	8.0	3311	331
21:12	4017	12.1	3118	7.7	3392	339
21:13	3936	11.8	3052	7.6	3427	343
21:14	3850	11.6	3122	7.7	3324	332
21:15	3843	11.5	3208	7.9	3376	338
21:16	3806	11.4	3212	8.0	3385	339
21:17	3814	11.5	3259	8.1	3365	337
21:18	3661	11.0	3273	8.1	3347	335
21:19	3639	10.9	3428	8.5	3435	344
<b>Avg</b>	<b>3897</b>	<b>11.7</b>	<b>3121</b>	<b>7.7</b>	<b>3422</b>	<b>342</b>

# RUN DATA

Number 6

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
<b>With NCGs</b>						
22:03	3783	11.4	3378	8.4	3499	350
22:04	3827	11.5	3287	8.1	3478	348
22:05	3799	11.4	3284	8.1	3441	344
22:06	3903	11.7	3265	8.1	3620	362
22:07	3885	11.7	3171	7.8	3452	345
22:08	3946	11.9	3173	7.9	3625	362
22:09	3995	12.0	3108	7.7	3377	338
22:10	3937	11.8	3066	7.6	3743	374
22:11	3913	11.8	3121	7.7	3484	348
22:12	3919	11.8	3149	7.8	3695	369
22:13	4001	12.0	3130	7.7	3397	340
22:14	3960	11.9	3053	7.6	3731	373
22:15	3924	11.8	3096	7.7	3490	349
22:16	3988	12.0	3134	7.8	3681	368
22:17	3995	12.0	3061	7.6	3401	340
22:18	3987	12.0	3050	7.5	3693	369
22:19	3942	11.8	3042	7.5	3534	353
22:20	3863	11.6	3099	7.7	3747	375
22:21	3882	11.7	3164	7.8	3551	355
22:22	3836	11.5	3156	7.8	3682	368
22:23	3719	11.2	3226	8.0	3364	336
22:24	3661	11.0	3350	8.3	3814	381
22:25	3671	11.0	3422	8.5	3662	366
22:26	3758	11.3	3379	8.4	3452	345
22:27	3744	11.3	3303	8.2	3443	344
22:28	3664	11.0	3344	8.3	3567	357
22:29	3639	10.9	3427	8.5	3384	338
22:30	3708	11.1	3438	8.5	3441	344
22:31	3762	11.3	3362	8.3	3397	340
22:32	3760	11.3	3302	8.2	3484	348
22:33	3739	11.2	3320	8.2	3207	321
22:34	3794	11.4	3316	8.2	3418	342
22:35	3790	11.4	3259	8.1	3201	320
22:36	3766	11.3	3282	8.1	3358	336
22:37	3843	11.5	3292	8.2	3155	316
22:38	3806	11.4	3222	8.0	3431	343
22:39	3791	11.4	3260	8.1	3226	323
22:40	3770	11.3	3282	8.1	3436	344
22:41	3739	11.2	3297	8.2	3194	319
22:42	3751	11.3	3334	8.3	3436	344

# RUN DATA

Number 6

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
22:43	3700	11.1	3326	8.2	3191	319
22:44	3696	11.1	3400	8.4	3382	338
22:45	3748	11.3	3372	8.3	3201	320
22:46	3738	11.2	3342	8.3	3358	336
22:47	3778	11.4	3339	8.3	3122	312
22:48	3787	11.4	3295	8.2	3252	325
22:49	3747	11.3	3299	8.2	3253	325
22:50	3784	11.4	3320	8.2	3166	317
22:51	3745	11.3	3311	8.2	3005	301
22:52	3796	11.4	3327	8.2	3280	328
22:53	3776	11.3	3279	8.1	3106	311
22:54	3785	11.4	3286	8.1	3386	339
22:55	3843	11.5	3277	8.1	3171	317
22:56	3787	11.4	3233	8.0	3267	327
22:57	3858	11.6	3256	8.1	3106	311
22:58	3805	11.4	3208	7.9	3292	329
22:59	3790	11.4	3271	8.1	3170	317
23:00	3860	11.6	3270	8.1	3222	322
23:01	3883	11.7	3196	7.9	3166	317
23:02	3897	11.7	3187	7.9	3246	325
<b>Avg</b>	<b>3816</b>	<b>11.5</b>	<b>3253</b>	<b>8.1</b>	<b>3396</b>	<b>340</b>



# BIAS AND CALIBRATION DRIFT

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 16:43

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	6	0.0	0.0	0.0 ✓	Pass
Span	10.1	3335	10.0	-0.1	-0.5 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	6	0.0	0.0 ✓	Pass	
Span	10.0	3335	10.0	0.0 ✓	Pass	

\*Bias No. 4

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	12	0.0	0.0	0.0 ✓	Pass
Span	10.2	4067	10.1	-0.1	-0.5 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	12	0.0	0.0 ✓	Pass	
Span	10.2	4067	10.1	-0.1	-0.5 ✓	Pass

\*Bias No. 4

*Handwritten mark*

# BIAS AND CALIBRATION DRIFT

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 16:43

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	1	79	8	7	1.5	Pass
Span	239	2341	234	-5	-1.1	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status	
Gas	ppm	mv	ppm	%		
Zero	5	79	8	3	0.7	Pass
Span	232	2341	234	2	0.4	Pass

\*Bias No. 4

# BIAS AND CALIBRATION DRIFT

Number 6

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 19:27

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	8	0.0	0.0	0.0 ✓	Pass
Span	10.1	3314	10.0	-0.1	-0.5 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	8	0.0	0.0 ✓	Pass	
Span	10.0	3314	10.0	0.0 ✓	Pass	

\*Bias No. 5

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	5	0.0	0.0	0.0 ✓	Pass
Span	10.2	4061	10.1	-0.1	-0.5 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	5	0.0	0.0 ✓	Pass	
Span	10.1	4061	10.1	0.0 ✓	Pass	

\*Bias No. 5

# BIAS AND CALIBRATION DRIFT

Number 6

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 19:27

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	1	70	7	6	1.3 ✓	Pass
Span	239	2397	240	1	0.2 ✓	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status	
Gas	ppm	mv	ppm	%		
Zero	8	70	7	-1	-0.2 ✓	Pass
Span	234	2397	240	6	1.3 ✓	Pass

\*Bias No. 5

# BIAS AND CALIBRATION DRIFT

Number 7

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 21:26

**O<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.2 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	2	0.0	0.0	0.0 ✓	Pass
Span	10.1	3323	10.0	-0.1	-0.5 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	2	0.0	0.0 ✓	Pass	
Span	10.0	3323	10.0	0.0 ✓	Pass	

\*Bias No. 6

**CO<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.3 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	6	0.0	0.0	0.0 ✓	Pass
Span	10.2	4056	10.1	-0.1	-0.5 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	6	0.0	0.0 ✓	Pass	
Span	10.1	4056	10.1	0.0 ✓	Pass	

\*Bias No. 6

# BIAS AND CALIBRATION DRIFT

Number 7

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 21:26

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	1	40	4	3	0.7	Pass
Span	239	2396	240	1	0.2	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	ppm	mv	ppm	%	
Zero	7	40	4	-0.7	Pass
Span	240	2396	240	0.0	Pass

\*Bias No. 6

# BIAS AND CALIBRATION DRIFT

Number 8

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 23:05

O<sub>2</sub>

Method: EPA 3A  
Span Conc. 20.2 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	8	0.0	0.0	0.0 ✓	Pass
Span	10.1	3341	10.0	-0.1	-0.5 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	8	0.0	0.0 ✓	Pass	
Span	10.0	3341	10.0	0.0 ✓	Pass	

\*Bias No. 7

CO<sub>2</sub>

Method: EPA 3A  
Span Conc. 20.3 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	21	0.0	0.0	0.0 ✓	Pass
Span	10.2	4100	10.2	0.0	0.0 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	21	0.0	0.0 ✓	Pass	
Span	10.1	4100	10.2	0.1 ✓	Pass	

\*Bias No. 7

*Handwritten signature*



# BIAS AND CALIBRATION DRIFT

Number 8

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 23:05

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	1	29	3	2	0.4 ✓	Pass
Span	239	2337	234	-5	-1.1 ✓	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status	
Gas	ppm	mv	ppm	%		
Zero	4	29	3	-1	-0.2 ✓	Pass
Span	240	2337	234	-6	-1.3 ✓	Pass

\*Bias No. 7

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 08:37

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	3
10.1 ✓	XC013544B	3354
20.2 ✓	CC275468	6750

Curve Coefficients

Slope	Intercept	Corr. Coeff.
333.3 ✓	-7 ✓	>0.9999 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	4
10.2 ✓	XC013544B	4128
20.3 ✓	CC275468	8145

Curve Coefficients

Slope	Intercept	Corr. Coeff.
401.6 ✓	18 ✓	>0.9999 ✓

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

Start Time: 08:37

**SO<sub>2</sub>**  
Method: EPA 6C  
Calibration Type: Linear Regression

---

Calibration Results		
ppm	Cylinder ID	Result, mv
Zero	-	9
242	CC234516	2392
458	EB0108003	4596

---

Curve Coefficients		
Slope	Intercept	Corr. Coeff.
10.01	-5	0.9999

---

---

*Handwritten signature*

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Start Time: 08:37

**O<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.2 %

Slope 333.3

Intercept -6.7

Standard %	Response mv	Result %	Difference %	Error %	Status
Zero	3	0.0	0.0	0.0 ✓	Pass
10.1	3354	10.1	0.0	0.0 ✓	Pass
20.2	6750	20.3	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.3 %

Slope 401.6

Intercept 18.5

Standard %	Response mv	Result %	Difference %	Error %	Status
Zero	4	0.0	0.0	0.0 ✓	Pass
10.2	4128	10.2	0.0	0.0 ✓	Pass
20.3	8145	20.2	-0.1	-0.5 ✓	Pass

**SO<sub>2</sub>**

Method: EPA 6C

Span Conc. 458 ppm

Slope 10.01

Intercept -5

Standard ppm	Response mv	Result ppm	Difference ppm	Error %	Status
Zero	9	1	1	0.2 ✓	Pass
242	2392	239	-3	-0.7 ✓	Pass
458	4596	459	1	0.2 ✓	Pass

# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

---

**File:** K:\15730 New Indy\001 Catawba SC\008\Data\210623 New Indy Catawba No. 1 CBb.com  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** WSAUBCHEMLABGC1 **Trailer:** 281  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	O <sub>2</sub>
Method	EPA 3A, Using Bias
Analyzer Make, Model & Serial No.	Teledyne T802 s/n: 172
Full-Scale Output, mv	10000
Analyzer Range, %	25.0
Span Concentration, %	20.2

## Channel 2

Analyte	CO <sub>2</sub>
Method	EPA 3A, Using Bias
Analyzer Make, Model & Serial No.	Teledyne T802 s/n: 172
Full-Scale Output, mv	10000
Analyzer Range, %	25.0
Span Concentration, %	20.3

## Channel 5

Analyte	SO <sub>2</sub>
Method	EPA 6C, Using Bias
Analyzer Make, Model & Serial No.	Teledyne T100H SN 374
Full-Scale Output, mv	10000
Analyzer Range, ppm	500
Span Concentration, ppm	458



**No. 2 COMBINATION BOILER  
(CONDITION 1: NCG AND SOG GASES)**

New Indy  
Catawba, SC

15730.001.008  
No. 2 Combination Boiler  
Condition 1: NCGs & SOGs

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
<b>Date</b>	6/24/21 ✓	6/24/21 ✓	6/24/21 ✓	---
<b>Time Began</b>	1445 ✓	1630 ✓	1806 ✓	---
<b>Time Ended</b>	1545 ✓	1730 ✓	1906 ✓	---
Volumetric Flow Rate, (Qs), DSCFM	1.57E+05 ✓	1.56E+05 ✓	1.54E+05 ✓	1.56E+05
BWS	0.135 ✓	0.141 ✓	0.148 ✓	0.141
% Oxygen	13.1 ✓	12.7 ✓	12.3 ✓	12.7
<hr/>				
<b>Sulfur Dioxide</b>	MW= 64.06			
Concentration, ppm	324.0 ✓	327.0 ✓	322.0 ✓	324.3
Emission Rate, lb/hr	508.7	507.2	496.1	504.0
<hr/>				
<b>Total Reduced Sulfur</b>	(TRS MW)= 34.08			
Concentration, ppm	0.92 ✓	0.76 ✓	0.77 ✓	0.82
Emission Rate, lb/hr	0.77	0.63	0.63	0.68

*M*



New Indy  
Catawba, SC

15730.001.008  
No. 2 Combination Boiler

**Condition 1: NCGs & SOGs**

**ISOKINETIC CALCULATIONS**

Run Number	1	2	3	Mean
Date	6/24/21 ✓	6/24/21 ✓	6/24/21 ✓	---
Time Began	1445 ✓	1630 ✓	1806 ✓	---
Time Ended	1607 ✓	1754 ✓	1931 ✓	---

**INPUT DATA**

Sampling Time, min	(Theta)	64.0 ✓	64 ✓	64 ✓	64
Stack Diameter, in.	(Dia.)	120.00 ✓	120.00 ✓	120.00 ✓	120.00
Barometric Pressure, in. Hg	(Pb)	29.65 ✓	29.65 ✓	29.65 ✓	29.65
Static Pressure, in. H2O	(Pg)	-0.60 ✓	-0.60 ✓	-0.60 ✓	-0.60
Pitot Tube Coefficient	(Cp)	0.84 ✓	0.84 ✓	0.84 ✓	0.84
Meter Correction Factor	(Y)	0.9880 ✓	0.9880 ✓	0.9880 ✓	0.9880
Orifice Calibration Value	(Delta H@)	1.7320 ✓	1.7320 ✓	1.7320 ✓	1.7320
Nozzle Diameter, in.	(Dn)	0.250 ✓	0.250 ✓	0.250 ✓	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	42.480 ✓	42.755 ✓	42.602 ✓	42.612
Meter Temperature, °F	(Tm)	89.8 ✓	95.3 ✓	94.8 ✓	93.3
Meter Temperature, °R	(Tm-R)	549.8	555.3	554.8	553.3
Meter Orifice Pressure, in. H2O	(Delta H)	1.300 ✓	1.300 ✓	1.300 ✓	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> avg)	1.140 ✓	1.140 ✓	1.140 ✓	1.140
Volume H2O Collected, mL	(Vlc)	133.3 ✓	138.7 ✓	147.2 ✓	139.7
CO2 Concentration, %	(CO2)	6.6 ✓	6.9 ✓	7.3 ✓	6.9
O2 Concentration, %	(O2)	13.1 ✓	12.7 ✓	12.3 ✓	12.7
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> avg)	0.907 ✓	0.900 ✓	0.904 ✓	0.904
Stack Temperature, °F	(Ts)	475.1 ✓	473.7 ✓	479.1 ✓	476.0
Stack Temperature, °R	(Ts-R)	935.1	933.7	939.1	936.0

**CALCULATED DATA**

Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	78.54 ✓	78.54 ✓	78.54 ✓	78.54
Stack Pressure, in. Hg	(Ps)	29.61	29.61	29.61	29.61
Meter Pressure, in. Hg	(Pm)	29.75	29.75	29.75	29.75
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	40.054	39.919	39.807	39.927
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	6.274	6.529	6.929	6.577
Moisture Fraction (Measured)	(BWS)	0.135	0.141	0.148	0.141
Moisture Fraction (lower sat/meas)	(BWS)	0.135	0.141	0.148	0.141
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	29.58	29.61	29.66	29.62
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	28.01	27.98	27.93	27.97
Average Stack Gas Velocity, ft/sec	(Vs)	69.18	68.65	69.21	69.01
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	326023	323490	326155	325223
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	157429	155507	154485	155807
Calibration check	(Yqa)	0.9922	0.9902	0.9925	0.992
Percent difference from Y					0.37%



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 2 Combination Boiler  
 Sample Location: Stack outlet  
 W. O. Number: 15730.001.008  
 Run Number: 1  
 Date: 6/24/21  
 Test Personnel: ATL/CLL  
 Sample Time: 15:07 min. 64

Console ID: A010  
 Meter Corr., Y: .988  
 Console ΔH@: 1.732  
 Probe ID/Length: PR38  
 Liner Material: SS  
 Pitot ID/Coeff.: P172  
 Thermo ID: A010  
 Nozzle ID/Diams.: .250  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp.: 90 °F  
 Baro. Pressure\*: 29.65 in. Hg  
 Static Pressure: -.60 in. H<sub>2</sub>O  
 Impinger Gain: 120.6 mL  
 Silica Gel Gain: 12.7 g  
 Stack Area: 78.54 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: NA  
 Leak Checks: Initial Final  
 Volume, ft<sup>3</sup>: .009 .001  
 @ Vac., in. Hg: 8 5  
 Pitot: .000 .000  
 Filter ID: NA  
 Sample ID: Run 1 u/ NLG+50G

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
1	3:4	14:45	.91	1.3	94.900	485	87	87	244	256	256	65	1.5	
2	6:8		.89	1.3	100.1	485	86	86	252	255	255	63	1.5	
3	9:12		.85	1.3	102.7	484	87	87	253	254	254	61	1.5	
4	12:16	15:01	.78	1.3	105.4	479	87	87	251	255	255	61	1.5	
1-D	15:20	15:07	.90	1.3	108.1	479	88	88	252	250	250	64	1.5	
2	18:24		.91	1.3	110.7	480	89	89	250	255	255	61	1.5	
3	21:26		.89	1.3	113.0	478	89	89	249	254	254	60	1.5	
4	24:32	15:23	.83	1.3	116.1	475	90	90	247	255	255	60	1.5	
1-A	27:36	15:27	.81	1.3	118.8	474	90	90	246	256	256	64	1.5	
2	30:46	15:27	.85	1.3	121.6	470	91	91	245	257	257	62	1.5	
3	33:44		.85	1.3	124.1	468	91	91	246	255	255	60	1.5	
4	36:48	15:43	.75	1.3	126.7	468	91	91	247	256	256	61	1.5	
1-B	39:52	15:51	.82	1.3	129.6	467	91	91	248	255	255	65	1.5	
?	42:56		.73	1.3	132.0	469	93	93	249	256	256	63	1.5	
3	45:60		.70	1.3	134.8	470	93	93	251	256	256	64	1.5	
4	48:64	16:07	.67	1.3	137.360	470	94	94	250	257	257	64	1.5	
*Barometric Pressure is at port elevation			Avg V <sub>ap</sub> : .9073	Avg ΔH: 1.3	Total Volume: 42.48	Avg T <sub>m</sub> : 475.06	Avg T <sub>in</sub> : 89.91	Min/Max: 245/257	Min/Max: 254/257	Min/Max: 254/257	Min/Max: 254/257	Max Temp: 65	Max Vac: 1.5	V <sub>m-std</sub> scf: 1.5



Flue Gas Composition: Oxygen, % 1.140; Carbon Dioxide, % 1.140; Moisture, % 1.140  
 O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run:         ; Post-run:           
 Thermocouple Check: Meter Temp., °F         ; Ref. Temp., °F         ; Result           
 Comments: w/ NLG+50G  
 15730.001.008  
 Pulp Dryer, #1 Saper Machine, #23 SIB V's, & #1-2 CBs  
 Calibration Report



# Isokinetic Field Data

## Method: EPA 4, Moisture

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 2 Combination Boiler  
 Sample Location Stack 50W/1E  
 W. O. Number 15730.001.008  
 Run Number 2  
 Date 6/24/21  
 Test Personnel ATY/LL  
 Sample Time 48 min.

Console ID A010  
 Meter Corr., Y .986  
 Console ΔH@ 1.732  
 Probe ID/Length PR5B 51  
 Liner Material 55  
 Pitot ID/Coeff. 0.84  
 Thermo ID A010  
 Nozzle ID/Diams. .250 in.  
 Avg. Nozzle Diam. .250 in.

Ambient Temp. 90 °F  
 Baro. Pressure\* 29.65 in. Hg  
 Static Pressure -.60 in. H<sub>2</sub>O  
 Impinger Gain 120.6 mL  
 Silica Gel Gain 13.7 g  
 Stack Area 78.54 ft<sup>2</sup>  
 Total Traverse Points 16

K Factor NA  
 Leak Checks  
 Volume, ft<sup>3</sup> .003  
 @ Vac., in. Hg 8.00  
 Pitot .000  
 Filter ID NA  
 Sample ID Runa w/ NLG + SOG

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
1 C	24	16:30	.90	1.3	137.600	475		94	232	256		64	2	
2	28		.87	1.3	142.4	474		94	251	255		62	2	
3	212		.83	1.3	145.6	473		95	250	256		61	2	
4	1216	16:46	.77	1.3	148.2	472		95	232	257		64	2.5	
1 D	1220	16:51	.91	1.3	150.8	471		95	253	256		65	2.5	
2	1224		.90	1.3	153.6	473		95	255	252		65	2.5	
3	2128		.92	1.3	156.2	474		96	254	250		64	2.5	
4	2132	17:07	.85	1.3	158.9	474		96	255	252		65	2.5	
1 A	2136	17:12	.80	1.3	161.4	473		96	256	253		63	2.5	
2	2140		.73	1.3	164.3	474		96	257	252		57	2.5	
3	2144		.77	1.3	167.2	474		95	256	250		55	2.5	
4	2148	17:28	.70	1.3	169.6	474		96	257	250		53	3	
1 B	2152	17:38	.85	1.3	172.4	474		95	256	251		62	3	
2	2156		.80	1.3	174.9	475		96	256	252		56	3	
3	2160		.72	1.3	177.7	474		95	255	251		55	3	
4	2164	17:54	.68	1.3	180.355	475		95	256	250		55	3	
*Barometric Pressure is at port elevation					Total Volume	Avg T <sub>g</sub>	Avg T <sub>g</sub>	Avg T <sub>g</sub>	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub> scf
					42.755	473.689	473.689	45.25	250/257	250/257	250/257	65	3	
					Avg ΔH	Avg ΔH	Avg ΔH							
					1.146	1.146	1.146							

15730.001.008  
 Pulp Dryer # Paper Machine,  
 #2-3 SB & #1-2 CBs  
 Emission Report

Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 Result \_\_\_\_\_

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run \_\_\_\_\_  
 Post-run \_\_\_\_\_

Flue Gas Composition  
 Oxygen, % \_\_\_\_\_  
 Carbon Dioxide, % \_\_\_\_\_  
 Moisture, % \_\_\_\_\_

Comments w/ NLG + SOG





# Isokinetic Field Data

## Method: EPA 4, Moisture

Client New Indy Console ID AG10 Ambient Temp. 95 °F  
 Location/Plant Catawba, SC Meter Corr., Y 988 Baro. Pressure\* 29.65 in. Hg  
 Source No. 2 Combination Boiler Console ΔH@ 1.732 Static Pressure -6.0 in. H<sub>2</sub>O  
 Sample Location Stack outlet Probe ID/Length PL58 5' Impinger Gain 134.5 mL  
 W. O. Number 15730.001.008 Liner Material SS Silica Gel Gain 12.7 g  
 Run Number 3 Pitot ID/Coeff. 0.172 Stack Area 78.54 ft<sup>2</sup>  
 Date 6/24/21 Thermo ID A016 Total Traverse Points 16  
 Test Personnel AKL/LL Nozzle ID/Diams. .250 in. Nozzle Diam. .250 in.  
 Sample Time 48 min.

K Factor NA  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	.003	.000
Pitot	8	5
	1,000	1,000

Filter ID NA  
 Sample ID R403 w/ NCV+SCG

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
P-1C	04	18:06	.40	1.3	180.600	476	94	94	248	251		64	2	
2	08		.89	1.3	185.0	477	94	94	249	252		63	2	
3	012		.86	1.3	184.7	476	95	95	250	253		61	2	
4	1316	18:22	.80	1.3	191.3	475	95	96	251	252		57	2	
P-1D	1820	18:28	.88	1.3	193.9	480	96	96	250	255		63	2	
2	1824		.90	1.3	196.8	481	96	96	250	256		57	2	
3	2128		.88	1.3	198.9	482	95	95	249	256		56	2	
4	2432	18:44	.81	1.3	202.3	478	95	95	250	255		57	2.5	
P-1A	2736	18:50	.82	1.3	204.8	479	95	95	252	257		65	2.5	
2	3040		.82	1.3	207.5	480	94	94	250	258		59	2.5	
3	3344		.85	1.3	210.3	484	95	95	250	256		59	2.5	
4	3648	19:06	.70	1.3	212.7	485	96	96	251	256		60	2.5	
P-1B	3952	19:12	.80	1.3	215.4	478	95	95	250	253		63	2.5	
2	4256	19:15	.80	1.3	218.0	474	94	94	250	253		61	2.5	
3	4560		.70	1.3	220.7	478	94	94	249	254		63	2.5	
4	4864	19:31	.70	1.3	223.402	478	94	94	249	255		64	2.5	
*Barometric Pressure is at port elevation														
			Avg Δp	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>			Min/Max	Min/Max	Min/Max	Max Temp	Max Vac
			.9044	1.3	42.602	479.12	94.81	248.85	251.258	251.258	251.258	65	2.5	2.5

**WESTON SOLUTIONS**  
 Integrated Air Services

Flue Gas Composition  
 Oxygen, % \_\_\_\_\_  
 Carbon Dioxide, % \_\_\_\_\_  
 Moisture, % \_\_\_\_\_

Thermocouple Check  
 Meter Temp., °F \_\_\_\_\_  
 Ref. Temp., °F \_\_\_\_\_  
 Result \_\_\_\_\_

Comments w/ NCV & Solr

15730.001.008  
 Pulp Dryer, #3 SBTVA, & #1-2 CBs  
 Emission Report



# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 2 Combination Boiler  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/24/21 Recovery Date 6/24/21  
 Sample ID Run 1 w/ NLG + SOG Filter ID NA Analyst ATR

Impingers				Imp.Total	Silica Gel grams	Total
1	2	3				
Contents	DI	DI	empty			
Final	995.1	771.4	643.0		858.1	
Initial	898.4	751.2	639.3		845.4	
Gain	96.7 ✓	20.2 ✓	3.7 ✓	120.6 ✓	12.7	133.3 ✓

Impinger Color clear Lable 1?   
 Silica Gel Condition used Sealed?

Run No. 2 Sample Date 6/24/21 Recovery Date 6/24/21  
 Sample ID Run 2 w/ NLG + SOG Filter ID NA Analyst ATR

Impingers				Imp.Total	Silica Gel grams	Total
1	2	3				
Contents	DI	DI	empty			
Final	<del>773.3</del> 749.6	786.9	657.0		903.4	
Initial	647.0	761.5	654.0		889.7	
Gain	102.6 ✓	19.4 ✓	3 ✓	125	13.7 ✓	138.7 ✓

Impinger Color clear Lable 1?   
 Silica Gel Condition used Sealed?

Run No. 3 Sample Date 6/24/21 Recovery Date 6/24/21  
 Sample ID Run 3 w/ NLG + SOG Filter ID NA Analyst ATR

Impingers				Imp.Total	Silica Gel grams	Total
1	2	3				
Contents	DI	DI	empty			
Final	830.5	793.5	646.3		847.3	
Initial	713.3	779.5	643.0		834.6	
Gain	117.2 ✓	14 ✓	3.3 ✓	134.5	12.7	147.2 ✓

Impinger Color clear Labeled?   
 Silica Gel Condition used Sealed?

Check COC for Sample IDs of Media Blanks





# Sample and Velocity Traverse Points - Method 1

Client New Indy  
Location/Plant Catawba, SC  
Operator VB

Source No. 2 Combination Boiler  
W.O. Number 15730.001.008  
Date 6/24/21

Duct Type  Circular  Rectangular  
Traverse Type  Particulate Traverse  Velocity Traverse  Stratification Traverse



Depth, far wall to outside of port (in) = C	129
Port Depth (in) = D	9
Depth of Duct, diameter (in) = C - D	120
Area of Duct (ft <sup>3</sup> )	78.54
Number of Ports	4
Traverse Points per Port	4
Total Traverse Points	16

Flow Disturbances	
Upstream - A (ft)	45
Downstream - B (ft)	32
Upstream - A (duct diameters)	4.5
Downstream - B (duct diameters)	3.2

**Rectangular Ducts Only**

Width of Duct (in)	
Equivalent Diameter (in)	

Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	3.2	3.9	12.9
2	10.5	12.6	21.6
3	19.4	23.3	32.3
4	32.3	38.8	47.8



		Traverse Point Location % of Stack - Circular											
		Number of Traverse Points											
		1	2	3	4	5	6	7	8	9	10	11	12
T r a v e r s e P o i n t	1		14.6	6.7	4.4		3.2		2.6		2.1		
	2		85.4	25.0	14.6		10.5		8.2		6.7		
	3			75.0	29.6		19.4		14.6		11.8		
	4			93.3	70.4		32.3		22.8		17.7		
	5				85.4	67.7		34.2		25.0			
	6				95.8	80.6		65.8		35.8			
	7					89.5		77.4		64.4			
	8					96.8		85.4		75.0			
	9							91.8		82.3			
	10									97.4			
	11												93.3
	12												

		Traverse Point Location % of Stack - Rectangular											
		Number of Traverse Points											
		1	2	3	4	5	6	7	8	9	10	11	12
T r a v e r s e P o i n t	1		25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
	2		75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
	3			83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
	4				87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
	5					90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
	6						91.7	78.6	68.8	61.1	55.0	50.0	45.8
	7							92.9	81.3	72.2	65.0	59.1	54.2
	8								93.8	83.3	75.0	68.2	62.5
	9									94.4	85.0	77.3	70.8
	10										95.0	86.4	79.2
	11											95.5	87.5
	12												95.8

Rectangular Stack Points & Matrix

- 9 - 3 x 3
- 12 - 4 x 3
- 16 - 4 x 4
- 20 - 5 x 4
- 25 - 5 x 5
- 30 - 6 x 5
- 36 - 6 x 6
- 42 - 7 x 6
- 49 - 7 x 7

Tape measure ID \_\_\_\_\_

# RUN SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

Start Time 14:45    End Time 15:45

---

Average Measured TRS Conc.    0.82 ppm ✓  
Recovery No. 2    89.5 % ✓  
TRS Corrected for Recovery    0.92 ppm ✓

✓



# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

**Start Time 16:30    End Time 17:30**

---

<b>Average Measured TRS Conc.</b>	<b>0.68 ppm</b>	✓
<b>Recovery No. 2</b>	<b>89.5 %</b>	✓
<b>TRS Corrected for Recovery</b>	<b>0.76 ppm</b>	✓

✓

# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

**Start Time 18:06    End Time 19:07**

---

**Average Measured TRS Conc.**    0.69 ppm ✓  
**Recovery No. 2**    89.5 % ✓  
**TRS Corrected for Recovery**    0.77 ppm ✓

*W*

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
14:45	2	0.08	59	0.68	<2	<0.077	<2	<0.036	0.76
14:48	3	0.10	57	0.66	<2	<0.077	<2	<0.036	0.76
14:51	2	0.08	57	0.66	<2	<0.077	<2	<0.036	0.74
14:54	3	0.09	58	0.67	<2	<0.077	<2	<0.036	0.76
14:57	<2	<0.077	58	0.67	<2	<0.077	<2	<0.036	0.67
15:00	<2	<0.077	55	0.65	<2	<0.077	<2	<0.036	0.65
15:03	<2	<0.077	56	0.66	<2	<0.077	<2	<0.036	0.66
15:06	<2	<0.077	53	0.64	<2	<0.077	2	0.04	0.72
15:09	2	0.09	59	0.67	<2	<0.077	<2	<0.036	0.76
15:12	3	0.09	62	0.69	<2	<0.077	<2	<0.036	0.78
15:15	<2	<0.077	90	0.84	<2	<0.077	<2	<0.036	0.84
15:18	3	0.09	77	0.78	<2	<0.077	<2	<0.036	0.86
15:21	<2	<0.077	90	0.84	<2	<0.077	<2	<0.036	0.84
15:24	<2	<0.077	144	1.08	<2	<0.077	<2	<0.036	1.08
15:27	3	0.10	115	0.96	<2	<0.077	<2	<0.036	1.06
15:30	<2	<0.077	79	0.79	<2	<0.077	<2	<0.036	0.79
15:33	2	0.08	120	0.98	<2	<0.077	<2	<0.036	1.06
15:36	<2	<0.077	77	0.78	<2	<0.077	<2	<0.036	0.78
15:39	2	0.09	124	1.00	<2	<0.077	<2	<0.036	1.08
15:42	<2	<0.077	77	0.78	<2	<0.077	<2	<0.036	0.78
<b>Average</b>		<b>&lt;0.077</b>		<b>0.77</b>		<b>&lt;0.077</b>		<b>&lt;0.036</b>	<b>0.82</b> ✓

✓

# RUN DATA

Number 2

15730.001.008  
Pulp Dryer, #3 Paper Machine,  
#2-3 SDTVs, & #1-2 CBs  
Emission Report

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
16:30	<2	<0.077	51	0.63	<2	<0.077	<2	<0.036	0.63
16:33	<2	<0.077	41	0.56	<2	<0.077	<2	<0.036	0.56
16:36	<2	<0.077	48	0.61	2	0.08	<2	<0.036	0.68
16:39	<2	<0.077	58	0.67	<2	<0.077	<2	<0.036	0.67
16:42	<2	<0.077	68	0.73	<2	<0.077	<2	<0.036	0.73
16:45	<2	<0.077	89	0.84	<2	<0.077	<2	<0.036	0.84
16:48	2	0.08	51	0.63	2	0.08	<2	<0.036	0.79
16:51	<2	<0.077	42	0.57	<2	<0.077	<2	<0.036	0.57
16:54	4	0.11	44	0.58	<2	<0.077	2	0.04	0.77
16:57	3	0.09	44	0.58	<2	<0.077	4	0.05	0.78
17:00	<2	<0.077	52	0.63	3	0.09	3	0.04	0.81
17:03	<2	<0.077	44	0.58	<2	<0.077	<2	<0.036	0.58
17:06	<2	<0.077	45	0.59	<2	<0.077	<2	<0.036	0.59
17:09	<2	<0.077	46	0.59	<2	<0.077	<2	<0.036	0.59
17:12	<2	<0.077	64	0.70	<2	<0.077	<2	<0.036	0.70
17:15	<2	<0.077	46	0.59	<2	<0.077	<2	<0.036	0.59
17:18	3	0.10	54	0.65	<2	<0.077	<2	<0.036	0.75
17:21	<2	<0.077	61	0.69	<2	<0.077	<2	<0.036	0.69
17:24	<2	<0.077	52	0.63	<2	<0.077	<2	<0.036	0.63
17:27	<2	<0.077	53	0.64	<2	<0.077	<2	<0.036	0.64
<b>Average</b>		<b>&lt;0.077</b>		<b>0.63</b>		<b>&lt;0.077</b>		<b>&lt;0.036</b>	<b>0.68</b> ✓

*AV*

# RUN DATA

Number 3

15730.001.008  
Pulp Dryer, #3 Paper Machine,  
#2-3 SDTVs, & #1-2 CBs  
Emission Report

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
18:06	<2	<0.077	60	0.68	<2	<0.077	<2	<0.036	0.68
18:09	<2	<0.077	45	0.59	<2	<0.077	<2	<0.036	0.59
18:12	3	0.09	45	0.59	<2	<0.077	<2	<0.036	0.68
18:15	3	0.09	49	0.61	<2	<0.077	2	0.04	0.78
18:18	<2	<0.077	44	0.58	<2	<0.077	<2	<0.036	0.58
18:21	<2	<0.077	49	0.62	<2	<0.077	<2	<0.036	0.62
18:25	<2	<0.077	47	0.60	<2	<0.077	<2	<0.036	0.60
18:28	3	0.09	61	0.69	2	0.08	<2	<0.036	0.86
18:31	<2	<0.077	50	0.62	<2	<0.077	<2	<0.036	0.62
18:34	<2	<0.077	50	0.62	<2	<0.077	<2	<0.036	0.62
18:37	3	0.09	51	0.63	<2	<0.077	<2	<0.036	0.72
18:40	<2	<0.077	88	0.83	<2	<0.077	<2	<0.036	0.83
18:43	<2	<0.077	56	0.66	7	0.15	<2	<0.036	0.80
18:46	<2	<0.077	53	0.64	<2	<0.077	<2	<0.036	0.64
18:49	<2	<0.077	55	0.65	<2	<0.077	3	0.04	0.74
18:52	2	0.08	55	0.65	<2	<0.077	<2	<0.036	0.73
18:55	3	0.09	51	0.63	<2	<0.077	<2	<0.036	0.72
18:58	<2	<0.077	52	0.63	<2	<0.077	<2	<0.036	0.63
19:01	<2	<0.077	52	0.63	<2	<0.077	<2	<0.036	0.63
19:04	<2	<0.077	52	0.63	<2	<0.077	<2	<0.036	0.63
<b>Average</b>		<b>&lt;0.077</b>		<b>0.64</b>		<b>&lt;0.077</b>		<b>&lt;0.036</b>	<b>0.69</b> ✓

~



# RECOVERY DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

## Before Run 1

Start Time 12:40    End Time 12:54

---

### Recovery Gas to Probe, Time 12:40

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
12316	12389	12588	12431	7.23

---

### Recovery Gas to GC, Time 12:50

<u>Peak Areas, mv-sec</u>			<u>Average</u>	<u>ppm</u>
15122	15025	15294	15147	8.02

---

Recovery 90.2% ✓

---

*m*



# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

After Run 3    Before Run 4  
Start Time 19:07    End Time 19:38

---

Recovery Gas to Probe, Time 19:07

Peak Areas, mv-sec			Average	ppm
11821	11900	11851	11857 ✓	7.06

---

Recovery Gas to GC, Time 19:36

Peak Areas, mv-sec			Average	ppm
14397	14822	14833	14684 /	7.89

---

Recovery 89.5% ✓

---

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

**Ambient Temperature: 72°C**

**Barometric Pressure: 29.25 in. Hg**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51828	33-53274	89-53332	89-53266
Perm. Rate, nL/min	351	369	477	241
Ret. Time, sec	16.0	22.5	48.0	127.0

**1 Flow = 37.6 mL/Min      9.34 ppm      9.81 ppm      12.7 ppm      6.42 ppm**

**Time: 07:00**

**Peak Areas, mv-sec**

19790	9921	31382	38948
20319	10076	31742	38693
19852	9986	30214	37936

**Average Area**

**19987 ✓      9995 ✓      31113 ✓      38526 ✓**

**2 Flow = 82.8 mL/Min      4.24 ppm      4.46 ppm      5.77 ppm      2.92 ppm**

**Time: 11:03**

**Peak Areas, mv-sec**

4788	2266	7435	8918
4588	2209	7188	8687
4419	2218	7198	8791

**Average Area**

**4598 ✓      2231 ✓      7274 ✓      8798 ✓**

**3 Flow = 180 mL/Min      1.95 ppm      2.05 ppm      2.66 ppm      1.34 ppm**

**Time: 11:47**

**Peak Areas, mv-sec**

998	492	1607	1968
985	496	1607	1963
982	497	1614	1971

**Average Area**

**988 ✓      495 ✓      1609 ✓      1967 ✓**

*Handwritten mark*

# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

H <sub>2</sub> S	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	9.34	4.24	1.95		
Area, mv-sec	19987	4598	988		
Calc. Conc., ppm	9.26	4.31	1.94		
% Error	-0.8	1.6	-0.8		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9212	2.4433	0.9998	2	0.077

MeSH	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	9.81	4.46	2.05		
Area, mv-sec	9995	2231	495		
Calc. Conc., ppm	9.79	4.48	2.05		
% Error	-0.3	0.5	-0.3		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9203	2.0975	>0.9999	2	0.12

DMS	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	12.7	5.77	2.66		
Area, mv-sec	31113	7274	1609		
Calc. Conc., ppm	12.6	5.85	2.64		
% Error	-0.7	1.4	-0.7		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8927	2.4098	0.9999	2	0.077

DMDS	1	2	3		
Time	07:00	11:03	11:47		
Concentration, ppm	6.42	2.92	1.34		
Area, mv-sec	38526	8798	1967		
Calc. Conc., ppm	6.39	2.94	1.34		
% Error	-0.4	0.8	-0.4		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9009	3.0543	>0.9999	2	0.036

*Handwritten mark*

# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

**Ambient Temperature: 72°C**

**Barometric Pressure: 29.55 in. Hg**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMSD
Perm. Device ID	T-51828	33-53274	89-53332	89-53266
Perm. Rate, nL/min	348	365	473	239
Ret. Time, sec	16.0	22.5	48.0	127.0

<b>1</b> Flow = <b>38.4 mL/Min</b>	<b>9.05 ppm</b>	<b>9.51 ppm</b>	<b>12.3 ppm</b>	<b>6.22 ppm</b>
<b>Time: 06:02</b>	<b>Peak Areas, mv-sec</b>			
	18150	9129	29752	37042
	18234	8899	29635	36567
	17949	9072	29588	35648
<b>Average Area</b>	<b>18111 ✓</b>	<b>9034 ✓</b>	<b>29658 ✓</b>	<b>36419 ✓</b>
<b>2</b> Flow = <b>86.9 mL/Min</b>	<b>4.00 ppm</b>	<b>4.20 ppm</b>	<b>5.44 ppm</b>	<b>2.75 ppm</b>
<b>Time: 08:24</b>	<b>Peak Areas, mv-sec</b>			
	4494	1991	6636	8003
	4478	2048	6673	8033
	4420	2010	6502	8101
<b>Average Area</b>	<b>4464 ✓</b>	<b>2016 ✓</b>	<b>6604 ✓</b>	<b>8046 ✓</b>
<b>3</b> Flow = <b>191 mL/Min</b>	<b>1.82 ppm</b>	<b>1.92 ppm</b>	<b>2.48 ppm</b>	<b>1.25 ppm</b>
<b>Time: 08:49</b>	<b>Peak Areas, mv-sec</b>			
	1072	443	1449	1837
	1039	453	1513	1835
	1077	449	1476	1874
<b>Average Area</b>	<b>1063 ✓</b>	<b>448 ✓</b>	<b>1479 ✓</b>	<b>1849 ✓</b>

*✓*

# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Method **16**

H <sub>2</sub> S	1	2	3		
Time	06:02	08:24	08:49		
Concentration, ppm	9.05	4.00	1.82		
Area, mv-sec	18111	4464	1063		
Calc. Conc., ppm	8.97	4.07	1.81		
% Error	-0.8	1.7	-0.9		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.7702	2.5709	0.9998	2	0.052

MeSH	1	2	3		
Time	06:02	08:24	08:49		
Concentration, ppm	9.51	4.20	1.92		
Area, mv-sec	9034	2016	448		
Calc. Conc., ppm	9.46	4.25	1.91		
% Error	-0.6	1.1	-0.6		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8751	2.1261	0.9999	2	0.11

DMS	1	2	3		
Time	06:02	08:24	08:49		
Concentration, ppm	12.3	5.44	2.48		
Area, mv-sec	29658	6604	1479		
Calc. Conc., ppm	12.2	5.49	2.47		
% Error	-0.5	1.0	-0.5		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8718	2.4355	0.9999	2	0.072

DMDS	1	2	3		
Time	06:02	08:24	08:49		
Concentration, ppm	6.22	2.75	1.25		
Area, mv-sec	36419	8046	1849		
Calc. Conc., ppm	6.21	2.76	1.25		
% Error	-0.2	0.4	-0.2		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8610	3.0854	>0.9999	2	0.032

*Handwritten mark*

# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
<b>Molecular Weight</b>	34.08	48.11	62.14	94.20
<b>Retention Time, sec</b>	16.0	22.5	48.0	127.0
<b>Peak Detection Window, sec</b>	3.0	7.0	10.0	10.0
<b>Minimum Peak Area, mv-sec</b>	2	2	2	2
<b>Minimum Peak Height, mv</b>	1	1	1	1
<b>Beginning Peak Width, sec</b>	1.0	1.0	2.0	3.0
<b>Ending Peak Width, sec</b>	2.0	6.0	4.0	5.0
<b>Permeation Device ID</b>	T-51828	33-53274	89-53332	89-53266
<b>Permeation Rate, ng/min</b>	483 ✓	716 ✓	1197 ✓	918 ✓
<b>Permeation Rate, nL/min*</b>	348	365	473	239

**Barometric Pressure:** 29.55 in. Hg    **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- PR<sub>ng</sub>** = Permeation Rate by weight, ng/min
- V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole
- W<sub>mol</sub>** = Molecular Weight of compound
- T<sub>a</sub>** = Ambient Temperature, °F
- T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)
- P<sub>s</sub>** = Standard Pressure = 29.92 in Hg
- P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 483 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.55) = 348 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

- C** = Concentration, ppmv
- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- F<sub>d</sub>** = Flow rate of diluent, mL/min

An

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

File: C:\Data\210624 New Indy Catawba No. 2 CB.trs  
Program Version: 2.0, built 15 May 2017 File Version: 2.0  
Computer: WLT5 Trailer: 281

Analog Input Device: MCC USB-1608G GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: Shimadzu GC8-A Serial No. C10493615061  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 140	Primary: Carbopack
Air	30	60	Detector: 140	Secondary: N/A
Carrier	50	30		Sample Loop: 4"

## Injection Cycle

Total Length: 180 sec Sampling Time: 170 sec Load/Backflush Time: 80 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 2 mv-sec Minimum peak height 1 mv above baseline

## Dynacalibrator

Chamber Temperature 50.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.55 in. Hg



# RUN SUMMARY

Number 1

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

Method	O <sub>2</sub>	CO <sub>2</sub>	SO <sub>2</sub>
Conc. Units	EPA 3A	EPA 3A	EPA 6C
	%	%	ppm

Time: 14:45 to 15:45

### Run Averages

13.0	6.6	320
------	-----	-----

### Pre-run Bias at 14:36

Zero Bias	0.1	0.0	4
Span Bias	10.1	10.2	242
Span Gas	10.1	10.2	242

### Post-run Bias at 15:50

Zero Bias	0.0	0.0	4
Span Bias	10.1	10.2	239
Span Gas	10.1	10.2	242

Run averages corrected for the average of the pre-run and post-run bias

13.1	✓	6.6	✓	324	✓
------	---	-----	---	-----	---

*Handwritten mark*

# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Method Conc. Units	O <sub>2</sub> EPA 3A %	CO <sub>2</sub> EPA 3A %	SO <sub>2</sub> EPA 6C ppm
-----------------------	-------------------------------	--------------------------------	----------------------------------

Time: 16:30 to 17:30

### Run Averages

12.6                  6.9                  324

### Pre-run Bias at 15:50

Zero Bias	0.0	0.0	4
Span Bias	10.1	10.2	239
Span Gas	10.1	10.2	242

### Post-run Bias at 17:33

Zero Bias	0.1	0.0	7
Span Bias	10.1	10.1	244
Span Gas	10.1	10.2	242

Run averages corrected for the average of the pre-run and post-run bias

12.7 ✓                  6.9 ✓                  327 ✓

✓

# RUN SUMMARY

Number 3

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

Method Conc. Units	O <sub>2</sub> EPA 3A %	CO <sub>2</sub> EPA 3A %	SO <sub>2</sub> EPA 6C ppm
-----------------------	-------------------------------	--------------------------------	----------------------------------

Time: 18:06 to 19:06

### Run Averages

12.2                  7.3                  321

### Pre-run Bias at 17:33

Zero Bias	0.1	0.0	7
Span Bias	10.1	10.1	244
Span Gas	10.1	10.2	242

### Post-run Bias at 19:08

Zero Bias	0.1	0.0	5
Span Bias	10.1	10.2	241
Span Gas	10.1	10.2	242

Run averages corrected for the average of the pre-run and post-run bias

12.3 ✓                  7.3 ✓                  322 ✓

✓

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm

**With NCGs & SOGs**

**Traversed @ 16.6%, 50.0%, & 83.3% of duct diameter**

**Point 1**

14:46	4108	12.4	2996	7.5	3011	300
14:47	4097	12.3	2991	7.4	3017	300
14:48	3977	12.0	3028	7.5	3055	304
14:49	3987	12.0	3156	7.9	3085	307
14:50	3979	12.0	3132	7.8	3072	306
14:51	3980	12.0	3149	7.8	2913	290
14:52	4083	12.3	3137	7.8	2875	286
14:53	4206	12.7	3007	7.5	2930	292
14:54	4236	12.8	2877	7.2	3006	299
14:55	4218	12.7	2850	7.1	3073	306
14:56	4370	13.2	2810	7.0	3033	302
14:57	4368	13.1	2667	6.6	3136	312
14:58	4294	12.9	2672	6.6	3154	314
14:59	4319	13.0	2752	6.8	3132	312
15:00	4296	12.9	2731	6.8	3223	321
15:01	4316	13.0	2753	6.8	3181	317
15:02	4381	13.2	2710	6.7	3211	320
15:03	4185	12.6	2684	6.7	3173	316
15:04	4069	12.3	2877	7.2	2984	297
15:05	4041	12.2	3001	7.5	3041	303

**Point 2**

15:06	4040	12.2	3033	7.5	3076	306
15:07	4140	12.5	2999	7.5	3038	303
15:08	4235	12.7	2901	7.2	3046	303
15:09	4259	12.8	2783	6.9	3069	306
15:10	4355	13.1	2749	6.8	3154	314
15:11	4384	13.2	2653	6.6	3311	330
15:12	4466	13.4	2604	6.5	3337	332
15:13	4555	13.7	2489	6.2	3276	326
15:14	4534	13.6	2410	6.0	3205	319
15:15	4491	13.5	2421	6.0	3145	313
15:16	4454	13.4	2451	6.1	3196	318
15:17	4454	13.4	2500	6.2	3166	315
15:18	4342	13.1	2515	6.2	3281	327
15:19	4342	13.1	2624	6.5	3244	323
15:20	4463	13.4	2612	6.5	3261	325
15:21	4483	13.5	2474	6.1	3373	336
15:22	4487	13.5	2458	6.1	3366	335

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
15:23	4539	13.7	2438	6.1	3201	319
15:24	4574	13.8	2381	5.9	3191	318
15:25	4521	13.6	2354	5.8	3329	332
<b>Point 3</b>						
15:26	4507	13.6	2413	6.0	3346	333
15:27	4454	13.4	2435	6.0	3376	336
15:28	4416	13.3	2485	6.2	3524	351
15:29	4404	13.3	2539	6.3	3496	348
15:30	4461	13.4	2540	6.3	3423	341
15:31	4560	13.7	2475	6.1	3252	324
15:32	4510	13.6	2370	5.9	3272	326
15:33	4479	13.5	2425	6.0	3328	332
15:34	4431	13.3	2459	6.1	3328	332
15:35	4429	13.3	2519	6.3	3325	331
15:36	4361	13.1	2540	6.3	3347	333
15:37	4435	13.3	2573	6.4	3340	333
15:38	4422	13.3	2527	6.3	3372	336
15:39	4476	13.5	2509	6.2	3481	347
15:40	4464	13.4	2455	6.1	3535	352
15:41	4395	13.2	2494	6.2	3451	344
15:42	4358	13.1	2563	6.4	3253	324
15:43	4318	13.0	2598	6.5	3260	325
15:44	4310	13.0	2647	6.6	3270	326
15:45	4298	12.9	2666	6.6	3261	325
<b>Avg</b>	<b>4335</b>	<b>13.0</b>	<b>2668</b>	<b>6.6</b>	<b>3214</b>	<b>320</b>

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm

**With NCGs & SOGs**  
**Traversed @ 16.6%, 50.0%, & 83.3% of duct diameter**

**Point 1**

16:31	4171	12.6	2672	6.6	3216	320
16:32	4119	12.4	2788	6.9	3200	319
16:33	4126	12.4	2856	7.1	3255	324
16:34	4203	12.7	2842	7.1	3239	323
16:35	4294	12.9	2741	6.8	3356	334
16:36	4374	13.2	2640	6.6	3431	342
16:37	4326	13.0	2566	6.4	3322	331
16:38	4338	13.1	2604	6.5	3146	313
16:39	4312	13.0	2606	6.5	3257	324
16:40	4358	13.1	2614	6.5	3196	318
16:41	4456	13.4	2562	6.4	3256	324
16:42	4497	13.5	2454	6.1	3263	325
16:43	4433	13.3	2410	6.0	3234	322
16:44	4408	13.3	2484	6.2	3253	324
16:45	4381	13.2	2513	6.2	3261	325
16:46	4286	12.9	2558	6.4	3171	316
16:47	4296	12.9	2654	6.6	3252	324
16:48	4265	12.8	2651	6.6	3433	342
16:49	4108	12.4	2702	6.7	3304	329
16:50	4012	12.1	2875	7.2	3162	315

**Point 2**

16:51	4020	12.1	2971	7.4	3150	314
16:52	4040	12.2	2975	7.4	3140	313
16:53	4117	12.4	2932	7.3	3064	305
16:54	4169	12.6	2860	7.1	3134	312
16:55	4080	12.3	2812	7.0	3235	322
16:56	4024	12.1	2918	7.3	3268	326
16:57	4039	12.2	2965	7.4	3366	335
16:58	4118	12.4	2933	7.3	3460	345
16:59	4178	12.6	2843	7.1	3359	335
17:00	4081	12.3	2796	7.0	3239	323
17:01	4041	12.2	2911	7.2	3179	317
17:02	4127	12.4	2921	7.3	3164	315
17:03	4118	12.4	2865	7.1	3219	321
17:04	4162	12.5	2847	7.1	3337	332
17:05	4157	12.5	2814	7.0	3355	334
17:06	4228	12.7	2798	7.0	3420	341
17:07	4265	12.8	2722	6.8	3258	325

# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
17:08	4049	12.2	2716	6.8	3091	308
17:09	3988	12.0	2952	7.3	3184	317
17:10	4218	12.7	2989	7.4	3145	313
<b>Point 3</b>						
17:11	4304	13.0	2738	6.8	3235	322
17:12	4144	12.5	2669	6.6	3288	328
17:13	4077	12.3	2848	7.1	3181	317
17:14	4102	12.3	2902	7.2	3201	319
17:15	4152	12.5	2887	7.2	3242	323
17:16	4200	12.6	2827	7.0	3326	331
17:17	4233	12.7	2760	6.9	3407	339
17:18	4267	12.8	2729	6.8	3435	342
17:19	4334	13.0	2703	6.7	3244	323
17:20	4262	12.8	2622	6.5	3225	321
17:21	4237	12.8	2700	6.7	3205	319
17:22	4242	12.8	2722	6.8	3095	308
17:23	4205	12.7	2711	6.7	3211	320
17:24	4237	12.8	2762	6.9	3277	326
17:25	4220	12.7	2727	6.8	3322	331
17:26	4226	12.7	2731	6.8	3456	344
17:27	4112	12.4	2751	6.8	3471	346
17:28	3963	11.9	2895	7.2	3258	325
17:29	4087	12.3	3036	7.6	3187	317
17:30	4290	12.9	2875	7.2	3147	313
<b>Avg</b>	<b>4198</b>	<b>12.6</b>	<b>2765</b>	<b>6.9</b>	<b>3256</b>	<b>324</b>



# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
<b>With NCGs &amp; SOGs</b>						
<b>Traversed @ 16.6%, 50.0%, &amp; 83.3% of duct diameter</b>						
<b>Point 1</b>						
18:07	4211	12.7	2670	6.6	3226	321
18:08	4167	12.5	2744	6.8	3287	327
18:09	4135	12.4	2791	6.9	3381	337
18:10	4078	12.3	2850	7.1	3388	337
18:11	4130	12.4	2872	7.1	3358	334
18:12	4218	12.7	2826	7.0	3176	316
18:13	4226	12.7	2731	6.8	3113	310
18:14	4187	12.6	2729	6.8	3126	311
18:15	4179	12.6	2764	6.9	3202	319
18:16	4163	12.5	2782	6.9	3191	318
18:17	4074	12.3	2813	7.0	3218	321
18:18	4040	12.2	2921	7.3	3165	315
18:19	4079	12.3	2945	7.3	3147	313
18:20	4099	12.3	2894	7.2	3166	315
18:21	4158	12.5	2880	7.2	3209	320
18:22	3944	11.9	2856	7.1	3328	332
18:23	3929	11.8	3056	7.6	3281	327
18:24	3911	11.8	3091	7.7	3245	323
18:25	4003	12.1	3120	7.8	3123	311
18:26	4117	12.4	2988	7.4	3047	303
<b>Point 2</b>						
18:27	4242	12.8	2825	7.0	3183	317
18:28	4129	12.4	2734	6.8	3203	319
18:29	4041	12.2	2845	7.1	3200	319
18:30	4020	12.1	2964	7.4	3329	332
18:31	3939	11.9	2995	7.5	3416	340
18:32	3931	11.8	3074	7.7	3363	335
18:33	3942	11.9	3072	7.6	3140	313
18:34	3967	11.9	3065	7.6	3141	313
18:35	3990	12.0	3043	7.6	3144	313
18:36	4051	12.2	2988	7.4	3136	312
18:37	4050	12.2	2952	7.3	3166	315
18:38	4177	12.6	2911	7.2	3147	313
18:39	4294	12.9	2765	6.9	3269	326
18:40	4135	12.4	2684	6.7	3425	341
18:41	4071	12.3	2854	7.1	3408	339
18:42	4087	12.3	2908	7.2	3243	323
18:43	3982	12.0	2920	7.3	3143	313

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
18:44	3985	12.0	3017	7.5	3084	307
18:45	3917	11.8	3024	7.5	3169	316
18:46	3920	11.8	3099	7.7	3200	319
<b>Point 3</b>						
18:47	4006	12.1	3072	7.6	3196	318
18:48	4096	12.3	2981	7.4	3334	332
18:49	4079	12.3	2899	7.2	3367	335
18:50	4091	12.3	2902	7.2	3216	320
18:51	4122	12.4	2900	7.2	3076	306
18:52	4122	12.4	2859	7.1	3144	313
18:53	4039	12.2	2873	7.1	3157	314
18:54	4078	12.3	2937	7.3	3167	315
18:55	3970	12.0	2928	7.3	3206	319
18:56	3924	11.8	3051	7.6	3177	316
18:57	4012	12.1	3077	7.7	3221	321
18:58	3967	11.9	2999	7.5	3408	339
18:59	3991	12.0	3032	7.5	3252	324
19:00	4119	12.4	2983	7.4	3119	311
19:01	4028	12.1	2885	7.2	3113	310
19:02	4042	12.2	2965	7.4	3084	307
19:03	3997	12.0	2966	7.4	3159	315
19:04	3963	11.9	3000	7.5	3214	320
19:05	3951	11.9	3036	7.6	3345	333
19:06	3958	11.9	3065	7.6	3360	335
<b>Avg</b>	<b>4058</b>	<b>12.2</b>	<b>2925</b>	<b>7.3</b>	<b>3220</b>	<b>321</b>

# BIAS

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 09:56

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	22	0.1	0.1	0.5 ✓	Pass
Span	10.1	3355	10.1	0.0	0.0 ✓	Pass

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	-0.1	35	0.0	0.1	0.5 ✓	Pass
Span	10.3	4075	10.2	-0.1	-0.5 ✓	Pass

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	-1	2	0	1	0.2 ✓	Pass
Span	244	2376	237	-7	-1.5 ✓	Pass

# BIAS AND CALIBRATION DRIFT

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 14:36

**O<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.2 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	37	0.1	0.1	0.5 ✓	Pass
Span	10.1	3339	10.1	0.0	0.0 ✓	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	%	mv	%	%	
Zero	0.1	37	0.1	0.0 ✓	Pass
Span	10.1	3339	10.1	0.0 ✓	Pass

\*Bias No. 1

**CO<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.3 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	-0.1	21	0.0	0.1	0.5 ✓	Pass
Span	10.3	4072	10.2	-0.1	-0.5 ✓	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	%	mv	%	%	
Zero	0.0	21	0.0	0.0 ✓	Pass
Span	10.2	4072	10.2	0.0 ✓	Pass

\*Bias No. 1

# BIAS AND CALIBRATION DRIFT

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 14:36

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	-1	43	4	5	1.1	Pass
Span	244	2432	242	-2	-0.4	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	ppm	mv	ppm	%	
Zero	0	43	4	0.9	Pass
Span	237	2432	242	1.1	Pass

\*Bias No. 1

# BIAS AND CALIBRATION DRIFT

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 15:50

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	3	0.0	0.0	0.0 ✓	Pass
Span	10.1	3340	10.1	0.0	0.0 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.1	3	0.0	-0.1	-0.5 ✓	Pass
Span	10.1	3340	10.1	0.0	0.0 ✓	Pass

\*Bias No. 2

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	-0.1	6	0.0	0.1	0.5 ✓	Pass
Span	10.3	4078	10.2	-0.1	-0.5 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	6	0.0	0.0	0.0 ✓	Pass
Span	10.2	4078	10.2	0.0	0.0 ✓	Pass

\*Bias No. 2

# BIAS AND CALIBRATION DRIFT

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 15:50

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	-1	48	4	5	1.1	Pass ✓
Span	244	2402	239	-5	-1.1	Pass ✓

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	ppm	mv	ppm	%	
Zero	4	48	4	0.0	Pass ✓
Span	242	2402	239	-0.7	Pass ✓

\*Bias No. 2



# BIAS AND CALIBRATION DRIFT

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 17:33

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	16	0.1	0.1	0.5 ✓	Pass
Span	10.1	3338	10.1	0.0	0.0 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	16	0.1	0.1	0.5 ✓	Pass
Span	10.1	3338	10.1	0.0	0.0 ✓	Pass

\*Bias No. 3

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

Bias Results						
Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	-0.1	6	0.0	0.1	0.5 ✓	Pass
Span	10.3	4045	10.1	-0.2	-1.0 ✓	Pass

Calibration Drift						
Standard	Initial*	Final	Difference	Drift	Status	
Gas	%	mv	%	%		
Zero	0.0	6	0.0	0.0	0.0 ✓	Pass
Span	10.2	4045	10.1	-0.1	-0.5 ✓	Pass

\*Bias No. 3

*W*

# BIAS AND CALIBRATION DRIFT

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 17:33

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	-1	77	7	8	1.7	Pass
Span	244	2447	244	0	0.0	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status	
Gas	ppm	mv	ppm	%		
Zero	4	77	7	3	0.7	Pass
Span	239	2447	244	5	1.1	Pass

\*Bias No. 3

# BIAS AND CALIBRATION DRIFT

Number 5

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 19:08

**O<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.2 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	16	0.1	0.1	0.5 ✓	Pass
Span	10.1	3349	10.1	0.0	0.0 ✓	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	%	mv	%	%	
Zero	0.1	16	0.1	0.0 ✓	Pass
Span	10.1	3349	10.1	0.0 ✓	Pass

\*Bias No. 4

**CO<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.3 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	-0.1	6	0.0	0.1	0.5 ✓	Pass
Span	10.3	4104	10.2	-0.1	-0.5 ✓	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	%	mv	%	%	
Zero	0.0	6	0.0	0.0 ✓	Pass
Span	10.1	4104	10.2	0.1 ✓	Pass

\*Bias No. 4

*VD*

# BIAS AND CALIBRATION DRIFT

Number 5

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

Start Time: 19:08

**SO<sub>2</sub>**  
 Method: EPA 6C  
 Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	-1	50	5	6	1.3 ✓	Pass
Span	244	2418	241	-3	-0.7 ✓	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	ppm	mv	ppm	%	
Zero	7	50	5	-0.4 ✓	Pass
Span	244	2418	241	-0.7 ✓	Pass

\*Bias No. 4

# CALIBRATION DATA

Number 1

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 2 Combination Boiler**

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **24 Jun 2021**

Start Time: 09:44

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	-2
10.1 ✓	XC013544B	3348
20.2 ✓	CC275468	6739

Curve Coefficients

Slope	Intercept	Corr. Coeff.
333.1 ✓	-11 ✓	>0.9999 ✓

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	4
10.2 ✓	XC013544B	4116
20.3 ✓	CC275468	8080

Curve Coefficients

Slope	Intercept	Corr. Coeff.
398.4 ✓	25 ✓	>0.9999 ✓

✓

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 09:44

**SO<sub>2</sub>**

Method: EPA 6C

Calibration Type: Linear Regression

---

Calibration Results

ppm	Cylinder ID	Result, mv
Zero	-	-5
242 ✓	CC234516	2450
458 ✓	EB0108003	4587

---

Curve Coefficients

Slope	Intercept	Corr. Coeff.
10.03	3 ✓	>0.9999 ✓

---

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Start Time: 09:44

**O<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.2 %

Slope 333.1                      Intercept -11.0

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-2	0.0	0.0	0.0 ✓	Pass
10.1	3348	10.1	0.0	0.0 ✓	Pass
20.2	6739	20.3	0.1	0.5 ✓	Pass

**CO<sub>2</sub>**

Method: EPA 3A  
Span Conc. 20.3 %

Slope 398.4                      Intercept 25.3

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	4	-0.1	-0.1	-0.5 ✓	Pass
10.2	4116	10.3	0.1	0.5 ✓	Pass
20.3	8080	20.2	-0.1	-0.5 ✓	Pass

**SO<sub>2</sub>**

Method: EPA 6C  
Span Conc. 458 ppm

Slope 10.03                      Intercept 3

Standard	Response	Result	Difference	Error	Status
ppm	mv	ppm	ppm	%	
Zero	-5	-1	-1	-0.2 ✓	Pass
242	2450	244	2	0.4 ✓	Pass
458	4587	457	-1	-0.2 ✓	Pass



# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

---

**File:** C:\Data\210624 New Indy Catawba No. 2 CB.cem  
**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04  
**Computer:** WSAUBCHEMLABGC1 **Trailer:** 281  
**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T802 s/n: 172</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.2</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T802 s/n: 172</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.3</b>

## Channel 5

Analyte	<b>SO<sub>2</sub></b>
Method	<b>EPA 6C, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T100H SN 374</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, ppm	<b>500</b>
Span Concentration, ppm	<b>458</b>



**No. 2 COMBINATION BOILER  
(CONDITION 2: NCG GASES ONLY)**

New Indy  
Catawba, SC

15730.001.008  
No. 2 Combination Boiler  
Condition 2: NCGs Only

EMISSION CALCULATIONS

	Run 1	Run 2	Run 3	Mean
Date	6/25/21 ✓	6/25/21 ✓	6/25/21 ✓	---
Time Began	1000 ✓	1135 ✓	1315 ✓	---
Time Ended	1100 ✓	1235 ✓	1415 ✓	---
Volumetric Flow Rate, (Qs), DSCFM	1.56E+05 ✓	1.55E+05 ✓	1.56E+05 ✓	1.56E+05
BWS	0.139 ✓	0.142 ✓	0.139 ✓	0.140
% Oxygen	12.8 ✓	12.7 ✓	12.3 ✓	12.6

---

Sulfur Dioxide	MW= 64.06				
Concentration, ppm		247.0 ✓	245.0 ✓	235.0 ✓	242.3
Emission Rate, lb/hr		383.2	380.0	366.2	376.4

---

Total Reduced Sulfur	(TRS MW)= 34.08				
Concentration, ppm		1.04 ✓	0.99 ✓	0.76 ✓	0.93
Emission Rate, lb/hr		0.86	0.82	0.63	0.77

---

*AKW*

New Indy  
Catawba, SC

15730.001.008  
No. 2 Combination Boiler

**Condition 2: NCGs Only**

**ISOKINETIC CALCULATIONS**

Run Number	1	2	3	Mean
Date	6/25/21 ✓	6/25/21 ✓	6/25/21 ✓	---
Time Began	1000 ✓	1135 ✓	1315 ✓	---
Time Ended	1124 ✓	1259 ✓	1441 ✓	---

**INPUT DATA**

Sampling Time, min	(Theta)	64.0 ✓	64 ✓	64 ✓	64
Stack Diameter, in.	(Dia.)	120.00 ✓	120.00 ✓	120.00 ✓	120.00
Barometric Pressure, in. Hg	(Pb)	29.60 ✓	29.60 ✓	29.60 ✓	29.60
Static Pressure, in. H2O	(Pg)	-0.64 ✓	-0.64 ✓	-0.64 ✓	-0.64
Pitot Tube Coefficient	(Cp)	0.84 ✓	0.84 ✓	0.84 ✓	0.84
Meter Correction Factor	(Y)	0.9880 ✓	0.9880 ✓	0.9880 ✓	0.9880
Orifice Calibration Value	(Delta H@)	1.7320 ✓	1.7320 ✓	1.7320 ✓	1.7320
Nozzle Diameter, in.	(Dn)	0.250 ✓	0.250 ✓	0.250 ✓	0.250
Meter Volume, ft <sup>3</sup>	(Vm)	42.272 ✓	42.147 ✓	42.353 ✓	42.257
Meter Temperature, °F	(Tm)	85.8 ✓	93.1 ✓	95.3 ✓	91.4
Meter Temperature, °R	(Tm-R)	545.8	553.1	555.3	551.4
Meter Orifice Pressure, in. H2O	(Delta H)	1.300 ✓	1.300 ✓	1.300 ✓	1.300
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> avg)	1.140 ✓	1.140 ✓	1.140 ✓	1.140
Volume H2O Collected, mL	(Vlc)	137.1 ✓	138.6 ✓	135.0 ✓	136.9
CO2 Concentration, %	(CO2)	6.9 ✓	6.8 ✓	7.3 ✓	7.0
O2 Concentration, %	(O2)	12.8 ✓	12.7 ✓	12.3 ✓	12.6
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> avg)	0.897 ✓	0.901 ✓	0.908 ✓	0.902
Stack Temperature, °F	(Ts)	468.3 ✓	470.3 ✓	480.9 ✓	473.2
Stack Temperature, °R	(Ts-R)	928.3	930.3	940.9	933.2

**CALCULATED DATA**

Nozzle Area, ft <sup>2</sup>	(An)	3.41E-04	3.41E-04	3.41E-04	3.41E-04
Stack Area, ft <sup>2</sup>	(As)	78.54 ✓	78.54 ✓	78.54 ✓	78.54
Stack Pressure, in. Hg	(Ps)	29.55	29.55	29.55	29.55
Meter Pressure, in. Hg	(Pm)	29.70	29.70	29.70	29.70
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	40.087	39.435	39.477	39.667
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	6.453	6.524	6.354	6.444
Moisture Fraction (Measured)	(BWS)	0.139	0.142	0.139	0.140
Moisture Fraction (lower sat/meas)	(BWS)	0.139	0.142	0.139	0.140
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	29.62	29.60	29.66	29.62
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	28.01	27.95	28.04	28.00
Average Stack Gas Velocity, ft/sec	(Vs)	68.24	68.63	69.48	68.78
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	321588	323402	327406	324132
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	155554	155499	156245	155766
Calibration check	(Yqa)	0.9937	1.0037	0.9996	0.999
Percent difference from Y					1.11%

✓



# Isokinetic Field Data

# Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 2 Combination Boiler  
 Sample Location: Stack Outlet  
 W. O. Number: 15730.001.008  
 Run Number: 1  
 Date: 6/25/21  
 Test Personnel: ATL/LL  
 Sample Time: 64 min.

Console ID: A010  
 Meter Corr., Y: .988  
 Console ΔH@: 1.732  
 Probe ID/Length: PR5B  
 Liner Material: SS  
 Pitot ID/Coeff.: 0.84  
 Thermo ID: A010  
 Nozzle ID/Diams.: .250  
 Avg. Nozzle Diam.: .250 in.

Ambient Temp.: 80 °F  
 Baro. Pressure\*: 24.60 in. Hg  
 Static Pressure: -0.64 in. H<sub>2</sub>O  
 Impinger Gain: 128.06 mL  
 Silica Gel Gain: 137.1 g  
 Stack Area: 8.5 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: 1.4

### Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	<u>.002</u>	<u>.000</u>
Pitot	<u>8</u>	<u>5</u>
	<u>1000</u>	<u>.000</u>

Filter ID: NA  
 Sample ID: Run 1 NCB 604


TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TFMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
1-C	0	10:00			223.860									
2	84		.88	1.3	226.4	466	79	79	245	247		65	2.5	
3	88		.85	1.3	224.2	468	80	80	243	250		63	2.5	
4	112		.85	1.3	231.7	467	81	81	246	252		60	2.5	
1-D	120	10:22	.90	1.3	234.3	468	84	84	245	253		58	2.5	
2	124		.87	1.3	239.5	466	85	85	246	254		59	2.5	
3	2128		.85	1.3	242.2	467	87	87	245	255		58	2.5	
4	232	10:38	.80	1.3	244.8	471	88	88	244	256		55	2.5	
1-A	236	10:42	.80	1.3	247.4	470	89	89	244	256		54	2.5	
2	3046		.77	1.3	250.3	470	89	89	243	255		60	2.5	
3	3044		.90	1.3	252.5	469	88	88	243	254		55	2.5	
4	3648	10:58	.72	1.3	255.5	464	88	88	244	255		56	2.5	
1-B	3952	11:04	.82	1.3	258.0	464	89	89	245	256		57	2.5	
2	4256		.80	1.3	260.56.6	469	90	90	246	255		63	3	
3	4860		.72	1.3	263.3	469	90	90	245	253		59	3	
4	4864	11:24	.70	1.3	266.072	470	90	90	245	254		55	3	
*Barometric Pressure is at port elevation			Avg V <sub>sp</sub> .8473	Avg ΔH 1.3	Total Volume 42,272	Avg T <sub>s</sub> 468.31	Avg T <sub>d</sub> 85.75	Min/Max 247/256	Min/Max 243/246	Min/Max 247/256	Min/Max ✓	Max Temp 65	Max Vac 3	V <sub>m-std</sub> , scf

Flue Gas Composition: Oxygen, % 1.140; Carbon Dioxide, % NA; Moisture, % NA

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A Leak Check, Pre-run NA; Post-run NA

Thermocouple Check: Meter Temp., °F NA; % Isokinetic NA; Ref. Temp., °F NA; Calculated by NA; Result NA; QC by NA

15730.001.008  
 Pulp Dryer, #1 Paper Machine,  
 #2-3 S/D #1, & #1-2 CBs  
 Emission Report



Integrated Air Services



# Isokinetic Field Data

# Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 2 Combination Boiler  
 Sample Location: Stack outlet  
 W. O. Number: 15730.001.008  
 Run Number: 2  
 Date: 6/25/21  
 Test Personnel: ATL  
 Sample Time: 64 min.

Console ID: A010  
 Meter Corr., Y: 1.988  
 Console ΔH@: 1.732  
 Probe ID/Length: PR5B 5'  
 Liner Material: SS  
 Pitot ID/Coeff.: PI72 0.84  
 Thermo ID: A010  
 Nozzle ID/Diams.: 230 1.250  
 Avg. Nozzle Diam.: 1.230 in.

Ambient Temp.: 85 °F  
 Baro. Pressure\*: 29.60 in. Hg  
 Static Pressure: -64 in. H<sub>2</sub>O  
 Impinger Gain: 126.9 mL  
 Silica Gel Gain: 11.7 g  
 Stack Area: 78.54 ft<sup>2</sup>  
 Total Traverse Points: 16

K Factor: NA  
 Leak Checks

Volume, ft <sup>3</sup>	Initial	Final
@ Vac., in. Hg	1,000	1,000
Pitot	8	5
	1,000	1,000


Filter ID: NA  
 Sample ID: RUN2 NIGANBY

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE ΔP (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in. Hg)	COMMENTS
A-1 C	84	11:35	.87	1.3	266.300	467		90	242	250		66	3.215	
2	88		.89	1.3	271.5	470		90	244	244		64	2.5	
3	912		.85	1.3	274.2	471		91	245	253		59	2.5	
4	1216		.75	1.3	276.7	470		92	246	254		57	2.5	
B-1 D	1510	11:57	.92	1.3	274.4	468		92	247	256		64	2.5	
2	1824		.90	1.3	282.0	464		92	248	255		60	2.5	
3	2128		.85	1.3	285.0	464		93	247	256		59	2.5	
4	2432	11:13	.83	1.3	287.5	468		93	248	255		60	2.5	
B-1 A	2736	11:18	.85	1.3	246.0	467		94	249	256		65	2.5	
2	3040		.80	1.3	243.5	470		95	250	256		63	2.5	
3	3344		.80	1.3	245.4	471		94	251	256		61	3	
4	3648	11:34	.65	1.3	247.8	468		94	252	255		61	3	
B-1 B	3952	11:43	.86	1.3	300.6	467		95	244	247		65	3	
2	4256		.85	1.3	303.1	475		95	245	249		65	3	
3	4560		.69	1.3	305.4	477		95	261	250		64	3.5	
4	4864	11:59	.65	1.3	308.447	478		96	245	250		64	3.5	
Barometric Pressure is at port elevation			Avg ΔP	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>m</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Vac	Max Temp	Q <sub>s</sub> , dscfm
			.9005	1.3	42.117	470.31	93.123	242/265	247/256	247/256	247/256	3.5	65.66	3.5
			.8131	1.140										

Thermocouple Check: Meter Temp., °F 65.66 % Isokinetic ✓  
 Ref. Temp., °F 65.66 Calculated by ATL QC by ATL

O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A: Leak Check, Pre-run 71.1 Post-run 71.1

Flue Gas Composition: Oxygen, % 11.40  
 Carbon Dioxide, % NA  
 Moisture, % NA



Integrated Air Services



# Isokinetic Field Data

# Method: EPA 4, Moisture

Client: New Indy  
 Location/Plant: Catawba, SC  
 Source: No. 2 Combination Boiler  
 Sample Location: stacks only  
 W. O. Number: 15730.001.008  
 Run Number: 3  
 Date: 6/25/21  
 Test Personnel: ATR/LL  
 Sample Time: 64 min.

Console ID: A010  
 Meter Corr., Y: .988  
 Console ΔH@: 1.732  
 Probe ID/Length: PR53 5'  
 Liner Material: SS  
 Pitot ID/Coeff.: PT72 0.84  
 Thermo ID: A010  
 Nozzle ID/Diams.: .250 in.  
 Avg. Nozzle Diam.: .256 in.

Ambient Temp: 45 °F  
 Baro. Pressure\*: 29.60 in. Hg  
 Static Pressure: -64 in. H<sub>2</sub>O  
 Impinger Gain: 126.9 mL  
 Silica Gel Gain: 11.7 g

Stack Area: 78.54 ft<sup>2</sup>  
 Total Traverse Points: 16  
 Filter ID: NA  
 Sample ID: RUN3 NCG only


K Factor: NA  
 Leak Checks: Initial Final  
 Volume, ft<sup>3</sup>: .003 .001  
 @ Vac., in. Hg: 8 5  
 Pitot: .000 .000

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Δp (in. H <sub>2</sub> O)	ORIFICE PRESSURE ΔH (in. H <sub>2</sub> O)	DRY GAS METER READING (ft <sup>3</sup> )	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (°F)	FILTER EXIT TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VACUUM (in Hg)	COMMENTS
A-1 C	0	13:15			308.700									
2	84		.44	1.3	311.4	481	96	250	250	250		65	3	
3	88		.40	1.3	313.7	486	96	252	252	251		61	3	
4	12		.86	1.3	316.8	485	96	253	253	250		58	3	
B-1 D	16	13:31	.77	1.3	319.3	485	97	252	253	253		57	3.5	
2	20	13:37	.95	1.3	322.4	484	96	253	250	250		55	3.5	
3	24		.90	1.3	324.6	484	96	252	250	250		55	3.5	
4	28		.85	1.3	327.1	484	96	253	251	251		56	3.5	
A-1 A	32	13:53	.83	1.3	329.8	482	95	254	250	250		56	3.5	
2	36	13:58	.85	1.3	332.4	479	96	253	251	251		63	3.5	
3	40	14:04	.75	1.3	335.7	479	96	254	250	250		58	3.5	
4	44	14:14	.75	1.3	337.5	478	96	255	249	249		58	3.5	
B-1 B	48	13:14	.72	1.3	340.7	478	95	254	248	248		54	3.5	
2	52	13:25	.85	1.3	343.6	475	93	255	247	247		65	3.5	
3	56	14:25	.83	1.3	345.8	476	93	256	246	246		63	3.5	
4	60	14:41	.75	1.3	348.4	480	93	257	248	248		63	3.5	
4	64	14:44	.70	1.3	351.053	479	94	256	249	249		64	3.5	
Barometric Pressure is at port elevation			Avg Δp	Avg ΔH	Total Volume	Avg T <sub>s</sub>	Avg T <sub>o</sub>	Min/Max	Min/Max	Min/Max	Min/Max	Max Temp	Max Vac	V <sub>m-std</sub> scf
			.9080	1.3	412.353	480.9	95.25	250/251	247/253	247/253	247/253	65	3.5	

Flue Gas Composition 711 ✓  
 O<sub>2</sub>/CO<sub>2</sub> by Orsat Fyrite M3A  
 Leak Check, Pre-run: \_\_\_\_\_ Post-run: \_\_\_\_\_  
 Oxygen, %: \_\_\_\_\_  
 Carbon Dioxide, %: \_\_\_\_\_  
 Moisture, %: \_\_\_\_\_

Thermocouple Check: \_\_\_\_\_  
 Meter Temp., °F: \_\_\_\_\_  
 Ref. Temp., °F: \_\_\_\_\_  
 Result: \_\_\_\_\_  
 QC by: \_\_\_\_\_

15730.001.008  
 Paper Machine,  
 #1-3 SB, #4 & #1-2 CBs  
 Emission Report



Integrated Air Services



# Sample Recovery Field Data

Method: EPA 4, Moisture

Client New Indy  
Location/Plant Catawba, SC

Source No. 2 Combination Boiler  
W.O. Number 15730.001.008

Impingers 1 - 3 measurements in grams

Run No. 1 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID Run 1 NLG only Filter ID NA Analyst ATR

	Impingers			Imp. Total	Silica Gel grams	Total
	1	2	3			
Contents	DI	DI	empty			
Final	779.7	796.5	660.3		905.3	
Initial	670	780.9	657	✓	896.8	✓
Gain	109.7 ✓	15.6 ✓	3.3 ✓	128.6	8.5 ✓	137.1

Impinger Color clear Labeled? ✓  
 Silica Gel Condition \_\_\_\_\_ Sealed? ✓

Run No. 2 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID Run 2 NLG only Filter ID NA Analyst ATR

	Impingers			Imp. Total	Silica Gel grams	Total
	1	2	3			
Contents	DI	DI	empty			
Final	820.9	818.9	634.7		850.7	
Initial	718.5	797.1	632.0	✓	839.6	
Gain	102.4 ✓	21.8 ✓	2.7 ✓	126.9	11.7	138.6

Impinger Color clear Labeled? ✓  
 Silica Gel Condition used Sealed? ✓

Run No. 3 Sample Date 6/25/21 Recovery Date 6/25/21  
 Sample ID Run 3 NLG only Filter ID ATR Analyst ATR

	Impingers			Imp. Total	Silica Gel grams	Total
	1	2	3			
Contents	DI	DI	empty			
Final	744.7	742.1	645.5		939.4	
Initial	639.4	724.7	643.0	✓	929.6	
Gain	105.3 ✓	17.4 ✓	2.5 ✓	125.2	9.6	134.8

Impinger Color clear Labeled? ✓  
 Silica Gel Condition used Sealed? ✓

Check COC for Sample IDs of Media Blanks



# RUN SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**Start Time 10:00    End Time 11:00**

---

**Average Measured TRS Conc.**    0.98 ppm ✓  
**Recovery No. 2**    93.5 % ✓  
**TRS Corrected for Recovery**    1.04 ppm ✓

✓  
R

# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**Start Time 11:35    End Time 12:35**

---

**Average Measured TRS Conc.**    0.92 ppm ✓  
**Recovery No. 2**    93.5 % ✓  
**TRS Corrected for Recovery**    0.99 ppm ✓

✓

4

# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**Start Time 13:15    End Time 14:15**

---

**Average Measured TRS Conc.**    0.71 ppm ✓  
**Recovery No. 2**    93.5 % ✓  
**TRS Corrected for Recovery**    0.76 ppm ✓

✓

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS
	area	ppm	area	ppm	area	ppm	area	ppm	ppm
10:00	<2	<0.052	81	0.76	2	0.08	<2	<0.032	0.84
10:03	2	0.06	84	0.78	<2	<0.072	<2	<0.032	0.84
10:06	2	0.06	93	0.82	<2	<0.072	<2	<0.032	0.88
10:09	2	0.05	132	0.99	<2	<0.072	2	0.03	1.11
10:12	<2	<0.052	123	0.96	<2	<0.072	<2	<0.032	0.96
10:15	<2	<0.052	219	1.30	<2	<0.072	<2	<0.032	1.30
10:18	<2	<0.052	106	0.89	<2	<0.072	<2	<0.032	0.89
10:21	<2	<0.052	126	0.97	<2	<0.072	<2	<0.032	0.97
10:24	<2	<0.052	111	0.91	<2	<0.072	<2	<0.032	0.91
10:27	<2	<0.052	108	0.89	<2	<0.072	<2	<0.032	0.89
10:30	<2	<0.052	105	0.88	<2	<0.072	<2	<0.032	0.88
10:33	<2	<0.052	99	0.85	<2	<0.072	<2	<0.032	0.85
10:36	<2	<0.052	102	0.86	<2	<0.072	4	0.05	0.96
10:39	<2	<0.052	106	0.88	<2	<0.072	<2	<0.032	0.88
10:42	3	0.07	106	0.88	<2	<0.072	<2	<0.032	0.95
10:45	<2	<0.052	132	0.99	<2	<0.072	<2	<0.032	0.99
10:48	<2	<0.052	149	1.06	<2	<0.072	<2	<0.032	1.06
10:51	<2	<0.052	133	1.00	<2	<0.072	<2	<0.032	1.00
10:54	3	0.07	135	1.01	<2	<0.072	<2	<0.032	1.07
10:57	<2	<0.052	171	1.14	9	0.16	<2	<0.032	1.30
<b>Average</b>		<b>&lt;0.052</b>		<b>0.94</b>		<b>&lt;0.072</b>		<b>&lt;0.032</b>	<b>0.98</b> ✓

*VD*

# RUN DATA

Number 2

15730.001.008  
Pulp Dryer, #3 Paper Machine,  
#2-3 SDTVs, & #1-2 CBs  
Emission Report

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
11:35	<2	<0.052	93	0.82	4	0.11	<2	<0.032	0.93
11:38	<2	<0.052	104	0.87	<2	<0.072	<2	<0.032	0.87
11:41	<2	<0.052	98	0.85	<2	<0.072	<2	<0.032	0.85
11:44	<2	<0.052	85	0.78	<2	<0.072	<2	<0.032	0.78
11:47	<2	<0.052	147	1.05	<2	<0.072	<2	<0.032	1.05
11:50	<2	<0.052	201	1.24	<2	<0.072	<2	<0.032	1.24
11:53	<2	<0.052	160	1.10	<2	<0.072	3	0.04	1.18
11:56	<2	<0.052	105	0.88	<2	<0.072	<2	<0.032	0.88
11:59	<2	<0.052	129	0.98	<2	<0.072	<2	<0.032	0.98
12:02	<2	<0.052	156	1.08	<2	<0.072	<2	<0.032	1.08
12:05	2	0.05	180	1.17	<2	<0.072	<2	<0.032	1.23
12:08	<2	<0.052	132	0.99	<2	<0.072	<2	<0.032	0.99
12:11	<2	<0.052	96	0.84	<2	<0.072	<2	<0.032	0.84
12:14	<2	<0.052	109	0.89	<2	<0.072	<2	<0.032	0.89
12:17	<2	<0.052	81	0.77	<2	<0.072	<2	<0.032	0.77
12:20	<2	<0.052	76	0.74	<2	<0.072	2	0.03	0.81
12:23	<2	<0.052	75	0.73	<2	<0.072	<2	<0.032	0.73
12:26	<2	<0.052	74	0.73	<2	<0.072	<2	<0.032	0.73
12:29	<2	<0.052	105	0.88	<2	<0.072	<2	<0.032	0.88
12:32	<2	<0.052	81	0.77	<2	<0.072	<2	<0.032	0.77
<b>Average</b>		<b>&lt;0.052</b>		<b>0.91</b>		<b>&lt;0.072</b>		<b>&lt;0.032</b>	<b>0.92</b> ✓

*VD*

# RUN DATA

Number 3

15730.001.008  
Pulp Dryer, #3 Paper Machine,  
#2-3 SDTVs, & #1-2 CBs  
Emission Report

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	H <sub>2</sub> S		MeSH		DMS		DMDS		TRS ppm
	area	ppm	area	ppm	area	ppm	area	ppm	
13:15	<2	<0.052	68	0.70	<2	<0.072	<2	<0.032	0.70
13:18	<2	<0.052	62	0.66	3	0.09	<2	<0.032	0.75
13:21	<2	<0.052	62	0.67	<2	<0.072	<2	<0.032	0.67
13:24	<2	<0.052	62	0.67	<2	<0.072	<2	<0.032	0.67
13:27	<2	<0.052	62	0.66	<2	<0.072	3	0.04	0.75
13:30	<2	<0.052	63	0.67	<2	<0.072	<2	<0.032	0.67
13:33	<2	<0.052	65	0.68	<2	<0.072	<2	<0.032	0.68
13:36	<2	<0.052	64	0.68	<2	<0.072	<2	<0.032	0.68
13:39	<2	<0.052	68	0.70	<2	<0.072	<2	<0.032	0.70
13:42	<2	<0.052	71	0.71	<2	<0.072	<2	<0.032	0.71
13:45	2	0.05	77	0.74	4	0.10	<2	<0.032	0.90
13:48	<2	<0.052	65	0.68	<2	<0.072	<2	<0.032	0.68
13:51	<2	<0.052	66	0.69	<2	<0.072	<2	<0.032	0.69
13:54	<2	<0.052	73	0.72	<2	<0.072	<2	<0.032	0.72
13:57	<2	<0.052	67	0.69	<2	<0.072	2	0.03	0.76
14:00	<2	<0.052	71	0.71	<2	<0.072	<2	<0.032	0.71
14:03	<2	<0.052	70	0.71	<2	<0.072	<2	<0.032	0.71
14:06	<2	<0.052	71	0.71	<2	<0.072	<2	<0.032	0.71
14:09	<2	<0.052	64	0.67	3	0.09	<2	<0.032	0.76
14:12	<2	<0.052	66	0.69	<2	<0.072	<2	<0.032	0.69
<b>Average</b>		<b>&lt;0.052</b>		<b>0.69</b>		<b>&lt;0.072</b>		<b>&lt;0.032</b>	<b>0.71</b> ✓

*VD*





# RECOVERY DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

---

**Before Run 1**

Start Time 09:13    End Time 09:27

---

**Recovery Gas to Probe, Time 09:13**

Peak Areas, mv-sec			Average	ppm
12553	12693	12570	12606 ✓	7.31

---

**Recovery Gas to GC, Time 09:23**

Peak Areas, mv-sec			Average	ppm
15183	15401	15355	15313 ✓	8.16

---

---

Recovery 89.6% ✓

---

✓

# RECOVERY DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**  
Calibration **1**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**After Run 3    Before Run 4**  
**Start Time 14:27    End Time 15:01**

---

**Recovery Gas to Probe, Time 14:27**

<b>Peak Areas, mv-sec</b>			<b>Average</b>	<b>ppm</b>
12960	12992	13133	13028 ✓	7.45

---

**Recovery Gas to GC, Time 14:57**

<b>Peak Areas, mv-sec</b>			<b>Average</b>	<b>ppm</b>
14768	14713	14525	14669 ✓	7.97

---

**Recovery 93.5%** ✓

---

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Ambient Temperature: 72°C

Barometric Pressure: 29.55 in. Hg

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
Perm. Device ID	T-51828	33-53274	89-53332	89-53266
Perm. Rate, nL/min	348	365	473	239
Ret. Time, sec	16.0	22.5	48.0	127.0

**1** Flow = **38.4** mL/Min      **9.05** ppm      **9.51** ppm      **12.3** ppm      **6.22** ppm

Time: **06:02**

Peak Areas, mv-sec

18150	9129	29752	37042
18234	8899	29635	36567
17949	9072	29588	35648

Average Area

**18111** /      **9034** /      **29658** /      **36419** /

**2** Flow = **86.9** mL/Min      **4.00** ppm      **4.20** ppm      **5.44** ppm      **2.75** ppm

Time: **08:24**

Peak Areas, mv-sec

4494	1991	6636	8003
4478	2048	6673	8033
4420	2010	6502	8101

Average Area

**4464** /      **2016** /      **6604** /      **8046** /

**3** Flow = **191** mL/Min      **1.82** ppm      **1.92** ppm      **2.48** ppm      **1.25** ppm

Time: **08:49**

Peak Areas, mv-sec

1072	443	1449	1837
1039	453	1513	1835
1077	449	1476	1874

Average Area

**1063** /      **448** /      **1479** /      **1849** /

# CALIBRATION SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Method **16**

H <sub>2</sub> S	1	2	3		
Time	06:02	08:24	08:49		
Concentration, ppm	9.05	4.00	1.82		
Area, mv-sec	18111	4464	1063		
Calc. Conc., ppm	8.97	4.07	1.81		
% Error	-0.8	1.7	-0.9		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.7702	2.5709	0.9998	2	0.052

MeSH	1	2	3		
Time	06:02	08:24	08:49		
Concentration, ppm	9.51	4.20	1.92		
Area, mv-sec	9034	2016	448		
Calc. Conc., ppm	9.46	4.25	1.91		
% Error	-0.6	1.1	-0.6		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8751	2.1261	0.9999	2	0.11

DMS	1	2	3		
Time	06:02	08:24	08:49		
Concentration, ppm	12.3	5.44	2.48		
Area, mv-sec	29658	6604	1479		
Calc. Conc., ppm	12.2	5.49	2.47		
% Error	-0.5	1.0	-0.5		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8718	2.4355	0.9999	2	0.072

DMDS	1	2	3		
Time	06:02	08:24	08:49		
Concentration, ppm	6.22	2.75	1.25		
Area, mv-sec	36419	8046	1849		
Calc. Conc., ppm	6.21	2.76	1.25		
% Error	-0.2	0.4	-0.2		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8610	3.0854	>0.9999	2	0.032

*mu*

# CALIBRATION DATA

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

		Ambient Temperature: 72°C		Barometric Pressure: 29.65 in. Hg		
Analyte	H <sub>2</sub> S	MeSH	DMS	DMS		
Perm. Device ID	T-51828	33-53274	89-53332	89-53266		
Perm. Rate, nL/min	346	364	471	238		
Ret. Time, sec	16.0	22.5	48.0	127.0		
<hr/>						
<b>1</b>	Flow = <b>38.9</b> mL/Min	<b>8.90</b> ppm	<b>9.36</b> ppm	<b>12.1</b> ppm	<b>6.12</b> ppm	
	<b>Time: 06:02</b>	<b>Peak Areas, mv-sec</b>				
		18368	8795	28785	34758	
		18368	8383	27462	34707	
		18202	8971	28270	35006	
	<b>Average Area</b>	<b>18313</b> ✓	<b>8716</b> ✓	<b>28172</b> ✓	<b>34824</b> ✓	
<hr/>						
<b>2</b>	Flow = <b>82.3</b> mL/Min	<b>4.21</b> ppm	<b>4.42</b> ppm	<b>5.72</b> ppm	<b>2.89</b> ppm	
	<b>Time: 07:54</b>	<b>Peak Areas, mv-sec</b>				
		4753	2023	6969	8481	
		4768	2067	7036	8510	
		4706	2032	7080	8577	
	<b>Average Area</b>	<b>4742</b> ✓	<b>2041</b> ✓	<b>7028</b> ✓	<b>8523</b> ✓	
<hr/>						
<b>3</b>	Flow = <b>175</b> mL/Min	<b>1.98</b> ppm	<b>2.08</b> ppm	<b>2.69</b> ppm	<b>1.36</b> ppm	
	<b>Time: 08:29</b>	<b>Peak Areas, mv-sec</b>				
		1079	476	1619	1945	
		1065	464	1599	1933	
		1045	467	1556	1954	
	<b>Average Area</b>	<b>1063</b> ✓	<b>469</b> ✓	<b>1591</b> ✓	<b>1944</b> ✓	

*M*

# CALIBRATION SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Method **16**

H <sub>2</sub> S	1	2	3		
Time	06:02	07:54	08:29		
Concentration, ppm	8.90	4.21	1.98		
Area, mv-sec	18313	4742	1063		
Calc. Conc., ppm	8.80	4.31	1.96		
% Error	-1.2	2.4	-1.2		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.8930	2.4749	0.9996	2	0.071

MeSH	1	2	3		
Time	06:02	07:54	08:29		
Concentration, ppm	9.36	4.42	2.08		
Area, mv-sec	8716	2041	469		
Calc. Conc., ppm	9.35	4.43	2.08		
% Error	-0.1	0.1	-0.1		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9432	2.0539	>0.9999	2	0.13

DMS	1	2	3		
Time	06:02	07:54	08:29		
Concentration, ppm	12.1	5.72	2.69		
Area, mv-sec	28172	7028	1591		
Calc. Conc., ppm	12.0	5.81	2.67		
% Error	-0.8	1.5	-0.8		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9111	2.3864	0.9998	2	0.081

DMDS	1	2	3		
Time	06:02	07:54	08:29		
Concentration, ppm	6.12	2.89	1.36		
Area, mv-sec	34824	8523	1944		
Calc. Conc., ppm	6.09	2.92	1.35		
% Error	-0.5	1.1	-0.5		
<u>Calibration Curve</u>	<b>Slope</b>	<b>Intercept</b>	<b>Corr. Coeff.</b>	<b>Min. Area</b>	<b>Det. Lim.</b>
	1.9189	3.0366	0.9999	2	0.038

*AN*



# ANALYTES AND STANDARDS

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Analyte	H <sub>2</sub> S	MeSH	DMS	DMDS
<b>Molecular Weight</b>	34.08	48.11	62.14	94.20
<b>Retention Time, sec</b>	16.0	22.5	48.0	127.0
<b>Peak Detection Window, sec</b>	3.0	7.0	10.0	10.0
<b>Minimum Peak Area, mv-sec</b>	2	2	2	2
<b>Minimum Peak Height, mv</b>	1	1	1	1
<b>Beginning Peak Width, sec</b>	1.0	1.0	2.0	3.0
<b>Ending Peak Width, sec</b>	2.0	6.0	4.0	5.0
<b>Permeation Device ID</b>	T-51828	33-53274	89-53332	89-53266
<b>Permeation Rate, ng/min</b>	483	716	1197	918
<b>Permeation Rate, nL/min*</b>	346	364	471	238

**Barometric Pressure:** 29.65 in. Hg    **Ambient Temperature:** 72 °F  
No Oxygen Correction

\*Permeation rates are gravimetrically determined by the manufacturer with results by weight in ng/min. Permeation rates by volume, in nL/min, are calculated from the permeation rates by weight as follows:

$$PR_{nl} = PR_{ng} \times (V_{mol} / W_{mol}) \times [(460^\circ + T_a) / T_s] \times (P_s / P_b)$$

Where:

- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- PR<sub>ng</sub>** = Permeation Rate by weight, ng/min
- V<sub>mol</sub>** = Molar Volume of any gas @32 °F & 29.92 mm Hg = 22.4 L/mole
- W<sub>mol</sub>** = Molecular Weight of compound
- T<sub>a</sub>** = Ambient Temperature, °F
- T<sub>s</sub>** = Standard Temperature = 492°R (32 °F)
- P<sub>s</sub>** = Standard Pressure = 29.92 in Hg
- P<sub>b</sub>** = Barometric Pressure, in Hg

For example, H<sub>2</sub>S:

$$PR_{nl} = 483 \times (22.4 / 34.08) \times [(460 + 72) / 492] \times (29.92 / 29.65) = 346 \text{ nL/min}$$

To calculate concentrations:

$$C = PR_{nl} / F_d$$

Where:

- C** = Concentration, ppmv
- PR<sub>nl</sub>** = Permeation Rate by volume, nL/min
- F<sub>d</sub>** = Flow rate of diluent, mL/min

# INSTRUMENT INFORMATION

Client: **New Indy**  
Location: **Catawba, NC**  
Source: **#2 Combination Boiler**

Method **16**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

File: C:\Data\210625 New Indy Catawba No. 2 CB.trs  
Program Version: 2.0, built 15 May 2017 File Version: 2.0  
Computer: WLT5 Trailer: 281

Analog Input Device: MCC USB-1608G GC Channel: 16

Sampling Rate: 0.050 sec. Data Interval: 0.5 sec.

Gas Chromatograph: Shimadzu GC8-A Serial No. C10493615061  
Detector Range: 10

Gases			Temperatures, °C	Columns
	Press.	Flow		
	psi	mL/min		
H <sub>2</sub>	30	50	Column: 140	Primary: Carbopack
Air	30	60	Detector: 140	Secondary: N/A
Carrier	50	30		Sample Loop: 4"

## Injection Cycle

Total Length: 180 sec Sampling Time: 170 sec Load/Backflush Time: 80 sec

## Default Integration Parameters

Signal Threshold 0.67 mv Peak detection window ±10 sec  
Minimum peak area 2 mv-sec Minimum peak height 1 mv above baseline

## Dynacalibrator

Chamber Temperature 50.0°C  
Ambient Temperature 72.0°F  
Barometric Pressure 29.65 in. Hg

# RUN SUMMARY

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Method	O <sub>2</sub>	CO <sub>2</sub>	SO <sub>2</sub>
Conc. Units	EPA 3A	EPA 3A	EPA 6C
	%	%	ppm

Time: 10:00 to 11:00

**Run Averages**

12.7            6.9            239

**Pre-run Bias at 08:17**

Zero Bias	0.1	0.0	0
Span Bias	10.1	10.1	235
Span Gas	10.1	10.2	242

**Post-run Bias at 11:02**

Zero Bias	0.1	0.0	3
Span Bias	10.1	10.2	234
Span Gas	10.1	10.2	242

**Run averages corrected for the average of the pre-run and post-run bias**

12.8            6.9            247

# RUN SUMMARY

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Method Conc. Units	O <sub>2</sub> EPA 3A %	CO <sub>2</sub> EPA 3A %	SO <sub>2</sub> EPA 6C ppm
-----------------------	-------------------------------	--------------------------------	----------------------------------

Time: 11:35 to 12:35

### Run Averages

12.6                  6.8                  236

### Pre-run Bias at 11:02

Zero Bias	0.1	0.0	3
Span Bias	10.1	10.2	234
Span Gas	10.1	10.2	242

### Post-run Bias at 12:37

Zero Bias	0.1	0.0	4
Span Bias	10.1	10.3	233
Span Gas	10.1	10.2	242

**Run averages corrected for the average of the pre-run and post-run bias**

12.7                  6.8                  245

# RUN SUMMARY

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Method Conc. Units	O <sub>2</sub> EPA 3A %	CO <sub>2</sub> EPA 3A %	SO <sub>2</sub> EPA 6C ppm
-----------------------	-------------------------------	--------------------------------	----------------------------------

Time: 13:15 to 14:15

**Run Averages**

12.2            7.4            227

**Pre-run Bias at 12:37**

<b>Zero Bias</b>	0.1	0.0	4
<b>Span Bias</b>	10.1	10.3	233
<b>Span Gas</b>	10.1	10.2	242

**Post-run Bias at 14:18**

<b>Zero Bias</b>	0.1	0.0	3
<b>Span Bias</b>	10.1	10.3	235
<b>Span Gas</b>	10.1	10.2	242

**Run averages corrected for the average of the pre-run and post-run bias**

12.3            7.3            235

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
<b>With NCGs</b>						
<b>Traversed @ 16.6%, 50.0%, &amp; 83.3% of duct diameter</b>						
<b>Point 1</b>						
10:01	4314	13.0	2711	6.8	2231	223
10:02	4127	12.4	2693	6.8	2427	243
10:03	3866	11.6	2882	7.2	3028	303
10:04	4048	12.2	3101	7.8	2931	294
10:05	4371	13.1	2830	7.1	2792	280
10:06	4214	12.7	2598	6.5	2744	275
10:07	4404	13.2	2717	6.8	2549	255
10:08	4432	13.3	2556	6.4	2381	239
10:09	4440	13.3	2525	6.3	2263	227
10:10	4322	13.0	2519	6.3	2158	216
10:11	4328	13.0	2637	6.6	2162	217
10:12	4385	13.2	2626	6.6	2193	220
10:13	4522	13.6	2530	6.3	2241	224
10:14	4412	13.3	2437	6.1	2406	241
10:15	4514	13.6	2516	6.3	2379	238
10:16	4438	13.3	2431	6.1	2199	220
10:17	4257	12.8	2535	6.4	2174	218
10:18	4213	12.7	2737	6.9	2241	224
10:19	4345	13.1	2739	6.9	2209	221
10:20	4343	13.1	2616	6.6	2331	234
<b>Point 2</b>						
10:21	4252	12.8	2645	6.6	2363	237
10:22	4189	12.6	2732	6.9	2403	241
10:23	4205	12.6	2804	7.0	2439	244
10:24	4123	12.4	2800	7.0	2285	229
10:25	4217	12.7	2868	7.2	2134	214
10:26	4152	12.5	2778	7.0	2284	229
10:27	4109	12.4	2854	7.2	2237	224
10:28	4114	12.4	2884	7.2	2323	233
10:29	4040	12.2	2895	7.3	2347	235
10:30	4070	12.2	2951	7.4	2390	239
10:31	3914	11.8	2946	7.4	2766	277
10:32	3838	11.5	3092	7.8	2952	296
10:33	3878	11.7	3148	7.9	2802	281
10:34	3881	11.7	3100	7.8	2829	283
10:35	3805	11.4	3128	7.8	2819	282
10:36	3986	12.0	3176	8.0	2678	268
10:37	4082	12.3	2992	7.5	2502	251

# RUN DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
10:38	4118	12.4	2910	7.3	2587	259
10:39	4064	12.2	2896	7.3	2602	261
10:40	4051	12.2	2923	7.3	2579	258
<b>Point 3</b>						
10:41	4186	12.6	2928	7.3	2285	229
10:42	4176	12.6	2836	7.1	2194	220
10:43	4231	12.7	2826	7.1	2244	225
10:44	4271	12.8	2751	6.9	2227	223
10:45	4322	13.0	2714	6.8	2311	231
10:46	4389	13.2	2648	6.6	2366	237
10:47	4368	13.1	2573	6.5	2239	224
10:48	4347	13.1	2602	6.5	2140	214
10:49	4333	13.0	2620	6.6	2257	226
10:50	4389	13.2	2635	6.6	2143	215
10:51	4232	12.7	2598	6.5	2222	223
10:52	4255	12.8	2745	6.9	2179	218
10:53	4285	12.9	2723	6.8	2198	220
10:54	4371	13.1	2691	6.7	2220	222
10:55	4374	13.2	2595	6.5	2301	230
10:56	4456	13.4	2583	6.5	2244	225
10:57	4396	13.2	2507	6.3	2304	231
10:58	4354	13.1	2561	6.4	2323	233
10:59	4335	13.0	2615	6.6	2320	232
11:00	4399	13.2	2622	6.6	2200	220
<b>Avg</b> s	<b>4231</b>	<b>12.7</b>	<b>2747</b>	<b>6.9</b>	<b>2388</b>	<b>239</b>



# RUN DATA

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm

**With NCGs**

**Traversed @ 16.6%, 50.0%, & 83.3% of duct diameter**

**Point 1**

11:36	4344	13.1	2609	6.5	2261	226
11:37	4302	12.9	2557	6.4	2328	233
11:38	4175	12.6	2622	6.6	2380	238
11:39	4135	12.4	2769	6.9	2403	241
11:40	4229	12.7	2771	7.0	2418	242
11:41	4252	12.8	2693	6.8	2431	244
11:42	4261	12.8	2631	6.6	2427	243
11:43	4153	12.5	2685	6.7	2490	249
11:44	4244	12.8	2730	6.8	2490	249
11:45	4281	12.9	2656	6.7	2413	242
11:46	4400	13.2	2615	6.6	2123	213
11:47	4480	13.5	2486	6.2	2236	224
11:48	4425	13.3	2412	6.0	2247	225
11:49	4445	13.4	2459	6.2	2277	228
11:50	4390	13.2	2462	6.2	2327	233
11:51	4419	13.3	2488	6.2	2313	232
11:52	4366	13.1	2479	6.2	2272	228
11:53	4331	13.0	2541	6.4	2031	203
11:54	4329	13.0	2569	6.4	2137	214
11:55	4207	12.7	2585	6.5	2166	217

**Point 2**

11:56	4245	12.8	2684	6.7	2242	225
11:57	4192	12.6	2667	6.7	2295	230
11:58	4263	12.8	2684	6.7	2253	226
11:59	4309	13.0	2615	6.6	2229	223
12:00	4311	13.0	2583	6.5	2253	226
12:01	4327	13.0	2550	6.4	2272	228
12:02	4234	12.7	2559	6.4	2271	227
12:03	4198	12.6	2673	6.7	2349	235
12:04	4358	13.1	2680	6.7	2273	228
12:05	4368	13.1	2534	6.4	2076	208
12:06	4291	12.9	2540	6.4	2099	210
12:07	4292	12.9	2607	6.5	2241	224
12:08	4287	12.9	2607	6.5	2314	232
12:09	4245	12.8	2624	6.6	2453	246
12:10	4182	12.6	2653	6.7	2521	253
12:11	4156	12.5	2744	6.9	2493	250
12:12	4206	12.6	2740	6.9	2592	260

# RUN DATA

Number 2

Client: **New Indy**  
 Location: **Catawba, SC**  
 Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
 Operator: **VD**  
 Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
12:13	4209	12.7	2689	6.7	2605	261
12:14	4238	12.7	2684	6.7	2666	267
12:15	4158	12.5	2669	6.7	2715	272
<b>Point 3</b>						
12:16	4055	12.2	2753	6.9	2751	276
12:17	3990	12.0	2868	7.2	2688	269
12:18	3939	11.8	2950	7.4	2548	255
12:19	3957	11.9	2993	7.5	2572	258
12:20	3826	11.5	3008	7.5	2717	272
12:21	3759	11.3	3146	7.9	2831	284
12:22	3791	11.4	3207	8.0	2823	283
12:23	3992	12.0	3141	7.9	2505	251
12:24	4042	12.2	2991	7.5	2388	239
12:25	4027	12.1	2983	7.5	2136	214
12:26	4021	12.1	2991	7.5	2238	224
12:27	4113	12.4	2988	7.5	2358	236
12:28	4294	12.9	2842	7.1	2311	231
12:29	4137	12.4	2721	6.8	2274	228
12:30	4179	12.6	2858	7.2	2199	220
12:31	4196	12.6	2831	7.1	2153	216
12:32	4211	12.7	2813	7.1	2155	216
12:33	4133	12.4	2811	7.1	2187	219
12:34	4123	12.4	2892	7.3	2167	217
12:35	4132	12.4	2906	7.3	2212	222
<b>Avg</b> s	<b>4203</b>	<b>12.6</b>	<b>2722</b>	<b>6.8</b>	<b>2360</b>	<b>236</b>

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm

**With NCGs**

**Point 1 Traversed @ 16.6%, 50.0%, & 83.3% of duct diameter**

**Point 1**

13:16	4025	12.1	2990	7.5	2283	229
13:17	4006	12.0	2985	7.5	2344	235
13:18	4014	12.1	3013	7.6	2374	238
13:19	4052	12.2	2989	7.5	2389	239
13:20	4026	12.1	2953	7.4	2531	254
13:21	4003	12.0	2988	7.5	2655	266
13:22	4076	12.3	2998	7.5	2518	252
13:23	4126	12.4	2928	7.3	2216	222
13:24	4036	12.1	2880	7.2	2164	217
13:25	3976	12.0	2977	7.5	2201	220
13:26	4029	12.1	3036	7.6	2207	221
13:27	3877	11.7	3020	7.6	2279	228
13:28	3883	11.7	3156	7.9	2224	223
13:29	3890	11.7	3160	7.9	2165	217
13:30	3945	11.9	3138	7.9	2191	219
13:31	4007	12.1	3072	7.7	2198	220
13:32	3980	12.0	3028	7.6	2190	219
13:33	4062	12.2	3024	7.6	2210	221
13:34	4082	12.3	2955	7.4	2299	230
13:35	4002	12.0	2933	7.4	2245	225

**Point 2**

13:36	4004	12.0	3017	7.6	2066	207
13:37	4042	12.2	3000	7.5	2123	213
13:38	4037	12.1	2961	7.4	2120	212
13:39	4072	12.2	2957	7.4	2115	212
13:40	4138	12.4	2912	7.3	2161	216
13:41	4128	12.4	2868	7.2	2192	220
13:42	4223	12.7	2882	7.2	2218	222
13:43	4167	12.5	2797	7.0	2404	241
13:44	4237	12.7	2841	7.1	2304	231
13:45	4204	12.6	2772	7.0	2163	217
13:46	4107	12.4	2820	7.1	2120	212
13:47	4040	12.2	2935	7.4	2206	221
13:48	4047	12.2	3002	7.5	2151	215
13:49	4005	12.0	3011	7.6	2182	219
13:50	4072	12.2	3028	7.6	2200	220
13:51	4137	12.4	2957	7.4	2212	222
13:52	4252	12.8	2874	7.2	2237	224

# RUN DATA

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
13:53	4203	12.6	2762	6.9	2299	230
13:54	4079	12.3	2834	7.1	2325	233
13:55	4099	12.3	2931	7.4	2314	232
<b>Point 3</b>						
13:56	3918	11.8	2960	7.4	2285	229
13:57	4031	12.1	3101	7.8	2072	208
13:58	4012	12.1	3007	7.5	2181	218
13:59	4139	12.4	2984	7.5	2175	218
14:00	4064	12.2	2888	7.2	2212	222
14:01	4020	12.1	2962	7.4	2361	237
14:02	4061	12.2	2999	7.5	2467	247
14:03	4059	12.2	2957	7.4	2321	232
14:04	4063	12.2	2957	7.4	2171	217
14:05	4076	12.3	2967	7.4	2230	223
14:06	4174	12.6	2927	7.3	2244	225
14:07	4149	12.5	2840	7.1	2293	230
14:08	4155	12.5	2860	7.2	2376	238
14:09	3989	12.0	2886	7.2	2434	244
14:10	4063	12.2	3018	7.6	2362	237
14:11	4079	12.3	2977	7.5	2283	229
14:12	4160	12.5	2927	7.3	2279	228
14:13	4188	12.6	2828	7.1	2288	229
14:14	4006	12.0	2839	7.1	2371	238
14:15	3961	11.9	3031	7.6	2439	244
<b>Avg</b>	<b>4063</b>	<b>12.2</b>	<b>2955</b>	<b>7.4</b>	<b>2264</b>	<b>227</b>

**BIAS**  
Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 08:17

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

**Bias Results**

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	24	0.1	0.1	0.5	Pass
Span	10.1	3365	10.1	0.0	0.0	Pass

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

**Bias Results**

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	6	0.0	0.0	0.0	Pass
Span	10.2	4038	10.1	-0.1	-0.5	Pass

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

**Bias Results**

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	0	-0	0	0	0.0	Pass
Span	242	2341	235	-7	-1.5	Pass

# BIAS AND CALIBRATION DRIFT

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 11:02

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	27	0.1	0.1	0.5	Pass
Span	10.1	3356	10.1	0.0	0.0	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	%	mv	%	%	
Zero	0.1	27	0.1	0.0	Pass
Span	10.1	3356	10.1	0.0	Pass

\*Bias No. 1

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	24	0.0	0.0	0.0	Pass
Span	10.2	4048	10.2	0.0	0.0	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	%	mv	%	%	
Zero	0.0	24	0.0	0.0	Pass
Span	10.1	4048	10.2	0.1	Pass

\*Bias No. 1

# BIAS AND CALIBRATION DRIFT

Number 2

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 11:02

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

## Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	0	31	3	3	0.7	Pass
Span	242	2334	234	-8	-1.7	Pass

## Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	ppm	mv	ppm	%	
Zero	0	31	3	0.7	Pass
Span	235	2334	234	-0.2	Pass

\*Bias No. 1



# BIAS AND CALIBRATION DRIFT

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 12:37

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
<b>Gas</b>	<b>%</b>	<b>mv</b>	<b>%</b>	<b>%</b>	<b>%</b>	
<b>Zero</b>	0.0	13	0.1	0.1	0.5	Pass
<b>Span</b>	10.1	3353	10.1	0.0	0.0	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
<b>Gas</b>	<b>%</b>	<b>mv</b>	<b>%</b>	<b>%</b>	
<b>Zero</b>	0.1	13	0.1	0.0	Pass
<b>Span</b>	10.1	3353	10.1	0.0	Pass

\*Bias No. 2

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
<b>Gas</b>	<b>%</b>	<b>mv</b>	<b>%</b>	<b>%</b>	<b>%</b>	
<b>Zero</b>	0.0	3	0.0	0.0	0.0	Pass
<b>Span</b>	10.2	4094	10.3	0.1	0.5	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
<b>Gas</b>	<b>%</b>	<b>mv</b>	<b>%</b>	<b>%</b>	
<b>Zero</b>	0.0	3	0.0	0.0	Pass
<b>Span</b>	10.2	4094	10.3	0.1	Pass

\*Bias No. 2

# BIAS AND CALIBRATION DRIFT

Number 3

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 12:37

**SO<sub>2</sub>**

Method: EPA 6C

Span Conc. 458 ppm

## Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	0	35	4	4	0.9	Pass
Span	242	2329	233	-9	-2.0	Pass

## Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status	
Gas	ppm	mv	ppm	%		
Zero	3	35	4	1	0.2	Pass
Span	234	2329	233	-1	-0.2	Pass

\*Bias No. 2

# BIAS AND CALIBRATION DRIFT

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 14:18

**O<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.2 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	34	0.1	0.1	0.5	Pass
Span	10.1	3356	10.1	0.0	0.0	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	%	mv	%	%	
Zero	0.1	34	0.1	0.0	Pass
Span	10.1	3356	10.1	0.0	Pass

\*Bias No. 3

**CO<sub>2</sub>**  
Method: EPA 3A  
Span Conc. 20.3 %

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	%	mv	%	%	%	
Zero	0.0	3	0.0	0.0	0.0	Pass
Span	10.2	4085	10.3	0.1	0.5	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	%	mv	%	%	
Zero	0.0	3	0.0	0.0	Pass
Span	10.3	4085	10.3	0.0	Pass

\*Bias No. 3

# BIAS AND CALIBRATION DRIFT

Number 4

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 14:18

**SO<sub>2</sub>**  
Method: EPA 6C  
Span Conc. 458 ppm

### Bias Results

Standard	Cal.	Response	Bias	Difference	Error	Status
Gas	ppm	mv	ppm	ppm	%	
Zero	0	30	3	3	0.7	Pass
Span	242	2344	235	-7	-1.5	Pass

### Calibration Drift

Standard	Initial*	Final	Difference	Drift	Status
Gas	ppm	mv	ppm	%	
Zero	4	30	3	-0.2	Pass
Span	233	2344	235	0.4	Pass

\*Bias No. 3

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 08:01

**O<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	-2
10.1 ✓	XC013544B	3344
20.2 ✓	CC275468	6752

Curve Coefficients

Slope	Intercept	Corr. Coeff.
333.7	-15	>0.9999

**CO<sub>2</sub>**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results

%	Cylinder ID	Result, mv
Zero	-	7
10.2 ✓	XC013544B	4046
20.3 ✓	CC275468	8070

Curve Coefficients

Slope	Intercept	Corr. Coeff.
397.8	6	1.0000

# CALIBRATION DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

Start Time: 08:01

**SO<sub>2</sub>**

Method: EPA 6C

Calibration Type: Linear Regression

---

Calibration Results

ppm	Cylinder ID	Result, mv
Zero	-	-1
242 ✓	CC234516	2413
458 ✓	EB0108003	4578

---

Curve Coefficients

Slope	Intercept	Corr. Coeff.
10.00	-4	>0.9999

---

# CALIBRATION ERROR DATA

Number 1

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

Start Time: 08:01

**O<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.2 %

Slope 333.7

Intercept -14.5

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	-2	0.0	0.0	0.0	Pass
10.1	3344	10.1	0.0	0.0	Pass
20.2	6752	20.3	0.1	0.5	Pass

**CO<sub>2</sub>**

Method: EPA 3A

Span Conc. 20.3 %

Slope 397.8

Intercept 6.2

Standard	Response	Result	Difference	Error	Status
%	mv	%	%	%	
Zero	7	0.0	0.0	0.0	Pass
10.2	4046	10.2	0.0	0.0	Pass
20.3	8070	20.3	0.0	0.0	Pass

**SO<sub>2</sub>**

Method: EPA 6C

Span Conc. 458 ppm

Slope 10.00

Intercept -4

Standard	Response	Result	Difference	Error	Status
ppm	mv	ppm	ppm	%	
Zero	-1	0	0	0.0	Pass
242	2413	242	0	0.0	Pass
458	4578	458	0	0.0	Pass



# METHODS AND ANALYZERS

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **25 Jun 2021**

---

**File:** C:\Users\Dubayv\Desktop\Catawba\210625 New Indy Catawba No. 2 CB.cem

**Program Version:** 2.2, built 3 Jul 2020 **File Version:** 2.04

**Computer:** WSAUBCHEMLABGC1 **Trailer:** 281

**Analog Input Device:** Keithley KUSB-3108

---

## Channel 1

Analyte	<b>O<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T802 s/n: 172</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.2</b>

## Channel 2

Analyte	<b>CO<sub>2</sub></b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T802 s/n: 172</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, %	<b>25.0</b>
Span Concentration, %	<b>20.3</b>

## Channel 5

Analyte	<b>SO<sub>2</sub></b>
Method	<b>EPA 6C, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Teledyne T100H SN 374</b>
Full-Scale Output, mv	<b>10000</b>
Analyzer Range, ppm	<b>500</b>
Span Concentration, ppm	<b>458</b>



## APPENDIX G LABORATORY REPORT

---



2655 Park Center Dr., Suite A  
Simi Valley, CA 93065  
T: +1 805 526 7161  
[www.alsglobal.com](http://www.alsglobal.com)

## LABORATORY REPORT

July 15, 2021

Daniel Mallett  
New-Indy Catawba LLC  
5300 Cureton Ferry Road  
Catawba, SC 29704

**RE: DHEC Order**

Dear Daniel:

Enclosed are the results of the samples submitted to our laboratory on June 29, 2021. For your reference, these analyses have been assigned our service request number P2103465.

All analyses were performed according to our laboratory's NELAP and DoD-ELAP-approved quality assurance program. The test results meet requirements of the current NELAP and DoD-ELAP standards, where applicable, and except as noted in the laboratory case narrative provided. For a specific list of NELAP and DoD-ELAP-accredited analytes, refer to the certifications section at [www.alsglobal.com](http://www.alsglobal.com). Results are intended to be considered in their entirety and apply only to the samples analyzed and reported herein.

If you have any questions, please call me at (805) 526-7161.

Respectfully submitted,

**ALS | Environmental**

A handwritten signature in black ink that reads 'Sue Anderson'.

*By Sue Anderson at 5:44 pm, Jul 15, 2021*

Sue Anderson  
Project Manager



2655 Park Center Dr., Suite A  
Simi Valley, CA 93065  
T: +1 805 526 7161  
[www.alsglobal.com](http://www.alsglobal.com)

Client: New-Indy Catawba LLC  
Project: DHEC Order

Service Request No: P2103465

---

## CASE NARRATIVE

The samples were received intact under chain of custody on June 29, 2021 and were stored in accordance with the analytical method requirements. Please refer to the sample acceptance check form for additional information. The results reported herein are applicable only to the condition of the samples at the time of sample receipt.

### Sulfur Analysis

The samples were analyzed for five sulfur compounds using a gas chromatograph equipped with a sulfur chemiluminescence detector (SCD). All compounds with the exception of hydrogen sulfide and carbonyl sulfide are quantitated against the initial calibration curve for methyl mercaptan. This method is not included on the laboratory's NELAP or DoD-ELAP scope of accreditation.

---

*The results of analyses are given in the attached laboratory report. All results are intended to be considered in their entirety, and ALS Environmental (ALS) is not responsible for utilization of less than the complete report.*

*Use of ALS Environmental (ALS)'s Name. Client shall not use ALS's name or trademark in any marketing or reporting materials, press releases or in any other manner ("Materials") whatsoever and shall not attribute to ALS any test result, tolerance or specification derived from ALS's data ("Attribution") without ALS's prior written consent, which may be withheld by ALS for any reason in its sole discretion. To request ALS's consent, Client shall provide copies of the proposed Materials or Attribution and describe in writing Client's proposed use of such Materials or Attribution. If ALS has not provided written approval of the Materials or Attribution within ten (10) days of receipt from Client, Client's request to use ALS's name or trademark in any Materials or Attribution shall be deemed denied. ALS may, in its discretion, reasonably charge Client for its time in reviewing Materials or Attribution requests. Client acknowledges and agrees that the unauthorized use of ALS's name or trademark may cause ALS to incur irreparable harm for which the recovery of money damages will be inadequate. Accordingly, Client acknowledges and agrees that a violation shall justify preliminary injunctive relief. For questions contact the laboratory.*



2655 Park Center Dr., Suite A  
Simi Valley, CA 93065  
T: +1 805 526 7161  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Environmental – Simi Valley

CERTIFICATIONS, ACCREDITATIONS, AND REGISTRATIONS

Agency	Web Site	Number
Alaska DEC	<a href="http://dec.alaska.gov/eh/lab.aspx">http://dec.alaska.gov/eh/lab.aspx</a>	17-019
Arizona DHS	<a href="http://www.azdhs.gov/preparedness/state-laboratory/lab-licensure-certification/index.php#laboratory-licensure-home">http://www.azdhs.gov/preparedness/state-laboratory/lab-licensure-certification/index.php#laboratory-licensure-home</a>	AZ0694
Florida DOH (NELAP)	<a href="http://www.floridahealth.gov/licensing-and-regulation/environmental-laboratories/index.html">http://www.floridahealth.gov/licensing-and-regulation/environmental-laboratories/index.html</a>	E871020
Louisiana DEQ (NELAP)	<a href="http://www.deq.louisiana.gov/page/la-lab-accreditation">http://www.deq.louisiana.gov/page/la-lab-accreditation</a>	05071
Maine DHHS	<a href="http://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml">http://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml</a>	2018027
Minnesota DOH (NELAP)	<a href="http://www.health.state.mn.us/accreditation">http://www.health.state.mn.us/accreditation</a>	1776326
New Jersey DEP (NELAP)	<a href="http://www.nj.gov/dep/enforcement/oqa.html">http://www.nj.gov/dep/enforcement/oqa.html</a>	CA009
New York DOH (NELAP)	<a href="http://www.wadsworth.org/labcert/elap/elap.html">http://www.wadsworth.org/labcert/elap/elap.html</a>	11221
Oregon PHD (NELAP)	<a href="http://www.oregon.gov/oha/ph/LaboratoryServices/EnvironmentalLaboratoryAccreditation/Pages/index.aspx">http://www.oregon.gov/oha/ph/LaboratoryServices/EnvironmentalLaboratoryAccreditation/Pages/index.aspx</a>	4068-008
Pennsylvania DEP	<a href="http://www.dep.pa.gov/Business/OtherPrograms/Labs/Pages/Laboratory-Accreditation-Program.aspx">http://www.dep.pa.gov/Business/OtherPrograms/Labs/Pages/Laboratory-Accreditation-Program.aspx</a>	68-03307 (Registration)
PJLA (DoD ELAP)	<a href="http://www.pjlabs.com/search-accredited-labs">http://www.pjlabs.com/search-accredited-labs</a>	65818 (Testing)
Texas CEQ (NELAP)	<a href="http://www.tceq.texas.gov/agency/qa/env_lab_accreditation.html">http://www.tceq.texas.gov/agency/qa/env_lab_accreditation.html</a>	T104704413- 19-10
Utah DOH (NELAP)	<a href="http://health.utah.gov/lab/lab_cert_env">http://health.utah.gov/lab/lab_cert_env</a>	CA01627201 9-10
Washington DOE	<a href="http://www.ecy.wa.gov/programs/eap/labs/lab-accreditation.html">http://www.ecy.wa.gov/programs/eap/labs/lab-accreditation.html</a>	C946

Analyses were performed according to our laboratory's NELAP and DoD-ELAP approved quality assurance program. A complete listing of specific NELAP and DoD-ELAP certified analytes can be found in the certifications section at [www.alsglobal.com](http://www.alsglobal.com), or at the accreditation body's website.

Each of the certifications listed above have an explicit Scope of Accreditation that applies to specific matrices/methods/analytes; therefore, please contact the laboratory for information corresponding to a particular certification.

ALS ENVIRONMENTAL

DETAIL SUMMARY REPORT

Client: New-Indy Catawba LLC  
Project ID: DHEC Order

Service Request: P2103465

Date Received: 6/29/2021  
Time Received: 10:20

Sulfur Liq - Sulfur

Client Sample ID	Lab Code	Matrix	Date Collected	Time Collected	Sulfur Liq - Sulfur
3A-TRS 1000	P2103465-001	Water	6/24/2021	10:00	X
3A-TRS 1115	P2103465-002	Water	6/24/2021	11:15	X
3A-TRS 1210	P2103465-003	Water	6/24/2021	12:10	X
3A-TRS 1331	P2103465-004	Water	6/24/2021	13:31	X
3A-TRS 1450	P2103465-005	Water	6/24/2021	14:50	X
2A-TRS 1510	P2103465-006	Water	6/24/2021	15:10	X
2B-TRS 1515	P2103465-007	Water	6/24/2021	15:15	X
3A-TRS 1600	P2103465-008	Water	6/24/2021	16:00	X
2A-TRS 1700	P2103465-009	Water	6/24/2021	17:00	X
2B-TRS 1705	P2103465-010	Water	6/24/2021	17:05	X
2A-TRS 1845	P2103465-011	Water	6/24/2021	18:45	X
2B-TRS 1850	P2103465-012	Water	6/24/2021	18:50	X
3A-TRS Duplicate 1115	P2103465-013	Water	6/24/2021	11:15	X
2A-TRS Duplicate 1510	P2103465-014	Water	6/24/2021	15:10	X
2B-TRS Duplicate 1515	P2103465-015	Water	6/24/2021	15:15	X
3A-TRS 1403	P2103465-016	Water	6/25/2021	14:03	X
3A-TRS 1630	P2103465-017	Water	6/25/2021	16:30	X
3A-TRS 1740	P2103465-018	Water	6/25/2021	17:40	X
3A-TRS 1845	P2103465-019	Water	6/25/2021	18:45	X
3A-TRS 0817	P2103465-020	Water	6/25/2021	08:17	X
3A-TRS 0924	P2103465-021	Water	6/25/2021	09:24	X
3A-TRS 1030	P2103465-022	Water	6/25/2021	10:30	X
2A-TRS 1035	P2103465-023	Water	6/25/2021	10:35	X
2B-TRS 1040	P2103465-024	Water	6/25/2021	10:40	X
2A-TRS 1205	P2103465-025	Water	6/25/2021	12:05	X
2B-TRS 1210	P2103465-026	Water	6/25/2021	12:10	X
3A-TRS 1200	P2103465-027	Water	6/25/2021	12:00	X
3A-TRS 1255	P2103465-028	Water	6/25/2021	12:55	X
2A-TRS 1345	P2103465-029	Water	6/25/2021	13:45	X
2B-TRS 1350	P2103465-030	Water	6/25/2021	13:50	X
3A-TRS 1010	P2103465-031	Water	6/26/2021	10:10	X
3A-TRS 1125	P2103465-032	Water	6/26/2021	11:25	X
3A-TRS 1230	P2103465-033	Water	6/26/2021	12:30	X
3B-TRS 1305	P2103465-034	Water	6/26/2021	13:05	X
3A-TRS 1400	P2103465-035	Water	6/26/2021	14:00	X
3B-TRS 1415	P2103465-036	Water	6/26/2021	14:15	X
3A-TRS 1445	P2103465-037	Water	6/26/2021	14:45	X
3B-TRS 1530	P2103465-038	Water	6/26/2021	15:30	X
3A-TRS 1550	P2103465-039	Water	6/26/2021	15:50	X



2655 Park Center Drive, Suite A  
 Simi Valley, California 93065  
 Phone (805) 526-7161  
 Fax (805) 526-7270

Soil / Water - Chain of Custody Record & Analytical Service Request

Requested Turnaround Time in Business Days (Surcharges) please circle  
 1 Day (100%) 3 Day (75%) 4 Day (50%) 5 Day (35%) 10 Day (Standard)

CAS Project No. P2103465  
 CAS Contact:

Company Name & Address (Reporting Information)  
**New Indy Containe Boss!**

Project Manager  
**Don Mallett**

Phone  
**(805) 981-8010**

Fax

Email Address for Result Reporting  
**Don.mallett@new-indy.cb.com**

Client Sample ID	Laboratory ID Number	Date Collected	Time Collected	P.O. # / Credit Card / Billing Information			Other	Comments
				Water	Solid	Soil		
3A-TRS #1 1000	①	6-24-21	1000	X			Liquid Sulfur	Collection date
3A-TRS #2 1000		6-24-21	1000	X			Liquid Sulfur	and time are
3A-TRS #1 1115	①	6-24-21	1115	X			Liquid Sulfur	crucial for
3A-TRS #2 1115		6-24-21	1115	<			Liquid Sulfur	sample
3A-TRS #1 1210	①	6-24-21	1210	X			Liquid Sulfur	identification
3A-TRS #2 1210		6-24-21	1210	X			Liquid Sulfur	
3A-TRS #1 1331	①	6-24-21	1331	X			Liquid Sulfur	
3A-TRS #2 1331		6-24-21	1331	X			Liquid Sulfur	
3A-TRS #1 1450	①	6-24-21	1450	X			Liquid Sulfur	
3A-TRS #2 1450		6-24-21	1450	<			Liquid Sulfur	

Report Tier Levels - please select  
 Tier I - Results (Default if not specified)  
 Tier II (Results + QC Summaries)  
 Tier III (Results + QC & Calibration Summaries)  
 Tier IV (Data Validation Package) 10% Surcharge

EDD required Yes / No  
 Type:

Received by: (Signature)	Date	Time	Received by: (Signature)	Date	Time
<i>[Signature]</i>	6/24/21	1010	Ref secured Area	6-24-21	1010/1170
<i>[Signature]</i>	6/24/21	1215	Ref secured Area	6-24-21	1215/1340
<i>[Signature]</i>	6/24/21	1340	Ref secured Area	6-24-21	1445

1445  
 6-24-21  
 1020 20 not





2655 Park Center Drive, Suite A  
 Simi Valley, California 93065  
 Phone (805) 526-7161  
 Fax (805) 526-7270

**Soil / Water - Chain of Custody Record & Analytical Service Request**

Requested Turnaround Time in Business Days (Surcharges) please circle  
 1 Day (100%) 2 Day (75%) 3 Day (50%) 4 Day (35%) 5 Day (25%) 10 Day-Standard  
 CAS Project No. 103465  
 CAS Contact

Project Name		Analysis		Comments	
DHEC Order					
Project Number					
P.O. # / Credit Card / Billing Information					
Water	Soil	Solid	Other		
X				Liquid Sulfur	Collection
X					Date and
X					Time are
X					critical for
X					sample
X					identification
X					
X					
X					
X					
X					
X					

Client Sample ID	Laboratory ID Number	Date Collected	Time Collected	Water	Soil	Solid	Other
2A-TRS #1	1510	6-24-21	1510	X			
2A-TRS #2	1510	6-24-21	1510	X			
2B-TRS #1	1515	6-24-21	1515	X			
2B-TRS #2	1515	6-24-21	1515	X			
3A-TRS #1	1600	6-24-21	1600	X			
3A-TRS #2	1600	6-24-21	1600	X			
2A-TRS #1	1700	6-24-21	1700	X			
2A-TRS #2	1700	6-24-21	1700	X			
2B-TRS #1	1705	6-24-21	1705	X			
2B-TRS #2	1705	6-24-21	1705	X			

Company Name & Address (Reporting Information)  
**New Indy Contain Board**

Project Manager: **Don Mallett**  
 Phone: **1803 981-8010**  
 Email Address for Result Reporting: **don.mallett@new-indy.cb.com**

Relinquished by (Signature): *Dele Pedersen*  
 Relinquished by (Signature): *Simi Valley*  
 Relinquished by (Signature): *Dele Pedersen*

Report Tier Levels - please select  
 Tier I - Results (Default if not specified) \_\_\_\_\_  
 Tier II (Results + QC Summaries) \_\_\_\_\_  
 Tier III (Results + QC & Calibration Summaries) \_\_\_\_\_  
 Tier IV (Data Validation Package) 10% Surcharge \_\_\_\_\_

EDD required Yes / No  
 Type: \_\_\_\_\_

Date:	Time:	Received by: (Signature)	Date:	Time:
6/24/21	1515/1720	REF SECURE AREA	6/24/21	1515/1520
6/24/21	1600	REF SECURE AREA	6/24/21	1600
6/24/21	1705/1710	REF SECURE AREA	6/24/21	1705/1710

15730.001.008  
 Pulp Dryer, #3 Paper Machine,  
 #2-3 SDCV, & #1-2 CB  
 Emission Report







2655 Park Center Drive, Suite A  
 Simi Valley, California 93065  
 Phone (805) 526-7161  
 Fax (805) 526-7270

Soil / Water - Chain of Custody Record & Analytical Service Request

Requested Turnaround Time in Business Days (Surcharges) please circle  
 1 Day (100%) 2 Day (75%) 3 Day (50%) 4 Day (35%) 5 Day (25%) 10 Day-Standard

CAS Project No. 2103465

Project Name: DHEC Order

Project Number: P.O. # / Credit Card / Billing Information

Company Name & Address (Reporting Information)  
 New Indy Container Board  
 5300 Curleton Ferry Rd  
 Castaway, SC 29704

Project Manager: Don Mallett  
 Phone: (803) 981-8010  
 Fax: don.mallett@new-indy.cb.com

Client Sample ID	Laboratory ID Number	Date Collected	Time Collected	Water	Soil	Solid	Other	Analysis	Comments
3A-TRS #1	1403	6-25-21	1403	X				Liquid Sulfur	* Collection date and time are crucial for sample identification
3A-TRS #2	1403	6-25-21	1403	X					
3A-TRS #1	1630	6-25-21	1630	X					
3A-TRS #2	1630	6-25-21	1630	X					
3A-TRS #1	1740	6-25-21	1740	X					
3A-TRS #2	1740	6-25-21	1740	X					
3A-TRS #1	1845	6-25-21	1845	X					
3A-TRS #2	1845	6-25-21	1845	X					

Report Tier Levels - please select  
 Tier I - Results (Default if not specified) \_\_\_\_\_ EDD required Yes / No \_\_\_\_\_  
 Tier II (Results + QC Summaries) \_\_\_\_\_ Type: \_\_\_\_\_  
 Tier III (Results + QC & Calibration Summaries) \_\_\_\_\_  
 Tier IV (Data Validation Package) 10% Surcharge \_\_\_\_\_

Relinquished by: (Signature) \_\_\_\_\_ Date: 6-25-21 Time: 1405/1035/1745  
 Relinquished by: (Signature) \_\_\_\_\_ Date: 6-25-21 Time: 1405/1035/1745  
 Relinquished by: (Signature) \_\_\_\_\_ Date: 6-25-21 Time: 1405/1035/1745





2655 Park Center Drive, Suite A  
 Simi Valley, California 93085  
 Phone (805) 526-7161  
 Fax (805) 526-7270

Soil / Water - Chain of Custody Record & Analytical Service Request

Requested Turnaround Time in Business Days (Surcharges) please circle  
 1 Day (100%) 2 Day (75%) 3 Day (50%) 4 Day (25%) 5 Day (25%) 10 Day-Standard  
 CAS Project # D103465

Project Name  
**DHEC Order**

Project Number  
 P.O. # / Credit Card / Billing Information

Company Name & Address (Reporting Information)  
**New Indy Containing Board**  
**5300 Cuyler Ferry Rd**  
**Catawba, SC 29704**

Project Manager  
**Don Mallett**

Phone  
**(803) 981-8010**

Fax

Email Address for Result Reporting  
**don.mallett@new-indy.cb.com**

Client Sample ID	Laboratory ID Number	Date Collected	Time Collected	Water	Soil	Solid	Other	Analysis	Comments
3A-TRS #1	0817	6-25-21	0817	X					
3A-TRS #2	0817	6-25-21	0817						
3A-TRS #1	0924	6-25-21	0924						
3A-TRS #2	0924	6-25-21	0924						
3A-TRS #1	1030	6-25-21	1030						
3A-TRS #2	1030	6-25-21	1030						
2A-TRS #1	1035	6-25-21	1035						
2A-TRS #2	1035	6-25-21	1035						
2B-TRS #1	1040	6-25-21	1040						
2B-TRS #2	1040	6-25-21	1040						

Report Tier Levels - please select  
 Tier I - Results (Default if not specified) \_\_\_\_\_  
 Tier II (Results + QC Summaries) \_\_\_\_\_  
 Tier III (Results + QC & Calibration Summaries) \_\_\_\_\_  
 Tier IV (Data Validation Package) 10% Surcharge \_\_\_\_\_  
 EDD required Yes / No \_\_\_\_\_  
 Type: \_\_\_\_\_

Relinquished by: (Signature)	Date:	Received by: (Signature)	Date:	Time:
<i>[Signature]</i>	6/25/21	6/25/21	0820	0930/1035
<i>[Signature]</i>	6/25/21	6/25/21	1040	1040/1045
<i>[Signature]</i>				

Relinquished by: (Signature) \_\_\_\_\_  
 Relinquished by: (Signature) \_\_\_\_\_  
 Relinquished by: (Signature) \_\_\_\_\_



2655 Park Center Drive, Suite A  
 Simi Valley, California 93065  
 Phone (805) 526-7161  
 Fax (805) 526-7270

Soil / Water - Chain of Custody Record & Analytical Service Request

Requested Turnaround Time in Business Days (Surcharges) please circle  
 1 Day (100%) 2 Day (75%) 3 Day (50%) 4 Day (35%) 5 Day (25%) 10 Day-Standard  
 CAS Project No. **103465**  
 CAS Contact

Project Name  
**DHEC Order**  
 Project Number  
 P.O. # / Credit Card / Billing Information

Company Name & Address (Reporting Information)  
**New Indy Container Board**  
**5300 Cuyleron Ferry Rd**  
**Cotuit, MA 01922**  
 Project Manager  
**Don Mallett**  
 Phone  
**(803) 981-8010**  
 Fax

Email Address for Result Reporting  
**don.mallett@new-indy.cb.com**

Client Sample ID	Laboratory ID Number	Date Collected	Time Collected	Water	Soil	Solid	Other	Analysis	Comments
2A-TRS #1	1205	6-25-21	1205	X				Liquid Sulfur	* Collection date and time are crucial for sample identification
2A-TRS #2	1205	6-25-21	1205	X					
2B-TRS #1	1210	6-25-21	1210	X					
2B-TRS #2	1210	6-25-21	1210	X					
3A-TRS #1	1200	6-25-21	1200	X					
3A-TRS #2	1200	6-25-21	1200	X					
3A-TRS #1	1255	6-25-21	1255	X					
3A-TRS #2	1255	6-25-21	1255	X					
2A-TRS #1	1345	6-25-21	1345	X					
2A-TRS #2	1345	6-25-21	1345	X					
2B-TRS #1	1350	6-25-21	1350	X					
2B-TRS #2	1350	6-25-21	1350	X					

Report Tier Levels - please select  
 Tier I - Results (Default if not specified)  
 Tier II (Results + QC Summaries)  
 Tier III (Results + QC & Calibration Summaries)  
 Tier IV (Data Validation Package) 10% Surcharge  
 EDD required Yes / No  
 Type:  
 Relinquished by (Signature)  
**Dale Robinson**  
 Date: 6/25/21  
 Relinquished by (Signature)  
**[Signature]**  
 Date: 6/25/21  
 Relinquished by (Signature)  
**[Signature]**  
 Date: 6/25/21  
 Received by (Signature)  
**REF SECURE AREA**  
 Date: 6-25-21  
 Received by (Signature)  
**SECURE AREA**  
 Date: 6-25-21  
 Received by (Signature)  
**[Signature]**  
 Date: 6-25-21  
 Date: 12/15/1355  
 Date: 12/08/1300  
 Date: 6-25-21



2655 Park Center Drive, Suite A  
 Simi Valley, California 93065  
 Phone (805) 526-7161  
 Fax (805) 526-7270

Soil / Water - Chain of Custody Record & Analytical Service Request

Requested Turnaround Time in Business Days (Surcharges) please circle 1 Day (100%) <u>2</u> Day (75%) 3 Day (50%) 4 Day (35%) 5 Day (25%) 10 Day-Standard		CAS Project No. <u>P103465</u>
Project Name <b>DHEC Order</b>		
Project Number		
P.O. # / Credit Card / Billing Information		
CAS Contact		
Analysis		
Comments		

Company Name & Address (Reporting Information)		P.O. # / Credit Card / Billing Information		Requested Turnaround Time in Business Days (Surcharges) please circle			
New Indy Container Board 5300 Curleton Ferry Rd Castroville, CA 95004				1 Day (100%) <u>2</u> Day (75%) 3 Day (50%) 4 Day (35%) 5 Day (25%) 10 Day-Standard			
Project Manager	Phone	Fax	CAS Project No.				
Don Mallett	(803) 981-8010		P103465				
Email Address for Result Reporting don.mallett@new-indy.cb.com							
Client Sample ID	Laboratory ID Number	Date Collected	Time Collected	Water	Soil	Solid	Other
3A-TRS #1	1010	6-26-21	1010	X			
3A-TRS #2	1010	6-26-21	1010	X			
3A-TRS #1	1125	6-26-21	1125	X			
3A-TRS #2	1125	6-26-21	1125	X			
3A-TRS #1	1230	6-26-21	1230	X			
3A-TRS #2	1230	6-26-21	1230	X			
3B-TRS #1	1305	6-26-21	1305	X			
3B-TRS #2	1305	6-26-21	1305	X			
3A-TRS #1	1400	6-26-21	1400	X			
3A-TRS #2	1400	6-26-21	1400	X			
3B-TRS #1	1415	6-26-21	1415	X			
3B-TRS #2	1415	6-26-21	1415	X			

Tier III (Results + QC & Calibration Summaries)		Tier IV (Data Validation Package) 10% Surcharge	
Date:	Received by: (Signature)	Date:	Received by: (Signature)
6-26-21	Ref Secure Area	6-26-21	Ref Secure Area
6-26-21	Ref Secure Area	6-26-21	Ref Secure Area

Report Tier Levels - please select	
Tier I - Results (Default if not specified)	EDD required Yes / No
Tier II (Results + QC Summaries)	Type:

Relinquished by: (Signature)	Date:	Relinquished by: (Signature)	Date:
Bob Anderson	6-26-21	Bob Anderson	6-26-21
Bob Anderson	6-26-21	Bob Anderson	6-26-21

Relinquished by: (Signature)	Date:
Bob Anderson	6-26-21





**ALS Environmental  
Sample Acceptance Check Form**

Client: New-Indy Catawba LLC Work order: P2103465  
 Project: DHEC Order  
 Sample(s) received on: 6/29/21 Date opened: 6/29/21 by: ADAVID

**Note:** This form is used for all samples received by ALS. The use of this form for custody seals is strictly meant to indicate presence/absence and not as an indication of compliance or nonconformity. Thermal preservation and pH will only be evaluated either at the request of the client and/or as required by the method/SOP.

- |                                                                                                                                            | <u>Yes</u>                          | <u>No</u>                           | <u>N/A</u>                          |
|--------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|
| 1 Were <b>sample containers</b> properly marked with client sample ID?                                                                     | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 2 Did <b>sample containers</b> arrive in good condition?                                                                                   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 3 Were <b>chain-of-custody</b> papers used and filled out?                                                                                 | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 4 Did <b>sample container labels</b> and/or tags agree with custody papers?                                                                | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 5 Was <b>sample volume</b> received adequate for analysis?                                                                                 | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 6 Are samples within specified holding times?                                                                                              | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 7 Was proper <b>temperature</b> (thermal preservation) of cooler at receipt adhered to?<br>Cooler Temperature: 2° C Blank Temperature: ° C | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 8 Were <b>custody seals</b> on outside of cooler/Box/Container?<br>Location of seal(s) _____ Sealing Lid?                                  | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| Were signature and date included?                                                                                                          | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| Were seals intact?                                                                                                                         | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 9 Do containers have appropriate <b>preservation</b> , according to method/SOP or Client specified information?                            | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| Is there a client indication that the submitted samples are <b>pH</b> preserved?                                                           | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Were <b>VOA vials</b> checked for presence/absence of air bubbles?                                                                         | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| Does the client/method/SOP require that the analyst check the sample pH and <u>if necessary</u> alter it?                                  | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 10 <b>Tubes:</b> Are the tubes capped and intact?                                                                                          | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 11 <b>Badges:</b> Are the badges properly capped and intact?                                                                               | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Are dual bed badges separated and individually capped and intact?                                                                          | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |

Lab Sample ID	Container Description	Required pH *	Received pH	Adjusted pH	VOA Headspace (Presence/Absence)	Receipt / Preservation Comments
P2103465-001.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-001.02	40mL VOA NP				A	
P2103465-002.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-002.02	40mL VOA NP				A	
P2103465-003.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-003.02	40mL VOA NP				A	
P2103465-004.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-004.02	40mL VOA NP				A	
P2103465-005.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-005.02	40mL VOA NP				A	
P2103465-006.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-006.02	40mL VOA NP				A	
P2103465-007.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-007.02	40mL VOA NP				A	
P2103465-008.01	40mL VOA NP		1	6	A	GG 7/1/21

Explain any discrepancies: (include lab sample ID numbers): \_\_\_\_\_

RSK - MEEPP, HCL (pH<2); RSK - CO2, (pH 5-8); Sulfur (pH>4)

**ALS Environmental  
Sample Acceptance Check Form**

Client: New-Indy Catawba LLC Work order: P2103465  
 Project: DHEC Order  
 Sample(s) received on: 6/29/21 Date opened: 6/29/21 by: ADAVID

Lab Sample ID	Container Description	Required pH *	Received pH	Adjusted pH	VOA Headspace (Presence/Absence)	Receipt / Preservation Comments
P2103465-008.02	40mL VOA NP				A	
P2103465-009.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-009.02	40mL VOA NP				A	
P2103465-010.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-010.02	40mL VOA NP				A	
P2103465-011.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-011.02	40mL VOA NP				A	
P2103465-012.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-012.02	40mL VOA NP				A	
P2103465-013.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-013.02	40mL VOA NP				A	
P2103465-014.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-014.02	40mL VOA NP				A	
P2103465-015.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-015.02	40mL VOA NP				A	
P2103465-016.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-016.02	40mL VOA NP				A	
P2103465-017.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-017.02	40mL VOA NP				A	
P2103465-018.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-018.02	40mL VOA NP				A	
P2103465-019.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-019.02	40mL VOA NP				A	
P2103465-020.01	40mL VOA NP		1	6	A	GG 7/1/21
P2103465-020.02	40mL VOA NP				A	
P2103465-021.01	40mL VOA NP		1	6	A	GG 7/9/21
P2103465-021.02	40mL VOA NP				A	
P2103465-022.01	40mL VOA NP		1	6	A	GG 7/9/21
P2103465-022.02	40mL VOA NP				A	
P2103465-023.01	40mL VOA NP		1	6	A	GG 7/9/21
P2103465-023.02	40mL VOA NP				A	
P2103465-024.01	40mL VOA NP		1	6	A	GG 7/9/21
P2103465-024.02	40mL VOA NP				A	
P2103465-025.01	40mL VOA NP		1	6	A	GG 7/9/21
P2103465-025.02	40mL VOA NP				A	
P2103465-026.01	40mL VOA NP		1	6	A	GG 7/9/21
P2103465-026.02	40mL VOA NP				A	
P2103465-027.01	40mL VOA NP		1	6	A	GG 7/9/21
P2103465-027.02	40mL VOA NP				A	
P2103465-028.01	40mL VOA NP		1	6	A	GG 7/9/21

Explain any discrepancies: (include lab sample ID numbers): \_\_\_\_\_

RSK - MEEPP, HCL (pH<2); RSK - CO2, (pH 5-8); Sulfur (pH>4)



ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1000  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-001

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/24/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	200,000	170	
74-93-1	Methyl Mercaptan	740	240	
75-18-3	Dimethyl Sulfide	ND	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	ND	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1115  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-002

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/24/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	210,000	170	
74-93-1	Methyl Mercaptan	700	240	
75-18-3	Dimethyl Sulfide	ND	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	ND	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1210  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-003

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/24/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	170,000	170	
74-93-1	Methyl Mercaptan	640	240	
75-18-3	Dimethyl Sulfide	ND	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	ND	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.



**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1331  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-004

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/24/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	<b>160,000</b>	170	
74-93-1	Methyl Mercaptan	<b>540</b>	240	
75-18-3	Dimethyl Sulfide	ND	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	ND	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1450  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-005

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/24/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	<b>170,000</b>	170	
74-93-1	Methyl Mercaptan	<b>560</b>	240	
75-18-3	Dimethyl Sulfide	ND	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	ND	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2A-TRS 1510  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-006

**Test Code:** GC/SCD Reduced Sulfur Analysis  
**Instrument ID:** Agilent 6890A/GC13/SCD  
**Analyst:** Gilbert Gutierrez  
**Sample Type:** Water  
**Test Notes:**

**Date Collected:** 6/24/21  
**Date Received:** 6/29/21  
**Date Analyzed:** 7/1/21  
**Liquid Amount:** 1.0 ml(s)  
**Purge Volume:** 0.30 Liter(s)  
**Injection Volume(s):** 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	130,000	170	
74-93-1	Methyl Mercaptan	14,000	240	
75-18-3	Dimethyl Sulfide	16,000	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	13,000	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2B-TRS 1515  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-007

**Test Code:** GC/SCD Reduced Sulfur Analysis  
**Instrument ID:** Agilent 6890A/GC13/SCD  
**Analyst:** Gilbert Gutierrez  
**Sample Type:** Water  
**Test Notes:**

**Date Collected:** 6/24/21  
**Date Received:** 6/29/21  
**Date Analyzed:** 7/1/21  
**Liquid Amount:** 10 ml(s)  
**Purge Volume:** 0.30 Liter(s)  
**Injection Volume(s):** 0.20 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	5,000	4.2	
74-93-1	Methyl Mercaptan	200	5.9	
75-18-3	Dimethyl Sulfide	2,800	7.6	
75-15-0	Carbon Disulfide	ND	4.7	
624-92-0	Dimethyl Disulfide	4,100	5.8	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1600  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-008

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/24/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	190,000	170	
74-93-1	Methyl Mercaptan	830	240	
75-18-3	Dimethyl Sulfide	360	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	710	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2A-TRS 1700  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-009

**Test Code:** GC/SCD Reduced Sulfur Analysis  
**Instrument ID:** Agilent 6890A/GC13/SCD  
**Analyst:** Gilbert Gutierrez  
**Sample Type:** Water  
**Test Notes:**

**Date Collected:** 6/24/21  
**Date Received:** 6/29/21  
**Date Analyzed:** 7/1/21  
**Liquid Amount:** 1.0 ml(s)  
**Purge Volume:** 0.30 Liter(s)  
**Injection Volume(s):** 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	140,000	170	
74-93-1	Methyl Mercaptan	17,000	240	
75-18-3	Dimethyl Sulfide	18,000	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	14,000	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2B-TRS 1705  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-010

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/24/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.20 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	7,100	4.2	
74-93-1	Methyl Mercaptan	540	5.9	
75-18-3	Dimethyl Sulfide	2,900	7.6	
75-15-0	Carbon Disulfide	ND	4.7	
624-92-0	Dimethyl Disulfide	3,900	5.8	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.



ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2A-TRS 1845  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-011

**Test Code:** GC/SCD Reduced Sulfur Analysis  
**Instrument ID:** Agilent 6890A/GC13/SCD  
**Analyst:** Gilbert Gutierrez  
**Sample Type:** Water  
**Test Notes:**

**Date Collected:** 6/24/21  
**Date Received:** 6/29/21  
**Date Analyzed:** 7/1/21  
**Liquid Amount:** 1.0 ml(s)  
**Purge Volume:** 0.30 Liter(s)  
**Injection Volume(s):** 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	150,000	170	
74-93-1	Methyl Mercaptan	19,000	240	
75-18-3	Dimethyl Sulfide	18,000	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	16,000	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2B-TRS 1850  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-012

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/24/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.20 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	8,100	4.2	
74-93-1	Methyl Mercaptan	760	5.9	
75-18-3	Dimethyl Sulfide	3,000	7.6	
75-15-0	Carbon Disulfide	ND	4.7	
624-92-0	Dimethyl Disulfide	4,100	5.8	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS Duplicate 1115  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-013

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/24/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	190,000	170	
74-93-1	Methyl Mercaptan	840	240	
75-18-3	Dimethyl Sulfide	310	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	680	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2A-TRS Duplicate 1510  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-014

**Test Code:** GC/SCD Reduced Sulfur Analysis  
**Instrument ID:** Agilent 6890A/GC13/SCD  
**Analyst:** Gilbert Gutierrez  
**Sample Type:** Water  
**Test Notes:**

**Date Collected:** 6/24/21  
**Date Received:** 6/29/21  
**Date Analyzed:** 7/1/21  
**Liquid Amount:** 1.0 ml(s)  
**Purge Volume:** 0.30 Liter(s)  
**Injection Volume(s):** 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	140,000	170	
74-93-1	Methyl Mercaptan	14,000	240	
75-18-3	Dimethyl Sulfide	16,000	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	17,000	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2B-TRS Duplicate 1515  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-015

**Test Code:** GC/SCD Reduced Sulfur Analysis  
**Instrument ID:** Agilent 6890A/GC13/SCD  
**Analyst:** Gilbert Gutierrez  
**Sample Type:** Water  
**Test Notes:**

**Date Collected:** 6/24/21  
**Date Received:** 6/29/21  
**Date Analyzed:** 7/1/21  
**Liquid Amount:** 10 ml(s)  
**Purge Volume:** 0.30 Liter(s)  
**Injection Volume(s):** 0.20 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	3,200	4.2	
74-93-1	Methyl Mercaptan	94	5.9	
75-18-3	Dimethyl Sulfide	3,000	7.6	
75-15-0	Carbon Disulfide	ND	4.7	
624-92-0	Dimethyl Disulfide	4,400	5.8	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1403  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-016

**Test Code:** GC/SCD Reduced Sulfur Analysis  
**Instrument ID:** Agilent 6890A/GC13/SCD  
**Analyst:** Gilbert Gutierrez  
**Sample Type:** Water  
**Test Notes:**

**Date Collected:** 6/25/21  
**Date Received:** 6/29/21  
**Date Analyzed:** 7/1/21  
**Liquid Amount:** 1.0 ml(s)  
**Purge Volume:** 0.30 Liter(s)  
**Injection Volume(s):** 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	180,000	170	
74-93-1	Methyl Mercaptan	1,200	240	
75-18-3	Dimethyl Sulfide	400	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	840	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1630  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-017

**Test Code:** GC/SCD Reduced Sulfur Analysis  
**Instrument ID:** Agilent 6890A/GC13/SCD  
**Analyst:** Gilbert Gutierrez  
**Sample Type:** Water  
**Test Notes:**

**Date Collected:** 6/25/21  
**Date Received:** 6/29/21  
**Date Analyzed:** 7/1/21  
**Liquid Amount:** 1.0 ml(s)  
**Purge Volume:** 0.30 Liter(s)  
**Injection Volume(s):** 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	160,000	170	
74-93-1	Methyl Mercaptan	1,300	240	
75-18-3	Dimethyl Sulfide	ND	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	430	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.



**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1740  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-018

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	170,000	170	
74-93-1	Methyl Mercaptan	1,300	240	
75-18-3	Dimethyl Sulfide	ND	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	250	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1845  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-019

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	140,000	170	
74-93-1	Methyl Mercaptan	1,300	240	
75-18-3	Dimethyl Sulfide	ND	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	ND	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 0817  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-020

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/1/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	<b>190,000</b>	170	
74-93-1	Methyl Mercaptan	<b>790</b>	240	
75-18-3	Dimethyl Sulfide	ND	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	ND	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 0924  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-021

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.10 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	130,000	84	
74-93-1	Methyl Mercaptan	560	120	
75-18-3	Dimethyl Sulfide	170	150	
75-15-0	Carbon Disulfide	ND	93	
624-92-0	Dimethyl Disulfide	ND	120	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1030  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-022

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.10 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	150,000	84	
74-93-1	Methyl Mercaptan	710	120	
75-18-3	Dimethyl Sulfide	170	150	
75-15-0	Carbon Disulfide	ND	93	
624-92-0	Dimethyl Disulfide	ND	120	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2A-TRS 1035  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-023

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.10 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	130,000	84	
74-93-1	Methyl Mercaptan	12,000	120	
75-18-3	Dimethyl Sulfide	12,000	150	
75-15-0	Carbon Disulfide	ND	93	
624-92-0	Dimethyl Disulfide	11,000	120	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2B-TRS 1040  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-024

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.20 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	3,300	4.2	
74-93-1	Methyl Mercaptan	100	5.9	
75-18-3	Dimethyl Sulfide	2,400	7.6	
75-15-0	Carbon Disulfide	ND	4.7	
624-92-0	Dimethyl Disulfide	3,600	5.8	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.



**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2A-TRS 1205  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-025

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.10 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	120,000	84	
74-93-1	Methyl Mercaptan	10,000	120	
75-18-3	Dimethyl Sulfide	12,000	150	
75-15-0	Carbon Disulfide	ND	93	
624-92-0	Dimethyl Disulfide	9,600	120	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2B-TRS 1210  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-026

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 1.0 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	550	0.84	
74-93-1	Methyl Mercaptan	4.8	1.2	
75-18-3	Dimethyl Sulfide	1,900	1.5	
75-15-0	Carbon Disulfide	2.0	0.93	
624-92-0	Dimethyl Disulfide	3,000	1.2	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1200  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-027

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.10 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	130,000	84	
74-93-1	Methyl Mercaptan	620	120	
75-18-3	Dimethyl Sulfide	340	150	
75-15-0	Carbon Disulfide	ND	93	
624-92-0	Dimethyl Disulfide	550	120	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1255  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-028

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.10 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	140,000	84	
74-93-1	Methyl Mercaptan	730	120	
75-18-3	Dimethyl Sulfide	180	150	
75-15-0	Carbon Disulfide	ND	93	
624-92-0	Dimethyl Disulfide	ND	120	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2A-TRS 1345  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-029

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	190,000	170	
74-93-1	Methyl Mercaptan	22,000	240	
75-18-3	Dimethyl Sulfide	22,000	300	
75-15-0	Carbon Disulfide	ND	190	
624-92-0	Dimethyl Disulfide	23,000	230	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 2B-TRS 1350  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-030

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/25/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.30 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	3,500	2.8	
74-93-1	Methyl Mercaptan	260	3.9	
75-18-3	Dimethyl Sulfide	2,500	5.1	
75-15-0	Carbon Disulfide	ND	3.1	
624-92-0	Dimethyl Disulfide	4,300	3.9	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1010  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-031

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/26/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.20 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	90,000	42	
74-93-1	Methyl Mercaptan	1,100	59	
75-18-3	Dimethyl Sulfide	420	76	
75-15-0	Carbon Disulfide	ND	47	
624-92-0	Dimethyl Disulfide	710	58	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.



**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1125  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-032

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/26/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.10 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	75,000	84	
74-93-1	Methyl Mercaptan	1,700	120	
75-18-3	Dimethyl Sulfide	180	150	
75-15-0	Carbon Disulfide	ND	93	
624-92-0	Dimethyl Disulfide	170	120	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1230  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-033

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/26/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.10 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	59,000	84	
74-93-1	Methyl Mercaptan	2,000	120	
75-18-3	Dimethyl Sulfide	170	150	
75-15-0	Carbon Disulfide	ND	93	
624-92-0	Dimethyl Disulfide	ND	120	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3B-TRS 1305  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-034

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/26/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 1.0 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	9.4	0.84	
74-93-1	Methyl Mercaptan	7.7	1.2	
75-18-3	Dimethyl Sulfide	37	1.5	
75-15-0	Carbon Disulfide	ND	0.93	
624-92-0	Dimethyl Disulfide	11	1.2	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1400  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-035

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/26/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.10 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	42,000	84	
74-93-1	Methyl Mercaptan	1,500	120	
75-18-3	Dimethyl Sulfide	150	150	
75-15-0	Carbon Disulfide	ND	93	
624-92-0	Dimethyl Disulfide	170	120	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3B-TRS 1415  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-036

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/26/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 1.0 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	7.7	0.84	
74-93-1	Methyl Mercaptan	5.8	1.2	
75-18-3	Dimethyl Sulfide	42	1.5	
75-15-0	Carbon Disulfide	ND	0.93	
624-92-0	Dimethyl Disulfide	15	1.2	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1445  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-037

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/26/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 1.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.10 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	37,000	84	
74-93-1	Methyl Mercaptan	1,500	120	
75-18-3	Dimethyl Sulfide	ND	150	
75-15-0	Carbon Disulfide	ND	93	
624-92-0	Dimethyl Disulfide	120	120	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3B-TRS 1530  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-038

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/26/21  
Date Received: 6/29/21  
Date Analyzed: 7/9/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 1.0 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	5.4	0.84	
74-93-1	Methyl Mercaptan	5.9	1.2	
75-18-3	Dimethyl Sulfide	47	1.5	
75-15-0	Carbon Disulfide	ND	0.93	
624-92-0	Dimethyl Disulfide	17	1.2	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.



**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** 3A-TRS 1550  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P2103465-039

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: 6/26/21  
Date Received: 6/29/21  
Date Analyzed: 7/15/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 0.050 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	41,000	17	
74-93-1	Methyl Mercaptan	1,700	24	
75-18-3	Dimethyl Sulfide	190	30	
75-15-0	Carbon Disulfide	22	19	
624-92-0	Dimethyl Disulfide	81	23	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** Method Blank  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P210701-MB

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: NA  
Date Received: NA  
Date Analyzed: 7/01/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 1.0 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	ND	0.84	
74-93-1	Methyl Mercaptan	ND	1.2	
75-18-3	Dimethyl Sulfide	ND	1.5	
75-15-0	Carbon Disulfide	ND	0.93	
624-92-0	Dimethyl Disulfide	ND	1.2	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** Method Blank  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P210709-MB

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: NA  
Date Received: NA  
Date Analyzed: 7/09/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 1.0 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	ND	0.84	
74-93-1	Methyl Mercaptan	ND	1.2	
75-18-3	Dimethyl Sulfide	ND	1.5	
75-15-0	Carbon Disulfide	ND	0.93	
624-92-0	Dimethyl Disulfide	ND	1.2	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** Method Blank  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P210715-MB

Test Code: GC/SCD Reduced Sulfur Analysis  
Instrument ID: Agilent 6890A/GC13/SCD  
Analyst: Gilbert Gutierrez  
Sample Type: Water  
Test Notes:

Date Collected: NA  
Date Received: NA  
Date Analyzed: 7/15/21  
Liquid Amount: 10 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume(s): 1.0 ml(s)

CAS #	Compound	Result µg/L	MRL µg/L	Data Qualifier
7783-06-4	Hydrogen Sulfide	ND	0.84	
74-93-1	Methyl Mercaptan	ND	1.2	
75-18-3	Dimethyl Sulfide	ND	1.5	
75-15-0	Carbon Disulfide	ND	0.93	
624-92-0	Dimethyl Disulfide	ND	1.2	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

LABORATORY CONTROL SAMPLE / DUPLICATE LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** Duplicate Lab Control Sample  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P210701-DLCS

**Test Code:** GC/SCD Reduced Sulfur Analysis  
**Instrument ID:** Agilent 6890A/GC13/SCD  
**Analyst:** Gilbert Gutierrez  
**Sample Type:** Water  
**Test Notes:**

**Date Collected:** NA  
**Date Received:** NA  
**Date Analyzed:** 7/01/21  
**Liquid Amount:** 10.0 ml(s)  
**Purge Volume:** 0.30 Liter(s)  
**Injection Volume:** 0.10 ml(s)

CAS #	Compound	Spike Amount LCS / DLCS ug/L	Result		% Recovery		ALS		Data Qualifier
			LCS ug/L	DLCS ug/L	LCS	DLCS	Acceptance Limits	RPD Limit	
7783-06-4	Hydrogen Sulfide	413	396	440	96	107	68-129	11	16
74-93-1	Methyl Mercaptan	620	631	718	102	116	69-136	13	17

**ALS ENVIRONMENTAL**

LABORATORY CONTROL SAMPLE / DUPLICATE LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** Duplicate Lab Control Sample  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P210709-DLCS

**Test Code:** GC/SCD Reduced Sulfur Analysis  
**Instrument ID:** Agilent 6890A/GC13/SCD  
**Analyst:** Gilbert Gutierrez  
**Sample Type:** Water  
**Test Notes:**

Date Collected: NA  
Date Received: NA  
Date Analyzed: 7/09/21  
Liquid Amount: 10.0 ml(s)  
Purge Volume: 0.30 Liter(s)  
Injection Volume: 0.10 ml(s)

CAS #	Compound	Spike Amount	Result		% Recovery		ALS	RPD	RPD	Data
		LCS / DLCS ug/L	LCS ug/L	DLCS ug/L	LCS	DLCS	Acceptance Limits			
7783-06-4	Hydrogen Sulfide	413	499	430	121	104	68-129	15	16	
74-93-1	Methyl Mercaptan	620	822	703	133	113	69-136	16	17	

**ALS ENVIRONMENTAL**

LABORATORY CONTROL SAMPLE / DUPLICATE LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

**Client:** New-Indy Catawba LLC  
**Client Sample ID:** Duplicate Lab Control Sample  
**Client Project ID:** DHEC Order

ALS Project ID: P2103465  
ALS Sample ID: P210715-DLCS

**Test Code:** GC/SCD Reduced Sulfur Analysis  
**Instrument ID:** Agilent 6890A/GC13/SCD  
**Analyst:** Gilbert Gutierrez  
**Sample Type:** Water  
**Test Notes:**

**Date Collected:** NA  
**Date Received:** NA  
**Date Analyzed:** 7/15/21  
**Liquid Amount:** 10.0 ml(s)  
**Purge Volume:** 0.30 Liter(s)  
**Injection Volume:** 0.10 ml(s)

CAS #	Compound	Spike Amount LCS / DLCS ug/L	Result		% Recovery		ALS		RPD	RPD Limit	Data Qualifier
			LCS ug/L	DLCS ug/L	LCS	DLCS	Acceptance Limits	RPD			
7783-06-4	Hydrogen Sulfide	413	483	487	117	118	68-129	0.9	16		
74-93-1	Methyl Mercaptan	620	815	806	131	130	69-136	0.8	17		





## APPENDIX H QUALITY CONTROL DATA

---



## EQUIPMENT CALIBRATIONS


# S - Type Pitot Tube Inspection Data Form

Pitot Tube ID NO. P172 Length 5' Probe ID.No. AUB-PR-5B

If all Criteria PASS Cp is equal to 0.84

Inspection Date 1/6/2021 Individual Conducting Inspection DDS

PASS/FAIL




Distance to A Plane (PA) - inches 0.488 PASS  
Distance to B Plane (PB) - inches 0.488 PASS  
Pitot OD (D<sub>i</sub>) - inches 0.375

$1.05 D_i < P < 1.5 D_i$

PA must Equal PB




Are Open Faces Aligned Perpendicular to the Tube Axis  YES  NO PASS



Angle of Q1 from vertical A Tube - degrees (absolute) 1 PASS  
Angle of Q2 from vertical B Tube - degrees (absolute) 1 PASS


Q1 and Q2 must be  $\leq 10^\circ$



Angle of B1 from vertical A Tube - degrees (absolute) 1 PASS  
Angle of B1 from vertical B Tube - degrees (absolute) 0 PASS

B1 or B2 must be  $\leq 5^\circ$

Y = 1 O = 1




A = 0.976

Z must be  $\leq 0.125$  inches

Z = A sin Y = 0.0170 PASS


W must be  $\leq 0.03125$  inches

W = A sin O = 0.0170 PASS




Distance between Sample Nozzle and Pitot (X) - inches N/A PASS


X must be  $\geq 0.75$  inches



Impact Pressure Opening Plane is above the Nozzle Entry Plane  YES  NO  NA PASS



Thermocouple meets the Distance Criteria in the adjacent figure  YES  NO  NA PASS



Thermocouple meets the Distance Criteria in the adjacent figure  YES  NO  NA

## POSTTEST CHECK

Client New Indy Catawba Work Order Number 15730.001.008

Date 7-16-21 Damage Found?  YES  NO

Checked By SJA

## Stack Temperature Sensor Calibration Data

### Choose Reference Thermometer Below:

- Digital Thermometer - Omega Model CL3515R (Serial# 06000183)
- Digital Thermometer - Omega Model CL3515R (Serial# 12000230)

Thermocouple Number: AU-PR-5B      Length: 5'  
Date: 6-Jan-21  
Ambient Temperature, °F: 57  
Calibrator: DDS

Reference Point Number	Reference Temperature °F	Thermocouple Temperature °F	Temperature Difference %
1 - A	57	57	0.00
B	57	57	0.00
C	57	57	0.00
2 - A	38	38	0.00
B	38	38	0.00
C	38	38	0.00
3 - A	211	211	0.00
B	211	210	0.15
C	211	210	0.15

$$\text{Temp Diff (\%)} = \frac{(\text{Ref Temp, } ^\circ\text{F} + 460) - (\text{Therm Temp } ^\circ\text{F} + 460)}{\text{Ref Temp, } ^\circ\text{F} + 460} \times 100$$

Are all temperature differences less than +/- 1.5% ?      YES

### POSTTEST STACK TEMPERATURE SENSOR CALIBRATION DATA

Client: New Indy Catalyst  
Work Order Number: 15730.001.008  
Date: 7-16-21  
Calibrator: JJA

Ambient Temp, °F	Reference Temp, °F	Thermocouple Temp, °F	Temperature Diff, %
<u>75</u>	<u>76</u>	<u>76</u>	<u>0</u>

Was a pretest temperature correction used?    no  
Is temperature difference within +/- 1.5%    yes  
If no, calculations done once with recorded values and once with corrected values \_\_\_\_\_


# S - Type Pitot Tube Inspection Data Form

Pitot Tube ID NO. P77 Length 6' Probe ID.No. AUB-PR-6C

If all Criteria PASS Cp is equal to 0.84

Inspection Date 12/29/2020 Individual Conducting Inspection DDS


**PASS/FAIL**




Distance to A Plane (PA) - inches 0.434 PASS  
Distance to B Plane (PB) - inches 0.434 PASS  
Pitot OD (D<sub>t</sub>) - inches 0.375

$1.05 D_t < P < 1.5 D_t$

PA must Equal PB




Are Open Faces Aligned Perpendicular to the Tube Axis  YES  NO PASS



Angle of Q1 from vertical A Tube-degrees (absolute) 1 PASS  
Angle of Q2 from vertical B Tube-degrees (absolute) 2 PASS

Q1 and Q2 must be  $\leq 10^\circ$



Angle of B1 from vertical A Tube-degrees (absolute) 1 PASS  
Angle of B1 from vertical B Tube-degrees (absolute) 1 PASS

B1 or B2 must be  $\leq 5^\circ$


Y = 1 O = 1



A = 0.868


Z must be  $\leq 0.125$  inches

Z = A sin Y = 0.0151 PASS




W must be  $\leq 0.03125$  inches

W = A sin O = 0.0151 PASS




Distance between Sample Nozzle and Pitot (X) - inches N/A PASS


X must be  $\geq 0.75$  inches



Impact Pressure Opening Plane is above the Nozzle Entry Plane  YES  NO  NA PASS



Thermocouple meets the Distance Criteria in the adjacent figure  YES  NO  NA



Thermocouple meets the Distance Criteria in the adjacent figure  YES  NO  NA PASS

## POSTTEST CHECK

Client New Indy Catawba Work Order Number 15720.001.008

Date 7-16-21 Damage Found?  YES  NO

Checked By JMA

## Stack Temperature Sensor Calibration Data

### Choose Reference Thermometer Below:

- Digital Thermometer - Omega Model CL3515R (Serial# 06000183)
- Digital Thermometer - Omega Model CL3515R (Serial# 12000230)

Thermocouple Number: AUB-PR-6C      Length: 6'  
Date: 29-Dec-20  
Ambient Temperature, °F: 65  
Calibrator: DDS

Reference Point Number	Reference Temperature °F	Thermocouple Temperature °F	Temperature Difference %
1 - A	65	65	0.00
B	65	65	0.00
C	65	65	0.00
2 - A	34	34	0.00
B	34	34	0.00
C	34	34	0.00
3 - A	210	210	0.00
B	210	210	0.00
C	210	210	0.00

$$\text{Temp Diff (\%)} = \frac{|\text{Ref Temp, } ^\circ\text{F} + 460 - (\text{Therm Temp } ^\circ\text{F} + 460)|}{\text{Ref Temp, } ^\circ\text{F} + 460} \times 100$$

Are all temperature differences less than +/- 1.5% ?      YES

### POSTTEST STACK TEMPERATURE SENSOR CALIBRATION DATA

Client: New Indy Catering  
Work Order Number: 15730.001.008  
Date: 7-16-21  
Calibrator: JJA

Ambient Temp, °F	Reference Temp, °F	Thermocouple Temp, °F	Temperature Diff, %
<u>76</u>	<u>76</u>	<u>76</u>	<u>0</u>

Was a pretest temperature correction used?    no  
Is temperature difference within +/- 1.5%    yes  
If no, calculations done once with recorded values and once with corrected values \_\_\_\_\_


# S - Type Pitot Tube Inspection Data Form

Pitot Tube ID NO. P320 Length 8' Probe ID.No. AUB-PR-8L

If all Criteria PASS Cp is equal to 0.84

Inspection Date 1/5/2021 Individual Conducting Inspection DDS


PASS/FAIL



Distance to A Plane (PA) - inches 0.472 PASS  
Distance to B Plane (PB) - inches 0.472 PASS  
Pitot OD (D<sub>t</sub>) - inches 0.375

$1.05 D_t < P < 1.5 D_t$


PA must Equal PB



Are Open Faces Aligned Perpendicular to the Tube Axis

YES  NO


PASS



Angle of Q1 from vertical A Tube - degrees (absolute) 1 PASS

Angle of Q2 from vertical B Tube - degrees (absolute) 1 PASS

Q1 and Q2 must be  $\leq 10^\circ$




Angle of B1 from vertical A Tube - degrees (absolute) 0 PASS

Angle of B1 from vertical B Tube - degrees (absolute) 0 PASS

B1 or B2 must be  $\leq 5^\circ$


Y = 1 O = 0

A = 0.943




Z must be  $\leq 0.125$  inches

Z = A sin Y = 0.0165 PASS




W must be  $\leq 0.03125$  inches

W = A sin O = 0.0000 PASS



X must be  $\geq 0.75$  inches


Distance between Sample Nozzle and Pitot (X) - inches N/A PASS



Impact Pressure Opening Plane is above the Nozzle Entry Plane


YES  NO  
 NA

PASS



Thermocouple meets the Distance Criteria in the adjacent figure  YES  NO  NA

PASS



Thermocouple meets the Distance Criteria in the adjacent figure  YES  NO  NA

## POSTTEST CHECK

Client West Indy Contractors Work Order Number 15730.001.008  
Date 7-16-21 Damage Found? YES  NO  
Checked By JJA



## Stack Temperature Sensor Calibration Data

### Choose Reference Thermometer Below:

- Digital Thermometer - Omega Model CL3515R (Serial# 06000183)
- Digital Thermometer - Omega Model CL3515R (Serial# 12000230)

Thermocouple Number: AUB-PR-8L      Length: 8'  
Date: 5-Jan-21  
Ambient Temperature, °F: 63  
Calibrator: DDS

Reference Point Number	Reference Temperature °F	Thermocouple Temperature °F	Temperature Difference %
1 - A	63	62	0.19
B	63	62	0.19
C	63	62	0.19
2 - A	38	38	0.00
B	38	38	0.00
C	38	38	0.00
3 - A	211	211	0.00
B	211	211	0.00
C	211	211	0.00

$$\text{Temp Diff (\%)} = \frac{(\text{Ref Temp, } ^\circ\text{F} + 460) - (\text{Therm Temp } ^\circ\text{F} + 460)}{\text{Ref Temp, } ^\circ\text{F} + 460} \times 100$$

Are all temperature differences less than +/- 1.5% ?      YES

### POSTTEST STACK TEMPERATURE SENSOR CALIBRATION DATA

Client: New Tully Catumba  
Work Order Number: 15730.001.008  
Date: 7-6-21  
Calibrator: SJA

Ambient Temp, °F	Reference Temp, °F	Thermocouple Temp, °F	Temperature Diff, %
<u>77</u>	<u>77</u>	<u>77</u>	<u>0</u>


Was a pretest temperature correction used?    no  
Is temperature difference within +/- 1.5%    yes  
If no, calculations done once with recorded values and once with corrected values \_\_\_\_\_

# S - Type Pitot Tube Inspection Data Form

Pitot Tube ID NO. P147 Length 6' Probe ID.No. N/A  
Inspection Date 1/4/2021 Individual Conducting Inspection DDS

If all Criteria PASS Cp is equal to 0.84

**PASS/FAIL**



Distance to A Plane (PA) - inches 0.448 **PASS**  
Distance to B Plane (PB) - inches 0.448 **PASS**  
Pitot OD (D<sub>t</sub>) - inches 0.375

$1.05 D_t < P < 1.5 D_t$


PA must Equal PB



Are Open Faces Aligned Perpendicular to the Tube Axis


YES  NO

**PASS**



Angle of Q1 from vertical A Tube - degrees (absolute) 1 **PASS**  
Angle of Q2 from vertical B Tube - degrees (absolute) 1 **PASS**

Q1 and Q2 must be  $\leq 10^\circ$



Angle of B1 from vertical A Tube - degrees (absolute) 1 **PASS**



Angle of B1 from vertical B Tube - degrees (absolute) 1 **PASS**

B1 or B2 must be  $\leq 5^\circ$

Y = 1 O = 1




A = 0.8416

Z must be  $\leq 0.125$  inches

Z = A sin Y = 0.0156 **PASS**


W must be  $\leq 0.03125$  inches

W = A sin O = 0.0156 **PASS**




Distance between Sample Nozzle and Pitot (X) - inches N/A **PASS**

X must be  $\geq 0.75$  inches




Impact Pressure Opening Plane is above the Nozzle Entry Plane

YES  NO  
 NA



Thermocouple meets the Distance Criteria in the adjacent figure  YES  NO  NA **PASS**



Thermocouple meets the Distance Criteria in the adjacent figure  YES  NO  NA

## POSTTEST CHECK

Client New Indy Catauba Work Order Number 15730.001.008  
Date 7-16-21 Damage Found?  YES  NO  
Checked By ABF/TJA

# METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in colored boxes below, other columns are automatically calculated.

DATE: **6-May-2021** METER SERIAL #: **1557659** METER PART #: **AO10** METER ID: **200667181**

INITIAL: **29.41** FINAL: **28.44** AVG (P<sub>bar</sub>): **29.43**

BAROMETRIC PRESSURE (in Hg): **29.41** Calibrated by: **LoF**

CRITICAL ORIFICE SET SERIAL #: **1331s & 1825**

ORIFICE #	RUN #	K FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )		NET (V <sub>m</sub> )	AMBIENT F°		DGM F° INITIAL	DGM F° FINAL	Avg DGM F° T <sub>m</sub>	ELAPSED TIME (MIN) θ	DGM ΔH (in H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	(4) ΔH <sub>θ</sub>
				INITIAL	FINAL		F°	F°									
8	1	0.2300	21	610.700	622.158	11.458	65	65	67	67	66	38	0.26	11.321	11.227	0.992	1.657
12	2	0.3326	23	711.400	724.636	13.236	69	70	71	71	71	30	0.54	12.976	12.769	0.984	1.646
16	3	0.4379	22	696.255	711.015	12.760	68	69	69	69	69	22	0.97	12.558	12.34	0.983	1.711
19	4	0.5162	21	686.356	697.885	11.529	67	69	69	69	69	17	1.40	11.359	11.251	0.991	1.778
25	5	0.6846	19	650.247	665.402	35.155	67	69	69	69	69	39	2.50	34.730	34.233	0.986	1.815
31	6	0.8304	17	624.604	649.402	24.798	66	67	69	69	68	23	3.60	24.612	24.511	0.996	1.786

### USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

$$(1) V_m (std) = K_1 V_m \frac{P_{bar} + (\Delta H / 13.6)}{T_m} = \text{Net volume of gas sample passed through DGM, corrected to standard conditions}$$

$$(2) V_{cr} (std) = K' \sqrt{\frac{P_{bar} \theta}{T_{amb}}} = \text{Volume of gas sample passed through the critical orifice, corrected to standard conditions}$$

$$(3) Y = \frac{V_{cr} (std)}{V_m (std)} = \text{DGM calibration factor}$$

$$(4) \Delta H_{\theta} = \frac{\Delta H \cdot 0.0319 T_m \theta^2}{P_{bar} Y^2 V_m^2}$$

Individual Y's .02 from average? **PASS**

Individual ΔH<sub>θ</sub> values 0.15 from average? **PASS**

Average Y value +/- .02 of 1.000? **PASS**

Next Calibration Due By: **5/6/2022**

# METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in colored boxes below, other columns are automatically calculated.

DATE: **4-May-2021** METER SERIAL #: **6842580** BAROMETRIC PRESSURE (in Hg): **29.21** AVG (P<sub>bar</sub>): **29.24** Barometer ID: **200567181**

METER PART #: **A023** CRITICAL ORIFICE SET SERIAL #: **1331s & 1825** Calibrated by: **LoF**

ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )		AMBIENT F°		DGM F° INITIAL	DGM F° FINAL	Avg DGM F° T <sub>m</sub>	ELAPSED TIME (MIN)	DGM ΔH (in H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	(4) ΔH <sub>g</sub>
				INITIAL	FINAL	INITIAL	FINAL									
8	1	0.2300	24	936.000	945.384	79	80	79	80	80	31	0.26	8.983	8.983	1.000	1.669
12	2	0.3326	21	970.300	976.463	82	83	83	83	83	14	0.57	5.866	5.85	0.987	1.751
16	3	0.4379	21	978.531	984.290	83	84	83	84	84	10	1.03	5.483	5.496	1.002	1.831
19	4	0.5162	20	919.000	935.661	77	79	78	79	79	25	1.40	16.024	16.288	1.016	1.791
25	5	0.6846	17	963.500	969.840	82	83	82	83	83	7	2.60	6.071	6.021	0.982	1.906
31	6	0.8304	16	948.400	959.124	81	82	81	82	82	10	3.70	10.316	10.442	1.012	1.854
													AVG =		<b>1.003</b>	<b>1.800</b>

### USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

$$(1) V_m (std) = K_1 V_m \frac{P_{bar} + (\Delta H / 13.6)}{T_m} = \text{Net volume of gas sample passed through DGM, corrected to standard conditions}$$

$$(2) V_{cr} (std) = K' \sqrt{\frac{P_{bar} \theta}{T_{amb}}} = \text{Volume of gas sample passed through the critical orifice, corrected to standard conditions}$$

$$(3) Y = \frac{V_{cr} (std)}{V_m (std)} = \text{DGM calibration factor}$$

$$(4) \Delta H_g = \frac{\Delta H \cdot 0.0319 T_m \theta^2}{P_{bar} Y^2 V_m^2}$$

Individual ΔH<sub>g</sub> values 0.15 from average?  
Average Y value +/- 0.02 of 1.000?

**PASS**  
**PASS**  
**PASS**

K<sub>1</sub> = 17.64 °R/in. Hg (English), 0.3858 °K/mm Hg (Metric)  
T<sub>m</sub> = Absolute DGM avg. temperature (°R - English, °K - Metric)

T<sub>amb</sub> = Absolute ambient temperature (°R - English, °K - Metric)  
K = Average K' factor from Critical Orifice Calibration

Next Calibration Due By: **5/4/2022**



### METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in colored boxes below, other columns are automatically calculated.

DATE: **14-May-2021** METER SERIAL #: **9717.61** METER PART #: **AO25** CRITICAL ORIFICE SET SERIAL #: **1331s & 1825** INITIAL: **29.59** FINAL: **29.59** AVG (P<sub>bar</sub>): **29.59** Barometer ID: **200567181**

BAROMETRIC PRESSURE (in Hg): **29.59** Calibrated by: **LoF**

ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )		AMBIENT F°	DGM F°		Avg DGM F° T <sub>m</sub>	ELAPSED TIME (MIN)	DGM ΔH (in H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	(4) ΔH <sub>θ</sub>
				INITIAL	FINAL		INITIAL	FINAL							
8	1	0.2300	23	929.100	937.472	69	70	71	71	28	0.30	8.248	8.288	1.005	1.900
12	2	0.3326	21	937.711	946.387	70	71	71	71	20	0.64	8.547	8.552	1.001	1.943
16	3	0.4379	21	972.140	989.873	71	73	74	74	31	1.20	17.412	17.437	1.001	2.102
19	4	0.5162	19	913.500	928.906	68	68	69	69	23	1.60	15.285	15.293	1.001	2.028
25	5	0.6846	17	962.902	971.830	71	72	73	73	10	2.95	8.821	8.793	0.997	2.137
31	6	0.8304	15	947.100	962.183	71	72	72	72	14	4.40	14.969	14.933	0.988	2.183
												AVG =		<b>1.000</b>	<b>2.049</b>

#### USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

$$(1) V_m (std) = \frac{K_1 V_m (P_{bar} + (\Delta H/13.6))}{T_m} = \text{Net volume of gas sample passed through DGM, corrected to standard conditions}$$

$$(2) V_{cr} (std) = K' \sqrt{\frac{P_{bar} \theta}{T_{amb}}} = \text{Volume of gas sample passed through the critical orifice, corrected to standard conditions}$$

$$(3) Y = \frac{V_{cr} (std)}{V_m (std)} = \text{DGM calibration factor}$$

$$(4) \Delta H_{\theta} = \frac{\Delta H \cdot 0.0319 T_m \theta^2}{P_{bar} Y^2 V_m^2}$$

Individual Y's 02 from average? **PASS**  
 Individual ΔH<sub>θ</sub> values 0.15 from average? **PASS**  
 Average Y value +/- 02 of 1.000? **PASS**

Next Calibration Due By: **5/11/2022**



## CALIBRATION GAS CERTIFICATES

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number: E03NI80E15A0138	Reference Number: 122-402016392-1
Cylinder Number: XC013544B	Cylinder Volume: 150.9 CF
Laboratory: 124 - Durham (SAP) - NC	Cylinder Pressure: 2015 PSIG
PGVP Number: B22021	Valve Outlet: 590
Gas Code: CO2,O2,BALN	Certification Date: Feb 01, 2021

**Expiration Date: Feb 01, 2029**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	10.00 %	10.16 %	G1	+/- 0.6% NIST Traceable	02/01/2021
OXYGEN	10.00 %	10.14 %	G1	+/- 0.7% NIST Traceable	02/01/2021
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13060638	CC414571	13.359 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	May 14, 2025
NTRM	10010616	K014963	9.967 % OXYGEN/NITROGEN	+/- 0.3%	Apr 19, 2022

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VA-5001 CO2 BF89GV17	Nondispersive Infrared (NDIR)	Jan 06, 2021
Horiba MPA510 O2 41499150042	Paramagnetic	Jan 07, 2021

Triad Data Available Upon Request



\_\_\_\_\_  
Signature on file  
Approved for Release



# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number:	E03NI60E15A0286	Reference Number:	122-402008217-1
Cylinder Number:	CC275468	Cylinder Volume:	159.6 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22021	Valve Outlet:	590
Gas Code:	CO2,O2,BALN	Certification Date:	Jan 22, 2021

**Expiration Date: Jan 22, 2029**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

### ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	20.00 %	20.27 %	G1	+/- 0.6% NIST Traceable	01/22/2021
OXYGEN	20.00 %	20.24 %	G1	+/- 0.9% NIST Traceable	01/22/2021
NITROGEN	Balance				

### CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12061508	CC354696	19.87 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 11, 2024
NTRM	08010202	1D003076	23.20 % OXYGEN/NITROGEN	+/- 0.4%	Jun 01, 2024

### ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VA-5001 CO2 BF89GV17	Nondispersive Infrared (NDIR)	Jan 06, 2021
Horiba MPA510 O2 41499150042	Paramagnetic	Jan 07, 2021

Triad Data Available Upon Request



Signature on file

Approved for Release



**Airgas Specialty Gases**  
Airgas USA, LLC  
630 United Drive  
Durham, NC 27713  
Airgas.com

## CERTIFICATE OF ANALYSIS

### Grade of Product: EPA Protocol

Part Number:	E03NI80E15A0138	Reference Number:	122-402016392-1
Cylinder Number:	SG9168283BAL	Cylinder Volume:	150.9 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22021	Valve Outlet:	590
Gas Code:	CO2,O2,BALN	Certification Date:	Feb 01, 2021

**Expiration Date: Feb 01, 2029**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	10.00 %	10.16 %	G1	+/- 0.6% NIST Traceable	02/01/2021
OXYGEN	10.00 %	10.12 %	G1	+/- 0.5% NIST Traceable	02/01/2021
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13060638	CC414571	13.359 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	May 14, 2025
NTRM	10010616	K014963	9.967 % OXYGEN/NITROGEN	+/- 0.3%	Apr 19, 2022

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VA-5001 CO2 BF89GV17	Nondispersive Infrared (NDIR)	Jan 06, 2021
Horiba MPA510 O2 41499150042	Paramagnetic	Jan 07, 2021

Triad Data Available Upon Request



\_\_\_\_\_  
Signature on file  
Approved for Release



**Airgas Specialty Gases**  
 Airgas USA, LLC  
 630 United Drive  
 Durham, NC 27713  
 Airgas.com

## CERTIFICATE OF ANALYSIS

### Grade of Product: EPA Protocol

Part Number:	E03NI60E15A0286	Reference Number:	122-401761927-1
Cylinder Number:	CC454190	Cylinder Volume:	159.6 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22020	Valve Outlet:	590
Gas Code:	CO2,O2,BALN	Certification Date:	Mar 16, 2020

**Expiration Date: Mar 16, 2028**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	20.00 %	20.41 %	G1	+/- 0.7% NIST Traceable	03/16/2020
OXYGEN	20.00 %	19.46 %	G1	+/- 0.5% NIST Traceable	03/16/2020
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12061508	CC354696	19.87 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 11, 2024
NTRM	08010202	1D003076	23.20 % OXYGEN/NITROGEN	+/- 0.4%	Jun 01, 2024

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA510 CO2 2L6YXWY0	Nondispersive Infrared (NDIR)	Mar 05, 2020
Horiba MPA510 O2 41499150042	Paramagnetic	Mar 05, 2020

Triad Data Available Upon Request



\_\_\_\_\_  
 Signature on file  
 Approved for Release

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0016	Reference Number:	122-401319824-1
Cylinder Number:	CC234516	Cylinder Volume:	144.4 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22018	Valve Outlet:	660
Gas Code:	SO2,BALN	Certification Date:	Oct 15, 2018

**Expiration Date: Oct 15, 2026**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

### ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
SULFUR DIOXIDE	250.0 PPM	242.3 PPM	G1	+/- 0.9% NIST Traceable	10/08/2018, 10/15/2018
NITROGEN	Balance				

### CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	15060654	CC450608	248.1 PPM SULFUR DIOXIDE/NITROGEN	+/- 0.6%	Dec 17, 2020

### ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801333 SO2	FTIR	Sep 22, 2018

Triad Data Available Upon Request



Signature on file

Approved for Release

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number: E02NI99E15A0259	Reference Number: 122-401777520-1
Cylinder Number: EB0108003	Cylinder Volume: 144.4 CF
Laboratory: 124 - Durham (SAP) - NC	Cylinder Pressure: 2015 PSIG
PGVP Number: B22020	Valve Outlet: 660
Gas Code: SO2,BALN	Certification Date: Apr 06, 2020

**Expiration Date: Apr 06, 2028**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
SULFUR DIOXIDE	450.0 PPM	457.9 PPM	G1	+/- 0.8% NIST Traceable	03/30/2020, 04/06/2020
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801549 SO2	FTIR	Apr 02, 2020

Triad Data Available Upon Request



\_\_\_\_\_  
Signature on file  
Approved for Release

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0678	Reference Number:	122-402048722-1
Cylinder Number:	CC416806	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22021	Valve Outlet:	330
Gas Code:	H2S,BALN	Certification Date:	Mar 10, 2021

**Expiration Date: Mar 10, 2024**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
HYDROGEN SULFIDE	7.000 PPM	7.257 PPM	G1	+/- 1.4% NIST Traceable	03/03/2021, 03/10/2021
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
GMIS	122401645168101	CC163645	10.10 PPM HYDROGEN SULFIDE/NITROGEN	+/- 0.80	Jan 23, 2023
RGM	12332	CC183693	10.07 PPM HYDROGEN SULFIDE/NITROGEN	+/- 0.8%	Dec 18, 2017

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Applied Analytics OMA-406 AA210266	Ultraviolet	Mar 03, 2021

Triad Data Available Upon Request



\_\_\_\_\_  
Signature on file  
Approved for Release



## PERMEATION DEVICE CERTIFICATES



## DYNACAL® PERMEATION DEVICE CERTIFICATE



26295 Twelve Trees, Poulsbo, WA 98370, USA | tel: (360) 697-9199 | toll free: (877) 377-1887 | web: vicimetronics.com

The permeation rate of the DYNACAL® PERMEATION DEVICE below is certified traceable to N.I.S.T standards.

Serial Number: T-51828

Certification Date: Jan 18, 2021      Certificate Expires: Jan 18, 2022  
Chemical: Hydrogen Sulfide (7783-06-4)  
Part Number: 147-543-0110-C50  
Device Type: Dynacal Wafer      Geometry: 40T3  
Permeation Rate: 482.97 ng/min      Temperature: 50 C  
True Accuracy: +/- 1.53 %      Max Allowed Accuracy: +/- 5.00 %  
Certification Method: Gravimetric      Order No: 132578  
Customer: WESTON SOLUTIONS, INC.  
Note: Empty weight 20.41 g.

Approved By: \_\_\_\_\_

### INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.I.S.T. standards. Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit has been achieved. Temperature control and accuracy are better than 0.05° C referenced against temperature standards traceable to the National Institute of Standards and Technology. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.I.S.T. traceable weight standards. Gravimetric permeation rate determination is continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.

## DYNACAL<sup>®</sup> PERMEATION DEVICE CERTIFICATE



26295 Twelve Trees, Poulsbo, WA 98370, USA | tel: (360) 697-9199 | toll free: (877) 377-1887 | web: vicimetronics.com

The permeation rate of the DYNACAL<sup>®</sup> PERMEATION DEVICE below is certified traceable to N.I.S.T standards.

Serial Number: 33-53274

Certification Date: Jan 18, 2021      Certificate Expires: Jan 18, 2022  
Chemical: Methyl Mercaptan 74-93-1  
Part Number: 187-040-6000-C50  
Device Type: Dynacal Tube      Length: 4.00  
Permeation Rate: 716.41 ng/min      Temperature: 50 C  
True Accuracy: +/- 1.50 %      Max Allowed Accuracy: +/- 2.00 %  
Certification Method: Gravimetric      Order No: 132578  
Customer: WESTON SOLUTIONS, INC.  
Note: Empty weight 10.9 g.

Approved By: \_\_\_\_\_

A handwritten signature in black ink, appearing to read 'J. Jones', written over a horizontal line.

### INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.I.S.T. standards. Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit has been achieved. Temperature control and accuracy are better than 0.05° C referenced against temperature standards traceable to the National Institute of Standards and Technology. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.I.S.T. traceable weight standards. Gravimetric permeation rate determination is continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.

# DYNACAL<sup>®</sup> PERMEATION DEVICE CERTIFICATE



26295 Twelve Trees, Poulsbo, WA 98370, USA | tel: (360) 697-9199 | toll free: (877) 377-1887 | web: vicimetronics.com

The permeation rate of the DYNACAL<sup>®</sup> PERMEATION DEVICE below is certified traceable to N.I.S.T standards.

Serial Number: 89-53332

Certification Date: Jan 26, 2021      Certificate Expires: Jan 26, 2022  
Chemical: Dimethyl Sulfide 75-18-3  
Part Number: 187-013-6200-89-C50  
Device Type: Dynacal Tube      Length: 1.30  
Permeation Rate: 1197.35 ng/min      Temperature: 50 C  
True Accuracy: +/- 1.26 %      Max Allowed Accuracy: +/- 2.00 %  
Certification Method: Gravimetric      Order No: 132578  
Customer: WESTON SOLUTIONS, INC.  
Note: Empty weight 15.0g

Approved By:  \_\_\_\_\_

## INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.I.S.T. standards. Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit has been achieved. Temperature control and accuracy are better than 0.05° C referenced against temperature standards traceable to the National Institute of Standards and Technology. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.I.S.T. traceable weight standards. Gravimetric permeation rate determination is continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.

# DYNACAL® PERMEATION DEVICE CERTIFICATE



26295 Twelve Trees, Poulsbo, WA 98370, USA | tel: (360) 697-9199 | toll free: (877) 377-1887 | web: vicimetronics.com

The permeation rate of the DYNACAL® PERMEATION DEVICE below is certified traceable to N.I.S.T standards.

Serial Number: 89-53266

Certification Date: Jan 18, 2021      Certificate Expires: Jan 18, 2022  
Chemical: Dimethyl Disulfide    624-92-0  
Part Number: 107-200-6301-C50S  
Device Type: Dynacal Tube              Length: 20.00  
Permeation Rate: 917.53 ng/min      Temperature: 50 C  
True Accuracy: +/- 1.85 %              Max Allowed Accuracy: +/- 2.00 %  
Certification Method: Gravimetric      Order No: 132578  
Customer: WESTON SOLUTIONS, INC.  
Note: Empty weight 15.5 g.

Approved By: \_\_\_\_\_

A handwritten signature in black ink, appearing to read 'J. Miller', written over a horizontal line.

## INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.I.S.T. standards. Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit has been achieved. Temperature control and accuracy are better than 0.05° C referenced against temperature standards traceable to the National Institute of Standards and Technology. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.I.S.T. traceable weight standards. Gravimetric permeation rate determination is continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.

# DYNACAL<sup>®</sup> PERMEATION DEVICE CERTIFICATE



26295 Twelve Trees, Poulsbo, WA 98370, USA | tel: (360) 697-9199 | toll free: (877) 377-1887 | web: vicimetronics.com

The permeation rate of the DYNACAL<sup>®</sup> PERMEATION DEVICE below is certified traceable to N.I.S.T standards.

Serial Number: T-51831

Certification Date: Jan 18, 2021      Certificate Expires: Jan 18, 2022  
Chemical: Hydrogen Sulfide (7783-06-4)  
Part Number: 147-543-0110-C50  
Device Type: Dynacal Wafer      Geometry: 40T3  
Permeation Rate: 642.30 ng/min      Temperature: 50 C  
True Accuracy: +/- 4.23 %      Max Allowed Accuracy: +/- 5.00 %  
Certification Method: Gravimetric      Order No: 132575  
Customer: WESTON SOLUTIONS, INC.

Note: Empty weight 20.32 g. chemical life for continuous use expires on 12/16/2021.

Approved By: *[Signature]*

## INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.I.S.T. standards. Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.0 mg, until a steady weight loss per unit has been achieved. Temperature control and accuracy are better than 0.05° C referenced against temperature standards traceable to the National Institute of Standards and Technology. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.I.S.T. traceable weight standards. Gravimetric permeation rate determination is continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.

# DYNACAL® PERMEATION DEVICE CERTIFICATE



26295 Twelve Trees, Poulsbo, WA 98370, USA | tel: (360) 697-9199 | toll free: (877) 377-1887 | web: vicimetronics.com

The permeation rate of the DYNACAL® PERMEATION DEVICE below is certified traceable to N.I.S.T standards.

Serial Number: 33-50536

Certification Date: Jan 18, 2021      Certificate Expires: Jan 18, 2022  
Chemical: Methyl Mercaptan 74-93-1  
Part Number: 187-040-6000-C50  
Device Type: Dynacal Tube      Length: 4.00  
Permeation Rate: 900.58 ng/mln      Temperature: 50 C  
True Accuracy: +/- 1.93 %      Max Allowed Accuracy: +/- 2.00 %  
Certification Method: Gravimetric      Order No: 132575  
Customer: WESTON SOLUTIONS, INC.  
Note: Empty weight 10.9 g.

Approved By: 

## INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.I.S.T. standards. Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit has been achieved. Temperature control and accuracy are better than 0.05° C referenced against temperature standards traceable to the National Institute of Standards and Technology. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.I.S.T. traceable weight standards. Gravimetric permeation rate determination is continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.

# DYNACAL<sup>®</sup> PERMEATION DEVICE CERTIFICATE




26295 Twelve Trees, Poulsbo, WA 98370, USA | tel: (360) 697-9199 | toll free: (877) 377-1887 | web: vicimetronics.com

The permeation rate of the DYNACAL<sup>®</sup> PERMEATION DEVICE below is certified traceable to N.I.S.T standards.

Serial Number: 89-50725

Certification Date: Jan 18, 2021      Certificate Expires: Jan 18, 2022  
Chemical: Dimethyl Sulfide 75-18-3  
Part Number: 187-013-6200-89-C50  
Device Type: Dynacal Tube      Length: 1.30  
Permeation Rate: 758.14 ng/min      Temperature: 50 C  
True Accuracy: +/- 1.42 %      Max Allowed Accuracy: +/- 2.00 %  
Certification Method: Gravimetric      Order No: 132575  
Customer: WESTON SOLUTIONS, INC.  
Note: Empty weight 15.0 g.

Approved By: 

### INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.I.S.T. standards. Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit has been achieved. Temperature control and accuracy are better than 0.05° C referenced against temperature standards traceable to the National Institute of Standards and Technology. The semi-microanalytical balances are routinely serviced and calibrated to an independent service organization using N.I.S.T. traceable weight standards. Gravimetric permeation rate determination is continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.



# DYNACAL<sup>®</sup> PERMEATION DEVICE CERTIFICATE



26295 Twelve Trees, Poulsbo, WA 98370, USA | tel: (360) 697-9199 | toll free: (877) 377-1887 | web: vicimetronics.com

The permeation rate of the DYNACAL<sup>®</sup> PERMEATION DEVICE below is certified traceable to N.I.S.T standards.

Serial Number: 89-53405

Certification Date: Jan 18, 2021      Certificate Expires: Jan 18, 2022  
Chemical: Dimethyl Disulfide    624-92-0  
Part Number: PD-6301-C50  
Device Type: Dynacal Tube      Length: 20.00  
Permeation Rate: 895.19 ng/mln    Temperature: 50 C  
True Accuracy: +/- 1.44 %      Max Allowed Accuracy: +/- 2.00 %  
Certification Method: Gravimetric    Order No: 132575  
Customer: WESTON SOLUTIONS, INC.  
Note: Empty weight 15.5 g.

Approved By: 

### INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.I.S.T. standards. Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit has been achieved. Temperature control and accuracy are better than 0.05° C referenced against temperature standards traceable to the National Institute of Standards and Technology. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.I.S.T. traceable weight standards. Gravimetric permeation rate determination is continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.



## CYCLONIC FLOW CHECKS



## PULP DRYER

## Determination of Stack Gas Velocity - Method 2

Client New Indy Source Pulp Dryer Pitot Coeff (C<sub>p</sub>) 0.84  
 Location/Plant Catawba, SC W.O. Number 15730.001.008 Stack Area (A<sub>s</sub>), ft<sup>2</sup> 19.63  
 Operator ATC Date 6/26/21 Pitot/Thermo ID P560 / A060

Run Number	<u>Prelim cyclone</u>
Time	<u>11:55</u>
Barometric Press (P <sub>bar</sub> ), in Hg*	
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O	
Source Moisture (B <sub>ws</sub> ), %	
O <sub>2</sub> , %	
CO <sub>2</sub> , %	

Cyclonic Flow Determination		Traverse Location		Leak Check good ? <input checked="" type="checkbox"/> N		Leak Check good ? Y / N		Leak Check good ? Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
0	<u>AR 80</u>	A	1						
.02	<u>5</u>		2						
.02	<u>5</u>		3						
.02	<u>5</u>		4						
.03	<u>5</u>		5						
.05	<u>10</u>		6						
.08	<u>20</u>		7						
.08	<u>26</u>		8						
0	<u>0</u>	B	1						
0	<u>0</u>		2						
.03	<u>3</u>		3						
.03	<u>3</u>		4						
.04	<u>5</u>		5						
.05	<u>10</u>		6						
.07	<u>15</u>		7						
.04	<u>15</u>		8						
Avg Angle	<u>9.83</u>	Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{(T_{s(abs)} / (P_s \times M_s))}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{sd} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
 M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
 M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
 T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
 P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
 V<sub>s</sub> = Average gas stream velocity, ft/sec.  
 Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
 Q<sub>sd</sub> = Volumetric flow rate of dry stack gas at standard conditions.

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_





## NO. 3 PAPER MACHINE



## Determination of Stack Gas Velocity - Method 2

Client	New Indy	Source	No. 1 Head Exhaust
		Pitot Coeff (C <sub>p</sub> )	0.84
Location/Plant	Catawba, SC	W.O. Number	15730.001.008
		Stack Area (A <sub>s</sub> ), ft <sup>2</sup>	13.64
Operator	VD/LF	Date	6/15/21
		Pitot/Thermo ID	P147/M-1

Run Number	Prelim		
Time	1221		
Barometric Press (P <sub>bar</sub> ), in Hg*			
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O			
Source Moisture (B <sub>ws</sub> ), %			
O <sub>2</sub> , %			
CO <sub>2</sub> , %			

Cyclonic Flow Determination		Traverse Location		Leak Check good ? Y / N		Leak Check good ? Y / N		Leak Check good ? Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.70	17	A	1						
.50	14		2						
.60	10		3						
.26	7		4						
.66	15		5						
.58	22		6						
.26	20		7						
.18	37		8						
.90	23	B	1						
.78	21		2						
.50	16		3						
.18	5		4						
.44	15		5						
.38	11		6						
.10	5		7						
.06	5		8						
Avg Angle	15.2	Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{(T_{s(abs)} / (P_s \times M_s))}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{std} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
V<sub>s</sub> = Average gas stream velocity, ft/sec.  
Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
Q<sub>std</sub> = Volumetric flow rate of dry stack gas at standard conditions,

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_



## Determination of Stack Gas Velocity - Method 2

Client New Indy Source No.2 Hood Exhaust Pitot Coeff (C<sub>p</sub>) 0.84  
 Location/Plant Catawba, SC W.O. Number 15730.001.008 Stack Area (A<sub>s</sub>), ft<sup>2</sup> 17.03  
 Operator VD/LF Date 6/15/21 Pitot/Thermo ID P147/M-1

Run Number	<u>Prelim</u>		
Time	<u>1157</u>		
Barometric Press (P <sub>bar</sub> ), in Hg*			
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O			
Source Moisture (B <sub>ws</sub> ), %			
O <sub>2</sub> , %			
CO <sub>2</sub> , %			

Cyclonic Flow Determination		Traverse Location		Leak Check good ? <u>DN</u>		Leak Check good ? <u>Y/N</u>		Leak Check good ? <u>Y/N</u>	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.72	13	A	1						
.78	13		2						
.92	13		3						
.96	16		4						
.40	10		5						
.92	25		6						
.46	17		7						
.60	20		8						
1.1	25	B	1						
1.1	22		2						
1.1	15		3						
.57	8		4						
.62	10		5						
.24	10		6						
.12	5		7						
.04	2		8						
Avg Angle	<u>14</u>	Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{(T_{s(abs)} / (P_s \times M_s))}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{std} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
 M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
 M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
 T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
 P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
 V<sub>s</sub> = Average gas stream velocity, ft/sec.  
 Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
 Q<sub>std</sub> = Volumetric flow rate of dry stack gas at standard conditions,

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_





## Determination of Stack Gas Velocity - Method 2

Client	New Indy	Source	No. 3 Hood Exhaust
Location/Plant	Catawba, SC	W.O. Number	15730.001.008
Operator	VD/LF	Date	6/15/21
		Pitot Coeff (C <sub>p</sub> )	0.84
		Stack Area (A <sub>s</sub> ), ft <sup>2</sup>	17.03
		Pitot/Thermo ID	P147/M-1

Run Number	Prelim		
Time	1105		
Barometric Press (P <sub>bar</sub> ), in Hg*			
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O			
Source Moisture (B <sub>ws</sub> ), %			
O <sub>2</sub> , %			
CO <sub>2</sub> , %			

Cyclonic Flow Determination		Traverse Location		Leak Check good ? Y / N		Leak Check good ? Y / N		Leak Check good ? Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.64	10	A	1						
.62	8		2						
.60	8		3						
.72	12		4						
.32	11		5						
.96	26		6						
.98	26		7						
.70	28		8						
.76	12	B	1						
.66	10		2						
.56	7		3						
.40	5		4						
.96	9		5						
1.1	22 24		6						
.86	24		7						
.59	25		8						
Avg Angle	15.3	Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{(T_{s(abs)} / (P_s \times M_s))}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{sd} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
V<sub>s</sub> = Average gas stream velocity, ft/sec.  
Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
Q<sub>sd</sub> = Volumetric flow rate of dry stack gas at standard conditions,

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_





## Determination of Stack Gas Velocity - Method 2

Client	New Indy	Source	No. 4 Hood Exhaust	Pitot Coeff (C <sub>p</sub> )	0.84
Location/Plant	Catawba, SC	W.O. Number	15730.001.008	Stack Area (A <sub>s</sub> ), ft <sup>2</sup>	17.18
Operator	JD/LF	Date	6/15/21	Pitot/Thermo ID	P147/M-1

Run Number	Prelim	
Time	1041	
Barometric Press (P <sub>bar</sub> ), in Hg*		
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O		
Source Moisture (B <sub>ws</sub> ), %		
O <sub>2</sub> , %		
CO <sub>2</sub> , %		

Cyclonic Flow Determination		Traverse Location		Leak Check good ? Y / N		Leak Check good ? Y / N		Leak Check good ? Y / N	
Δp at 90°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.38	15	A	1						
.32	17		2						
.20	15		3						
.08	7		4						
.22	12		5						
.28	17		6						
.16	13		7						
.12	14		8						
.60	27	B	1						
.56	25		2						
.40	20		3						
.20	3		4						
.40	16		5						
.22	13		6						
.02	8		7						
.02	8		8						
Avg Angle	14.4	Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{(T_{s(abs)} / (P_s \times M_s))}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{sd} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
V<sub>s</sub> = Average gas stream velocity, ft/sec.  
Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
Q<sub>sd</sub> = Volumetric flow rate of dry stack gas at standard conditions,

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_



## Determination of Stack Gas Velocity - Method 2

Client	New Indy	Source	No. 6 Hood Exhaust	Pitot Coeff (C <sub>p</sub> )	0.84
Location/Plant	Catawba, SC	W.O. Number	15730.001.008	Stack Area (A <sub>s</sub> ), ft <sup>2</sup>	14.75
Operator	VD / LF	Date	6/15/21	Pitot/Thermo ID	P147/M-1

Run Number	Prelim		
Time	1014		
Barometric Press (P <sub>bar</sub> ), in Hg*			
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O			
Source Moisture (B <sub>ws</sub> ), %			
O <sub>2</sub> , %			
CO <sub>2</sub> , %			

Cyclonic Flow Determination		Traverse Location		Leak Check good ? Y / N		Leak Check good ? Y / N		Leak Check good ? Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
1.2	34	A	1						
1.8	34		2						
1.2	29		3						
.30	10		4						
.66	9		5						
.50	10		6						
.10	8		7						
.10	8		8						
1.1	21	B	1						
1.1	19		2						
1.0	18		3						
.80	10		4						
.74	10		5						
.46	15		6						
.14	8		7						
.12	8		8						
Avg Angle	15.6	Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg} \times (T_{s(abs)} / (P_s \times M_s))}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{std} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
V<sub>s</sub> = Average gas stream velocity, ft/sec.  
Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
Q<sub>std</sub> = Volumetric flow rate of dry stack gas at standard conditions,

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_





## Determination of Stack Gas Velocity - Method 2

Client New Indy Source No. 7 Hood Exhaust Pitot Coeff (C<sub>p</sub>) 0.84  
 Location/Plant Catawba, SC W.O. Number 15730.001.008 Stack Area (A<sub>s</sub>), ft<sup>2</sup> 23.76  
 Operator VD/LF Date 6/15/21 Pitot/Thermo ID P147/M-1

Run Number Prelim  
 Time 1001  
 Barometric Press (P<sub>bar</sub>), in Hg\*  
 Static Press (P<sub>g</sub>), in H<sub>2</sub>O  
 Source Moisture (B<sub>ws</sub>), %  
 O<sub>2</sub>, %  
 CO<sub>2</sub>, %

Cyclonic Flow Determination		Traverse Location		Leak Check good ? <u>Y</u> N		Leak Check good ? Y / N		Leak Check good ? Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.90	15	A	1						
.88	14		2						
.78	12		3						
.64	12		4						
.50	10		5						
.50	13		6						
.12	10		7						
0	0		8						
.68	14	B	1						
1.0	18		2						
.92	18		3						
.68	10		4						
.44	10		5						
.22	0		6						
.14	6		7						
0	0		8						
Avg Angle	<u>10.6</u>	Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{T_{s(abs)} / (P_s \times M_s)}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{sd} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
 M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
 M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
 T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
 P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
 V<sub>s</sub> = Average gas stream velocity, ft/sec.  
 Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacfm  
 Q<sub>sd</sub> = Volumetric flow rate of dry stack gas at standard conditions,

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_





## Determination of Stack Gas Velocity - Method 2

Client	New Indy	Source	No. 8 Hood Exhaust
		Pitot Coeff (C <sub>p</sub> )	0.84
Location/Plant	Catawba, SC	W.O. Number	15730.001.008
		Stack Area (A <sub>s</sub> ), ft <sup>2</sup>	23.70
Operator	VD/LF	Date	6/15/21
		Pitot/Thermo ID	P147/M-1

Run Number	Prelim		
Time	945		
Barometric Press (P <sub>bar</sub> ), in Hg*			
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O			
Source Moisture (B <sub>ws</sub> ), %			
O <sub>2</sub> , %			
CO <sub>2</sub> , %			

Cyclonic Flow Determination		Traverse Location		Leak Check good ? Y / N		Leak Check good ? Y / N		Leak Check good ? Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
1.1	15	A	1						
1.1	15		2						
1.1	15		3						
.98	14		4						
.68	8		5						
.50	9		6						
.16	10		7						
.14	10		8						
.96	13	B	1						
1.1	18		2						
.96	20		3						
.48	11		4						
.30	7		5						
.24	7		6						
.16	3		7						
.10	5		8						
Avg Angle	11.3	Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_w = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{(T_{s(abs)} / (P_s \times M_w))}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{std} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
M<sub>w</sub> = Wet molecular weight source gas, lb/lb-mole.  
T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
V<sub>s</sub> = Average gas stream velocity, ft/sec.  
Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
Q<sub>std</sub> = Volumetric flow rate of dry stack gas at standard conditions.

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_





## Determination of Stack Gas Velocity - Method 2

Client New Indy Source o. 1 Hood Exhaust Pitot Coeff (C<sub>p</sub>) 0.84  
 Location/Plant Catawba, SC W.O. Number 15730.001.008 Stack Area (A<sub>s</sub>), ft<sup>2</sup> 13.64  
 Operator BEA/BE Date 6/25/21 Pitot/Thermo ID P77

Run Number	<u>Prelim</u>
Time	<u>7:30-7:45</u>
Barometric Press (P <sub>bar</sub> ), in Hg*	<u>29.68</u>
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O	<u>-.68</u>
Source Moisture (B <sub>ws</sub> ), %	<u>~20</u>
O <sub>2</sub> , %	<u>20.9</u>
CO <sub>2</sub> , %	<u>8</u>

Cyclonic Flow Determination		Traverse Location		Leak Check good ? Y/N		Leak Check good ? Y/N		Leak Check good ? Y/N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.40	11	A	1		173				
.26	13		2		173				
.19	6		3		174				
.14	5		4		173				
.07	15		5		174				
.07	4		6		174				
.02	4		7		173				
.01	2		8		169				
.70	18	B	1		171				
.58	14		2		174				
.41	14		3		174				
.15	11		4		174				
.03	16		5		174				
.03	19		6		174				
.01	6		7		173				
.03	2		8		168				
Avg Angle		Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_w = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{T_{s(abs)} / (P_s \times M_w)}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{std} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

\*Barometric Pressure is at port elevation

where:  
 M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
 M<sub>w</sub> = Wet molecular weight source gas, lb/lb-mole.  
 T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
 P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
 V<sub>s</sub> = Average gas stream velocity, ft/sec.  
 Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
 Q<sub>std</sub> = Volumetric flow rate of dry stack gas at standard conditions,

Comments \_\_\_\_\_



# Determination of Stack Gas Velocity - Method 2

Client New Indy Source 0. Hood Exhaust Pitot Coeff (C<sub>p</sub>) 0.84  
 Location/Plant Catawba, SC W.O. Number 15730.001.008 Stack Area (A<sub>s</sub>), ft<sup>2</sup> 17.03  
 Operator BEA/BE Date 6/24/21 Pitot/T/thermo ID P77

Run Number	<u>Prelim</u>
Time	<u>18:30-18:50</u>
Barometric Press (P <sub>bar</sub> ), in Hg*	<u>29.58</u>
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O	
Source Moisture (B <sub>ws</sub> ), %	
O <sub>2</sub> , %	
CO <sub>2</sub> , %	

Cyclonic Flow Determination		Traverse Location		Leak Check good ? <u>Y</u> N		Leak Check good ? Y <u>N</u>		Leak Check good ? Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.55	6	A	1		186				
.60	8		2		186				
.35	3		3		185				
.57	8		4		180				
.30	4		5		180				
.85	16		6		176				
.88	26		7		173				
.77	26		8		180				
.74	14	B	1		180				
.52	8		2		181				
.56	8		3		181				
.28	4		4		183				
.28	4		5		183				
.83	20		6		184				
.92	24		7		182				
.90	28		8		180				
Avg Angle		Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{T_{s(abs)} / (P_s \times M_s)}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{sd} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
 M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
 M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
 T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
 P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
 V<sub>s</sub> = Average gas stream velocity, ft/sec.  
 Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
 Q<sub>sd</sub> = Volumetric flow rate of dry stack gas at standard conditions.

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_





## Determination of Stack Gas Velocity - Method 2

Client New Indy Source o. 3 Hood Exhaust 24 Pitot Coeff (C<sub>p</sub>) 0.84  
 Location/Plant Catawba, SC W.O. Number 15730.001.008 Stack Area (A<sub>s</sub>), ft<sup>2</sup> \_\_\_\_\_  
 Operator BEA/BE Date 6/25/21 Pitot/Termo ID P77

Run Number	<u>Prelim</u>	
Time	<u>7:45-7:55</u>	
Barometric Press (P <sub>bar</sub> ), in Hg*	<u>29.68</u>	
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O		
Source Moisture (B <sub>ws</sub> ), %		
O <sub>2</sub> , %		
CO <sub>2</sub> , %		

Cyclonic Flow Determination		Traverse Location		Leak Check good ? <u>Y/N</u>		Leak Check good ? Y / N		Leak Check good ? Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
<u>1.0</u>	<u>28</u>	A	1		<u>190</u>				
<u>1.3</u>	<u>30</u>		2		<u>191</u>				
<u>.99</u>	<u>25</u>		3		<u>191</u>				
<u>.70</u>	<u>12</u>		4		<u>191</u>				
<u>.53</u>	<u>14</u>		5		<u>192</u>				
<u>.47</u>	<u>8</u>		6		<u>193</u>				
<u>.09</u>	<u>7</u>		7		<u>190</u>				
<u>.06</u>	<u>5</u>		8		<u>191</u>				
<u>1.1</u>	<u>20</u>	B	1		<u>188</u>				
<u>.56</u>	<u>15</u>		2		<u>187</u>				
<u>.69</u>	<u>8</u>		3		<u>190</u>				
<u>.53</u>	<u>13</u>		4		<u>191</u>				
<u>.50</u>	<u>14</u>		5		<u>192</u>				
<u>.12</u>	<u>6</u>		6		<u>191</u>				
<u>.18</u>	<u>7</u>		7		<u>190</u>				
<u>.10</u>	<u>5</u>		8		<u>190</u>				
Avg Angle		Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg} \times (T_{s(abs)} / (P_s \times M_s))}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{std} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
 M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
 M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
 T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
 P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
 V<sub>s</sub> = Average gas stream velocity, ft/sec.  
 Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
 Q<sub>std</sub> = Volumetric flow rate of dry stack gas at standard conditions,

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_





## Determination of Stack Gas Velocity - Method 2

Client	New Indy	Source o. 4 Hood Exhaust	Pitot Coeff (C <sub>p</sub> )	0.84
Location/Plant	Catawba, SC	W.O. Number	15730.001.008	Stack Area (A <sub>s</sub> ), ft <sup>2</sup>
Operator	BEA/EG	Date	6/25/21	Pitot/Thermo ID
				P77

Run Number	Prelim
Time	11:05-11:20
Barometric Press (P <sub>bar</sub> ), in Hg*	29.68
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O	-1.49
Source Moisture (B <sub>ws</sub> ), %	~20
O <sub>2</sub> , %	20.9
CO <sub>2</sub> , %	0

Cyclonic Flow Determination		Traverse Location		Leak Check good ? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N		Leak Check good ? Y / N		Leak Check good ? Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.32	14	A	1		192				
.33	16		2		193				
.19	13		3		192				
.08	6		4		192				
.23	12		5		193				
.29	17		6		192				
.12	9		7		191				
.07	4		8		190				
.51	23	B	1		190				
.48	20		2		192				
.47	22		3		193				
.16	11		4		193				
.23	12		5		194				
.20	10		6		192				
.02	6		7		191				
.08	10		8		189				
Avg Angle		Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg} \times (T_{s(abs)} / (P_s \times M_s))}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{sd} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
M<sub>s</sub> = Wet molecular weight; source gas, lb/lb-mole.  
T<sub>s(abs)</sub> = Source Temperature, absolute (°R)  
P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
V<sub>s</sub> = Average gas stream velocity, ft/sec.  
Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
Q<sub>sd</sub> = Volumetric flow rate of dry stack gas at standard conditions.

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_







## Determination of Stack Gas Velocity - Method 2

Client New Indy Source o. 7 Hood Exhaust Pitot Coeff (C<sub>p</sub>) 0.84  
 Location/Plant Catawba, SC W.O. Number 15730.001.008 Stack Area (A<sub>s</sub>), ft<sup>2</sup> 23.76  
 Operator BEA/BE Date 6/26/21 Pitot/Thermo ID P77

Run Number	<u>Prelim</u>
Time	<u>8:05 - 8:25</u>
Barometric Press (P <sub>bar</sub> ), in Hg*	<u>29.68</u>
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O	<u>-.30</u>
Source Moisture (B <sub>ws</sub> ), %	<u>~20</u>
O <sub>2</sub> , %	<u>20.9</u>
CO <sub>2</sub> , %	<u>Ø</u>

Cyclonic Flow Determination		Traverse Location		Leak Check good ? <u>(Y) N</u>		Leak Check good ? Y / N		Leak Check good ? Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.02	11	A	1		158				
.05	13		2		159				
.02	10		3		164				
.01	4		4		184				
.31	8		5		167				
.16	7		6		188				
0	0		7		155				
.01	2		8		189				
.05	14	B	1		186				
.03	7		2		184				
.02	3		3		185				
.06	5		4		186				
.25	18		5		184				
.01	2		6		182				
0	0		7		181				
0	0		8		181				
Avg Angle		Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta P_{ava}} \times \sqrt{(T_{s(abs)} / (P_s \times M_s))}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{sd} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
 M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
 M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
 T<sub>s(abs)</sub> = Source Temperature, absolute (°R)  
 P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
 V<sub>s</sub> = Average gas stream velocity, ft/sec.  
 Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
 Q<sub>sd</sub> = Volumetric flow rate of dry stack gas at standard conditions.

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_



## Determination of Stack Gas Velocity - Method 2

Client	New Indy	Source o. 8 Hood Exhaust	Pitot Coeff (C <sub>p</sub> )	0.84	
Location/Plant	Catawba, SC	W.O. Number	15730.001.008	Stack Area (A <sub>s</sub> ), ft <sup>2</sup>	23.76
Operator	BEA/BE	Date	6/26/21	Pitot/Thermo ID	P77

Run Number	Precision
Time	16:45 - 16:55
Barometric Press (P <sub>bar</sub> ), in Hg*	29.66
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O	-.71
Source Moisture (B <sub>ws</sub> ), %	~20
O <sub>2</sub> , %	20.5
CO <sub>2</sub> , %	Ø

Cyclonic Flow Determination		Traverse Location		Leak Check good ?		Leak Check good ?		Leak Check good ?	
				(Y) N		Y / N		Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
-.07	15	A	1		186				
-.06	13		2		181				
-.06	17		3		180				
-.04	14		4		180				
.08	3		5		182				
.04	4		6		180				
.03	4		7		181				
-.01	2		8		181				
-.09	18	B	1		180				
-.07	16		2		180				
-.06	14		3		180				
-.05	16		4		184				
.14	6		5		184				
-.09	10		6		182				
.05	9		7		181				
.04	6		8		180				
Avg Angle		Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{(T_{s(abs)} / (P_s \times M_s))}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{std} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
V<sub>s</sub> = Average gas stream velocity, ft/sec.  
Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
Q<sub>std</sub> = Volumetric flow rate of dry stack gas at standard conditions.

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_





## NO. 2 AND 3 SMELT DISSOLVING TANK VENTS



## Determination of Stack Gas Velocity - Method 2

Client New Indy Source SDTV Pitot Coeff (C<sub>p</sub>) 0.84  
 Location/Plant Catawba, SC W.O. Number 15730.001.008 Stack Area (A<sub>s</sub>), ft<sup>2</sup> 27.49  
 Operator ATR / CL Date ATR Pito/Thermo ID p320 / A025

Run Number	Prelim cyclonic		
Time	10:10		
Barometric Press (P <sub>bar</sub> ), in Hg"	29.40		
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O			
Source Moisture (B <sub>ws</sub> ), %			
O <sub>2</sub> , %			
CO <sub>2</sub> , %			

Cyclonic Flow Determination		Traverse Location		Leak Check good ? Y / N		Leak Check good ? Y / N		Leak Check good ? Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.04	5	A	1						
.04	5		2						
.03	4		3						
.10	3		4						
.10	2		5						
.09	6		6						
.05	6		7						
.05	7		8						
.06	6	B	1						
.05	6		2						
.04	5		3						
.03	4		4						
.03	4		5						
.05	5		6						
.06	7		7						
.06	8		8						
Avg Angle	5.18	Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_w = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{T_{s(abs)} / (P_s \times M_s)}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{std} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
 M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
 M<sub>w</sub> = Wet molecular weight source gas, lb/lb-mole.  
 T<sub>s(abs)</sub> = Source Temperature, absolute (°R)  
 P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
 V<sub>s</sub> = Average gas stream velocity, ft/sec.  
 Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
 Q<sub>std</sub> = Volumetric flow rate of dry stack gas at standard conditions.

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_





## NO. 1 AND 2 COMBINATION BOILERS



## Determination of Stack Gas Velocity - Method 2

Client New Indy Source No. 1 Combination Boiler Pitot Coeff (C<sub>p</sub>) 0.84  
 Location/Plant Catawba, SC W.O. Number 15730.001.008 Stack Area (A<sub>s</sub>), ft<sup>2</sup> 78.54  
 Operator ATR Date 6/23/21 Pitot/Thermo ID P172 / A010

Run Number	<u>prelim cyclon. 2</u>
Time	<u>9:36</u>
Barometric Press (P <sub>bar</sub> ), in Hg*	<u>29.45</u>
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O	
Source Moisture (B <sub>ws</sub> ), %	
O <sub>2</sub> , %	
CO <sub>2</sub> , %	

Cyclonic Flow Determination		Traverse Location		Leak Check good ? <u>Y/N</u>		Leak Check good ? <u>Y/N</u>		Leak Check good ? <u>Y/N</u>	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.08	15	A	1						
.08	12		2						
.06	10		3						
.09	14		4						
.09	10	B	1						
.08	13		2						
.08	13		3						
.09	12		4						
.07	10	C	1						
.08	12		2						
.06	10		3						
.07	10		4						
.09	13	D	1						
.08	12		2						
.07	12		3						
.08	13		4						
Avg Angle	<u>11.9</u>	Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$$

$$M_s = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$$

$$T_{s(abs)} = T_s + 460$$

$$P_s = P_{bar} + P_g / 13.6$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{T_{s(abs)} / (P_s \times M_s)}$$

$$Q_{act} = 60 \times V_s \times A_s$$

$$Q_{sd} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$$

where:  
 M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
 M<sub>s</sub> = Wet molecular weight source gas, lb/lb-mole.  
 T<sub>s(abs)</sub> = Source Temperature, absolute (°R)  
 P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
 V<sub>s</sub> = Average gas stream velocity, ft/sec.  
 Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
 Q<sub>sd</sub> = Volumetric flow rate of dry stack gas at standard conditions,

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_



## Determination of Stack Gas Velocity - Method 2

Client New Indy Source No. 2 Combination Boiler Pitot Coeff (C<sub>p</sub>) 0.84  
 Location/Plant Catawba, SC W.O. Number 15730.001.008 Stack Area (A<sub>s</sub>), ft<sup>2</sup> 78.54  
 Operator ATR Date 6/24/21 Pitot/Thermo ID P172/A010

Run Number	<u>prelim cyclonic</u>	
Time	<u>11:58</u>	
Barometric Press (P <sub>bar</sub> ), in Hg	<u>29.65</u>	
Static Press (P <sub>g</sub> ), in H <sub>2</sub> O		
Source Moisture (B <sub>ws</sub> ), %		
O <sub>2</sub> , %		
CO <sub>2</sub> , %		

Cyclonic Flow Determination		Traverse Location		Leak Check good ?		Leak Check good ?		Leak Check good ?	
				Y / N		Y / N		Y / N	
Δp at 0°	Angle yielding Δp = 0	Port	Point	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F	Δp, in H <sub>2</sub> O	Source Temperature (T <sub>s</sub> ), °F
.07	9	A	1						
.07	10		2						
.08	10		3						
.07	12		4						
.09	15	B	1						
.09	12		2						
.08	12		3						
.08	10		4						
.08	10	C	1						
.07	10		2						
.07	12		3						
.08	12		4						
.06	10	D	1						
.08	13		2						
.08	15		3						
.07	13		4						
Avg Angle	<u>11.56</u>	Avg Δp & Temp							
		Avg √Δp							
		Average gas stream velocity, ft/sec.							
		Vol. flow rate at actual conditions, acf/min							
		Vol. flow rate at standard conditions, dscf/min							

$M_d = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (100\% - (\%O_2 + \%CO_2))$   
 $M_w = M_d \times (1 - B_{ws} / 100) + 18 \times B_{ws} / 100$   
 $T_{s(abs)} = T_s + 460$   
 $P_s = P_{bar} + P_g / 13.6$   
 $V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{(T_{s(abs)} / (P_s \times M_s))}$   
 $Q_{act} = 60 \times V_s \times A_s$   
 $Q_{std} = Q_{act} \times 17.64 \times (1 - B_{ws} / 100) \times P_s / T_{s(abs)}$

where:  
 M<sub>d</sub> = Dry molecular weight source gas, lb/lb-mole.  
 M<sub>w</sub> = Wet molecular weight source gas, lb/lb-mole.  
 T<sub>s(abs)</sub> = Source Temperature, absolute(°R)  
 P<sub>s</sub> = Absolute stack static pressure, inches Hg.  
 V<sub>s</sub> = Average gas stream velocity, ft/sec.  
 Q<sub>act</sub> = Volumetric flow rate of wet stack gas at actual, wacf/min  
 Q<sub>std</sub> = Volumetric flow rate of dry stack gas at standard conditions.

\*Barometric Pressure is at port elevation

Comments \_\_\_\_\_





## STRATIFICATION AND RESPONSE TIME CHECKS



## No. 1 COMBINATION BOILER



Client: New Indy  
Location: Catawba, SC  
Date: 6/23/2021

WO# 15730.001.008  
Source: No. 1 Combination Boiler  
Operating load: Normal

Source											
Port	Point	O2	% difference from Mean	Absolute difference	CO2	% difference from Mean	Absolute difference	SO2	% difference from Mean	Absolute difference	
D	1	12.55	3.8%	0.454	7.10	6.0%	0.454	264.5	2.8%	7.250	
	2	12.50	3.3%	0.404	7.25	4.0%	0.304	284.0	10.4%	26.750	
	3	12.25	1.3%	0.154	7.40	2.0%	0.154	281.5	9.4%	24.250	
	4	12.45	2.9%	0.354	7.20	4.7%	0.354	276.5	7.5%	19.250	
	5	12.10	0.0%	0.004	7.50	0.7%	0.054	263.5	2.4%	6.250	
	6	12.00	0.8%	0.096	7.60	0.6%	0.046	243.0	5.5%	14.250	
C	1	12.10	0.0%	0.004	7.45	1.4%	0.104	259.5	0.9%	2.250	
	2	12.05	0.4%	0.046	7.65	1.3%	0.096	261.0	1.5%	3.750	
	3	11.55	4.5%	0.546	8.20	8.5%	0.646	252.5	1.8%	4.750	
	4	11.65	3.7%	0.446	7.95	5.2%	0.396	231.5	10.0%	25.750	
	5	11.95	1.2%	0.146	7.70	1.9%	0.146	226.0	12.1%	31.250	
	6	12.00	0.8%	0.096	7.65	1.3%	0.096	243.5	5.3%	13.750	
Mean:		12.10			7.55			257.25			

Compliance Testing	
Results	Not Stratified per O2
Sampling Approach	Sampled at single point which most closely represented the mean

EPA Part 60 Testing	
Results	Not Stratified per O2
Sampling Approach	Sampled at 0.4m, 1.0m and 2.0m from stack wall or sampled at 16.7%, 50%, and 83.3% of duct diameter

EPA Part 75 Testing	
Results	Not Stratified per O2
Sampling Approach	Sampled at single point located no less than 1m from the stack wall and located on the same line as the traverse test

Per EPA Method 7E, a 12 point traverse was conducted to measure for stratification of the flue gas. According to Method 7E, the gas stream can stratified, minimally stratified, or not stratified. If at each point any pollutant or diluent is determined to be less than 5% or 0.5 ppm different than the mean concentration, the source is not stratified. If at each point any pollutant or diluent is determined to be greater than 5% but less than 10% or greater than 0.5 ppm but less than 1.0 ppm different than the mean concentration, the source is minimally stratified. If at any point the pollutants and diluents are greater than 10% or 1.0 ppm different than the mean concentration, the source is stratified.

Per EPA Part 60, a 12 point traverse was conducted to measure for stratification of the flue gas. If at each point any pollutant or diluent is determined to be less than 10% different than the mean concentration, the source is not stratified. If at any point the pollutants or diluents are greater than 10% different than the mean concentration, the source is stratified.

Per EPA Part 75, a 12 point traverse was conducted to measure for stratification of the flue gas. If at each point any pollutant or diluent is determined to be less than 5% different than the mean concentration, the source is not stratified. If at any point the pollutants are determined to be less than 3.0 ppm less than 3.0 ppm or the diluents determined to be less than 0.3% different than the mean concentration, the source is not stratified. If at any point the pollutants or diluents are greater than 5%, the pollutants are greater than 3.0 ppm, or the diluents are greater than 0.3% different than the mean concentration the source is stratified.

AM

# RUN DATA

Number 0

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm

### Stratification Check

Response time - 4 minutes, timed during 1st bias

Points Selected by Table 1-2 of EPA Method 1

Port D Point 1 (O2 higher due to interference from open port)

08:53	4339	13.0	2768	6.8	2406	241
08:54	4279	12.9	2789	6.9	2303	230
08:55	4339	13.0	2836	7.0	2224	223
08:56	4186	12.6	2840	7.0	2077	208
08:57	4317	13.0	2896	7.2	2030	203
08:58	4391	13.2	2798	6.9	2221	222
08:59	4518	13.6	2700	6.7	2311	231
09:00	4563	13.7	2543	6.3	2383	238

#### Point 2

09:01	4490	13.5	2549	6.3	2367	237
09:02	4449	13.4	2583	6.4	2376	238
09:03	4246	12.8	2676	6.6	2389	239
09:04	4262	12.8	2848	7.0	2338	234
09:05	4234	12.7	2846	7.0	2288	229
09:06	4192	12.6	2870	7.1	2708	271
09:07	4163	12.5	2907	7.2	2808	281
09:08	4169	12.5	2949	7.3	2873	287

#### Point 3

09:09	4239	12.7	2917	7.2	2776	278
09:10	4239	12.7	2866	7.1	2526	253
09:11	4099	12.3	2877	7.1	2470	247
09:12	4083	12.3	3024	7.5	2360	236
09:13	4169	12.5	3019	7.5	2334	234
09:14	4154	12.5	2930	7.2	2763	276
09:15	4071	12.2	2961	7.3	2847	285
09:16	4084	12.3	3043	7.5	2778	278

#### Point 4

09:17	4145	12.5	3027	7.5	2632	263
09:18	4171	12.5	2961	7.3	2537	254
09:19	4209	12.6	2922	7.2	2590	259
09:20	4198	12.6	2880	7.1	2538	254
09:21	4139	12.4	2891	7.2	2560	256
09:22	4172	12.5	2934	7.3	2801	280
09:23	4163	12.5	2900	7.2	2873	287
09:24	4133	12.4	2906	7.2	2657	266

#### Point 5

09:25	4175	12.5	2919	7.2	2406	241
-------	------	------	------	-----	------	-----

# RUN DATA

Number 0

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
09:26	4232	12.7	2872	7.1	2308	231
09:27	4241	12.7	2826	7.0	2273	227
09:28	4169	12.5	2822	7.0	2447	245
09:29	4091	12.3	2897	7.2	2770	277
09:30	4011	12.1	2969	7.3	2819	282
09:31	4029	12.1	3033	7.5	2821	282
09:32	4013	12.1	3034	7.5	2453	245
<b>Port stuffer fell out</b>						
09:33	5096	15.3	2841	7.0	1574	158
09:34	5110	15.3	2003	4.9	1594	160
09:35	4584	13.8	1940	4.8	2221	222
<b>Point 6</b>						
09:36	3905	11.7	2614	6.5	2642	264
09:37	3914	11.8	3145	7.8	3031	303
09:38	3956	11.9	3132	7.8	2875	288
09:39	3989	12.0	3101	7.7	2929	293
09:40	3980	12.0	3068	7.6	2649	265
09:41	4021	12.1	3087	7.6	2464	247
09:42	4013	12.1	3057	7.6	2374	238
09:43	3957	11.9	3061	7.6	2474	248
<b>Interference from open port</b>						
09:44	4003	12.0	3129	7.7	2424	243
09:45	4594	13.8	2963	7.3	2253	225
09:46	4365	13.1	2490	6.2	2512	251
<b>Point 1</b>						
09:47	4028	12.1	2787	6.9	2643	264
09:48	4021	12.1	3046	7.5	2444	245
09:49	4131	12.4	3041	7.5	2438	244
09:50	4160	12.5	2942	7.3	2344	235
09:51	4158	12.5	2894	7.2	2593	259
09:52	4204	12.6	2890	7.1	2577	258
09:53	4191	12.6	2852	7.1	2665	267
09:54	4170	12.5	2864	7.1	2615	262
<b>Port Change</b>						
09:55	4202	12.6	2878	7.1	2634	264
09:56	4125	12.4	2869	7.1	2415	242
09:57	4086	12.3	2946	7.3	2459	246
09:58	5619	16.9	2802	6.9	902	91
09:59	6924	20.8	294	0.7	122	13
10:00	6928	20.8	6	0.0	59	6
10:01	6932	20.8	6	0.0	40	4



# RUN DATA

Number 0

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
10:02	6934	20.8	6	0.0	30	3
10:03	6937	20.8	6	0.0	23	3
10:04	6941	20.8	6	0.0	16	2
10:05	6940	20.8	6	0.0	12	2
10:06	5040	15.1	388	0.9	1610	161
<b>Port C Point 1</b>						
10:07	3989	12.0	2906	7.2	2393	239
10:08	4005	12.0	3070	7.6	2375	238
10:09	4016	12.1	3076	7.6	2668	267
10:10	4046	12.2	3053	7.6	2778	278
10:11	4028	12.1	3027	7.5	2772	277
10:12	4084	12.3	3027	7.5	2651	265
10:13	4050	12.2	2991	7.4	2596	260
10:14	3999	12.0	3032	7.5	2590	259
<b>Point 2</b>						
10:15	4016	12.1	3070	7.6	2528	253
10:16	3911	11.8	3083	7.6	2523	252
10:17	3855	11.6	3188	7.9	2826	283
10:18	3872	11.6	3255	8.1	2823	282
10:19	3884	11.7	3244	8.0	2803	280
10:20	4008	12.0	3218	8.0	2575	258
10:21	4003	12.0	3094	7.7	2638	264
10:22	4036	12.1	3083	7.6	2575	258
<b>Point 3</b>						
10:23	4043	12.1	3061	7.6	2489	249
10:24	4020	12.1	3046	7.5	2518	252
10:25	3931	11.8	3087	7.6	2785	279
10:26	3849	11.6	3188	7.9	2818	282
10:27	3789	11.4	3283	8.1	2757	276
10:28	3759	11.3	3351	8.3	2443	244
10:29	3839	11.5	3365	8.3	2509	251
10:30	3866	11.6	3290	8.1	2534	254
<b>Point 4</b>						
10:31	3886	11.7	3251	8.0	2680	268
10:32	3900	11.7	3236	8.0	2566	257
10:33	3884	11.7	3233	8.0	2871	287
10:34	3917	11.8	3228	8.0	2764	277
10:35	3995	12.0	3174	7.9	2260	226
10:36	3983	12.0	3095	7.7	1976	198
10:37	3842	11.5	3150	7.8	2298	230
10:38	3913	11.8	3272	8.1	2328	233

# RUN DATA

Number 0

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 1 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **23 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
<b>Point 5</b>						
10:39	4002	12.0	3182	7.9	2024	203
10:40	4039	12.1	3096	7.7	1908	191
10:41	4118	12.4	3033	7.5	2372	237
10:42	4042	12.1	2973	7.4	2540	254
10:43	3981	12.0	3040	7.5	2288	229
10:44	3976	11.9	3113	7.7	2001	200
10:45	3996	12.0	3123	7.7	2186	219
10:46	3966	11.9	3104	7.7	2330	233
<b>Point 6</b>						
10:47	3995	12.0	3128	7.7	2014	202
10:48	4059	12.2	3089	7.6	2056	206
10:49	4040	12.1	3046	7.5	2233	223
10:50	4029	12.1	3039	7.5	2260	226
10:51	3949	11.9	3065	7.6	2304	231
10:52	4019	12.1	3118	7.7	2156	216
10:53	4007	12.0	3067	7.6	2390	239
10:54	4010	12.0	3091	7.7	2483	248
<b>Avg</b>	<b>4288</b>	<b>12.9</b>	<b>2787</b>	<b>6.9</b>	<b>2323</b>	<b>232</b>

# Sample and Velocity Traverse Point Data Sheet - Method 1

15730.001.008  
Pulp Dyer, #3 Paper Machine,  
#1-3 SDTV4, & #1-2 CBs  
Emission Report

Client New Indy  
Location/Plant Catawba, SC  
Source No. 1 Combination Boiler

Operator VD  
Date 21-Jun-21  
W.O. Number 15730.001.008

**Duct Type**  Circular  Rectangular Duct Indicate appropriate type  
**Traverse Type**  Particulate Traverse  Velocity Traverse

Distance from far wall to outside of port (in.) = C	127.5
Port Depth (in.) = D	7.5
Depth of Duct, diameter (in.) = C-D	120
Area of Duct (ft <sup>2</sup> )	78.54
Total Traverse Points	12
Total Traverse Points per Port	6

**Rectangular Ducts Only**


Width of Duct, rectangular duct only (in.)	
Total Ports (rectangular duct only)	

**Traverse Point Locations**

Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	4.4	5 1/2	13
2	14.6	17 1/2	25
3	29.6	35 1/2	43
4	70.4	84 1/2	92
5	85.4	102 1/2	110
6	95.6	114 1/2	122
7			
8			
9			
10			
11			
12			

**Flow Disturbances**

Upstream - A (ft)	45.0
Downstream - B (ft)	32.0
Upstream - A (duct diameters)	4.50
Downstream - B (duct diameters)	3.20



Equivalent Diameter =  $(2 * L * W) / (L + W)$

**Traverse Point Location Percent of Stack -Circular**

		Number of Traverse Points											
		1	2	3	4	5	6	7	8	9	10	11	12
Traverse Point Location Percent of Stack -Circular	1		14.6		6.7		4.4		3.2		2.6		2.1
	2		85.4		25		14.6		10.5		8.2		6.7
	3				75		29.6		19.4		14.6		11.8
	4				93.3		70.4		32.3		22.6		17.7
	5						85.4		67.7		34.2		25
	6						95.6		80.6		65.8		35.6
	7								89.5		77.4		64.4
	8								96.8		85.4		75
	9										91.8		82.3
	10										97.4		88.2
	11												93.3
	12												

**Traverse Point Location Percent of Stack -Rectangular**

		Number of Traverse Points											
		1	2	3	4	5	6	7	8	9	10	11	12
Traverse Point Location Percent of Stack -Rectangular	1		25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
	2		75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
	3			83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
	4				87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
	5					90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
	6						91.7	78.6	68.8	61.1	55.0	50.0	45.8
	7							92.9	81.3	72.2	65.0	59.1	54.2
	8								93.8	83.3	75.0	68.2	62.5
	9									94.4	85.0	77.3	70.8
	10										95.0	86.4	79.2
	11											95.5	87.5
	12												95.8

**Rectangular Stack Points & Matrix**

- 9 - 3 x 3
- 12 - 4 x 3
- 16 - 4 x 4
- 20 - 5 x 4
- 25 - 5 x 5
- 30 - 6 x 5
- 36 - 6 x 6
- 42 - 7 x 6
- 49 - 7 x 7

Port Diam. (in) = \_\_\_\_\_  
Number of Ports = \_\_\_\_\_

Tape Measure I.D. # \_\_\_\_\_ **636**





## No. 2 COMBINATION BOILER

Client New Indy  
Location Catawba, SC  
Date 6/24/2021

WO# 15730.001.008  
Source No. 2 Combination Boiler

Source										
Port	Point	O2	% difference from Mean	Absolute difference	CO2	% difference from Mean	Absolute difference	SO2	% difference from Mean	Absolute difference
B	1	12.30	1.1%	0.142	7.45	4.0%	0.288	324.5	0.9%	2.875
	2	12.80	2.9%	0.358	6.95	3.0%	0.213	308.0	4.2%	13.625
	3	12.45	0.1%	0.008	7.20	0.5%	0.037	323.5	0.6%	1.875
	4	11.80	5.2%	0.642	6.85	4.4%	0.313	335.0	4.2%	13.375
	5	12.70	2.1%	0.258	7.20	0.5%	0.037	313.5	2.5%	8.125
	6	12.10	2.7%	0.342	7.50	4.7%	0.337	303.5	5.6%	18.125
C	1	12.95	4.1%	0.508	7.15	0.2%	0.013	343.5	6.8%	21.875
	2	12.15	2.3%	0.292	7.15	0.2%	0.013	319.5	0.7%	2.125
	3	12.75	2.5%	0.308	6.80	5.1%	0.363	331.5	3.1%	9.875
	4	12.65	1.7%	0.208	6.90	3.7%	0.263	333.0	3.5%	11.375
	5	12.45	0.1%	0.008	7.20	0.5%	0.037	318.5	1.0%	3.125
	6	12.20	1.9%	0.242	7.60	6.1%	0.437	305.5	5.0%	16.125
Mean:		12.44			7.16			321.63		

Compliance Testing	
Results	Minimally Stratified per O2
Sampling Approach	Sampled at three points in line with the highest concentration at 16.7%, 50%, and 83.3% or sampled at three points of 0.4m, 1.0m, and

EPA Part 60 Testing	
Results	Not Stratified per O2
Sampling Approach	Sampled at 0.4m, 1.0m and 2.0m from stack wall or sampled at 16.7%, 50%, and 83.3% of duct diameter

EPA Part 75 Testing	
Results	Stratified
Sampling Approach	Sampled at single point located no less than 1m from the stack wall and located on the same line as the traverse test

Per EPA Method 7E, a 12 point traverse was conducted to measure for stratification of the flue gas. According to Method 7E, the gas stream can stratified, minimally stratified, or not stratified. If at each point any pollutant or diluent is determined to be less than 5% or 0.5 ppm different than the mean concentration, the source is not stratified. If at each point any pollutant or diluent is determined to be greater than 5% but less than 10% or greater than 0.5 ppm but less than 1.0 ppm different than the mean concentration, the source is minimally stratified. If at any point the pollutants and diluents are greater than 10% or 1.0 ppm different than the mean concentration, the source is stratified.

Per EPA Part 60, a 12 point traverse was conducted to measure for stratification of the flue gas. If at each point any pollutant or diluent is determined to be less than 10% different than the mean concentration, the source is not stratified. If at any point the pollutants or diluents are greater than 10% different than the mean concentration, the source is stratified.

Per EPA Part 75, a 12 point traverse was conducted to measure for stratification of the flue gas. If at each point any pollutant or diluent is determined to be less than 5% different than the mean concentration, the source is not stratified. If at any point the pollutants are determined to be less than 3.0 ppm less than 3.0 ppm or the diluents determined to be less than 0.3% different than the mean concentration, the source is not stratified. If at any point the pollutants or diluents are greater than 5%, the pollutants are greater than 3.0 ppm, or the diluents are greater than 0.3% different than the mean concentration the source is stratified.

# RUN DATA

Number 0

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub> mv	%	CO <sub>2</sub> mv	%	SO <sub>2</sub> mv	ppm
------	----------------------	---	-----------------------	---	-----------------------	-----

## Stratification Check

Response Time - 4 minutes, timed during 1st bias

Points selected by Table 1-2 of EPA Method 1

### Port B Point 1

12:03	4121	12.4	2975	7.4	3136	312
12:04	4225	12.7	2954	7.4	3085	307
12:05	4466	13.4	2797	7.0	3128	312
12:06	4312	13.0	2586	6.4	3283	327
12:07	4211	12.7	2755	6.9	3351	334
12:08	4103	12.4	2875	7.2	3396	338
12:09	4088	12.3	2971	7.4	3304	329
12:10	4101	12.3	3009	7.5	3211	320

### Point 2

12:11	4161	12.5	2981	7.4	3140	313
12:12	4185	12.6	2926	7.3	3082	307
12:13	4165	12.5	2917	7.3	3062	305
12:14	4166	12.5	2956	7.4	3041	303
12:15	4243	12.8	2927	7.3	3063	305
12:16	4316	13.0	2839	7.1	3105	309
12:17	4280	12.9	2776	6.9	3137	312
12:18	4224	12.7	2808	7.0	3055	304

### Point 3

12:19	4216	12.7	2866	7.1	3021	301
12:20	4261	12.8	2847	7.1	3103	309
12:21	4249	12.8	2837	7.1	3168	316
12:22	4326	13.0	2802	7.0	3206	319
12:23	4288	12.9	2754	6.8	3258	325
12:24	4258	12.8	2778	6.9	3205	319
12:25	4165	12.5	2843	7.1	3194	318
12:26	4129	12.4	2916	7.3	3301	329

### Point 4

12:27	4093	12.3	2960	7.4	3393	338
12:28	3796	11.4	3026	7.5	4221	421
12:29	3709	11.2	3320	8.3	4324	431
12:30	4274	12.9	3287	8.2	3850	384
12:31	4415	13.3	2769	6.9	3805	379
12:32	4279	12.9	2721	6.8	3499	349
12:33	4450	13.4	2833	7.0	3372	336
12:34	4482	13.5	2676	6.7	3354	334

### Point 5

12:35	4397	13.2	2636	6.6	3369	336
-------	------	------	------	-----	------	-----

# RUN DATA

Number 0

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
12:36	4326	13.0	2722	6.8	3299	329
12:37	4298	12.9	2761	6.9	3269	326
12:38	4270	12.9	2778	6.9	3235	322
12:39	4218	12.7	2839	7.1	3201	319
12:40	4188	12.6	2884	7.2	3198	319
12:41	4197	12.6	2908	7.2	3187	317
12:42	4248	12.8	2908	7.2	3111	310
<b>Point 6</b>						
12:43	4304	13.0	2847	7.1	3137	312
12:44	4299	12.9	2793	6.9	3109	310
12:45	4368	13.1	2775	6.9	3196	318
12:46	4421	13.3	2705	6.7	3305	329
12:47	4431	13.3	2655	6.6	3253	324
12:48	4440	13.4	2638	6.6	3179	317
12:49	4460	13.4	2634	6.5	3132	312
12:50	4537	13.7	2590	6.4	3167	315
<b>Port Change</b>						
12:51	4637	14.0	2500	6.2	2698	269
12:52	6832	20.5	1490	3.7	269	27
12:53	6942	20.9	15	0.0	85	8
12:54	5605	16.9	118	0.2	2307	230
12:55	4420	13.3	2357	5.9	3325	331
<b>Port C Port 1</b>						
12:56	4332	13.0	2660	6.6	3321	331
12:57	4421	13.3	2721	6.8	3382	337
12:58	4342	13.1	2624	6.5	3466	345
12:59	4070	12.3	2747	6.8	3665	365
13:00	3992	12.0	3025	7.5	3853	384
13:01	4129	12.4	3074	7.7	3750	374
13:02	4237	12.8	2932	7.3	3483	347
13:03	4362	13.1	2823	7.0	3412	340
<b>Point 2</b>						
13:04	4480	13.5	2671	6.6	3330	332
13:05	4458	13.4	2583	6.4	3339	333
13:06	4571	13.8	2576	6.4	3321	331
13:07	4618	13.9	2452	6.1	3372	336
13:08	4541	13.7	2420	6.0	3429	342
13:09	4538	13.7	2489	6.2	3312	330
13:10	4551	13.7	2505	6.2	3301	329
13:11	4619	13.9	2479	6.2	3308	330



# RUN DATA

Number 0

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
<b>Point 3</b>						
13:12	4531	13.6	2393	5.9	3470	346
13:13	4458	13.4	2436	6.1	3491	348
13:14	4280	12.9	2494	6.2	3423	341
13:15	4171	12.6	2694	6.7	3260	325
13:16	4253	12.8	2780	6.9	3269	326
13:17	4204	12.7	2720	6.8	3259	325
13:18	4213	12.7	2753	6.8	3297	328
13:19	4264	12.8	2746	6.8	3362	335
<b>Point 4</b>						
13:20	4201	12.6	2704	6.7	3341	333
13:21	4339	13.1	2742	6.8	3271	326
13:22	4315	13.0	2621	6.5	3271	326
13:23	4297	12.9	2618	6.5	3356	334
13:24	4158	12.5	2682	6.7	3460	345
13:25	4197	12.6	2810	7.0	3434	342
13:26	4191	12.6	2783	6.9	3403	339
13:27	4208	12.7	2755	6.9	3281	327
<b>Point 5 (process changed)</b>						
13:28	4138	12.5	2779	6.9	3255	324
13:29	4113	12.4	2851	7.1	3302	329
13:30	4068	12.2	2911	7.2	3294	328
13:31	4040	12.2	2904	7.2	3313	330
13:32	3939	11.9	2999	7.5	3304	329
13:33	3950	11.9	3074	7.7	3333	332
13:34	3810	11.5	3103	7.7	3408	339
13:35	3647	11.0	3250	8.1	3867	385
<b>Point 6</b>						
13:36	3452	10.4	3420	8.5	4106	409
13:37	3594	10.8	3572	8.9	3836	382
13:38	3761	11.3	3451	8.6	3698	368
13:39	3858	11.6	3268	8.1	3529	352
13:40	3944	11.9	3169	7.9	3491	348
13:41	3868	11.6	3110	7.7	3259	325
13:42	3941	11.9	3185	7.9	3215	320
13:43	4060	12.2	3067	7.6	3149	314
<b>Point 5</b>						
13:44	3997	12.0	2970	7.4	3147	313
13:45	3992	12.0	3025	7.5	3193	318
13:46	4066	12.2	3030	7.5	3154	314
13:47	4065	12.2	2962	7.4	3153	314

# RUN DATA

Number 0

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
13:48	4063	12.2	2932	7.3	3203	319
13:49	4068	12.2	2976	7.4	3148	314
13:50	4157	12.5	2933	7.3	3193	318
13:51	4119	12.4	2860	7.1	3201	319
<b>Avg</b>	<b>4274</b>	<b>12.9</b>	<b>2772</b>	<b>6.9</b>	<b>3260</b>	<b>325</b>

# RUN DATA

Number 0

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**  
Operator: **VD**  
Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
<b>Stratification Check cont.</b>						
<b>Port C Point 2</b>						
13:56	4148	12.5	2790	6.9	3180	317
13:57	4210	12.7	2786	6.9	3180	317
13:58	4147	12.5	2761	6.9	3257	324
13:59	4216	12.7	2784	6.9	3290	328
14:00	4131	12.4	2758	6.9	3193	318
14:01	4139	12.5	2836	7.1	3102	309
14:02	4081	12.3	2848	7.1	3235	322
14:03	3994	12.0	2911	7.2	3181	317
<b>Point 6</b>						
14:04	4001	12.0	3014	7.5	3223	321
14:05	4121	12.4	2969	7.4	3164	315
14:06	4107	12.4	2855	7.1	3117	310
14:07	4033	12.1	2879	7.2	3157	314
14:08	3993	12.0	2972	7.4	3124	311
14:09	3990	12.0	2994	7.5	3132	312
14:10	3818	11.5	3036	7.6	3217	320
14:11	3864	11.6	3224	8.0	3181	317
14:12	4036	12.2	3125	7.8	3108	310
14:13	4037	12.2	2961	7.4	3020	301
<b>Port Change</b>						
14:14	3982	12.0	2976	7.4	3069	306
14:15	4051	12.2	3044	7.6	2597	259
14:16	6805	20.5	1871	4.6	308	30
14:17	6926	20.8	22	0.0	91	9
14:18	5009	15.1	367	0.9	2413	240
<b>Port B Point 6</b>						
14:19	3986	12.0	2860	7.1	3212	320
14:20	3971	12.0	3018	7.5	3032	302
14:21	3904	11.8	3065	7.6	2897	289
14:22	3947	11.9	3128	7.8	2928	292
14:23	4006	12.1	3071	7.6	2951	294
14:24	4007	12.1	3015	7.5	2973	296
14:25	4009	12.1	3019	7.5	3041	303
14:26	4010	12.1	3014	7.5	3055	304
<b>Point 4</b>						
14:27	4012	12.1	3009	7.5	2995	298
14:28	3996	12.0	3007	7.5	2988	298
14:29	3899	11.7	3051	7.6	3126	311
14:30	3877	11.7	3146	7.8	3154	314

# RUN DATA

Number 0

Client: **New Indy**  
Location: **Catawba, SC**  
Source: **No. 2 Combination Boiler**

Calibration 1

Project Number: **15730.001.008**

Operator: **VD**

Date: **24 Jun 2021**

Time	O <sub>2</sub>		CO <sub>2</sub>		SO <sub>2</sub>	
	mv	%	mv	%	mv	ppm
14:31	3916	11.8	3167	7.9	3081	307
14:32	3940	11.9	3110	7.7	2924	291
14:33	3899	11.7	3097	7.7	2878	287
<b>Avg</b>	<b>4190</b>	<b>12.6</b>	<b>2804</b>	<b>7.0</b>	<b>2915</b>	<b>290</b>

# Sample and Velocity Traverse Point Data Sheet - Method 1

15730.001.008  
 PDP Dr, #3 Paper Machine,  
 #1-3 SDTVs, & #1-2 CBs  
 Emission Report

Client New Indy  
 Location/Plant Catawba, SC  
 Source No. 2 Combination Boiler

Operator VD  
 Date 21-Jun-21  
 W.O. Number 15730.001.008

**Duct Type**  Circular  Rectangular Duct Indicate appropriate type  
**Traverse Type**  Particulate Traverse  Velocity Traverse


Distance from far wall to outside of port (in.) = C	129.0
Port Depth (in.) = D	9.0
Depth of Duct, diameter (in.) = C-D	120
Area of Duct (ft <sup>2</sup> )	78.54
Total Traverse Points	12
Total Traverse Points per Port	6

**Rectangular Ducts Only**

Width of Duct, rectangular duct only (in.)	
Total Ports (rectangular duct only)	

Traverse Point Locations			
Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	4.4	5 1/2	14 1/2
2	14.6	17 1/2	26 1/2
3	29.6	35 1/2	44 1/2
4	70.4	84 1/2	93 1/2
5	85.4	102 1/2	111 1/2
6	95.6	114 1/2	123 1/2
7			
8			
9			
10			
11			
12			

Flow Disturbances	
Upstream - A (ft)	45.0
Downstream - B (ft)	32.0
Upstream - A (duct diameters)	4.50
Downstream - B (duct diameters)	3.20



Equivalent Diameter =  $(2 * L * W) / (L + W)$

Traverse Point Location Percent of Stack -Circular													
		Number of Traverse Points											
		1	2	3	4	5	6	7	8	9	10	11	12
Traverse Point Location	1		14.6		6.7		4.4		3.2		2.6		2.1
	2		85.4		25		14.6		10.5		8.2		6.7
	3				75		29.6		19.4		14.6		11.8
	4				93.3		70.4		32.3		22.6		17.7
	5						85.4		67.7		34.2		25
	6						95.6		80.6		65.8		35.6
	7								89.5		77.4		64.4
	8								96.8		85.4		75
	9										91.8		82.3
	10										97.4		88.2
	11												93.3
	12												97.9

Traverse Point Location Percent of Stack -Rectangular													
		Number of Traverse Points											
		1	2	3	4	5	6	7	8	9	10	11	12
Traverse Point Location	1		25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
	2		75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
	3			83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
	4				87.5	70.0	58.3	50.0	42.8	38.9	35.0	31.8	29.2
	5					90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
	6						91.7	78.6	68.8	61.1	55.0	50.0	45.8
	7							92.9	81.3	72.2	65.0	59.1	54.2
	8								93.8	83.3	75.0	68.2	62.5
	9									94.4	85.0	77.3	70.8
	10										95.0	86.4	79.2
	11											95.5	87.5
	12												95.8

**Rectangular Stack Points & Matrix**

- 9 - 3 x 3
- 12 - 4 x 3
- 16 - 4 x 4
- 20 - 5 x 4
- 25 - 5 x 5
- 30 - 6 x 5
- 36 - 6 x 6
- 42 - 7 x 6
- 49 - 7 x 7

Port Diam. (in) = \_\_\_\_\_  
 Number of Ports = \_\_\_\_\_

Tape Measure I.D. # \_\_\_\_\_





## INTERFERENCE CHECKS



Method 7E-Interference Response

Applies to Models: 600 Series NDIR/PMD, 100/200/300 Series NDIR/PMD, ZRE w/PMD  
Date of Test: 1/26/2011  
Analyzer Type: PMD  
Model: 602-P  
Serial Number: U09018-M  
Calibration Span: 20.7% O2, balance N2

Test Gas	Interfermt Concentration	Zero Response	Span Response	Interferent Response
SO2	513 ppm	0.000%	0.020%	0.020%
H2O	0.82%	0.015%	0.020%	0.020%
N2O	10.00 ppm	0.000%	0.000%	0.000%
NO	94.9 ppm	0.000%	0.000%	0.000%
NO2	99.8 ppm	0.000%	0.000%	0.000%
CO	900 ppm	0.000%	0.000%	0.000%
CH4	90.9 ppm	0.000%	0.000%	0.000%
HCl	27.99ppm	0.000%	0.000%	0.000%
Sum of Responses				0.004%
% of Calibration Span				0.019%





Method 7E-Interference Response

Applies to Models: 600 Series NDIR, 100/200/300 Series NDIR, ZRE  
Date of Test: 1/26/2011  
Analyzer Type: NDIR  
Model: 602-P  
Serial Number: U09018-M  
Calibration Span: 20.2% CO2/Balance N2

Test Gas	Interfernt Concentration	Zero Response	Span Response	Interferent Response
SO2	102.6 ppm	0.000%	0.000%	0.000%
H2O	0.82%	0.055%	0.055%	0.055%
N2O	10.00 ppm	0.005%	0.010%	0.010%
NO	94.9 ppm	0.005%	0.025%	0.025%
NO2	99.8 ppm	0.010%	0.010%	0.010%
CO	100.0 ppm	0.010%	0.010%	0.010%
CH4	101.0 ppm	0.010%	0.010%	0.010%
HCl	27.99ppm	0.010%	0.010%	0.010%
Sum of Responses				0.013%
% of Calibration Span				0.064%



August 4, 2014

**To Whom It May Concern:**

Teledyne Advanced Pollution Instrumentation has introduced new instrument models to replace our existing E Series gas analyzers. The new instruments are collectively referred to as our T Series models.

The fundamental design and all critical wetted, electronic, electrical and analytical components of the T Series instruments are identical to the E Series, including: UV sources, photo detectors, power supplies, pressure and flow transducers, pneumatic connectors and valves as well as external signal I/O connectors for serial data (RS-232/485 and Ethernet), analog concentration and status signals, and control inputs.

The design of all analytical algorithms, signal processing and control software algorithms are identical as well, including A/D measurements, digital signal filtering, concentration calculations, calibration factors and algorithms, temperature and pressure compensation, temperature control loops.

The primary differences between the models E Series and T Series instrument designs are provided below:

1. The 2 line by 40 character vacuum fluorescent display module is replaced by a 7" color LCD display with a touch screen interface. The current human user interface is emulated on the color, graphical display. The touch screen is used to emulate the existing 8 button context sensitive keyboard.
2. The software platform has been upgraded to support the graphical display and touchscreen. Software routines have been added to support the new analog input option, and a native Ethernet port on the CPU.
3. An upgraded CPU board that includes hardware to drive the LCD display and is backwards compatible with the current E-series CPU is used for the T-series analyzers.
4. A new front panel assembly has been designed to house the new display, and a new 9-pin connector will be added to the rear panel to support the new analog input option.
5. The new analog input option is designed to permit users to display and log, using the analyzer's internal data logger, signals from meteorological and other miscellaneous external sensors. None of the external signals are used in the calculations that yield calibrated concentration.

Internal production testing of the T Series analyzers that have been manufactured to date has shown that they meet the same analytical specifications as the equivalent E Series analyzers, including noise, linearity, drift, and response time.

We feel that, due to the nature of the changes described above and the testing performed to date, the modifications will not affect the performance characteristics of the analyzer.

Best Regards,



Doug Haugen  
US National Sales Manager  
Teledyne Advanced Pollution Instrumentation  
(970) 224-3686  
[Douglas.haugen@teledyne.com](mailto:Douglas.haugen@teledyne.com)

Method 7E Results for TAPI High Level Gas Analyzers			Instrument Type									
Potential Interferent Gas	Potential Interferent Gas Concentration	M100EH	M200EM	M200EH	M200EH Sensor	M201E	M300E	M300EM	M320E	M803E O2 Sensor	M803E CO2 Sensor	
SO2	20 ppmv		0.012	-0.167	-0.014	0.001	-0.058	-0.092	-0.106	-0.061	-0.015	
NO	15 ppmv	0.162			0.002		-0.015	-0.054	-0.035	-0.051	-0.015	
NO2	15 ppmv	0.053			-0.026		-0.059	-0.007	0.041	-0.051	-0.027	
N2O	10 ppmv	-0.198	-0.033	-0.166	-0.036	0.040	0.113	-0.009	-2.518	-0.041	-0.034	
CO	50 ppmv	-0.084	0.022	-0.211	0.000	-0.005	-0.025	-0.030	-0.068	-0.164	-0.034	
CH4	50 ppmv	-0.051	-0.042	-0.461	-0.043	0.037	-0.061	-0.128	0.000	0.000	-0.015	
H2	50 ppmv	-0.230	-0.035	-0.253	-0.038	0.030	-0.061	-0.128	0.000	-0.010	-0.008	
CO2	15%	0.361	-2.397	-0.808	0.000	-1.076	0.470	0.313	7.843	-0.026	0.000	
NH3	10 ppmv	0.000	0.000		0.000		0.000	0.000	0.000	0.000	0.000	
HCl	10 ppmv	0.047	0.168	-0.133	-0.032	0.078	-0.002	-0.087	0.073	-0.043	-0.027	
H2O	1%	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
Absolute Sum of Responses		1.186	2.710	2.198	0.191	1.268	0.803	0.720	10.685	0.447	0.175	
Calibration Span		90 ppm	90 ppm	90 ppm	15%	18 ppm	90 ppm	90 ppm	90 ppm	20.95%	15%	
Percent of Calibration Span		1.318	3.011	2.442	1.273	7.046	0.892	0.800	11.872	2.134	1.163	





## PROJECT TEAM QUALIFICATIONS

<b>Weston Solutions, Inc. Integrated Air Services Employee Qualifications</b>					
Name	Title/Position	Education/Training	QSTI	Years of Experience	
				Total	Emission Testing
Allredge, Bryan	Emissions Testing Specialist	AAS - Electronic Engineering Tehcnology Snead State Community College (1998)	QSTI 1 & 3	7	7
Bryant, Ashley	Report Coordinator	BS - English Ed. - Jacksonville State University (2011) MA - English - Jacksonville State University (2012)	QSTI 1	9	9
Ennis, Brock	Emissions Testing Specialist	BA - Urban Environmental Studies Birmingham-Southern College (2021)		1	1
Dubay, Van	Emissions Testing Specialist	BS - Horticulture Auburn University (2007)	QSTI 1, 3, & 4	6	6
Hammonds, Natalie	Quality Manager	BS - Environmental Science Auburn University (1998)	QSTI 1	23	18
Hartsky, Chris	Emission Testing Specialist	BA - Environmental Studies Washington College (2016)		10	5
Lestochi, Cory	Emissions Testing Specialist	BS - Biochemistry & Molecular Biology Penn State University (2019)	QSTI 1	1	1
Roberts, Wayne	Operations Manager	BS - Env. Science AU (1992)		28	27
Robinson, Tyler	Emissions Testing Specialist	BA - IDSC - Natural Resource Ecology, Sustainability - AU (2017)	QSTI 1	4	4
Simpkins, Templeton	Project Manager	BS - Zoology Auburn University (1997)	QSTI 1 & 3	20	20





## APPENDIX I

# PROCESS OPERATING/PRODUCTION DATA

---



## PULP DRYER

Pulp Dryer Vent Testing

Pulp Dryer Vent - 6/26/21

Run #	Start Time	Speed (FPM)	Steam Usage (10 <sup>3</sup> lbs/hr)	TRS Emissions (lbs/hr)
1	1230	105	68106	0.21
2	1347	105	67090	0.18
3	1506	105	67567	0.17
Average:		105	67588	0.19



## NO. 3 PAPER MACHINE VENTS

## Paper Machine Dryer Vent Testing

### #3 Dryer Vent - 6/24/21

Run #	Start Time	Reel Speed (FPM)	Steam Usage (10 <sup>3</sup> lbs/hr)	TRS Emissions (lbs/hr)
1	937	2459	266	0.23
2	1042	2459	279	0.19
3	1145	2459	293	0.21
Average:		2459	279	0.21

### #2 Dryer Vent - 6/24/21

Run #	Start Time	Reel Speed (FPM)	Steam Usage (10 <sup>3</sup> lbs/hr)	TRS Emissions (lbs/hr)
1	1310	2459	297	0.19
2	1416	2459	310	0.17
3	1522	2461	296	0.16
Average:		2460	301	0.18

### #1 Dryer Vent - 6/25/21

Run #	Start Time	Reel Speed (FPM)	Steam Usage (10 <sup>3</sup> lbs/hr)	TRS Emissions (lbs/hr)
1	755	2651	294	0.08
2	900	2651	306	0.09
3	1005	2651	315	0.10
Average:		2651	305	0.09

### #4 Dryer Vent - 6/25/21

Run #	Start Time	Reel Speed (FPM)	Steam Usage (10 <sup>3</sup> lbs/hr)	TRS Emissions (lbs/hr)
1	1135	2651	331	0.10
2	1240	2628	328	0.10
3	1345	2615	328	0.11
Average:		2631	329	0.10



## NO. 2 AND 3 SMELT DISSOLVING TANK VENTS

#6 Dryer Vent - 6/25/21

Run #	Start Time	Reel Speed (FPM)	Steam Usage (10 <sup>3</sup> lbs/hr)	TRS Emissions (lbs/hr)
1	1555	2583	319	0.13
2	1715	2574	314	0.13
3	1820	2584	309	0.13
Average:		2580	314	0.13

#7 Dryer Vent - 6/26/21

Run #	Start Time	Reel Speed (FPM)	Steam Usage (10 <sup>3</sup> lbs/hr)	TRS Emissions (lbs/hr)
1	945	2550	306	0.14
2	1050	2593	313	0.15
3	1155	2641	326	0.18
Average:		2595	315	0.16

#8 Dryer Vent - 6/26/21

Run #	Start Time	Reel Speed (FPM)	Steam Usage (10 <sup>3</sup> lbs/hr)	TRS Emissions (lbs/hr)
1	1315	2652	328	0.20
2	1420	2664	338	0.18
3	1524	2691	322	0.19
Average:		2669	329	0.19



Smelt Dissolving Tank Vent Testing

Smelt Dissolving Tank Vent - 6/27/21

SMELT DISSOLVING TANK VENT														RB #2		RB #3	
Run #	Start Time	Scrubber Pump		Weak Wash		Differential		Liquor Firing				TRS Emissions					
		Discharge Pressure (PSIG)	Spray Flow (gpm)	Flow (gpm)	Water	Pressure (" Water)	Rate (gpm)	Solids %	Lbs/Hr BLS	Rate (gpm)	Solids %	Lbs/Hr BLS	Tons LBS/hr (lbs/hr)				
1	1100	55.9	93.3	91.6	4.8	201.7	70.3	92950	314.8	69.0	142388	117.7	1.02				
2	1222	55.9	93.7	90.2	4.8	205.8	70.4	94974	315.5	69.0	142704	118.8	1.28				
3	1344	55.9	93.7	90.6	4.7	199.1	70.4	91882	315.5	69.1	142911	117.4	1.10				
Average:		55.9	93.6	90.8	4.8	202.2	70.4	93269	315.3	69.0	142668	118.0	1.13				



## No. 1 COMBINATION BOILER

Combination Boiler #1

Condition 1: With NCGs, with SOGs  
23-Jun-21

Run #	Start Time	Steam Rate (10 <sup>3</sup> lbs/hr)	Bark Rate (Tons/hr)	Gas Flow (10 <sup>3</sup> SCF/hr)	TDF (TPH)	NCG Scrubber Flow (GPM)	NCG Scrubber pH (SU)	Stripper Foul Condensate Flow (GPM)	Foul Condensate Flow (GPM)	LVHC Flow to		HVLC Flow to		SO <sub>2</sub> Emissions (lbs/hr)	SO <sub>2</sub> Emissions (lbs/ODT Pulp)	TRs Emissions (lbs/hr)
										Boilers (SCFM)	Boilers (SCFM)	Boilers (SCFM)	Boilers (SCFM)			
1	1158	208	25.1	80.8	1.37	40	10.9	458	146	1585	621	11575	49.7	262.7	5.29	0.56
2	1400	225	29.3	68.8	1.37	40	10.9	491	152	1595	1219	11048	54.0	362.5	6.71	0.49
3	1541	207	24.8	81.2	1.37	40	10.9	491	45	1578	1136	11009	64.0	457.4	7.15	0.50
Average:		213	26.4	76.9	1.37	40	10.9	480	114	1586	992	11211	55.9	360.9	6.46	0.52

Condition 2: With NCGs, without SOGs  
23-Jun-21

Run #	Start Time	Steam Rate (10 <sup>3</sup> lbs/hr)	Bark Rate (Tons/hr)	Gas Flow (10 <sup>3</sup> SCF/hr)	TDF (TPH)	NCG Scrubber Flow (GPM)	NCG Scrubber pH (SU)	Stripper Foul Condensate Flow (GPM)	Foul Condensate Flow (GPM)	LVHC Flow to		HVLC Flow to		SO <sub>2</sub> Emissions (lbs/hr)	SO <sub>2</sub> Emissions (lbs/ODT Pulp)	TRs Emissions (lbs/hr)
										Boilers (SCFM)	Boilers (SCFM)	Boilers (SCFM)	Boilers (SCFM)			
1	1824	230	26.3	94.9	1.37	40	10.9	489	123	1587	10515	74.1	404.4	5.46	0.43	
2	2019	216	23.7	97.5	1.37	40	10.9	491	184	1593	10377	74.7	452.9	6.06	0.42	
3	2202	220	25.2	92.4	1.37	40	10.9	490	152	1570	10573	79.2	450.8	5.69	0.46	
Average:		222	25.1	94.9	1.37	40	10.9	490	153	1583	10488	76.0	436.1	5.74	0.44	



## No. 2 COMBINATION BOILER

Combination Boiler #2

Condition 1: With NCGs, with SOGs  
24-Jun-21

Run #	Start Time	Steam Rate (10 <sup>3</sup> lbs/hr)	Bark Rate (Tons/Hr)	Gas Flow (10 <sup>3</sup> SCF/Hr)	TDF (TPH)	NCG Scrubber Flow (GPM)	NCG Scrubber pH (SU)	Stripper Foul Condensate Flow (GPM)	Hard Pipe Foul Condensate Flow (GPM)	LVHC Flow to Boilers (SCFM)	SO <sub>2</sub> Flow to Boilers (SCFM)	HVLC Flow to Boilers (SCFM)	Pulp Production (ODT/Hr)	SO <sub>2</sub> Emissions (lbs/hr)	SO <sub>2</sub> Emissions (lbs/ODT Pulp)	TRS Emissions (lbs/hr)
1	1445	219	39.0	125.3	1.37	40	10.9	491	190	1572	1231	10253	87.8	508.7	5.79	0.77
2	1630	224	31.1	146.4	1.37	40	10.9	490	186	1576	1231	10277	88.6	507.2	5.72	0.63
3	1806	241	33.6	146.4	1.37	40	10.9	490	190	1580	1231	10300	88.6	496.1	5.60	0.63
Average:		228	34.6	139.4	1.37	40	10.9	490	189	1576	1231	10277	88.3	504.0	5.71	0.68

Condition 2: With NCGs, without SOGs  
25-Jun-21

Run #	Start Time	Steam Rate (10 <sup>3</sup> lbs/hr)	Bark Rate (Tons/Hr)	Gas Flow (10 <sup>3</sup> SCF/Hr)	TDF (TPH)	NCG Scrubber Flow (GPM)	NCG Scrubber pH (SU)	Stripper Foul Condensate Flow (GPM)	Hard Pipe Foul Condensate Flow (GPM)	LVHC Flow to Boilers (SCFM)	SO <sub>2</sub> Flow to Boilers (SCFM)	HVLC Flow to Boilers (SCFM)	Pulp Production (ODT/Hr)	SO <sub>2</sub> Emissions (lbs/hr)	SO <sub>2</sub> Emissions (lbs/ODT Pulp)	TRS Emissions (lbs/hr)
1	1000	234	35.7	132.7	1.37	40	10.9	482	155	1579	10475	10475	87.2	383.2	4.39	0.86
2	1135	225	30.8	147.8	1.37	40	10.9	479	252	1573	10425	10425	84.3	380.0	4.51	0.82
3	1315	245	30.6	141.7	1.37	40	10.9	482	97	1571	10500	10500	84.2	366.2	4.35	0.63
Average:		235	32.4	140.7	1.37	40	10.9	481	168	1574	10467	10467	85.2	376.4	4.42	0.77

**END  
OF  
DOCUMENT**