

treatment, storage, or distribution system that the Department determines to be causing, or have the potential for causing, the introduction of contamination into the water delivered to consumers.

(e) Within 120 days, or earlier if directed by the Department, of receiving written notification from the Department of a significant deficiency, written notice from a laboratory that a ground water source sample collected under R.61-58.16.E(1)(c) was found to be fecal indicator positive, or direction from the Department that a fecal indicator positive sample collected under R.61-58.16.E(1)(b), R.61-58.16.E(1)(d), or R.61-58.16.E(2) requires corrective action, the ground water system must either:

(i) Have completed corrective action in accordance with applicable Department plan review processes or other Department guidance or direction, if any, including Department-specified interim measures; or

(ii) Be in compliance with a Department-approved corrective action plan and schedule subject to the following conditions:

(A) Any subsequent modifications to a Department-approved corrective action plan and schedule must also be approved by the Department.

(B) If the Department specifies interim measures for the protection of public health pending Department approval of the corrective action plan and schedule or pending completion of the corrective action plan, the system must comply with these interim measures as well as with any schedule specified by the Department.

(f) Corrective action alternatives. Ground water systems that meet the conditions of R.61-58.16.F(1)(a) or (b) must implement one or more of the following corrective action alternatives:

(i) Correct all significant deficiencies.

(ii) Provide an alternate source of water.

(iii) Eliminate the source of contamination.

(iv) Provide treatment that reliably achieves at least 4-log treatment of viruses (using inactivation, removal, or a Department-approved combination of 4-log virus inactivation and removal) before or at the first customer for the ground water source.

(g) Special notice to the public of significant deficiencies or source water fecal contamination.

(i) In addition to the applicable public notification requirements of R.61-58.6.E(2), a community ground water system that receives notice from the Department of a significant deficiency or notification of a fecal indicator positive ground water source sample that is not invalidated by the Department must inform the public served by the water system under R.61-58.12.C(11)(f) of the fecal indicator positive source sample or of any significant deficiency that has not been corrected. The system must continue to inform the public annually until the significant deficiency is corrected or the fecal contamination in the ground water source is determined by the Department to be corrected under R.61-58.16.F(1)(e).

(ii) In addition to the applicable public notification requirements of R.61-58.6.E(2), a non-community ground water system that receives notice from the Department of a significant deficiency must inform the public served by the water system in a manner approved by the Department of any significant deficiency that has not been corrected within 12 months of being notified by the

Department, or earlier if directed by the Department. The system must continue to inform the public annually until the significant deficiency is corrected. The information must include:

(A) The nature of the significant deficiency and the date the significant deficiency was identified by the Department.

(B) The Department-approved plan and schedule for correction of the significant deficiency, including interim measures, progress to date, and any interim measures completed.

(C) For systems with a large proportion of non-English speaking consumers, as determined by the Department, information in the appropriate language(s) regarding the importance of the notice or a telephone number or address where consumers may contact the system to obtain a translated copy of the notice or assistance in the appropriate language.

(iii) If directed by the Department, a non-community water system with significant deficiencies that have been corrected must inform its customers of the significant deficiencies, how the deficiencies were corrected, and the dates of correction under R.61-58.16.F(1)(g)(ii).

(2) Compliance monitoring

(a) Existing ground water sources. A ground water system that is not required to meet the source water monitoring requirements of R.61-58.16 because it provides at least 4-log treatment of viruses (using inactivation, removal, or a Department-approved combination of 4-log virus inactivation and removal) before or at the first customer for any ground water source before December 1, 2009, must notify the Department in writing that it provides at least 4-log treatment of viruses (using inactivation, removal, or a Department-approved combination of 4-log virus inactivation and removal) before or at the first customer for the specified ground water source and begin compliance monitoring in accordance with R.61-58.16.F(2)(c) by December 1, 2009. Notification to the Department must include engineering, operational, or other information that the Department requests to evaluate the submission. If the system subsequently discontinues 4-log treatment of viruses (using inactivation, removal, or a Department-approved combination of 4-log virus inactivation and removal) before or at the first customer for a ground water source, the system must conduct ground water source monitoring as required under R.61-58.16.E.

(b) New ground water sources. A ground water system that places a ground water source in service after November 30, 2009, that is not required to meet the source water monitoring requirements of R.61-58.16 because the system provides at least 4-log treatment of viruses (using inactivation, removal, or a Department-approved combination of 4-log virus inactivation and removal) before or at the first customer for the ground water source must comply with all of the requirements of R.61-58.16.F(2)(b)(i) to (iii).

(i) The system must notify the Department in writing that it provides at least 4-log treatment of viruses (using inactivation, removal, or a Department-approved combination of 4-log virus inactivation and removal) before or at the first customer for the ground water source. Notification to the Department must include engineering, operational, or other information that the Department requests to evaluate the submission.

(ii) The system must conduct compliance monitoring under R.61-58.16.F(2)(c) within 30 days of placing the source in service.

(iii) The system must conduct ground water source monitoring under R.61-58.16.E if the system subsequently discontinues 4-log treatment of viruses (using inactivation, removal, or a Department-approved combination of 4-log virus inactivation and removal) before or at the first customer for the ground water source.

(c) Monitoring requirements. A ground water system subject to the requirements of R.61-58.16.F(1), R.61-58.16.F(2)(a), or R.61-58.16.F(2)(b) must monitor the effectiveness and reliability of treatment for that ground water source before or at the first customer as follows:

(i) Chemical disinfection

(A) A ground water systems that serves greater than 3,300 people must continuously monitor the residual disinfectant concentration using analytical methods specified in 40 CFR 141.74(a)(2) at a location approved by the Department and must record the lowest residual disinfectant concentration each day that the water from the ground water source is served to the public. The ground water system must maintain the Department-determined residual disinfectant concentration every day the ground water system serves the water from the ground water source to the public. If there is a failure in the continuous monitoring equipment, the ground water system must conduct grab sampling every four hours until the continuous monitoring equipment is returned to service. The system must resume continuous residual disinfectant monitoring within 14 days.

(B) A ground water system that serves 3,300 or fewer people must monitor the residual disinfectant concentration using analytical methods specified in 40 CFR 141.74(a)(2) at a location approved by the Department and record the residual disinfection concentration each day that the water from the ground water source is served to the public. The ground water system must maintain the Department-determined residual disinfectant concentration every day the ground water system serves water from the ground water source to the public. The ground water system must take a daily grab sample during the hour of peak flow or at another time specified by the Department. If any daily grab sample measurement falls below the Department-determined residual disinfectant concentration, the ground water system must take follow up samples every four hours until the residual disinfectant concentration is restored to the Department-determined level. Alternatively, a ground water system that serves 3,300 or fewer people may monitor continuously and meet the requirements of R.61-58.16.F.(2)(c)(i)(A).

(ii) Membrane filtration. A ground water system that uses membrane filtration to meet the requirements of R.61-58.16 must monitor the membrane filtration process in accordance with all Department-specified monitoring requirements and must operate the membrane filtration in accordance with all Department-specified compliance requirements. A ground water system that uses membrane filtration is in compliance with the requirement to achieve at least 4-log removal of viruses when the following conditions are met:

(A) The membrane has an absolute molecular weight cut-off or an alternate parameter that describes the exclusion characteristics of the membrane that can reliably achieve at least 4-log removal of viruses.

(B) The membrane process is operated in accordance with Department-specified compliance requirements.

(C) The integrity of the membrane is intact.

(iii) Alternative treatment. A ground water system that uses a Department-approved alternative treatment to meet the requirements of R.61-58.16 by providing at least 4-log treatment of viruses (using inactivation, removal, or a Department-approved combination of 4-log virus inactivation and removal) before or at the first customer must:

(A) Monitor the alternative treatment in accordance with all Department-specified monitoring requirements.

(B) Operate the alternative treatment in accordance with all compliance requirements that the Department determines to be necessary to achieve at least 4-log treatment of viruses.

(3) A ground water system may discontinue 4-log treatment of viruses (using inactivation, removal, or a Department-approved combination of 4-log virus inactivation and removal) before or at the first customer for a ground water source if the Department determines and documents in writing that 4-log treatment of viruses is no longer necessary for that ground water source. A system that discontinues 4-log treatment of viruses is subject to the source water monitoring and analytical methods requirements of R.61-58.16.E.

(4) Failure to meet the monitoring requirements of R.61-58.16.F(2) is a monitoring violation and requires the ground water system to provide public notification under R.61-58.6.E(4).

G. Treatment technique violations for ground water systems.

(1) A ground water system with a significant deficiency is in violation of the treatment technique requirement if, within 120 days (or earlier if directed by the Department) of receiving written notice from the Department of the significant deficiency, the system:

(a) Does not complete corrective action in accordance with any applicable Department plan review processes or other Department guidance and direction, including Department specified interim actions and measures, or

(b) Is not in compliance with a Department-approved corrective action plan and schedule.

(2) Unless the Department invalidates a fecal indicator positive ground water source sample under R.61-58.16.E(4), a ground water system is in violation of the treatment technique requirement if, within 120 days (or earlier if directed by the Department) of meeting the conditions of R.61-58.16.F(1)(a) or R.61-58.16.F(1)(b), the system:

(a) Does not complete corrective action in accordance with any applicable Department plan review processes or other Department guidance and direction, including Department-specified interim measures, or

(b) Is not in compliance with a Department-approved corrective action plan and schedule.

(3) A ground water system subject to the requirements of R.61-58.16.F(2)(c) that fails to maintain at least 4-log treatment of viruses (using inactivation, removal, or a Department-approved combination of 4-log virus inactivation and removal) before or at the first customer for a ground water source is in violation of the treatment technique requirement if the failure is not corrected within four hours of determining the system is not maintaining at least 4-log treatment of viruses before or at the first customer.

(4) Ground water systems must give public notification under R.61-58.6.E(3) for the treatment technique violations specified in R.61-58.16.G(1), G(2), and G(3).

H. Reporting and recordkeeping for ground water systems.

(1) Reporting. In addition to the requirements of R.61-58.6.B, a ground water system regulated under R.61-58.16 must provide the following information to the Department:

(a) A ground water system conducting compliance monitoring under R.61-58.16.F(2) must notify the Department any time the system fails to meet any Department-specified requirements including, but not limited to, minimum residual disinfectant concentration, membrane operating criteria or membrane integrity, and alternative treatment operating criteria, if operation in accordance with the criteria or requirements is not restored within four hours. The ground water system must notify the Department as soon as possible, but in no case later than the end of the next business day.

(b) After completing any corrective action under R.61-58.16.F(1), a ground water system must notify the Department within 30 days of completion of the corrective action.

(c) If a ground water system subject to the requirements of R.61-58.16.E(1) does not conduct source water monitoring under R.61-58.16.E(1)(e)(ii), the system must provide documentation to the Department within 30 days of the total coliform positive sample that it met the Department criteria.

(2) Recordkeeping. In addition to the requirements of R.61-58.6.D, a ground water system regulated under R.61-58.16 must maintain the following information in its records:

(a) Documentation of corrective actions shall be kept for a period of not less than ten years.

(b) Documentation of notice to the public as required under R.61-58.16.F(1)(g) shall be kept for a period of not less than three years.

(c) Records of decisions under R.61-58.16.E(1)(e)(ii) and records of invalidation of fecal indicator positive ground water source samples under R.61-58.16.E(4) shall be kept for a period of not less than five years.

(d) For consecutive systems, documentation of notification to the wholesale system(s) of total coliform positive samples that are not invalidated under R.61-58.5.G(3) shall be kept for a period of not less than five years.

(e) For systems, including wholesale systems, that are required to perform compliance monitoring under R.61-58.16.F(2):

(i) Records of the Department-specified minimum disinfectant residual shall be kept for a period of not less than ten years.

(ii) Records of the lowest daily residual disinfectant concentration and records of the date and duration of any failure to maintain the Department-specified minimum residual disinfectant concentration for a period of more than four hours shall be kept for a period of not less than five years.

(iii) Records of Department-specified compliance requirements for membrane filtration and of parameters specified by the Department for Department-approved alternative treatment and records of the date and duration of any failure to meet the membrane operating, membrane integrity, or alternative treatment operating requirements for more than four hours shall be kept for a period of not less than five years.

APPENDIX A TO 61-58.6: VIOLATIONS AND OTHER SITUATIONS REQUIRING PUBLIC NOTICE<sup>1</sup>

CONTAMINANT	MCL/MRDL/TT/VIOLATIONS <sup>2</sup>		MONITORING & TESTING PROCEDURE VIOLATIONS	
	TIER OF PUBLIC NOTICE REQUIRED	CITATION	TIER OF PUBLIC NOTICE REQUIRED	CITATION
<b>I. Violations of the State Primary Drinking Water Regulations (SPDWR):<sup>3</sup></b>				
<b>A. Microbiological Contaminants</b>				
1. Total coliform	2	61-58.5.F(1)	3	61-58.5.G(1) - (5)
2. Fecal coliform/E. coli	1	61-58.5.F(2)	<sup>4</sup> 1, 3	61-58.5.G(5)
3. Turbidity MCL	2	61-58.10.E, H, & I	3	61-58.10.F
4. Turbidity MCL (average of 2 days samples greater than 5 NTU)	<sup>5</sup> 2, 1	61-58.10.C, E, H & I	3	61-58.10.F
5. Turbidity (for TT violations resulting from a single exceedance of maximum allowable turbidity level)	<sup>6</sup> 2, 1	61-58.10.C(i)(b) 61-58.10.C(3)(b) 61-58.10.F(2)(b), 61-58.10.E(1)(b), 61-58.10.E(2)(b), 61-58.10.E(3)(b), 61-58.10.E(4), 61-58.10.H(4)(a)(ii), 61-58.10.H(4)(b), 61-58.10.I(6)(b)	3	61-58.10.F  61-58.10.F(3) 61-58.10.H  61-58.10(I)(7)(a) (i)-(iii) & (b)
6. Surface Water Treatment Rule violations, other than violations resulting from single exceedance of max. allowable turbidity level (TT).	2	61-58.10.B - E		61-58.10
7. Interim Enhanced Surface Water Treatment Rule violations, other than violations resulting from single exceedance of max. turbidity level (TT)	<sup>7</sup> 2	61-58.10.B - E 61-58.10.I(1)-(7)	3	61-58.10.H(3), (5) 61-58.10.I(4) & (5) 61-58.10.I(7)
8. Filter Backwash Recycling Rule violations	2	61-58.10.J(3)	3	61-58.10.J(2) & (4)
9. Long Term 1 Enhanced Surface Water	2	61-58.10.I(1)-(7)	3	61-58.10.I(4) & (5)

Appendix A

Treatment Rule Violations.				61-58.10.I(7)
10. LT2ESWTR Violations	2	61-58.10.K(11) - (21)	<sup>22</sup> 2,3	61-58.10.K(2) - (6) & 61-58.10.K(9) - (10)
✓11. Ground Water Rule Violations	2	61-58.16.G	3	61-58.16.E(8) 61-58.16.F(4)

**B. Inorganic Chemicals (IOCs)**

1. Antimony	2	61-58.5.B(2)	3	61-58.5.C(7), (9)
2. Arsenic	2	<sup>8</sup> 61-58.5.B(2)	3	<sup>9</sup> 61-58.5.C(7)
3. Asbestos (fibers >10µm)	2	61-58.5.B(2)	3	61-58.5.C(7), (8)
4. Barium	2	61-58.5.B(2)	3	61-58.5.C(7), (9)
5. Beryllium	2	61-58.5.B(2)	3	61-58.5.C(7), (9)
6. Cadmium	2	61-58.5.B(2)	3	61-58.5.C(7), (9)
7. Chromium (total)	2	61-58.5.B(2)	3	61-58.5.C(7), (9)
8. Cyanide	2	61-58.5.B(2)	3	61-58.5.C(7), (9)
9. Fluoride	2	61-58.5.B(2)	3	61-58.5.C(7), (9)
10. Mercury (inorganic)	2	61-58.5.B(2)	3	61-58.5.C(7), (9)
11. Nitrate	1	61-58.5.B(2)	<sup>10</sup> 1, 3	61-58.5.C(7), (10) 61-58.5.C(12)
12. Nitrite	1	61-58.5.B(2)	<sup>10</sup> 1, 3	61-58.5.C (7), (10), 61-58.5.C(12)
13. Total Nitrate and Nitrite	1	61-58.5.B(2)	3	61-58.5.C(7)
14. Selenium	2	61-58.5.B(2)	3	61-58.5.C(7), (9)
15. Thallium	2	61-58.5.B(2)	3	61-58.5.C(7), (9)

**C. Lead and Copper Rule (Action Level for lead is 0.015 mg/L, for copper is 1.3 mg/L)**

1. Lead and Copper Rule (TT)	2	61-58.11.B - G	3	61-58.11.H - K
------------------------------	---	----------------	---	----------------

**D. Synthetic Organic Chemicals (SOCs)**

1. 2,4-D	2	61-58.5.D	3	61-58.5.E(7)
2. 2,4,5-TP (Silvex)	2	61-58.5.D	3	61-58.5.E(7)
3. Alachlor	2	61-58.5.D	3	61-58.5.E(7)
4. Atrazine	2	61-58.5.D	3	61-58.5.E(7)
5. Benzo(a)pyrene (PAHs)	2	61-58.5.D	3	61-58.5.E(7)
6. Carbofuran	2	61-58.5.D	3	61-58.5.E(7)
7. Chlordane	2	61-58.5.D	3	61-58.5.E(7)
8. Dalapon	2	61-58.5.D	3	61-58.5.E(7)
9. Di (2-ethylhexyl) adipate	2	61-58.5.D	3	61-58.5.E(7)

## Appendix A

10. Di (2-ethylhexyl) phthalate	2	61-58.5.D	3	61-58.5.E(7)
11. Dibromochloropropane	2	61-58.5.D	3	61-58.5.E(7)
12. Dinoseb	2	61-58.5.D	3	61-58.5.E(7)
13. Dioxin (2,3,7,8-TCDD)	2	61-58.5.D	3	61-58.5.E(7)
14. Diquat	2	61-58.5.D	3	61-58.5.E(7)
15. Endothall	2	61-58.5.D	3	61-58.5.E(7)
16. Endrin	2	61-58.5.D	3	61-58.5.E(7)
17. Ethylene dibromide	2	61-58.5.D	3	61-58.5.E(7)
18. Glyphosate	2	61-58.5.D	3	61-58.5.E(7)
19. Heptachlor	2	61-58.5.D	3	61-58.5.E(7)
20. Heptachlor epoxide	2	61-58.5.D	3	61-58.5.E(7)
21. Hexachlorobenzene	2	61-58.5.D	3	61-58.5.E(7)
22. Hexachlorocyclo-pentadiene	2	61-58.5.D	3	61-58.5.E(7)
23. Lindane	2	61-58.5.D	3	61-58.5.E(7)
24. Methoxychlor	2	61-58.5.D	3	61-58.5.E(7)
25. Oxamyl (Vydate)	2	61-58.5.D	3	61-58.5.E(7)
26. Pentachlorophenol	2	61-58.5.D	3	61-58.5.E(7)
27. Picloram	2	61-58.5.D	3	61-58.5.E(7)
28. Polychlorinated biphenyls (PCBs)	2	61-58.5.D	3	61-58.5.E(7)
29. Simazine	2	61-58.5.D	3	61-58.5.E(7)
30. Toxaphene	2	61-58.5.D	3	61-58.5.E(7)

**E. Volatile Organic Chemicals (VOCs)**

1. Benzene	2	61-58.5.N	3	61-58.5.O
2. Carbon tetrachloride	2	61-58.5.N	3	61-58.5.O
3. Chlorobenzene (monochlorobenzene)	2	61-58.5.N	3	61-58.5.O
4. o-Dichlorobenzene	2	61-58.5.N	3	61-58.5.O
5. p-Dichlorobenzene	2	61-58.5.N	3	61-58.5.O
6. 1,2-Dichloroethane	2	61-58.5.N	3	61-58.5.O
7. 1,1-Dichloroethylene	2	61-58.5.N	3	61-58.5.O
8. cis-1,2-Dichloroethylene	2	61-58.5.N	3	61-58.5.O
9. trans-1,2-Dichloroethylene	2	61-58.5.N	3	61-58.5.O
10. Dichloromethane	2	61-58.5.N	3	61-58.5.O
11. 1,2-Dichloropropane	2	61-58.5.N	3	61-58.5.O
12. Ethylbenzene	2	61-58.5.N	3	61-58.5.O
13. Styrene	2	61-58.5.N	3	61-58.5.O
14. Tetrachloroethylene	2	61-58.5.N	3	61-58.5.O
15. Toluene	2	61-58.5.N	3	61-58.5.O
16. 1,2,4-Trichlorobenzene	2	61-58.5.N	3	61-58.5.O
17. 1,1,1-Trichloroethane	2	61-58.5.N	3	61-58.5.O
18. 1,1,2-Trichloroethane	2	61-58.5.N	3	61-58.5.O

Appendix A

19. Trichloroethylene	2	61-58.5.N	3	61-58.5.O
20. Vinyl chloride	2	61-58.5.N	3	61-58.5.O
21. Xylenes (total)	2	61-58.5.N	3	61-58.5.O

**F. Radioactive Contaminants**

1. Beta/photon emitters	2	61-58.5.H(4)	3	61-58.5.K(1), 61-58.5.I(3)
2. Alpha emitters	2	61-58.5.H(3)	3	61-58.5.K(1), 61-58.5.I(2)
3. Combined radium (226 & 228)	2	61-58.5.H(2)	3	61-58.5.K(1), 61-58.5.I2
4. Uranium	<sup>11</sup> 2	61-58.5.H(5)	<sup>12</sup> 3	61-58.5.K(1), 61-58.5.I(2)

**G. Disinfection Byproducts (DBPs), Byproduct Precursors, Disinfectant Residuals. Where disinfection is used in the treatment of drinking water, disinfectants combine with organic and inorganic matter present in water to form chemicals called disinfection byproducts (DBPs). EPA sets standards for controlling the levels of disinfectants and DBPs in drinking water, including trihalomethanes (THMs) and haloacetic acids (HAAs).<sup>13</sup>**

1. Total trihalomethanes (TTHMs)	2	<sup>14</sup> 61-58.5.L, 61-58.5.P	3	<sup>14</sup> 61-58.5.M 61-58.13.C(1), (2) 61-58.14, 61-58.15
2. Haloacetic Acids (HAA5)	2	61-58.5.P	3	61-58.13.C(1), (2) 61-58.14, 61-58.15
3. Bromate	2	61-58.5.P	3	61-58.13.C(1), (2)
4. Chlorite	2	61-58.5.P	3	61-58.13.C(1), (2)
5. Chlorine (MRDL)	2	61-58.5.Q	3	61-58.13.C(1), (3)
6. Chloramine (MRDL)	2	61-58.5.Q	3	61-58.13.C(1), (3)
7. Chlorine dioxide (MRDL) where any 2 consecutive daily samples at entrance to distribution system only are above MRDL	2	61-58.5.Q, 61-58.13.D	2 <sup>15</sup> , 3	61-58.13.C(1), (3), 61-58.13.C(3)(b)
8. Chlorine dioxide (MRDL), where sample(s) in distribution system the next day are also above MRDL	<sup>16</sup> 1	61-58.5.Q, 61-58.13.D(3)	1	61-58.13.C(1), (3), 61-58.13.D(3)(b)
9. Control of DBP precursors--TOC (TT)	2	61-58.13.F(1), (2)	3	61-58.13.C(1), (4)
10. Bench marking and disinfection profiling.	N/A	N/A	3	61-58.10.G(3) 61-58.10.H(3) 61-58.10.I(4) & (5)
11. Development of monitoring plan	N/A	N/A	3	61-58.13.C(6)

**H. Other Treatment Techniques**

1. Acrylamide (TT)	2	61-58.5.AA	N/A	N/A
2. Epichlorohydrin (TT)	2	61-58.5.AA	N/A	N/A

**II. Unregulated Contaminant Monitoring:**<sup>17</sup>

A. Unregulated contaminants	N/A	N/A	3	61-58.5.T
B. Nickel	N/A	N/A	3	61-58.5.C(9), (17)

**III. Public Notification for Variances and Exemptions:**

A. Operation under a variance or exemption	3	<sup>18</sup> 61-58.9	N/A	N/A
B. Violation of conditions of a variance or exemption	2	<sup>19</sup> 61-58.9	N/A	N/A

**IV. Other Situations Requiring Public Notification:**

A. Fluoride secondary maximum contaminant level (SMCL) exceedance	3	61-58.5.R	N/A	N/A
B. Exceedance of nitrate MCL for non-community systems, as allowed by Department	1	61-58.5.B(3)	N/A	N/A
C. Availability of unregulated contaminant monitoring data	3	61-58.5.T	N/A	N/A
D. Waterborne disease outbreak	1	61-58.B(156) 61-58.10.C(3)(b)(ii)	N/A	N/A
E. Other waterborne emergency <sup>20</sup>	1	N/A	N/A	N/A
F. Source Water Sample Positive for Ground Water Rule Fecal indicators: E. coli, enterococci, or coliphage	1	61-58.16.E(7)	N/A	N/A
G. Other situations as determined by the Department	<sup>21</sup> 1, 2, 3	N/A	N/A	N/A

## Appendix A to R.61-58.6 - Endnotes

<sup>1</sup> Violations and other situations not listed in this table (e.g., failure to prepare Consumer Confidence Reports), do not require notice, unless otherwise determined by the Department. The Department may, at its option, also require a more stringent public notice tier (e.g., Tier 1 instead of Tier 2 or Tier 2 instead of Tier 3) for specific violations and situations listed in this Appendix, as authorized under R.61-58.6.E(2)(a) and (3)(a).

- <sup>2</sup> MCL--Maximum contaminant level, MRDL--Maximum residual disinfectant level, TT--Treatment technique
- <sup>3</sup> The term Violations of State Primary Drinking Water Regulations (SPDWR) is used here to include violations of MCL, MRDL, treatment technique, monitoring, and testing procedure requirements.
- <sup>4</sup> Failure to test for fecal coliform or E. coli is a Tier 1 violation if testing is not done after any repeat sample tests positive for coliform. All other total coliform monitoring and testing procedure violations are Tier 3.
- <sup>5</sup> Systems that violate the turbidity MCL of 5 NTU based on an average of measurements over two consecutive days must consult with the Department within 24 hours after learning of the violation. Based on this consultation, the Department may subsequently decide to elevate the violation to Tier 1. If a system is unable to make contact with the Department in the 24-hour period, the violation is automatically elevated to Tier 1.
- <sup>6</sup> Systems with treatment technique violations involving a single exceedance of a maximum turbidity limit under the Surface Water Treatment Rule (SWTR) Interim Enhanced Surface Water Treatment Rule (IESWTR), or the Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR) are required to consult with the Department within 24 hours after learning of the violation. Based on this consultation, the Department may subsequently decide to elevate the violation to Tier 1. If a system is unable to make contact with the Department in the 24-hour period, the violation is automatically elevated to Tier 1.
- <sup>7</sup> Most of the requirements of the Interim Enhanced Surface Water Treatment Rule, R.61-58.10.B - C become effective January 1, 2002 for surface water systems and ground water systems under the direct influence of surface water serving at least 10,000 persons. However, R.61-58.10.H(3) has some requirements that become effective as early as April 16, 1999. The Surface Water Treatment Rule remains in effect for systems serving at least 10,000 persons even after 2002; the Interim Enhanced Surface Water Treatment Rule adds additional requirements and does not in many cases supercede the SWTR.
- <sup>8</sup> The arsenic MCL citations are effective January 23, 2006. Until then the citations are R.61-58.5(B)(2).
- <sup>9</sup> The arsenic Tier 3 violations MCL citations are effective January 23, 2006. Until then, the citations are R.61-58.C(7).
- <sup>10</sup> Failure to take a confirmation sample within 24 hours for nitrate or nitrite after an initial sample exceeds the MCL is a Tier 1 violation. Other monitoring violations for nitrate are Tier 3.
- <sup>11</sup> The uranium MCL, Tier 2 violation citations are effective December 8, 2003 for all community water systems.
- <sup>12</sup> The uranium Tier 3 violation citations are effective December 8, 2000 for all community water systems.
- <sup>13</sup> Community and non-transient non-community surface water systems and ground water systems under the direct influence of surface water serving 10,000 must comply with new DBP MCLs, disinfectant MRDLs, and related monitoring requirements beginning January 1, 2002. All other community and non-transient non-community systems must meet the MCLs and MRDLs beginning January 1, 2004. Transient non-community surface water systems and ground water systems under the direct influence of surface water serving 10,000 or more persons and using chlorine dioxide as a disinfectant or oxidant must comply with the chlorine dioxide MRDL beginning January 1, 2002. Transient non-community surface water systems and ground water systems under the direct influence of surface water serving fewer than 10,000 persons and using only ground water not under the direct influence of surface water and using chlorine dioxide as a disinfectant or oxidant must comply with the chlorine dioxide MRDL beginning January 1, 2004.
- <sup>14</sup> R.61-58.5.L, and R.61-58.13.C(1) - (2) apply until R.61-58.14 and R.61-58.15 take effect under the schedule in R.61-58.14.
- <sup>15</sup> Failure to monitor for chlorine dioxide at the entrance to the distribution system the day after exceeding the MRDL at the entrance to the distribution system is a Tier 2 violation.
- <sup>16</sup> If any daily sample taken at the entrance to the distribution system exceeds the MRDL for chlorine dioxide and one or more samples taken in the distribution system the next day exceed the MRDL, Tier 1 notification is required. Failure to take the required samples in the distribution system after the MRDL is exceeded at the entry point also triggers Tier 1 notification.
- <sup>17</sup> Some water systems must monitor for certain unregulated contaminants listed in R.61-58.5.T

<sup>18</sup> This citation refers to the requirements in R.61-58.9 that "a schedule prescribed . . . for a public water system granted a variance [or exemption] shall require compliance by the system . . ."

<sup>19</sup> In addition to R.61-58.9 specifies the items and schedule milestones that must be included in a variance for small systems.

<sup>20</sup> Other waterborne emergencies require a Tier 1 public notice under R.61-58.6.E(2)(a) for situations that do not meet the definition of a waterborne disease outbreak given in R.61-58.B(174) but that still have the potential to have serious adverse effects on health as a result of short-term exposure. These could include outbreaks not related to treatment deficiencies, as well as situations that have the potential to cause outbreaks, such as failures or significant interruption in water treatment processes, natural disasters that disrupt the water supply or distribution system, chemical spills, or unexpected loading of possible pathogens into the source water.

<sup>21</sup> The Department may place other situations in any tier they believe appropriate, based on threat to public health.

<sup>22</sup> Failure to collect three or more samples for Cryptosporidium analysis is a Tier 2 violation requiring special notice as specified in R.61-58.6.E(11). All other monitoring and testing procedure violations are Tier 3.

## APPENDIX B TO R.61-58.6: STANDARD HEALTH EFFECTS LANGUAGE FOR PUBLIC NOTIFICATION

Contaminant	MCLG <sup>1</sup> mg/L	MCL <sup>2</sup> mg/L	Standard health effects language for public notification
<b>State Primary Drinking Water Regulations (SPDWR):</b>			
<b>A. Microbiological Contaminants:</b>			
1a. Total coliform	Zero	See footnote <sup>3</sup>	Coliforms are bacteria that are naturally present in the and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.
1b. Fecal coliform/E. coli	Zero	Zero	Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants young children, some of the elderly, and people with severely compromised immune systems.
1c. Fecal Indicators (Ground Water Rule)			Fecal indicators are microbes whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term health effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.
i. E. coli	Zero	TT	
ii. enterococci	None	TT	
iii. coliphage	None	TT	
1d. Ground Water Rule TT violations	None	TT	Inadequately treated or inadequately protected water may contain disease-causing organisms. These organisms can cause symptoms such as diarrhea, nausea, cramps, and associated headaches.
2a. Turbidity (MCL) <sup>4</sup>	None	1 NTU <sup>5</sup> /5 NTU	Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial microbial growth. Turbidity may indicate presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.
2b. Turbidity (SWTR TT) <sup>6</sup>	None	TT <sup>7</sup>	Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated

2c. Turbidity (IESWTR TT) <sup>8</sup>	None	TT	headaches. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.
--	------	----	--

**B. Surface Water Treatment Rule (SWTR), Interim Enhanced Surface Water Treatment Rule (IESWTR), Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR) and Filter Backwash Recycling Rule (FBRR) violations:**

3. <i>Giardia lamblia</i> (SWTR/IESWTR/LT1ESWTR)	Zero	TT <sup>10</sup>	Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
4. Viruses (SWTR/IESWTR/LT1ESWTR)			
5. Heterotrophic plate count (HPC) bacteria <sup>9</sup> (SWTR/IESWTR/LT1ESWTR).			
6. <i>Legionella</i> (SWTR/IESWTR/LT1ESWTR).			
7. <i>Cryptosporidium</i> (IESWTR/FBRR/LT1ESWTR).			

**C. Inorganic Chemicals (IOCs):**

8. Antimony	0.006	0.006	Some people who drink water containing antimony well in excess of the MCL over many years could experience increases in blood cholesterol and decreases in blood sugar.
9. Arsenic <sup>11</sup>	Zero	0.010	Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
10. Asbestos (10 µm)	7 MFL <sup>12</sup>	7 MFL	Some people who drink water containing asbestos in excess of the MCL over many years may have an increased risk of developing benign intestinal polyps.
11. Barium	2	2	Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.
12. Beryllium	0.004	0.004	Some people who drink water containing beryllium well in excess of the

Appendix B

13. Cadmium	0.005	0.005	MCL over many years could develop intestinal lesions. Some people who drink water containing cadmium in excess of the MCL over many years could experience kidney damage.
14. Chromium (total)	0.1	0.1	Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.
15. Cyanide	0.2	0.2	Some people who drink water containing cyanide well in excess of the MCL over many years could experience nerve damage or problems with their thyroid.
16. Fluoride	4.0	4.0	Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.
17. Mercury (inorganic)	0.002	0.002	Some people who drink water containing inorganic mercury well in excess of the MCL over many years could experience kidney damage.
18. Nitrate	10	10	Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.
19. Nitrite	1	1	Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.
20. Total Nitrate and Nitrite	10	10	Infants below the age of six months who drink water containing nitrate and nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.
21. Selenium	0.05	0.05	Selenium is an essential nutrient. However, some people who drink water containing selenium in excess of the MCL over many years could experience hair or fingernail losses, numbness in fingers or toes, or problems with their circulation.
22. Thallium	0.0005	0.002	Some people who drink water containing thallium in excess of the MCL over many years could experience hair loss, changes in their blood, or problems with their kidneys, intestines, or liver.

**D. Lead and Copper Rule:**

23. Lead	Zero	TT <sup>13</sup>	Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years
----------	------	------------------	---

24. Copper	1.3	TT <sup>14</sup>	could develop kidney problems or high blood pressure. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
<b>E. Synthetic Organic Chemicals (SOCs):</b>			
25. 2,4-D	0.07	0.07	Some people who drink water containing the weed killer 2,4-D well in excess of the MCL over many years could experience problems with kidneys, liver, or adrenal glands.
26. 2,4,5-TP (Silvex)	0.05	0.05	Some people who drink water containing silvex in excess of the MCL over many years could experience liver problems.
27. Alachlor	Zero	0.002	Some people who drink water containing alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or experience anemia, and may have an increased risk of getting cancer.
28. Atrazine	0.003	0.003	Some people who drink water containing atrazine well in excess of the MCL over many years could experience problems with their cardiovascular system or reproductive difficulties.
29. Benzo(a)pyrene (PAHs)	Zero	0.0002	Some people who drink water containing benzo(a)pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.
30. Carbofuran	0.04	0.04	Some people who drink water containing carbofuran in excess of the MCL over many years could experience problems with their blood, or nervous or reproductive systems.
31. Chlordane	Zero	0.002	Some people who drink water containing chlordane in excess of the MCL over many years could experience problems with their liver or nervous system, and may have an increased risk of getting cancer.
32. Dalapon	0.2	0.2	Some people who drink water containing dalapon well in excess of the MCL over many years could experience minor kidney changes.
33. Di (2-ethylhexyl) adipate	0.4	0.4	Some people who drink water containing di(2-ethylhexyl) adipate well in excess of the MCL over many years could experience toxic effects such as weight loss, liver enlargement or possible reproductive difficulties.
34. Di (2-ethylhexyl) phthalate	Zero	0.006	Some people who drink water containing di(2-ethylhexyl) phthalate well in excess of the MCL many years may have problems with their liver, or experience reproductive difficulties, and may have an increased risk of getting cancer.
35. Dibromochloropropane (DBCP)	Zero	0.0002	Some people who drink water containing DBCP in of the MCL over

Appendix B

36. Dinoseb	0.007	0.007	many years could experience reproductive difficulties and may have an increased risk of getting cancer.
37. Dioxin (2,3,7,8-TCDD).	Zero	$3 \times 10^{-8}$	Some people who drink water containing dinoseb well in excess of the MCL over many years could experience reproductive difficulties.
38. Diquat	0.02	0.02	Some people who drink water containing dioxin in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.
39. Endothall	0.1	0.1	Some people who drink water containing diquat in excess of the MCL over many years could get cataracts.
40. Endrin	0.002	0.002	Some people who drink water containing endothall in excess of the MCL over many years could experience problems with their stomach or intestines.
41. Ethylene dibromide	Zero	0.00005	Some people who drink water containing endrin in excess of the MCL over many years could experience liver problems.
42. Glyphosate	0.7	0.7	Some people who drink water containing ethylene dibromide in excess of the MCL over many years could experience problems with their liver, stomach, reproductive system, or kidneys, and may have an increased risk of getting cancer.
43. Heptachlor	Zero	0.0004	Some people who drink water containing glyphosate in excess of the MCL over many years could experience problems with their kidneys or reproductive difficulties.
44. Heptachlor epoxide	Zero	0.0002	Some people who drink water containing heptachlor in excess of the MCL over many years could experience liver damage and may have an increased risk of getting cancer.
45. Hexachlorobenzene	Zero	0.001	Some people who drink water containing heptachlor epoxide in excess of the MCL over many years could experience liver damage, and may have an increased risk of getting cancer.
46. Hexachlorocyclo pentadiene	0.05	0.05	Some people who drink water containing hexachlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys, or adverse reproductive effects, and may have an increased risk of getting cancer.
47. Lindane	0.0002	0.0002	Some people who drink water containing Hexachlorocyclo-pentadiene well in excess of the MCL over many years could experience problems with their kidneys or stomach.
48. Methoxychlor	0.04	0.04	Some people who drink water containing lindane in excess of the MCL over many years could experience problems with their kidneys or liver.
49. Oxamyl (Vydate)	0.2	0.2	Some people who drink water containing methoxychlor in excess of the MCL over many years could experience reproductive difficulties.
50. Pentachlorophenol	Zero	0.001	Some people who drink water containing oxamyl in excess of the MCL over many years could experience slight nervous system effects.
			Some people who drink water containing pentachlorophenol in excess of

51. Picloram	0.5	0.5	the MCL over many years could experience problems with their liver or kidneys, and may have an increased risk of getting cancer.
52. Polychlorinated biphenyls (PCBs).	Zero	0.0005	Some people who drink water containing picloram in excess of the MCL over many years could experience problems with their liver.
53. Simazine	0.004	0.004	Some people who drink water containing PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland, immune deficiencies, or reproductive or nervous system difficulties, and may have an increased risk of getting cancer.
54. Toxaphene	Zero	0.003	Some people who drink water containing simazine in excess of the MCL over many years could experience problems with their blood.
			Some people who drink water containing toxaphene in excess of the MCL over many years could have problems with their kidneys, liver, or thyroid, and may have an increased risk of getting cancer.

#### F. Volatile Organic Chemicals (VOCs):

55. Benzene	Zero	0.005	Some people who drink water containing benzene in excess of the MCL over many years could experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.
56. Carbon tetrachloride	Zero	0.005	Some people who drink water containing carbon tetrachloride in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.
57. Chlorobenzene (monochlorobenzene)	0.1	0.1	Some people who drink water containing chlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys.
58. o-Dichlorobenzene	0.6	0.6	Some people who drink water containing o-dichlorobenzene well in excess of the MCL over many years could experience problems with their liver, kidneys, or circulatory systems.
59. p-Dichlorobenzene	0.075	0.075	Some people who drink water containing p-dichlorobenzene in excess of the MCL over many years could experience anemia, damage to their liver, kidneys, or spleen, or changes in their blood.
60. 1,2-Dichloroethane	Zero	0.005	Some people who drink water containing 1,2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer.
61. 1,1-Dichloroethylene	0.007	0.007	Some people who drink water containing 1,1-dichloroethylene in excess of the MCL over many years could experience problems with their liver.
62. cis-1,2-Dichloroethylene	0.07	0.07	Some people who drink water containing cis-1,2-dichloroethylene in excess of the MCL over many years could experience problems with their liver.
63. trans-1,2-Dichloroethylene	0.1	0.1	Some people who drink water containing trans-1,2-dichloroethylene well

Appendix B

64. Dichloromethane	Zero	0.005	in excess of the MCL over many years could experience problems with their liver. Some people who drink water containing dichloromethane in excess of the MCL over many years could have liver problems and may have an increased risk of getting cancer.
65. 1,2-Dichloropropane	Zero	0.005	Some people who drink water containing 1,2-dichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.
66. Ethylbenzene	0.7	0.7	Some people who drink water containing ethylbenzene well in excess of the MCL over many years could experience problems with their liver or kidneys.
67. Styrene	0.1	0.1	Some people who drink water containing styrene well in excess of the MCL over many years could have problems with their liver, kidneys, or circulatory system.
68. Tetrachloroethylene	Zero	0.005	Some people who drink water containing tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.
69. Toluene	1	1	Some people who drink water containing toluene well in excess of the MCL over many years could have problems with their nervous system, kidneys, or liver.
70. 1,2,4-Trichlorobenzene	0.07	0.07	Some people who drink water containing 1,2,4-trichlorobenzene well in excess of the MCL over many years could experience changes in their adrenal glands.
71. 1,1,1-Trichloroethane	0.2	0.2	Some people who drink water containing 1,1,1-trichloroethane in excess of the MCL over many years could experience problems with their liver, nervous system, or circulatory system.
72. 1,1,2-Trichloroethane	0.003	0.005	Some people who drink water containing 1,1,2-trichloroethane well in excess of the MCL over many years could have problems with their liver, kidneys, or immune systems.
73. Trichloroethylene	Zero	0.005	Some people who drink water containing trichloroethylene in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.
74. Vinyl chloride	Zero	0.002	Some people who drink water containing vinyl chloride in excess of the MCL over many years may have an increased risk of getting cancer.
75. Xylenes (total)	10	10	Some people who drink water containing xylenes in excess of the MCL over many years could experience damage to their nervous system.

**G. Radioactive Contaminants:**

76. Beta/photon emitters	Zero	4 mrem/yr <sup>15</sup>	Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta and photon emitters in excess of the MCL over
--------------------------	------	-------------------------	---

77. Alpha emitters	Zero	15 pCi/L <sup>16</sup>	many years may have an increased risk of getting cancer. Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.
78. Combined radium (226 & 228)	Zero	5 pCi/L	Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.
79. Uranium <sup>17</sup>	Zero	30µg/L	Some people who drink water containing uranium in excess of the MCL over many years may have an increased risk of getting cancer and kidney toxicity.

**H. Disinfection Byproducts (DBPs), Byproduct Precursors, and Disinfectant Residuals: Where disinfection is used in the treatment of drinking water, disinfectants combine with organic and inorganic matter present in water to form chemicals called disinfection byproducts (DBPs). EPA sets standards for controlling the levels of disinfectants and DBPs in drinking water, including trihalomethanes (THMs) and haloacetic acids (HAAs):<sup>18</sup>**

80. Total trihalomethanes (TTHMs)	N/A	0.08017 <sup>19,20</sup>	Some people who drink water containing trihalomethanes excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system and may have an increased risk of getting cancer.
81. Haloacetic Acids (HAA)	N/A	0.060 <sup>21</sup>	Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.
82. Bromate	Zero	0.010	Some people who drink water containing bromate in excess of the MCL over many years may have an increased risk of getting cancer.
83. Chlorite	0.08	1.0	Some infants and young children who drinking water containing chlorite in excess of the MCL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorite in excess of the MCL. Some people may experience anemia.
84. Chlorine	4 (MRDLG) <sup>22</sup>	4.0 (MRDL) <sup>23</sup>	Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.
85. Chloramines	4 (MRDLG)	4.0 (MRDL)	Some people who use water containing chloramines well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chloramines well in excess of the MRDL could experience stomach discomfort or anemia.
86a. Chlorine dioxide, where any 2 consecutive daily samples taken	0.8 (MRDLG)	0.8 (MRDL)	Some infants and young children who drink water containing chlorine dioxide in excess of a the MRDL could experience nervous system

Appendix B

at the entrance to the distribution system are above the MRDL.

86b. Chlorine dioxide, where one or more water distribution system are above the MRDL      0.8 (MRDLG)      0.8 (MRDL)

effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorine ioxide in excess of the MRDL. Some people may experience anemia.

*Add for public notification only:* The chlorine dioxide violations reported today are the result of exceedances at the treatment facility only not within the distribution system which delivers water to consumers. Continued compliance with chlorine dioxide levels within the distribution system minimizes the potential risk of these violations to consumers.

Some infants and young children who drink containing chlorine dioxide in excess of the MRDL could experience nervous effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorine dioxide in excess of the MRDL. Some people may experience anemia.

*Add for public notification only:* The chlorine dioxide violations reported today include exceedances of the EPA standard within the distribution system which delivers water to consumers. Violations of the chlorine dioxide standard within the distribution system may harm human health based on short-term exposures. Certain groups, including fetuses, infants, and young children, may be especially susceptible to nervous system effects from excessive chlorine dioxide exposure.

87. Control of DBP precursors (DBP)      None      TT

Total organic carbon (TOC) has no health effects However, total organic carbon provides a medium for the formation of disinfection by-products. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these by-products in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

**I. Other Treatment Techniques:**

88. Acrylamide      Zero      TT

Some people who drink water containing high levels of acrylamide over a long period of time could have problems with their nervous system or blood, and may have an increased risk of getting cancer.

89. Epichlorohydrin      Zero      TT

Some people who drink water containing high levels of epichlorohydrin over a long period of time could experience stomach problems, and may have an increased risk of getting cancer.

Appendix B to R.61-58.6 - endnotes

- <sup>1</sup>. MCLG - Maximum contaminant level goal
- <sup>2</sup>. MCL - Maximum contaminant level
- <sup>3</sup>. For water systems analyzing at least 40 samples per month, no more than 5.0 percent of the monthly samples may be positive for total coliforms. For systems analyzing fewer than 40 samples per month, no more than one sample per month may be positive for total coliforms.
- <sup>4</sup>. There are various regulations that set turbidity standards for different types of systems, including the 1989 Surface Water Treatment Rule, the 1998 Interim Enhanced Surface Water Treatment Rule, and the 2002 Long Term 1 Enhanced Surface Water Treatment Rule. The MCL for the monthly turbidity average is 1 NTU; the MCL for the 2-day average is 5 NTU for systems that are required to filter but have not yet installed filtration.
- <sup>5</sup>. NTU - Nephelometric turbidity unit
- <sup>6</sup>. There are various regulations that set turbidity standards for different types of systems, including the 1989 Surface Water Treatment Rule (SWTR), the 1998 Interim Enhanced Surface Water Treatment Rule (IESWTR), and the 2001 Long Term 1 Enhanced Surface Water Treatment Rule. Systems subject to the Surface Water Treatment Rule (both filtered and unfiltered) may not exceed 5 NTU. In addition, in filtered systems, 95 percent of samples each month must not exceed 0.5 NTU in systems using conventional or direct filtration and must not exceed 1 NTU in systems using slow sand or diatomaceous earth filtration or other filtration technologies approved by the Department.
- <sup>7</sup>. TT - Treatment technique
- <sup>8</sup>. There are various regulations that set turbidity standards for different types of systems, including the 1989 Surface Water Treatment Rule (SWTR), the 1998 Interim Enhanced Surface Water Treatment Rule (IESWTR), and the 2002 Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR). For systems subject to the IESWTR (systems serving at least 10,000 people, using surface water or ground water under the direct influence of surface water), that use conventional filtration or direct filtration, after January 1, 2002, the turbidity level of a system's combined filter effluent may not exceed 0.3 NTU in at least 95 percent of monthly measurements, and the turbidity level of a system's combined filter effluent must not exceed 1 NTU at any time. Systems subject to the IESWTR using technologies other than conventional, direct, slow sand, or diatomaceous earth filtration must meet turbidity limits set by the Department. For systems subject to the LT1ESWTR (systems serving fewer than 10,000 people, using surface water or ground water under the direct influence of surface water) that use conventional filtration or direct filtration, after January 1, 2005 the turbidity level of a system's combined filter effluent may not exceed 0.3 NTU in at least 95 percent of monthly measurements, and the turbidity level of a system's combined filter effluent must not exceed 1 NTU at any time. Systems subject to the LT1ESWTR using technologies other than conventional, direct, slow sand, or diatomaceous earth filtration must meet turbidity limits set by the Department.
- <sup>9</sup>. The bacteria detected by heterotrophic plate count (HPC) are not necessarily harmful. HPC is simply an alternative method of determining disinfectant residual levels. The number of such bacteria is an indicator of whether there is enough disinfectant in the distribution system.
- <sup>10</sup>. SWTR, IESWTR, and LT1ESWTR treatment technique violations that involve turbidity exceedances may use the health effects language for turbidity instead.
- <sup>11</sup>. These arsenic values are effective January 23, 2006. Until then, the MCL is 0.05 mg/L and there is no MCLG.
- <sup>12</sup>. Millions fibers per liter.
- <sup>13</sup>. Action Level = 0.015 mg/L
- <sup>14</sup>. Action Level = 1.3 mg/L
- <sup>15</sup>. Millirems per years
- <sup>16</sup>. Picocuries per liter
- <sup>17</sup>. The uranium MCL is effective December 8, 2003 for all community water systems.

## Appendix B

---

<sup>18.</sup> Surface water systems and ground water systems under the direct influence of surface water are regulated under R.61-58.10 Community and non-transient non-community systems serving greater than, or equal to, 10,000 must comply with R.61-58.13 DBP MCLs and disinfectant maximum residual disinfectant levels (MRDLs) beginning January 1, 2002. All other community and non-transient non-community systems must comply with R.61-58.13 DBP MCLs and MRDLs beginning January 1, 2004. Transient non-community surface water systems and ground water systems under the direct influence of surface water serving 10,000 or more persons and using chlorine dioxide as a disinfectant or oxidant must comply with the chlorine dioxide MRDL beginning January 1, 2002. All other transient non-community systems that use chlorine dioxide as a disinfectant or oxidant must comply with the chlorine dioxide MRDL beginning January 1, 2004.

<sup>19.</sup> Community and non-transient non-community systems that must comply with R.61-58.14 TTHM and HAA5 MCLs of 0.080 mg/L and 0.060 mg/L, respectively (with compliance calculated as a locational running annual average) on the schedule in R.61-58.15.

<sup>20.</sup> The MCL for total trihalomethanes is the sum of the concentrations of the individual trihalomethanes.

<sup>21.</sup> The MCL for haloacetic acids is the sum of the concentrations of the individual haloacetic acids.

<sup>22.</sup> MRDLG--Maximum residual disinfectant level goal.

<sup>23.</sup> MRDL--Maximum residual disinfectant level.

**APPENDIX C TO R.61-58.6 - LIST OF ACRONYMS USED IN PUBLIC NOTIFICATION REGULATION**

CCR Consumer Confidence Report  
CWS Community Water System  
DBP Disinfection Byproduct  
EPA Environmental Protection Agency  
FBR Filter Backwash Recycle Rule  
✓GWR Ground Water Rule  
HPC Heterotrophic Plate Count  
IESWTR Interim Enhanced Surface Water Treatment Rule  
IOC Inorganic Chemical  
LCR Lead and Copper Rule  
LT1ESWTR Long Term 1 Enhanced Surface Water Treatment Rule  
MCL Maximum Contaminant Level  
MCLG Maximum Contaminant Level Goal  
MRDL Maximum Residual Disinfectant Level  
MRDLG Maximum Residual Disinfectant Level Goal  
NCWS Non-Community Water System  
NPDWR National Primary Drinking Water Regulation  
NTNCWS Non-Transient Non-Community Water System  
NTU Nephelometric Turbidity Unit  
OGWDW Office of Ground Water and Drinking Water  
OW Office of Water  
PN Public Notification  
PWS Public Water System  
SDWA Safe Drinking Water Act  
SMCL Secondary Maximum Contaminant Level  
SOC Synthetic Organic Chemical  
SPDWR State Primary Drinking Water Regulations  
SWTR Surface Water Treatment Rule  
TCR Total Coliform Rule  
TT Treatment Technique  
TWS Transient Non-Community Water System  
VOC Volatile Organic Chemical

Appendix D

**APPENDIX D TO R.61-58.12: CONSUMER CONFIDENCE REPORTS: REGULATED CONTAMINANTS**

Contaminant (units)	Traditional MCL in mg/L	To convert for CCR, multiply by	MCL in CCR units	MCLG	Major sources in drinking water	Health effects language
<b>Microbiological contaminants:</b>						
Total Coliform Bacteria	MCL: (systems that collect $\geq$ 40 samples/month) 5% of monthly samples are positive; (systems that collect <40 samples/month) 1 positive monthly sample.		MCL: (systems that collect $\geq$ 40 samples/month) 5% of monthly samples are positive; (systems that collect <40 samples/month) 1 positive monthly sample.	0	Naturally present in the environment	Coliforms are bacteria that are naturally present in the and are used as an indicator that other, potentially harmful bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.
Fecal coliform and E. coli	0		0	0	Human and animal fecal waste	Fecal coliforms and E. Coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely-compromised immune systems.
Fecal Indicators (enterococci or coliphage).	TT		TT	N/A	Human and animal fecal waste.	Fecal indicators are microbes whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term health effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.
Total organic carbon (ppm)	TT		TT	N/A	Naturally present	Total organic carbon (TOC) has no health effects. However, total in the environment organic carbon provides

Turbidity (NTU)	TT	TT	N/A	Soil runoff	<p>a medium for the formation of disinfection by-products. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these by-products in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.</p> <p>Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.</p>
-----------------	----	----	-----	-------------	--

**Radioactive contaminants:**

Beta/photon emitters (mrem/yr)	4 mrem/yr	4	N/A	Decay of natural and man-made deposits.	Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta and photon in excess of the MCL over many years may have an increased risk of getting cancer.
Alpha emitters (pCi/L)	15 pCi/L	15	N/A	Erosion of natural deposits.	Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.
Combined radium (pCi/L)	5 pCi/L	5	N/A	Erosion of natural deposits.	Some people who drink water containing radium-226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.
Uranium (pCi/L)	30 µg/L	30	0	Erosion of natural deposits.	Some people who drink water containing uranium in excess of the MCL over many years may have an increased risk getting cancer and kidney

Appendix D

toxicity.

**Inorganic contaminants:**

Antimony (ppb)	.006	1000	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.	Some people who drink water containing antimony well in excess of the MCL over many years could experience increases in blood cholesterol and decreases in blood sugar.
Arsenic (ppb)	0.010	1000	10	10	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.	Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
Asbestos (MFL)	7 MFL		7	7	Decay of asbestos cement water mains; production wastes; erosion of natural deposits.	Some people who drink water containing asbestos in excess of the MCL over many years may have an increased risk of developing benign intestinal polyps.
Barium (ppm)	2		2	2	Discharge of drilling; wastes; Discharge from metal refineries; Erosion of natural deposits.	Some people who drink water containing barium in of the MCL over many years could experience an increase in their blood pressure.
Beryllium (ppb)	.004	1000	4	4	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries	Some people who drink water containing beryllium well in excess of the MCL over many years could develop intestinal lesions
Bromate (ppb)	.010	1000	10	0	By-product of drinking water	Some people who drink water containing bromate in excess of the MCL over

Appendix D

Cadmium (ppb)	.005	1000	5	5	chlorination. Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; Runoff from waste batteries and paints.	many years may have an increased risk of getting cancer. Some people who drink water containing cadmium in excess of the MCL over many years could experience kidney damage.
Chloramines (ppm)	MRDL = 4		MRDL = 4	MRDLG = 4	Water additive used to control microbes.	Some people who use water containing chloramines well in excess of the MRDL could experience irritating to their eyes and nose. Some people who drink water containing chloramines well in excess of the MRDL could experience stomach discomfort or anemia.
Chlorine (ppm)	MRDL = 4		MRDL = 4	MRDLG = 4	Water additive used to control microbes	Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.
Chlorine dioxide (ppb)	MRDL = .8	1000	MRDL = 800	MRDLG = 800	Water additive used to control microbes	Some infants and young children who drink water containing chlorine dioxide in excess of the MRDL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorine dioxide in excess of the MRDL. Some people may experience anemia.
Chlorite (ppm)	1		1	0.8	By-product of drinking water chlorination.	Some infants and young children who drink water containing chlorite in excess of the MCL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorite in excess of the MCL. Some people may experience anemia.

Appendix D

Chromium (ppb)	.1	1000	100	100	Discharge from steel and pulp; mills; Erosion of Natural deposits.	Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.
Copper (ppm)	AL=1.3		AL=1.3	1.3	Corrosion of household plumbing. Erosion of natural deposits.	Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
Cyanide (ppb)	2	1000	200	200	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories.	Some people who drink water containing cyanide well in excess of the MCL over many years could experience nerve damage or problems with their thyroid.
Fluoride (ppm)	4		4	4	Erosion of natural deposits; Water additive which promotes strong teeth Discharge from fertilizer and aluminum factories	Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.
Lead (ppb)	AL=.015	1000	AL=15	0	Corrosion of household plumbing systems; Erosion of natural deposits	Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Appendix D

Mercury [inorganic] (ppb)	.002	1000	2	2	Erosion of natural deposits; discharge from refineries and factories; Runoff from landfills; Runoff from cropland.	Some people who drink water containing inorganic mercury well in excess of the MCL over many years could experience kidney damage
Nitrate (ppm)	10		10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.	Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.
Nitrite (ppm)	1		1	1	Runoff from fertilizer use; Leaching from septic tanks sewage; Erosion of natural deposits	Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.
Selenium (ppb)	.05	1000	50	50	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.	Selenium is an essential nutrient. However, some people who drink water containing selenium in excess of the MCL over many years could experience hair or fingernail losses, numbness in fingers or toes, or problems with their circulation
Thallium (ppb)	.002	1000	2	0.5	Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories.	Some people who drink water containing thallium in excess of the MCL over many years could experience hair loss, changes in their blood, or problems with their kidneys, intestines, or liver.

**Synthetic organic contaminants including pesticides and herbicides:**

Appendix D

2,4-D (ppb)	.07	1000	70	70	Runoff from herbicide used on row crops.	Some people who drink water containing the weed killer 2,4-D well in excess of the MCL over many years could experience problems with their kidneys, liver, or adrenal glands.
2,4,5-TP [Silvex](ppb)	.05	1000	50	50	Residue of banned herbicide	Some people who drink water containing silvex in excess of the MCL over many years could experience liver problems.
Acrylamide	TT		TT	0	Added to water during sewage/wastewater treatment.	Some people who drink water containing high levels of acrylamide over a long period of time could have an increased problems with their nervous system or blood, and may have risk of getting cancer.
Alachlor (ppb)	.002	1000	2	0	Runoff from herbicide used on row crops.	Some people who drink water containing alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or experience anemia, and may have an increased risk of getting cancer.
Atrazine (ppb)	.003	1000	3	3	Runoff from herbicide used on row crops.	Some people who drink water containing atrazine well in excess of the MCL over many years could experience on problems with their cardiovascular system or reproductive difficulties.
Benzo(a)pyrene [PAH] (nanograms/l).	.0002	1,000,000	200	0	Leaching from linings of water storage tanks distribution lines.	Some people who drink water containing benzo(a)pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.
Carbofuran (ppb)	.04	1000	40	40	Leaching of soil fumigant used on rice and alfalfa.	Some people who drink carbofuran in excess of the MCL over many years could experience problems with their blood, or nervous or reproductive systems.
Chlordane (ppb)	.002	1000	2	0	Residue of banned termiticide	Some people who drink water containing chlordane in excess of the MCL over many years could experience problems with their liver or nervous system, and may have an increased risk of getting cancer.

Appendix D

Dalapon (ppb)	.2	1000	200	200	Runoff from herbicide used on rights of way.	Some people who drink water containing dalapon well in excess of the MCL over many years could experience minor kidney changes.
Di(2-ethylhexyl) adipate (ppb).	.4	1000	400	400	Discharge from chemical factories.	Some people who drink water containing di(2-ethylhexyl) adipate well in excess of the MCL over many years could experience toxic effects such as weight loss, liver enlargement or possible reproductive difficulties.
Di(2-ethylhexyl) phthalate (ppb).	.006	1000	6	0	Discharge from rubber and chemical factories.	Some people who drink water containing di(2-ethylhexyl) phthalate well in excess of the MCL over many years may have problems with their liver, or experience reproductive difficulties, and may have an increased risk of getting cancer.
Dibromochloropropane (ppt)	.0002	1,000,000	200	0	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards.	Some people who drink water containing DBCP in excess of the MCL over many years could experience reproductive problems and may have an increased risk of getting cancer.
Dinoseb (ppb)	.007	1000	7	7	Runoff from herbicide used on soybeans and vegetables.	Some people who drink water containing dinoseb well in excess of the MCL over many years could experience reproductive difficulties.
Diquat (ppb)	.02	1000	20	20	Runoff from herbicide use.	Some people who drink water containing diquat in excess of the MCL over many years could get cataracts.
Dioxin [2,3,7,8-TCDD] (ppq).	.00000003	1,000,000,000	30	0	Emissions from waste incineration and other combustion; Discharge from chemical factories.	Some people who drink water containing dioxin in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.
Endothall (ppb)	.1	1000	100	100	Runoff from herbicide use.	Some people who drink water containing endothall in excess of the MCL over many years could experience problems with their stomach or intestines.

Appendix D

Endrin (ppb)	.002	1000	2	2	Residue of banned insecticide.	Some people who drink water containing endrin in excess of the MCL over many years could experience liver problems.
Epichlorohydrin.	TT		TT	0	Discharge from industrial chemical factories; An impurity of some water treatment chemicals.	Some people who drink water containing high levels of epichlorohydrin over a long period of time could experience stomach problems, and may have an increased risk of getting cancer.
Ethylene dibromide (ppt)	.00005	1,000,000	50	0	Discharge from petroleum refineries.	Some people who drink water containing ethylene dibromide in excess of the MCL over many years could experience problems with their liver, stomach, reproductive system, or kidneys, and may have an increased risk of getting cancer.
Glyphosate (ppb)	.7	1000	700	700	Runoff from herbicide use	Some people who drink water containing glyphosate in excess of the MCL over many years could experience problems with their kidneys or reproductive difficulties.
Heptachlor (ppt)	.0004	1,000,000	400	0	Residue of banned pesticide.	Some people who drink water containing heptachlor in excess of the MCL over many years could experience liver damage and may have an increased risk of getting cancer.
Heptachlor epoxide (ppt)	.0002	1,000,000	200	0	Breakdown of heptachlor.	Some people who drink water containing heptachlor epoxide in excess of the MCL over many years could experience liver damage, and may have an increased risk of getting cancer.
Hexachlorobenzene (ppb)	.001	1000	1	0	Discharge from metal refineries and agricultural chemical factories.	Some people who drink water containing Hexachlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys, or adverse reproductive effects and may have an increased risk of getting cancer
Hexachlorocyclopentadiene (ppb)	.05	1000	50	50	Discharge from chemical factories	Some people who drink water containing hexachlorocyclopentadiene well in excess of the MCL over many years could experience problems with their kidneys or stomach.

Appendix D

Lindane (ppt)	.0002	1,000,000	200	200	Runoff/leaching from insecticide used on cattle, lumber, gardens.	Some people who drink water containing lindane in excess of the MCL over many years could experience problems with their kidneys or liver.
Methoxychlor (ppb)	.04	1000	40	40	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock.	Some people who drink water containing methoxychlor in excess of the MCL over many years could experience reproductive difficulties
Oxamyl [Vydate] (ppb)	.2	1000	200	200	Runoff/leaching from insecticide used on apples potatoes and tomatoes.	Some people who drink water containing oxamyl in excess of the MCL over many years could experience slight nervous system effects.
PCBs [Polychlorinated biphenyls] (ppt).	.0005	1,000,000	500	0	Runoff from landfills Discharge of waste chemicals	Some people who drink water containing PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland, immune deficiencies, or reproductive or nervous system difficulties, and may have an increased risk of getting cancer.
Pentachlorophenol (ppb)	.001	1000	1	0	Discharge from wood preserving factories	Some people who drink water containing pentachlorophenol in excess of the MCL over many years could experience problems with their liver or kidneys, and may have an increased risk of getting cancer.
Picloram (ppb)	.5	1000	500	500	Herbicide runoff	Some people who drink water containing picloram in excess of the MCL over many years could experience problems with their liver.
Simazine (ppb)	.004	1000	4	4	Herbicide runoff	Some people who drink water containing simazine in excess of the MCL over many years could experience problems with their blood.
Toxaphene (ppb)	.003	1000	3	0	Runoff/leaching from insecticide used on cotton and cattle.	Some people who drink water containing toxaphene in excess of the MCL over many years could have problems with their kidneys, liver, or thyroid, and may have an increased risk of getting cancer

Appendix D

**Volatile organic contaminants:**

Benzene (ppb)	.005	1000	5	0	Discharge from factories; Leaching from gas storage tanks and landfills.	Some people who drink water containing benzene in excess of the MCL over many years could experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.
Carbon tetrachloride (ppb)	.005	1000	5	0	Discharge from chemical plants and other industrial activities.	Some people who drink water containing carbon tetrachloride in excess of the MCL over many years could experience problems with in their liver and may have an increased risk of getting cancer.
Chlorobenzene (ppb)	.1	1000	100	100	Discharge from chemical and agricultural chemical factories	Some people who drink water containing chlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys.
o-Dichlorobenzene (ppb)	.6	1000	600	600	Discharge from industrial chemical	Some people who drink water containing o-dichlorobenzene well in excess of the MCL over liver, kidneys, or circulatory systems.
p-Dichlorobenzene (ppb)	.075	1000	75	75	Discharge from industrial chemical factories	Some people who drink water containing p-dichlorobenzene in excess of the MCL over many years could experience anemia, damage to their liver, kidneys, or spleen, or changes in their blood.
1,2-Dichloroethane (ppb)	.005	1000	5	0	Discharge from industrial chemical factories.	Some people who drink water containing 1,2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer
1,1-Dichloroethylene (ppb)	.007	1000	7	7	Discharge from industrial chemical factories.	Some people who drink water containing 1,1-dichloroethylene in excess of the MCL over many years could experience problems with their liver.
cis-1,2-Dichloroethylene (ppb)	.07	1000	70	70	Discharge from industrial chemical factories.	Some people who drink water containing cis-1,2-dichloroethy -lene in excess of the MCL over many years could experience problems with their liver.

Appendix D

trans-1,2-Dichloroethylene (ppb).	.1	1000	100	10	Discharge from industrial chemical factories.	Some people who drink water containing trans-1,2-dichloro-ethylene well in excess of the MCL over many years could experience problems with their liver.
Dichloromethane (ppb)	.005	1000	5	0	Discharge from pharmaceutical and chemical factories	Some people who drink water containing dichloromethane in excess of the MCL over many years could have liver problems and may have an increase risk of getting cancer.
1,2-Dichloropropane (ppb)	.005	1000	5	0	Discharge from industrial chemical factories.	Some people who drink water containing 1,2-Dichloropropane excess of the MCL over many years may have an increased risk of getting cancer.
Ethylbenzene (ppb)	.7	1000	700	700	Discharge from petroleum refineries.	Some people who drink water containing ethylbenzene well in excess of the MCL over many years could experience problems with their liver or kidneys.
Haloacetic Acids (HAA) (ppb).	.060	1000	60	N/A	By-product of drinking water disinfection.	Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.
Styrene (ppb)	.1	1000	100	100	Discharge from rubber and plastic factories and leaching from landfills.	Some people who drink water containing styrene well in excess of the MCL over many years could have problems with their liver, kidneys or circulatory system.
Tetrachloroethylene (ppb)	.005	1000	5	0	Discharge from factories and dry cleaners.	Some people who drink water containing tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.
1,2,4-Trichlorobenzene (ppb)	.07	1000	70	70	Discharge from textile-finishing factories.	Some people who drink water containing 1,2,4-trichlorobenzene well in excess of the MCL over many years could experience changes in their adrenal glands.
1,1,1-Trichloroethane (ppb)	.2	1000	200	200	Discharge from metal degreasing sites and other factories.	Some people who drink water containing 1,1,1-trichloroethane in excess of the MCL over many years could experience liver, problems with their nervous system, or circulatory system.

Appendix D

1,1,2-Trichloroethane (ppb).	.005	1000	5	3	Discharge from industrial chemical factories.	Some people who drink water containing 1,1,2-trichloroethane well in excess of the MCL over many years could have problems with their liver; kidneys, or immune systems.
Trichloroethylene (ppb)	.005	1000	5	0	Discharge from metal degreasing sites and other factories	Some people who drink water containing trichloroethylene in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.
TTHMs [Total trihalomethanes] (ppb)	0.10/.080	1000	100/80	N/A	By-product of drinking water disinfection.	Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.
Toluene (ppm)	1		1	1	Discharge from petroleum factories.	Some people who drink water containing toluene well in excess of the MCL over many years could have problems with their nervous system, kidneys, or liver.
Vinyl Chloride (ppb)	.002	1000	2	0	Leaching from PVC piping; Discharge from plastics factories.	Some people who drink water containing vinyl chloride in excess of the MCL over many years may have an increased risk of getting cancer.
Xylenes (ppm)	10		10	10	Discharge from petroleum factories; Discharge from chemical factories.	Some people who drink water containing xylenes in excess of the MCL over many years could experience damage to their nervous system.

**Key:**

AL=Action Level

MCLG=Maximum Contaminant Level Goal

MRDL=Maximum Residual Disinfectant Level

mrem/year=millirems per year (a measure of radiation absorbed by the body)

N/A=Not Applicable

pCi/l=picocuries per liter (a measure of radioactivity)

ppb=parts per billion, or micrograms per liter (µg/l)

ppq=parts per quadrillion, or picograms per liter

MCL=Maximum Contaminant Level

MFL=million fibers per liter

MRDLG=Maximum Residual Disinfectant Level Goal

NTU=Nephelometric Turbidity Units (a measure of water clarity)

ppm=parts per million, or milligrams per liter (mg/L)

ppt=parts per trillion, or nanograms per liter

TT=Treatment Technique

**Appendix D to R.61-58.12 - endnotes**

<sup>1</sup> These arsenic values are effective January 23, 2006. Until then, the MCL is 0.05 mg/L and there is no MCLG.



## Appendix A

### PROPOSED REVISION TO RECORDS SCHEDULE (Schedule to be determined)

DESCRIPTION: The Ground Water Rule (federal) requires the Department to keep certain records pertaining to the Rule. This federal regulation, adopted as part of the State Primary Drinking Water Regulations R.61-58.16 applies to systems that have a ground water source. Some of these records are sent from the Department to the water system, and some are submitted by Public Drinking Water Systems. The required information consists of sampling results and records of decisions that the Department makes with regards to the provisions in the Rule.

- Records of the currently applicable or most recent Department determination, including all supporting information and an explanation of the technical basis of each decision made under R.61-58.16.
- Records of written notices, from the Department, to the water system, of significant deficiencies found with that water system.
- Records of corrective action plans, schedule approvals, and Department-specified interim measures, if any.
- Records, from the Public Water System, of confirmations that a significant deficiency has been corrected, or the fecal contamination in the ground water source has been addressed.
- Records of the Department's determinations and records of ground water system's documentation for not conducting triggered source water monitoring.
- ✓▪ Records of the Department's invalidations of fecal indicator-positive ground water source samples.
- Records of the Department's approvals of source water monitoring plans.
- Records of notices, from the Department, to water systems identifying the minimum residual disinfection concentration needed to achieve at least 4-log virus inactivation. *before or at the first occurrence*
- Records of notices, from the Department, to water systems, identifying Department-specified monitoring and compliance requirements for membrane filtration or alternative treatment used to achieve at least 4-log virus inactivation or removal. *before or at the first occurrence*

- Records of notices, from the water system, that the system is providing at least 4-log virus inactivation or removal.
- Records of written determinations, from the Department, that a water system may discontinue 4-log virus inactivation or removal.

**RETENTION:** All records listed above will be kept 5 years, microfilm (or scan),  
destroy.

# Appendix B

## Public Water System Sanitary Survey Report Ground Water Systems

Site Name:

System number:

Last Survey:

Survey Date:

**Overall Rating**

Type of Inspection or Visit  
Operator/Owner present?

**Source**

- \* Protection from Contamination
- Quantity
- Security
- Wellhead Piping

**Water Treatment**

- \* Chemical Feed
- Chemical Storage & Handling
- Chemical Injection Points
- Filtration
- Equipment Maintenance

**Distribution**

- \* Water Quality
- Adequate Pressure
- Disinfectant Residual
- Cross Connection Control
- Fire Flow
- Valve & Hydrant Maintenance
- Flushing program
- Leak Detection & Repair
- System Map

**Storage**

- \* Protection from Contamination
- Capacity
- Security
- Appurtenances
- Maintenance

**Pumps, Pump Facilities, & Controls**

- \* Reliable Capacity
- Operation & Control
- Pumps
- Flow Measuring Device

**Monitoring, Reporting, & Data Verification**

- \* Monitoring & Recordkeeping
- Testing Equipment
- Sample Siting Plan

**System Management & Operation**

- \* Corrections from Previous Survey
- Emergency Plan
- Plant Security
- Facility Maintenance
- Supplies/Spare Parts Inventory
- Waste Disposal
- Procedures Manual
- Stand-by Power
- Is system presently under order?
- If yes, is system complying?

**Operator Certification**

- \* Certified Operator
- Staffing
- Treatment System Group (I - VI)
- Treatment Operator Grade
- A
- B
- C
- D
- T
- Dist. Group (I-V)
- Distribution Operator Grade
- A
- B
- C
- D
- T
- G

**Other Requirements**

- Drought Response Plan
- Are all services metered?
- Percent metered:

**Field Tests:**

Location or address

Parameter	Result
Chlorine	
pH	
Pressure	
Flow	
Other	
Bacteriological	
Inorganic	

**Samples Taken**

- Organic
- Radiological
- Other

Follow up scheduled?  
Date scheduled

\* Items with an asterisk are significant deficiency items.



## Appendix C

### Examples of Significant Deficiencies on a Sanitary Survey

Source Significant Deficiency: Protection from contamination. This item would be considered a significant deficiency when the condition of the well pad, piping, or other equipment has caused or has the potential to cause contamination of the source. Some examples include, but are not limited to: a severely cracked well pad, missing vent screen, or an improper seal.

- ✓ Treatment Significant Deficiency: Chemical feed. This item would be considered a significant deficiency when there is inadequate application of treatment chemicals or feeding chemicals that are not certified through the National Sanitation Foundation (NSF).

Distribution Significant Deficiency: Water quality. This item would be considered a significant deficiency when there are health-related water quality problems in the distribution system. Some examples include, but are not limited to: bacteriological (TCR) violations or persistent chemical MCL violations.

Storage Significant Deficiency: Protection from contamination. This item would be considered a significant deficiency when the condition of the storage tank(s) causes or has the potential to cause contamination of the system. Some examples include, but are not limited to: improper or missing vent screens on vents and overflow piping, inadequate hatch seals, or inadequate internal cleaning or maintenance of storage tanks.

- ✓ Pumps, Pump Facilities, & Controls Significant Deficiency: Reliable capacity. This item would be considered a significant deficiency when there is inadequate pump capacity to adequately maintain system flows and pressures.

Monitoring, Reporting, & Data Verification Significant Deficiency: Monitoring & Recordkeeping. This item would be considered a significant deficiency when a water system is not adequately monitored or is not meeting the recordkeeping requirements. Some examples of this include, but are not limited to: not monitoring according to the Department-approved monitoring plan or site sampling plan, or not keeping adequate process control records.

System Management & Operation Significant Deficiency: Corrections from a previous survey. This item would be considered a significant deficiency when a water system does not correct items identified on a previous survey that can be associated with potential health risks. Some examples of this include, but are not limited to: inoperable equipment, cracked well pad, deficiencies in the cross connection control, flushing, valve exercising, or leak detection programs.

Operator Compliance with State Requirements Significant Deficiency: Certified Operator. This item would be considered a significant deficiency when the system is not in compliance with the state operator certification requirements. Examples of this include, but are not limited to: operators failing to make daily facility visits, improper grade operators, or operating without a license.