



June 30, 2022

To all interested parties:

Annual State Public Water System Report – Calendar Year 2021

Each quarter, primacy agencies submit data to the Safe Drinking Water Information System (SDWIS/FED), an automated database maintained by the Environmental Protection Agency (EPA). The data submitted include, but are not limited to, PWS inventory information, the incidence of Maximum Contaminant Level (MCL), Maximum Residual Disinfectant Level (MRDL), Monitoring/Reporting (M/R), Monitoring (M), Reporting (R) and treatment technique (TT) violations; and information on enforcement activity related to these violations. Section 1414(c)(3)(A)(i-ii) of the Safe Drinking Water Act requires states to provide EPA with an annual report of violations of the primary drinking water standards. The categories of violations are:

- a) Maximum Contaminant Level (MCL) violation - Under the Safe Drinking Water Act (SDWA), the EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as MCLs.
- b) Treatment Technique (TT) violation - For some regulations, the EPA establishes treatment techniques in lieu of an MCL to control unacceptable levels of certain contaminants. For example, treatment techniques have been established for viruses, bacteria, turbidity, and lead.
- c) Monitoring & Reporting (M/R) violation – If a PWS fails to have its water tested as required or fails to report test results correctly to the primacy agency, a monitoring violation occurs.
- d) Monitoring (M) or Reporting (R) violation – Microbials under the Revised Total Coliform Rule, beginning April 1, 2016, a PWS is required to monitor and verify that the levels of contaminants present in the water do not exceed the MCL or MRDL. If a PWS fails to have its water tested as required, a monitoring violation occurs. If a PWS fails to report test results correctly to the primacy agency, a reporting violation occurs.

Public Water System

A Public Water System (PWS) is defined as a system that provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of PWSs. PWSs can be community systems (such as towns), non-transient non-community systems (such as schools or factories), or transient non-community systems (such as rest stops or parks).

PWS Type	#PWS	Population Served	% of Total Population
Community (CWS)	577	4,308,242	98%
Non-transient non-community (NTNCWS)	93	25,782	1%
Transient non-community (TNCWS)	732	47,752	1%
	1,402	4,381,776	

There are two types of source water: groundwater and surface water. Ground water systems (GWS) are those systems depending on wells to provide their drinking water supply; while surface water systems (SWS) are those systems that depend on lakes, rivers, and streams for their drinking water supply. SWS, as defined by federal regulation, provided water to a population of 3,748,118 residents, or 86% of the total population. GWS, as defined by federal regulation, provided water to a population of 633,658 residents, or 14% of the total population.

Source Type	Population Served	% of Total Population
SWS (420 systems)	3,748,118	86%
GWS (982 systems)	633,658	14%
	4,381,776	

Additional Information Regarding Violations

In 2021, there were 174 total violations. The violation categories include Maximum Contaminant Level Violations (MCL), Treatment Technique Violations (TT), Monitoring and Reporting Violations (M/R), Monitoring Violations (M), and Reporting Violations (R). The violations for 2021 represented 124 federally defined PWSs* or 9% of the 1,402 federally defined PWSs, serving 739,140 or 17% of the total South Carolina population of 4,381,776.

Violation Category	Rule Group	Rule Name	# of Violations	# of Resolved Violations†	# of PWS with Violations*
MCL	Chemicals	Radionuclides	6	0	2
MCL	Disinfectants and Disinfection Byproducts Rule	Stage 2 Disinfectants and Disinfection Byproducts Rule	12	0	4
MCL	Microbials	Revised Total Coliform Rule (1A)	8	6	8
TT	Chemicals	Lead and Copper Rule	3	2	3
TT	Microbials	Long Term 1 Enhanced Surface Water Treatment Rule	2	1	2
TT	Disinfectants and Disinfection Byproducts Rule	Stage 1 Disinfectants and Disinfection Byproducts Rule	8	7	2
M/R	Chemicals	Lead and Copper Rule	57	13	55
M/R	Disinfectants and Disinfection Byproducts Rule	Stage 1 Disinfectants and Disinfection Byproducts Rule	3	2	3
M/R	Disinfectants and Disinfection Byproducts Rule	Stage 2 Disinfectants and Disinfection Byproducts Rule	3	1	2
M	Microbials	Revised Total Coliform Rule	13	8	12
M/R	Microbials	Ground Water Rule	42	13	36
M/R	Microbials	Surface Water Treatment Rule	2	0	1
R	Microbials	Revised Total Coliform Rule	1	1	1
Other	Public Notification	Public Notice	2	0	2
Other	Consumer Confidence Reporting Rule	Consumer Confidence	12	6	12
Totals			174*	60[†]	145* (124 unique PWSs*)

*The table indicates the total number of PWSs with violations as 145, but some PWSs had more than one type/category of violation. The unique number of PWSs with violations (more than one, and/or more than one type) was 124 PWSs for 2021. The table above summarizes the violations in 2021.

† - # of Resolved Violations represents the number of violations that have been resolved (returned to compliance) during the calendar year. Due to EPA requirements to consider a system's violation resolved, it could take up to a year of monitoring data meet the standard to return to compliance.

Microbials

South Carolina's microbiological program monitors PWS for compliance with the Revised Total Coliform Rule (RTCR) and the Groundwater Rule (GWR). The RTCR establishes a MCL for *E. coli* and uses *E. coli* and total coliforms to initiate a 'find and fix' approach to address fecal contamination that could enter the distribution system (DS). It requires PWSs to perform assessments to identify sanitary defects and act to correct them. The RTCR applies to all PWSs and requires all federally defined PWSs to develop a self-monitoring program for their system. The GWR establishes a risk-targeted approach to identify GWSs susceptible to fecal contamination and requires corrective action to correct significant deficiencies and source water fecal contamination in all federally defined public GWSs. The GWR applies to all PWSs that use ground water, including consecutive systems. The GWR requires all federally defined systems that detect total coliform in their DS to collect a sample from each source in use at the time of the total coliform positive. South Carolina requires all CWS and NTNCWS develop a self-monitoring program utilizing a South Carolina certified lab for analyzing samples. South Carolina DHEC collects and analyzes microbiological samples quarterly, monthly, or annually for TNCWS.

The RTCR requires that when total coliforms are found present in a routine sample, *E. coli* must be analyzed to confirm its absence or presence in the sample. The presence of *E. coli* is a health-related contamination of drinking water and requires the PWS to notify its customers. This type of violation is shown in the report as MCL *E. coli* (RTCR).

South Carolina had eight (8) MCL *E. coli* (RTCR) violations in eight (8) PWSs (CWS-6, NTNCWS-1, TNCWS-1) serving a population of 361,213 or 8% of the total population (4,381,776). The MCL *E. coli* (RTCR) violations represented 5% of the total violations (174) and 1% of the total number of PWSs (1,402) in South Carolina.

There were forty-two (42) M/R source water (GWR) violations in thirty-six (36) PWSs (CWS-27, NTNCWS-4, TNCWS-5) serving a population of 25,353 or 1% of the total population (4,381,776). Some PWSs incurred more than one violation in the calendar year. The M/R, Source Water (GWR) violations represented 24% of the total violations (174) and 3% of the total number of PWSs (1,402) in South Carolina. The GWR requires PWSs that detect total coliform in their distribution system to collect a sample from each groundwater source in use at the time of the total coliform positive. This M/R violation occurs when the PWS fails to sample/monitor (indicated "Major" - 39 violations) or fails to sample/monitor all groundwater sources active at the time of the total coliform positive sample event (indicated "Minor" - 3 violations).

There were thirteen (13) Monitoring (M) violations in twelve (12) PWSs (CWS-8, NTNCWS-2, TNCWS-2) serving a population of 3,281 or <1% of the total population (4,381,776). One CWSs incurred more than one violation in the calendar year. These M violations represented 7% of the total violations (174) and 1% of the total number of PWSs (1,402) in South Carolina. If the routine or repeat samples were not collected, the violation was major. Ten (10) of the M violations were M, Routine, Major (RTCR) (CWS-8, NTNCWS-1) serving a population of 2,886 or <1% of the total population (4,381,776). The M, Routine, Major (RTCR) violations represented 1% of the total number of PWSs (1,402) and 6% of the total number of violations (174).

RTCR further requires that a PWS on a monitoring frequency less than monthly (e.g., quarterly, annually), must collect an additional three (3) routine samples the month following a total coliform positive (TC+) sample result. The violation, M, Addl Routine (RTCR), has both major and minor severity indicators. A major indicator means that none of the additional routine samples were collected the month following a TC+ sample result. A minor indicator means that some, but not all the additional routine samples were collected.

In 2021, there were three (3) M violations for M, Addl Routine (RTCR) (NTNCWS-1, TNCWS-2) serving a population of 395 or <1% of the total population (4,381,776). The three (3) violations were indicated "Major" and represented <1% of the total number of PWSs (1,402) and 2% of the total violations (174).

RTCR requires a PWSs to notify the State within 24-hours about an EC+ compliance sample result. During 2021, one NTNCWS failed to notify the State within the 24-hour requirement. This NTNCWS served a population of 148, representing <1% of the total population served (4,381,776), <1% of the total number of PWSs (1,402), and 1% of the total violations (174). This violation has been indicated on the chart as "R, Notification, E coli Positive (RTCR)".

Chemicals

South Carolina DHEC collects and analyzes chemical samples utilizing a Standardized Monitoring Framework (SMF) which standardizes, simplifies, and consolidates monitoring requirements across contaminant groups. The SMF increases public protection by simplifying monitoring plans and synchronizing monitoring schedules leading to increased compliance with monitoring requirements. The SMF reduces the variability within monitoring requirements for chemical and radiological contaminants across systems sizes and types. The regulated contaminants include fifteen (15) Inorganic Contaminants (IOCs), fifty-one (51) Synthetic Organic Contaminants (SOCs) and Volatile Organic Contaminants (VOCs), and four (4) Radionuclides. South Carolina's monitoring includes monitoring for all federally defined PWSs, including CWS, NTNCWS and TNCWS. All federally defined PWSs are monitored for Nitrate and Nitrite. All CWS are monitored for IOCs, SOCs, VOCs and Radionuclides. All NTNCWS are monitored for IOCs, SOCs and VOCs.

In 2021, two (2) PWS incurred six (6) violations for chemicals. These violations represented one (1) PWSs (CWS-1, serving a population of 41) with four (4) violations for MCL Gross Alpha and one (1) PWSs (CWS-1, serving a population of 190) with one (1) violation for MCL Combined Radium 226/228. Together these systems served a population of 231, <1% of the total population (4,381,776).

These chemical violations represent <1% of the PWSs in South Carolina and 3% of the total violations (174). In 2021, 99% of South Carolina PWSs were without chemical violations, serving 99% of the total population. These violations have been indicated on the chart with a description of MCL Violation, Average (Gross Alpha) and MCL Violation, Average (Combined Radium 226/228).

Disinfection and Disinfection Byproducts

South Carolina DHEC collects and analyzes samples for disinfectants and disinfection byproducts in according with the Stage 1 Disinfectants and Disinfection Byproducts (S1D/DBP) Rule and Stage 2 Disinfectants and Disinfection Byproducts (S2D/DBP) Rule. The addition of a chemical disinfectant requires a PWS to monitor Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAA5). Upon implementation of S2D/DBP Rule, monitoring was required for all CWS and NTNCWS that use primary or residual disinfectant or delivers (sells) treated water. These rules also required water systems to submit an initial distribution system evaluation (IDSE) to identify sites for D/DBP sampling.

There were twelve (12) MCL violations for TTHM in (4) PWSs (CWS-4) serving a population of 19,965 or <1% of the total population (4,381,776). Some PWSs incurred more than one violation in the calendar year. These violations, MCL Violation, Average (TTHM), represented 7% of the total violations (174) and <1% of all PWSs (1,402).

In rare instances, DHEC staff and regional staff may fail to identify or collect required samples for a water system. In 2021, three (3) sampling events were recorded as missed, resulting in three (3) violations (CWS-3). These three (3) CWS served a total of 9,977, <1% of the total population (4,381,776), <1% of the total PWSs (1,402), and 2% of total violations (174). These violations are recorded as M/R (DBP) on the violation chart. These M/R violations will return to compliance in 2022.

Three (3) MR violations (CWS-3) for failure to monitor and report disinfectant residual or to maintain certification with the State to analyze residuals occurred in 2021. The total population served by these systems was 2,424 representing <1% of the total population (4,381,776), <1% of the total PWSs (1,402), and 2% of the total violations (174). These violations are recorded as M/R Residual (DBP) on the violation chart.

There were eight (8) TT violations under S1D/DBP during 2021. The violations were for failure to operate the water system by a state-approved qualified operator. These violations occurred in two (2) CWSs serving a total population of 50,645 or 1% of the total population (4,381,776). One system incurred more than one violation. These violations represented <1% of the total PWSs (1,402) and 5% of the total violations (174). Both CWSs have returned to compliance and operate with state-approved qualified operators. These violations are recorded as TT No Certif. Operator on the violation chart.

Surface Water Treatment

The Surface Water Treatment Rule (SWTR), Interim Enhanced Surface Water Treatment Rule (IESWTR), Filter Backwash Recycling Rule (FBRR), Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR), and Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR) apply to surface water systems and groundwater systems under the influence of surface water. These rules improve public health protection through the control of microbial contaminants, particularly viruses, *Giardia lamblia*, and *Cryptosporidium*. South Carolina DHEC requires the PWSs to which these rules apply to self-monitor and report to DHEC through monthly operating reports.

Under IESWTR there were two (2) violations for two (2) PWSs (CWS-1, serving 3,558, NTNCWS-1, serving 700) representing a TT violation for Single Turbidity Exceedance (Enhanced SWTR). These two (2) violations represented 1% of the total violations (174), <1% of the total population (4,381,776) and <1% of the public water systems (1,402). These violations are noted as Single Turbidity Exceed (Enhanced SWTR) on the violation chart.

Under SWTR there were two (2) violations for one (1) CWS serving 1,539. The violation was for failure to collect and report distribution system disinfectant concentrations. These violations represented <1% of the public water systems (1,402), <1% of the total population (4,381,776), and 1% of the total violations (174). These violations are noted on the chart as Monitoring of Treatment (SWTR).

Lead and Copper

The Lead and Copper Rule (LCR) establishes an Action Level (AL) of 0.015 mg/L for Lead (Pb) and 1.3 mg/L for Copper (Cu) based on 90th percentile levels of tap water samples. An AL exceedance is not a violation but triggers other requirements that may include water quality parameter (WQP) monitoring, corrosion control treatment (CCT), source water monitoring/treatment, public education, or lead service line replacement (LSLR). The LCR applies to all CWS and NTNCWS.

Reported in Calendar Year 2021 are fifty-seven (57) M/R violations under LCR. These violations will be presented in two types, one type will be designated LCR Tap M/R which is the failure of the PWS to either (a) collect all or some of the required initial tap samples or (b) collect all or some of the required follow-up/routine tap samples. The other will be designated Lead Consumer Notice which is the failure of the PWS to provide notice of lead results to individuals served by taps used for LCR tap monitoring, in accordance with the timing, content and delivery requirements or failure to submit a sample notice and certification to the State. Monitoring and reporting violations do not represent health-based violations.

There were thirty-one (31) LCR Tap M/R violations which occurred in twenty-nine (29) PWSs (CWS-21, NTNCWS-8) serving a population of 52,699 which represents 1% of the total population (4,381,776), 1% of the total PWSs (1,402) and 18% of the total violations (174). Two (2) CWSs incurred more than one violation. Twenty-one (21) CWSs served a population of 51,631 representing 1% of the total population

(4,381,776), 1% of the total number of PWSs (1,402), and 13% of the total violations (174). Eight (8) NTNCWS served a population of 1,068 representing <1% of the total population (4,381,776), 1% of the PWSs (1,402), and 5% of the total violations (174). One (1) of the thirty-one (31) violations was incurred by a NTNCWS that did not conduct initial lead and copper sampling. The NTNCWS served a population of 25. The violation chart will indicate this one violation as Initial Tap Sampling LCR.

There were twenty-six (26) Lead Consumer Notice violations which occurred in twenty-six (26) PWSs (CWS-24, NTNCWS-2) serving a population of 7,435 which represents <1% of the total population (4,381,776), 2% of the total PWSs (1,402), and 15% of the total violations (174). Twenty-four (24) CWSs served a population of 7,041 representing <1% of the total population (4,381,776), 2% of the total number of PWSs (1,402), and 14% of the total violations (174). Two (2) NTNCWS served a population of 394 representing <1% of the total population (4,381,776), <1% of the PWSs (1,402), and 1% of the total violations (174).

Three (3) TT violations under LCR occurred in 2021. These violations occurred in three (3) PWSs (CWS-2, NTNCWS-1) serving 140,257 or 3% of the total population (4,381,776), <1% of the total PWSs (1,402), and 2% of the total violations (174). One violation has been identified in the chart as OCCT/SOWT Study/Recommendation and the system has returned to compliance in 2021, maintaining 90th percentiles below the ALs. Two violations have been identified in the chart as WQP EP/Tap TT Non-Compliance. One CWSs serving 140,024 has returned to compliance and the other CWS serving 134 is no longer subject to LCR as their system status changed from active to inactive.

Public Notice

The Public Notice (PN) Rule requires all public water systems (PWSs) to notify their consumers any time a PWS violates a National Primary Drinking Water Regulation or has a situation posing a risk to public health. This rule applies to all PWSs. In 2021, there were two (2) violations, PN Violation for NPDWR Violation, in two (2) PWS (NTNCWS-2). The total population served for these PWSs was 375 representing <1% of the total population (4,381,776), <1% of the total PWSs (1,402), and 1% of the total violations (174).

Consumer Confidence Rule

The Consumer Confidence Reports Rule (CCR) established minimum requirements for the content of annual reports that community water systems (CWS) delivered to their customers. The reports contained information on the quality of the water delivered by the PWSs and characterized the risks (if any) from exposure to contaminants detected in the drinking water in an accurate and understandable manner. The Regulation applied only to CWS. Calendar Year 2020 all CWS delivered the required report on or before July 1, 2021.

In addition, the CCR established that no later than the date the system was required to distribute the report to its customers, each CWS was required to mail a copy of the report to the Department, followed within three (3) months by a Certification that the report had been distributed to customers, that the information was correct and consistent with compliance monitoring data either provided by or submitted to the Department. In 2021, for the Certification which represented Calendar Year 2020, there were twelve (12) violations (CWS-12). The total population served for these CWS was 73,924 representing 2% of the total population (4,381,776), 1% of the total PWSs (1,402), and 7% of the total violations (174). These are represented as Failure to submit CCR Certification on the violation chart.

Enforcement

The Drinking Water Enforcement Section functions to carry out enforcement actions involving all aspects of public water system compliance. The functions of the Enforcement section, combined with the efforts of the Drinking Water Compliance Monitoring Section, the Drinking Water Protection Division, the Bureau of Water, the Bureau of Environmental Health Services Regional Offices, and other areas within DHEC, work together to ensure safe drinking water for the continued health and welfare of the citizens of South Carolina. The goal is to bring PWSs back into compliance and protect the health of the public.

Variations and Exemptions

Variations and exemptions to specific requirements of the Safe Drinking Water Act Amendments of 1996 may be granted under certain circumstances. If a PWS meets the specific criteria outlined in the *State Primary Drinking Water Regulation*, R.61-58, DHEC may approve such a variance or exemption. South Carolina has three (3) non-community public water systems subject to a variance for Nitrate.

Additional Informational Charts

Number of PWSs with Violations and Population Served				
Size of PWS	#PWSs	% of PWSs	Population Served	% of Total Population
Large (>50,000)	2	<1%	459,524	10%
Medium (>3,300≤50,000)	15	1%	236,939	5%
Small (≤3,300)	107	8%	42,677	1%
Total	124	9%	739,140	9%

Number of PWSs with MCL or TT Violations (excludes M/R, M, R, Other) and Population Served				
Size of PWS	#PWSs	% of PWSs	Population Served	% of Total Population
Large (>50,000)	2	<1%	459,524	10%
Medium (>3,300≤50,000)	5	<1%	109,025	2%
Small (≤3,300)	14	1%	8,020	<1%
Total	21	1%	576,569	13%

Number of PWSs with M/R Violations (excludes Lead & Copper) and Population Served				
Size of PWS	#PWSs	% of PWSs	Population Served	% of Total Population
Large (>50,000)	0	N/A	N/A	N/A
Medium (>3,300≤50,000)	4	<1%	22,726	1%
Small (≤3,300)	45	3%	14,494	<1%
Total	49	3%	37,220	1%

Number of PWSs with Lead and Copper M/R Violations and Population Served				
Size of PWS	#PWSs	% of PWSs	Population Served	% of Total Population
Large (>50,000)	0	N/A	N/A	N/A
Medium (>3,300≤50,000)	3	<1%	43,833	1%
Small (≤3,300)	52	4%	16,301	<1%
Total	55	4%	60,134	1%

SWS/GWS Number of PWSs with MCL or TT Violations (excludes M/R, M, R, or Other) and Population Served				
Size of PWS	#PWSs	% of PWSs	Population Served	% of Total Population
Surface (SWS)	8	1%	555,886	13%
Groundwater (GWS)	13	1%	20,683	<1%
Total	21	2%	576,569	13%

SWS/GWS Number of PWSs with M/R Violations (excludes Lead & Copper) and Population Served				
Size of PWS	#PWSs	% of PWSs	Population Served	% of Total Population
Surface (SWS)	5	<1%	60,152	1%
Groundwater (GWS)	55	4%	45,146	1%
Total	60	4%	105,298	2%

SWS/GWS Number of PWSs with Lead and Copper Violations and Population Served				
Size of PWS	#PWSs	% of PWSs	Population Served	% of Total Population
Surface (SWS)	8	1%	50,946	1%
Groundwater (GWS)	47	3%	9,188	<1%
Total	55	4%	60,134	1%

Additional Monitoring – Per- and Polyfluoroalkyl Substances (PFAS)

Protecting public health and ensuring the safety of South Carolina’s air, land, and water has continued to remain one of DHEC’s highest priorities. One of the challenges with this priority has been addressing chemicals for which the agency has no regulatory authority. These chemicals, referred to as emerging contaminants, are those with which we have a new awareness and understanding of how they behave in the environment and affect public health.

One class of these emerging contaminants is per- and polyfluoroalkyl substances (PFAS), a group now believed to be more than 9,000 man-made chemicals that have been used since the 1940s for their heat resistance and water-, oil-, and dirt-repellence. Because of their stability, PFAS resist breakdown by natural processes and persist in the environment indefinitely, earning them the nickname “forever chemicals.” The most common exposure route is from swallowing food or water that contains PFAS.

Historically, from 2013 to 2015, as part of the EPA Unregulated Contaminant Monitoring Rule 3, SCDHEC conducted testing for six (6) PFAS, including PFOA and PFOS, at all public water systems that served

greater than 10,000 persons and at some small systems randomly selected by EPA. Of 498 samples collected and analyzed, one (1) sample from one (1) utility returned detections of 12 ppt for PFHpA and 24 ppt for PFOA (the LHA of 70 ppt for PFOA/PFOS was not exceeded). Three (3) follow-up sample events were conducted at that system; all follow-up results were non-detects.

SCDHEC has developed a strategy for addressing PFAS in drinking water. That strategy is two-fold and sampling began in the first quarter of 2021 with (1) Focus on community water systems because approximately 80% of the State's residents are served by such a system and (2) Focus on private (i.e., individual) wells located in areas with higher vulnerability to potential PFAS sources. Please visit our website for further details and data regarding per- and polyfluoroalkyl substances at: <https://scdhec.gov/BOW/perfluoroalkyl-substances-pfas> .

Conclusions

In summary, South Carolina's PWSs and South Carolina DHEC continue to work cooperatively to provide quality drinking water for South Carolinians. Of the State's 1,402 PWSs, 1,278 PWSs, or approximately 91% were in full compliance with all regulatory requirements (health-based, monitoring and reporting, other) during Calendar Year 2021, serving a population of 3,642,636 or 83% of the total population.

Monitoring and Reporting violations and 'Other' violations (Public Notice, CCR Certification) are not health-based violations. Excluding these violations (monitoring, reporting, other), South Carolina had 1,381 systems, 99% of all PWSs, that served a population of 3,805,207 or 87% of the total population that met all health-based standards. South Carolina DHEC is committed to improving the quality of life for all South Carolinians by protecting and promoting the health of the public and the environment.

Report Distribution and Availability

This report provides the consumers in the State of South Carolina information useful in assessing the quality of their drinking water and the success of South Carolina DHEC's compliance and enforcement activities. By disseminating this information, consumers will become more aware of their individual water providers and water quality. Consumers should feel free to ask questions of their PWS or of South Carolina DHEC. In addition, community water systems produce an annual Consumer Confidence Report, which provides detailed information about chemical sampling results and drinking water violations. Any additional information not contained in this report contact South Carolina DHEC's Freedom of Information Office at (803) 898-3880.

As required by the Safe Drinking Water Act South Carolina has made the 2021 Public Water Systems report available to public. Interested individuals can obtain a copy of the 2021 Annual Public Water Systems Report for South Carolina by accessing:

www.dhec.sc.gov

Telephone: 803-898-4300

Fax Number: 803-898-3795

E-Mail: fullerma@dhec.sc.gov

Mary Ann Fuller, Program Manager

Drinking Water Compliance Monitoring

Drinking Water Protection

SC DHEC Bureau of Water

2600 Bull Street

Columbia, SC 29201

SC ACR CY2021 (9 pages)

Attachment: SC ACR CY2021 Violation Chart (3 pages)

County	PWSID	PWSName	FedType	Source	Population	Violation Type	Violation Type Description
Anderson	SC0410012	ELECTRIC CITY UTILITIES (SC0410012)	CWS	SWP	38204	MCL	MCL E. coli (RTCR)
Greenville	SC2320004	MARIETTA W/D (2320004)	CWS	SWP	3255	MCL	MCL E. coli (RTCR)
Lexington	SC3260183	SAND MOUNTAIN MHP (SC3260183)	CWS	GW	40	MCL	MCL E. coli (RTCR)
Richland	SC4010001	COLUMBIA CITY OF (SC4010001)	CWS	SW	319500	MCL	MCL E. coli (RTCR)
Richland	SC4060010	MCDONALDS MHP (SC4060010)	CWS	GW	16	MCL	MCL E. coli (RTCR)
Richland	SC4060012	LOWER RICHLAND MHP (SC4060012)	CWS	GW	24	MCL	MCL E. coli (RTCR)
Richland	SC4030001	DESCI WATEREE STATION (SC4030001)	NTNCWS	GW	148	MCL	MCL E. coli (RTCR)
McCormick	SC1970675	ROCKY CREEK CHRISTIAN RETREAT (1970675)	TNCWS	GW	26	MCL	MCL E. coli (RTCR)
Berkeley	SC0860037	SANDY RUN MHP (SC0860037)	CWS	GW	41	MCL	MCL Violation, Average (Gross Alpha)
Berkeley	SC0860037	SANDY RUN MHP (SC0860037)	CWS	GW	41	MCL	MCL Violation, Average (Gross Alpha)
Berkeley	SC0860037	SANDY RUN MHP (SC0860037)	CWS	GW	41	MCL	MCL Violation, Average (Gross Alpha)
Berkeley	SC0860037	SANDY RUN MHP (SC0860037)	CWS	GW	41	MCL	MCL Violation, Average (Gross Alpha)
Lexington	SC3260164	BASIN ROCK MHP (SC3260164)	CWS	GW	190	MCL	MCL Violation, Average (Combined Radium 226/228)
Lexington	SC3260164	BASIN ROCK MHP (SC3260164)	CWS	GW	190	MCL	MCL Violation, Average (Combined Radium 226/228)
Charleston	SC1050011	DEWEES UTILITIES (SC1050011)	CWS	GW	55	MCL	MCL Violation, Average (TTHM)
Charleston	SC1050011	DEWEES UTILITIES (SC1050011)	CWS	GW	55	MCL	MCL Violation, Average (TTHM)
Dorchester	SC1870914	DCWS I-95 (SC1870914)	CWS	GW	99	MCL	MCL Violation, Average (TTHM)
Dorchester	SC1870914	DCWS I-95 (SC1870914)	CWS	GW	99	MCL	MCL Violation, Average (TTHM)
Dorchester	SC1870914	DCWS I-95 (SC1870914)	CWS	GW	99	MCL	MCL Violation, Average (TTHM)
Dorchester	SC1870914	DCWS I-95 (SC1870914)	CWS	GW	99	MCL	MCL Violation, Average (TTHM)
Horry	SC2620003	BUCKSPORT WATER COMPANY (SC2620003)	CWS	GW	16618	MCL	MCL Violation, Average (TTHM)
Horry	SC2620003	BUCKSPORT WATER COMPANY (SC2620003)	CWS	GW	16618	MCL	MCL Violation, Average (TTHM)
Horry	SC2620003	BUCKSPORT WATER COMPANY (SC2620003)	CWS	GW	16618	MCL	MCL Violation, Average (TTHM)
Williamsburg	SC4510004	HEMINGWAY TOWN OF (SC4510004)	CWS	GW	3193	MCL	MCL Violation, Average (TTHM)
Williamsburg	SC4510004	HEMINGWAY TOWN OF (SC4510004)	CWS	GW	3193	MCL	MCL Violation, Average (TTHM)
Williamsburg	SC4510004	HEMINGWAY TOWN OF (SC4510004)	CWS	GW	3193	MCL	MCL Violation, Average (TTHM)
Abbeville	SC0110001	ABBEVILLE CITY OF (0110001)	CWS	SW	5555	TT	TT No Certif. Operator
Aiken	SC0210001	AIKEN CITY OF (0210001)	CWS	SW	45090	TT	TT No Certif. Operator
Aiken	SC0210001	AIKEN CITY OF (0210001)	CWS	SW	45090	TT	TT No Certif. Operator
Aiken	SC0210001	AIKEN CITY OF (0210001)	CWS	SW	45090	TT	TT No Certif. Operator
Aiken	SC0210001	AIKEN CITY OF (0210001)	CWS	SW	45090	TT	TT No Certif. Operator
Aiken	SC0210001	AIKEN CITY OF (0210001)	CWS	SW	45090	TT	TT No Certif. Operator
Aiken	SC0210001	AIKEN CITY OF (0210001)	CWS	SW	45090	TT	TT No Certif. Operator
Aiken	SC0210001	AIKEN CITY OF (0210001)	CWS	SW	45090	TT	TT No Certif. Operator
Kershaw	SC2830001	INV CAMDEN PLANT (SC2830001)	NTNCWS	SW	700	TT	Single Turbidity Exceed (Enhanced SWTR)
Saluda	SC4120001	SALUDA CO W&S AUTHORITY (4120001)	CWS	SW	3558	TT	Single Turbidity Exceed (Enhanced SWTR)
Lexington	SC3260170	REGENCY SQUARE 2 (SC3260170)	CWS	GW	99	TT	OCCT/SOWT Study/Recommendation
Clarendon	SC1470001	WINDSOR MANOR INC (SC1470001)	NTNCWS	GW	134	TT	WQP EP/ Tap TT Non-Compliance
Spartanburg	SC4210001	SPARTANBURG WATER SYSTEM (4210001)	CWS	SW	140024	TT	WQP EP/ Tap TT Non-Compliance
Aiken	SC0260038	CAMERON MHP (SC0260038)	CWS	GW	83	MR	M/R, Source Water Major (GWR)
Allendale	SC0310001	ALLENDALE TOWN OF (SC0310001)	CWS	GW	3882	MR	M/R, Source Water Major (GWR)
Allendale	SC0310001	ALLENDALE TOWN OF (SC0310001)	CWS	GW	3882	MR	M/R, Source Water Major (GWR)
Allendale	SC0310001	ALLENDALE TOWN OF (SC0310001)	CWS	GW	3882	MR	M/R, Source Water Major (GWR)
Bamberg	SC0510004	OLAR GOVAN WATER SYSTEM (0510004)	CWS	GW	257	MR	M/R, Source Water Major (GWR)
Bamberg	SC0510004	OLAR GOVAN WATER SYSTEM (0510004)	CWS	GW	257	MR	M/R, Source Water Major (GWR)
Berkeley	SC0850014	O HAYNES SYSTEM (0850014)	CWS	GW	205	MR	M/R, Source Water Major (GWR)
Clarendon	SC1450006	SIGFIELD WATER CO INC (SC1450006)	CWS	GW	271	MR	M/R, Source Water Major (GWR)
Clarendon	SC1450012	GOAT ISLAND WSC (SC1450012)	CWS	GW	0	MR	M/R, Source Water Major (GWR)
Clarendon	SC1450012	GOAT ISLAND WSC (SC1450012)	CWS	GW	0	MR	M/R, Source Water Major (GWR)
Colleton	SC1510006	EDISTO BEACH TOWN OF (SC1510006)	CWS	GW	5568	MR	M/R, Source Water Major (GWR)
Greenwood	SC2450057	COUNTRY ACRES (SC2450057)	CWS	GW	34	MR	M/R, Source Water Major (GWR)
Greenwood	SC2450057	COUNTRY ACRES (SC2450057)	CWS	GW	34	MR	M/R, Source Water Major (GWR)
Hampton	SC2510002	ESTILL TOWN OF (SC2510002)	CWS	GW	2120	MR	M/R, Source Water Major (GWR)
Lee	SC3110002	LYNCHBURG TOWN OF (SC3110002)	CWS	GW	488	MR	M/R, Source Water Major (GWR)
Lexington	SC3250050	BGWC LEXINGTON ESTATES (SC3250050)	CWS	GW	419	MR	M/R, Source Water Major (GWR)
Lexington	SC3260207	HIDDEN ACRES MHP (SC3260207)	CWS	GW	74	MR	M/R, Source Water Major (GWR)
Newberry	SC3670108	BOYS FARM INC (SC3670108)	CWS	GW	40	MR	M/R, Source Water Major (GWR)
Newberry	SC3670108	BOYS FARM INC (SC3670108)	CWS	GW	40	MR	M/R, Source Water Major (GWR)
Orangeburg	SC3810003	ELLOREE WATER SYSTEM (3810003)	CWS	GW	1498	MR	M/R, Source Water Major (GWR)
Orangeburg	SC3820002	SILVER SPRINGS W/D (SC3820002)	CWS	SWP	2536	MR	M/R, Source Water Major (GWR)
Richland	SC4060006	PALMETTO PARK (4060006)	CWS	GW	132	MR	M/R, Source Water Major (GWR)
Richland	SC4060008	WINSOR VALLEY MHP (4060008)	CWS	GW	68	MR	M/R, Source Water Major (GWR)
Richland	SC4060019	SILVER HILL MANUF HOME COMM. (SC4060019)	CWS	GW	180	MR	M/R, Source Water Major (GWR)
Richland	SC4060021	PERCIVAL ESTATES MHP (SC4060021)	CWS	GW	12	MR	M/R, Source Water Major (GWR)

County	PWSID	PWSName	FedType	Source	Population	Violation Type	Violation Type Description
Richland	SC4060024	PINE VALLEY COMMUNITY (SC4060024)	CWS	GW	21	MR	M/R, Source Water Major (GWR)
Richland	SC4060052	PINEY LANE MHP (SC4060052)	CWS	GW	32	MR	M/R, Source Water Major (GWR)
Williamsburg	SC4510002	KINGSTREE TOWN OF (SC4510002)	CWS	GW	6009	MR	M/R, Source Water Major (GWR)
York	SC4650019	LOST COLONY S/D (SC4650019)	CWS	GW	54	MR	M/R, Source Water Major (GWR)
York	SC4660077	CHUCKS MHP (SC4660077)	CWS	GW	168	MR	M/R, Source Water Major (GWR)
Chesterfield	SC1360008	COUNTRY VILLAGE MHP (SC1360008)	CWS	GW	89	MR	M/R, Source Water Minor (GWR)
Greenville	SC2350010	BGWC TROLLINGWOOD S/D (SC2350010)	CWS	GW	180	MR	M/R, Source Water Minor (GWR)
Williamsburg	SC4510003	STUCKEY TOWN OF (SC4510003)	CWS	GW	317	MR	M/R, Source Water Minor (GWR)
Charleston	SC1070256	OYSTER PARK POA (1070256)	NTNCWS	GW	40	MR	M/R, Source Water Major (GWR)
Dorchester	SC1830005	ARGOS CEMENT LLC (1830005)	NTNCWS	GW	105	MR	M/R, Source Water Major (GWR)
Dorchester	SC1870902	MIDDLETON PLACE (SC1870902)	NTNCWS	GW	85	MR	M/R, Source Water Major (GWR)
Georgetown	SC2230002	INTERFOR (2230002)	NTNCWS	GW	88	MR	M/R, Source Water Major (GWR)
Calhoun	SC0970910	SCOTCHMAN 3886 (SC0970910)	TNCWS	GW	50	MR	M/R, Source Water Major (GWR)
Horry	SC2670924	SAM #8 (SC2670924)	TNCWS	GW	25	MR	M/R, Source Water Major (GWR)
Lexington	SC3279014	SHIV MART #4 (3279014)	TNCWS	GW	27	MR	M/R, Source Water Major (GWR)
Orangeburg	SC3870220	LAKESIDE MARINA & RESORT (SC3870220)	TNCWS	GW	136	MR	M/R, Source Water Major (GWR)
Williamsburg	SC4570945	BOBOS ON THE RIVER (SC4570945)	TNCWS	GW	60	MR	M/R, Source Water Major (GWR)
Charleston	SC1010007	LINCOLNVILLE TOWN OF (SC1010007)	CWS	SWP	1539	MR	M/R Residual (DBP)
Clarendon	SC1470863	NORTH SHORE WATER SYS (SC1470863)	CWS	GW	35	MR	M/R Residual (DBP)
Williamsburg	SC4510001	GREELEYVILLE TOWN OF (SC4510001)	CWS	GW	850	MR	M/R Residual (DBP)
Aiken	SC0220002	COLLEGE ACRES PUBLIC W/D (SC0220002)	CWS	GW	1355	MR	M/R (DBP)
Union	SC4420001	MEANSVILLE RILEY W/D (SC4420001)	CWS	SWP	7267	MR	M/R (DBP)
Aiken	SC0220002	COLLEGE ACRES PUBLIC W/D (SC0220002)	CWS	GW	1355	MR	M/R (DBP)
Charleston	SC1010007	LINCOLNVILLE TOWN OF (SC1010007)	CWS	SWP	1539	MR	Monitoring of Treatment (SWTR)
Charleston	SC1010007	LINCOLNVILLE TOWN OF (SC1010007)	CWS	SWP	1539	MR	Monitoring of Treatment (SWTR)
Bamberg	SC0510003	EHRHARDT TOWN OF (SC0510003)	CWS	GW	507	MR	LCR Tap M/R
Berkeley	SC0820009	BCWSA EAST COOPER (SC0820009)	CWS	SWP	10362	MR	LCR Tap M/R
Charleston	SC1010504	AWENDAW TOWN OF (SC1010504)	CWS	GW	473	MR	LCR Tap M/R
Cherokee	SC1120005	MACEDONIA WATER WORKS INC (1120005)	CWS	SWP	2604	MR	LCR Tap M/R
Fairfield	SC2020005	MITFORD WATER DISTRICT (SC2020005)	CWS	SWP	1878	MR	LCR Tap M/R
Laurens	SC3010003	GRAY COURT TOWN OF (SC3010003)	CWS	SWP	1069	MR	LCR Tap M/R
Laurens	SC3050008	RANCH ROAD WATER (SC3050008)	CWS	GW	40	MR	LCR Tap M/R
Lexington	SC3260090	HALTER ACRES MHP (SC3260090)	CWS	GW	90	MR	LCR Tap M/R
Lexington	SC3260138	SUNNYVALE MHP (SC3260138)	CWS	GW	65	MR	LCR Tap M/R
Lexington	SC3260170	REGENCY SQUARE 2 (SC3260170)	CWS	GW	99	MR	LCR Tap M/R
Lexington	SC3260170	REGENCY SQUARE 2 (SC3260170)	CWS	GW	99	MR	LCR Tap M/R
Lexington	SC3270011	AAA RAPHA RESIDENTIAL CARE (3270011)	CWS	GW	69	MR	LCR Tap M/R
Lexington	SC3270304	BOARDWALK VILLA (3270304)	CWS	GW	104	MR	LCR Tap M/R
Lexington	SC3270802	SIESTA COVE RV PARK MARINA (SC3270802)	CWS	GW	40	MR	LCR Tap M/R
Oconee	SC3720001	PIONEER RURAL WATER DIST (SC3720001)	CWS	SW	15518	MR	LCR Tap M/R
Pickens	SC3910004	CLEMSON CITY OF (SC3910004)	CWS	SWP	17953	MR	LCR Tap M/R
Pickens	SC3950008	GAULEY FALLS 2 4 5 6 (SC3950008)	CWS	GW	23	MR	LCR Tap M/R
Richland	SC4060014	MEADOW LANE MHP (SC4060014)	CWS	GW	35	MR	LCR Tap M/R
Richland	SC4060035	CEDAR CREEK MHP (4060035)	CWS	GW	26	MR	LCR Tap M/R
York	SC4610005	SHARON TOWN OF (SC4610005)	CWS	GW	573	MR	LCR Tap M/R
York	SC4660003	PECAN GROVE COMMONS (SC4660003)	CWS	GW	58	MR	LCR Tap M/R
York	SC4660008	MCAFEES MHP (4660008)	CWS	GW	45	MR	LCR Tap M/R
York	SC4660008	MCAFEES MHP (4660008)	CWS	GW	45	MR	LCR Tap M/R
Orangeburg	SC3870116	WRIGHT WAY CDC - VANCE (SC3870116)	NTNCWS	GW	25	MR	Initial Tap Sampling LCR
Aiken	SC0270678	CAMP LONG LEADERSHIP CENTER (0270678)	NTNCWS	GW	175	MR	LCR Tap M/R
Charleston	SC1070103	CCSD LINCOLN HIGH CAMPUS (SC1070103)	NTNCWS	GW	350	MR	LCR Tap M/R
Charleston	SC1070143	ST JAMES SCHOOL (SC1070143)	NTNCWS	GW	240	MR	LCR Tap M/R
Charleston	SC1070256	OYSTER PARK POA (1070256)	NTNCWS	GW	40	MR	LCR Tap M/R
Florence	SC2170006	HANNAH RESIDENTIAL MANOR (2170006)	NTNCWS	GW	63	MR	LCR Tap M/R
Saluda	SC4130002	TIMBERMEN INC 'THE' (4130002)	NTNCWS	GW	75	MR	LCR Tap M/R
York	SC4670120	BETHESDA PRSBYTRN CHILD DVLPMTNT(4670120)	NTNCWS	GW	100	MR	LCR Tap M/R
Abbeville	SC0150013	COLONY EAST II (SC0150013)	CWS	GW	30	MR	Lead Consumer Notice
Aiken	SC0260038	CAMERON MHP (SC0260038)	CWS	GW	83	MR	Lead Consumer Notice
Bamberg	SC0510004	OLAR GOVAN WATER SYSTEM (0510004)	CWS	GW	257	MR	Lead Consumer Notice
Beaufort	SC0750026	WELLS EAST S/D (SC0750026)	CWS	GW	60	MR	Lead Consumer Notice
Charleston	SC1010007	LINCOLNVILLE TOWN OF (SC1010007)	CWS	SWP	1539	MR	Lead Consumer Notice
Fairfield	SC2070002	RIDGEWAY MANOR (SC2070002)	CWS	GW	158	MR	Lead Consumer Notice
Horry	SC2660045	THOMPSONS MHP (SC2660045)	CWS	GW	42	MR	Lead Consumer Notice
Lexington	SC3250014	AAA MURRAY HILL ESTATES (SC3250014)	CWS	GW	134	MR	Lead Consumer Notice

County	PWSID	PWSName	FedType	Source	Population	Violation Type	Violation Type Description
Lexington	SC3250105	AAA RIDGE POINT S/D (SC3250105)	CWS	GW	170	MR	Lead Consumer Notice
Lexington	SC3260147	PLEASANT RIDGE MHP (SC3260147)	CWS	GW	22	MR	Lead Consumer Notice
Lexington	SC3260157	PINE RIDGE MHP (SC3260157)	CWS	GW	100	MR	Lead Consumer Notice
Lexington	SC3260187	COUNTRY PARK (SC3260187)	CWS	GW	36	MR	Lead Consumer Notice
Lexington	SC3270301	LAKE LODGE APARTMENTS (3270301)	CWS	GW	130	MR	Lead Consumer Notice
Marlboro	SC3420002	WALLACE WATER COMPANY (SC3420002)	CWS	GW	3212	MR	Lead Consumer Notice
Newberry	SC3670108	BOYS FARM INC (SC3670108)	CWS	GW	40	MR	Lead Consumer Notice
Pickens	SC3950005	RIVER BLUFF S/D (SC3950005)	CWS	GW	190	MR	Lead Consumer Notice
Pickens	SC3950007	ROCK POINT HOA (SC3950007)	CWS	GW	75	MR	Lead Consumer Notice
Pickens	SC3950009	CLIFFS AT KEOWEE (SC3950009)	CWS	SWP	23	MR	Lead Consumer Notice
Pickens	SC3970300	TABLE ROCK RESORT (SC3970300)	CWS	GW	33	MR	Lead Consumer Notice
Richland	SC4060005	FREEWAY MHP (4060005)	CWS	GW	80	MR	Lead Consumer Notice
Richland	SC4060019	SILVER HILL MANUF HOME COMM. (SC4060019)	CWS	GW	180	MR	Lead Consumer Notice
Richland	SC4060038	BEVERLYS HILL (SC4060038)	CWS	GW	64	MR	Lead Consumer Notice
York	SC4660009	CEDAR VALLEY MHP (4660009)	CWS	GW	290	MR	Lead Consumer Notice
York	SC4660055	WHITLEY ESTATES (4660055)	CWS	GW	93	MR	Lead Consumer Notice
Berkeley	SC0830012	CR BARD INC (0830012)	NTNCWS	GW	350	MR	Lead Consumer Notice
Lexington	SC3230005	US SILICA (SC3230005)	NTNCWS	GW	44	MR	Lead Consumer Notice
Charleston	SC1010007	LINCOLNVILLE TOWN OF (SC1010007)	CWS	SWP	1539	M	M, Routine, Major (RTCR)
Charleston	SC1010007	LINCOLNVILLE TOWN OF (SC1010007)	CWS	SWP	1539	M	M, Routine, Major (RTCR)
Lexington	SC3250060	SHADY ACRES (SC3250060)	CWS	GW	73	M	M, Routine, Major (RTCR)
Lexington	SC3260138	SUNNYVALE MHP (SC3260138)	CWS	GW	65	M	M, Routine, Major (RTCR)
Lexington	SC3260207	HIDDEN ACRES MHP (SC3260207)	CWS	GW	74	M	M, Routine, Major (RTCR)
Lexington	SC3270010	CEDAR RETIREMENT CENTER (SC3270010)	CWS	GW	45	M	M, Routine, Major (RTCR)
Newberry	SC3670108	BOYS FARM INC (SC3670108)	CWS	GW	40	M	M, Routine, Major (RTCR)
Sumter	SC4360012	SHAW MOBILE HOME PARK (SC4360012)	CWS	GW	173	M	M, Routine, Major (RTCR)
Williamsburg	SC4510001	GREELEYVILLE TOWN OF (SC4510001)	CWS	GW	850	M	M, Routine, Major (RTCR)
Aiken	SC0230003	DIXIE CLAY COMPANY (0230003)	NTNCWS	GW	27	M	M, Routine, Major (RTCR)
Dorchester	SC1830005	ARGOS CEMENT LLC (1830005)	NTNCWS	GW	105	M	M, Addl Routine, Major (RTCR)
Fairfield	SC2070675	CAMP LONGRIDGE (SC2070675)	TNCWS	GW	264	M	M, Addl Routine, Major (RTCR)
Hampton	SC2572000	NIXVILLE COUNTRY STORE (SC2572000)	TNCWS	GW	26	M	M, Addl Routine, Major (RTCR)
Richland	SC4030001	DESCI WATREEE STATION (SC4030001)	NTNCWS	GW	148	R	R, Notification, E coli Positive (RTCR)
Charleston	SC1070103	CCSD LINCOLN HIGH CAMPUS (SC1070103)	NTNCWS	GW	350	Other	PN Violation for NPDWR Violation
Orangeburg	SC3870116	WRIGHT WAY CDC - VANCE (SC3870116)	NTNCWS	GW	25	Other	PN Violation for NPDWR Violation
Allendale	SC0310004	FAIRFAX TOWN OF (SC0310004)	CWS	GW	1962	Other	Failure to submit CCR Certification
Berkeley	SC0860058	GARNETT MHP (SC0860058)	CWS	GW	41	Other	Failure to submit CCR Certification
Darlington	SC1610004	LAMAR TOWN OF (SC1610004)	CWS	GWP	1039	Other	Failure to submit CCR Certification
Georgetown	SC2210003	ANDREWS TOWN OF (SC2210003)	CWS	GW	3221	Other	Failure to submit CCR Certification
Horry	SC2610011	N MYRTLE BEACH CITY OF (SC2610011)	CWS	SWP	30256	Other	Failure to submit CCR Certification
Richland	SC4060014	MEADOW LANE MHP (SC4060014)	CWS	GW	35	Other	Failure to submit CCR Certification
Richland	SC4060019	SILVER HILL MANUF HOME COMM. (SC4060019)	CWS	GW	180	Other	Failure to submit CCR Certification
Richland	SC4060052	PINEY LANE MHP (SC4060052)	CWS	GW	32	Other	Failure to submit CCR Certification
Sumter	SC4320003	HIGH HILLS RURAL WATER CO INC (4320003)	CWS	GW	12545	Other	Failure to submit CCR Certification
Williamsburg	SC4510002	KINGSTREE TOWN OF (SC4510002)	CWS	GW	6009	Other	Failure to submit CCR Certification
York	SC4610003	FORT MILL TOWN OF (SC4610003)	CWS	SWP	18554	Other	Failure to submit CCR Certification
York	SC4650015	PINETUCK S/D (SC4650015)	CWS	GW	50	Other	Failure to submit CCR Certification