



August 10, 2023

To all interested parties:

**Annual State Public Water System Report – Calendar Year 2022**

Each quarter, primacy agencies submit data to the Safe Drinking Water Information System (SDWIS/FED), an automated database maintained by the Environmental Protection Agency (EPA). The data submitted include, but are not limited to, PWS inventory information, the incidence of Maximum Contaminant Level (MCL), Maximum Residual Disinfectant Level (MRDL), Monitoring/Reporting (M/R), Monitoring (M), Reporting (R) and treatment technique (TT) violations; and information on enforcement activity related to these violations. Section 1414(c)(3)(A)(i-ii) of the Safe Drinking Water Act requires states to provide EPA with an annual report of violations of the primary drinking water standards. The categories of violations are:

- a) Maximum Contaminant Level (MCL) violation - Under the Safe Drinking Water Act (SDWA), the EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as MCLs.
- b) Treatment Technique (TT) violation - For some regulations, the EPA establishes treatment techniques in lieu of an MCL to control unacceptable levels of certain contaminants. For example, treatment techniques have been established for viruses, bacteria, turbidity, and lead.
- c) Monitoring & Reporting (M/R) violation – If a PWS fails to have its water tested as required or fails to report test results correctly to the primacy agency, a monitoring violation occurs.
- d) Monitoring (M) or Reporting (R) violation – Microbials under the Revised Total Coliform Rule, beginning April 1, 2016, a PWS is required to monitor and verify that the levels of contaminants present in the water do not exceed the MCL or MRDL. If a PWS fails to have its water tested as required, a monitoring violation occurs. If a PWS fails to report test results correctly to the primacy agency, a reporting violation occurs.

**Public Water System**

A Public Water System (PWS) is defined as a system that provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of PWSs. PWSs can be community systems (such as towns), non-transient non-community systems (such as schools or factories), or transient non-community systems (such as rest stops or parks).

PWS Type	#PWS	Population Served	% of Total Population
<b>Community (CWS)</b>	574	4,453,837	98%
<b>Non-transient non-community (NTNCWS)</b>	89	25,298	1%
<b>Transient non-community (TNCWS)</b>	739	48,225	1%
	<b>1,402</b>	<b>4,527,360</b>	

There are two types of source water: groundwater and surface water. Ground water systems (GWS) are those systems depending on wells to provide their drinking water supply; while surface water systems (SWS) are those systems that depend on lakes, rivers, and streams for their drinking water supply. SWS, as defined by federal regulation, provided water to a population of 3,885,656 residents, or 86% of the total population. GWS, as defined by federal regulation, provided water to a population of 641,704 residents, or 14% of the total population.

Source Type	Population Served	% of Total Population
<b>SWS (423 systems)</b>	3,885,656	86%
<b>GWS (979 systems)</b>	641,704	14%
	<b>4,527,360</b>	

### Additional Information Regarding Violations

In 2022, there were 242 total violations. The violation categories include Maximum Contaminant Level Violations (MCL), Treatment Technique Violations (TT), Monitoring and Reporting Violations (M/R), Monitoring Violations (M), and Reporting Violations (R). The violations for 2022 represented 157 federally defined PWSs\* or 11% of the 1,402 federally defined PWSs, serving 313,010 or 7% of the total South Carolina population of 4,527,360.

Violation Category	Rule Group	Rule Name	# of Violations	# of Resolved Violations†	# of PWS with Violations*
<b>MCL</b>	Chemicals	Radionuclides	4	0	1
<b>MCL</b>	Disinfectants and Disinfection Byproducts Rule	Stage 2 Disinfectants and Disinfection Byproducts Rule	21	2	10
<b>MCL</b>	Microbials	Revised Total Coliform Rule (1A)	1	0	1
<b>TT</b>	Chemicals	Lead and Copper Rule	2	0	2
<b>TT</b>	Microbials	Revised Total Coliform Rule	4	4	4
<b>TT</b>	Disinfectants and Disinfection Byproducts Rule	Stage 1 Disinfectants and Disinfection Byproducts Rule	2	2	1
<b>M/R</b>	Chemicals	Lead and Copper Rule	57	6	54
<b>M/R</b>	Disinfectants and Disinfection Byproducts Rule	Stage 1 Disinfectants and Disinfection Byproducts Rule	16	15	15
<b>M/R</b>	Disinfectants and Disinfection Byproducts Rule	Stage 2 Disinfectants and Disinfection Byproducts Rule	10	0	10
<b>M</b>	Microbials	Revised Total Coliform Rule	34	30	29
<b>M/R</b>	Microbials	Ground Water Rule	33	20	28
<b>M/R</b>	Microbials	Surface Water Treatment Rule	8	8	8
<b>Other</b>	Consumer Confidence Reporting Rule	Consumer Confidence	48	27	48
<b>Other</b>	Public Notification	Public Notice	2	0	2
		<b>Totals</b>	<b>242 violations</b>	<b>114 Resolved</b>	<b>213 PWS with Violations* (157 unique PWSs*)</b>

\*The table indicates the total number of PWSs with violations as 213, but some PWSs had more than one type/category of violation. The unique number of PWSs with violations (more than one, and/or more than one type) was 157 PWSs for 2022. The table above summarizes the violations in 2022.

† - # of Resolved Violations represents the number of violations that have been resolved (returned to compliance) during the calendar year. Due to EPA requirements to consider a system's violation resolved, it could take up to a year of monitoring data meet the standard to return to compliance.

## Microbials

South Carolina's microbiological program monitors PWS for compliance with the Revised Total Coliform Rule (RTCR) and the Groundwater Rule (GWR). The RTCR establishes a MCL for *E. coli* and uses *E. coli* and total coliforms to initiate a 'find and fix' approach to address fecal contamination that could enter the distribution system (DS). It requires PWSs to perform assessments to identify sanitary defects and act to correct them. The RTCR applies to all PWSs and requires all federally defined PWSs to develop a self-monitoring program for their system. The GWR establishes a risk-targeted approach to identify GWSs susceptible to fecal contamination and requires corrective action to correct significant deficiencies and source water fecal contamination in all federally defined public GWSs. The GWR applies to all PWSs that use ground water, including consecutive systems. The GWR requires all federally defined systems that detect total coliform in their DS to collect a sample from each source in use at the time of the total coliform positive. South Carolina requires all CWS and NTNCWS develop a self-monitoring program utilizing a South Carolina certified lab for analyzing samples. South Carolina DHEC collects and analyzes microbiological samples quarterly, monthly, or annually for TNCWS.

The RTCR requires that when total coliforms are found present in a routine sample, *E. coli* must be analyzed to confirm its absence or presence in the sample. The presence of *E. coli* is a health-related contamination of drinking water and requires the PWS to notify its customers. This type of violation is shown in the report as MCL *E. coli* (RTCR).

South Carolina had one (1) MCL *E. coli* (RTCR) violations in one (1) PWSs ( TNCWS-1) serving a population of 26 or <1% of the total population (4,527,360). The MCL *E. coli* (RTCR) violations represented <1% of the total violations (242) and <1% of the total number of PWSs (1,402) in South Carolina.

There were thirty-three (33) M/R source water (GWR) violations in twenty-eight (28) PWSs (CWS-21 NTNCWS-5, TNCWS-2) serving a population of 25,427 or 1% of the total population (4,527,360). Some PWSs incurred more than one violation in the calendar year. The M/R, Source Water (GWR) violations represented 12% of the total violations (242) and 2% of the total number of PWSs (1,402) in South Carolina. The GWR requires PWSs that detect total coliform in their distribution system to collect a sample from each groundwater source in use at the time of the total coliform positive. This M/R violation occurs when the PWS fails to sample/monitor (indicated "Major" - 31 violations) or fails to sample/monitor all groundwater sources active at the time of the total coliform positive sample event (indicated "Minor" - 2 violations).

There were thirty (30) Monitoring (M) violations in twenty-six (26) PWSs (CWS-20, NTNCWS-4, TNCWS-2) serving a population of 3,281 or <1% of the total population (4,527,360). Some CWSs incurred more than one violation in the calendar year. These M violations represented 12% of the total violations (242) and 1% of the total number of PWSs (1,402) in South Carolina. If the routine or repeat samples were not collected, the violation was major. Ten (10) of the M violations were M, Routine, Major (RTCR) (CWS-8, NTNCWS-1) serving a population of 2,886 or <1% of the total population (4,527,360). The M, Routine, Major (RTCR) violations represented 1% of the total number of PWSs (1,402) and 4% of the total number of violations (242).

RTCR further requires that a PWS on a monitoring frequency less than monthly (e.g., quarterly, annually), must collect an additional three (3) routine samples the month following a total coliform positive (TC+) sample result. The violation, M, Addl Routine (RTCR), has both major and minor severity indicators. A major indicator means that none of the additional routine samples were collected the month following a TC+ sample result. A minor indicator means that some, but not all the additional routine samples were collected.

In 2022, there were four (4) M violations for M, Addl Routine (RTCR) (NTNCWS-2, TNCWS-2) serving a population of 337 or <1% of the total population (4,527,360). The four (4) violations were indicated "Major" and represented <1% of the total number of PWSs (1,402) and 2% of the total violations (242). One NTNCWS had a violation for both M, Routine, Major (RTCR) and M, Addl Routine (RTCR).

## Chemicals

South Carolina DHEC collects and analyzes chemical samples utilizing a Standardized Monitoring Framework (SMF) which standardizes, simplifies, and consolidates monitoring requirements across contaminant groups. The SMF increases public protection by simplifying monitoring plans and synchronizing monitoring schedules leading to increased compliance with monitoring requirements. The SMF reduces the variability within monitoring requirements for chemical and radiological contaminants across systems sizes and types. The regulated contaminants include fifteen (15) Inorganic Contaminants (IOCs), fifty-one (51) Synthetic Organic Contaminants (SOCs) and Volatile Organic Contaminants (VOCs), and four (4) Radionuclides. South Carolina's monitoring includes monitoring for all federally defined PWSs, including CWS, NTNCWS and TNCWS. All federally defined PWSs are monitored for Nitrate and Nitrite. All CWS are monitored for IOCs, SOCs, VOCs and Radionuclides. All NTNCWS are monitored for IOCs, SOCs and VOCs.

In 2022, one (1) PWS incurred four (4) violations for chemicals. These violations represented one (1) PWSs (CWS-1, serving a population of 41) with four (4) violations for MCL Gross Alpha. This system served a population of 41, <1% of the total population (4,527,360).

These chemical violations represent <1% of the PWSs in South Carolina and 2% of the total violations (242). In 2022, 99% of South Carolina PWSs were without chemical violations, serving 99% of the total population. These violations have been indicated on the chart with a description of MCL Violation, Average (Gross Alpha).

## Disinfection and Disinfection Byproducts

South Carolina DHEC collects and analyzes samples for disinfectants and disinfection byproducts in according with the Stage 1 Disinfectants and Disinfection Byproducts (S1D/DBP) Rule and Stage 2 Disinfectants and Disinfection Byproducts (S2D/DBP) Rule. The addition of a chemical disinfectant requires a PWS to monitor Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAA5). Upon implementation of S2D/DBP Rule, monitoring was required for all CWS and NTNCWS that use primary or residual disinfectant or delivers (sells) treated water. These rules also required water systems to submit an initial distribution system evaluation (IDSE) to identify sites for D/DBP sampling.

There were twenty-one (21) MCL violations for TTHM in (10) PWSs (CWS-10) serving a population of 28,772 or <1% of the total population (4,527,360). Some PWSs incurred more than one violation in the calendar year. These violations, MCL Violation, Average (TTHM), represented 9% of the total violations (242) and <1% of all PWSs (1,402).

In rare instances, DHEC staff and regional staff may fail to identify or collect required samples for a water system. In 2022, ten (10) sampling events were recorded as missed, resulting in ten (10) violations (CWS-9, NTNCWS-1) serving a population of 68,220 which represents 2% of the total population (4,527,360), <1% of the total PWSs (1,402) and 4% of the total violations (242). Nine (9) CWSs served a population of 68,170 representing 2% of the total population (4,527,360), <1% of the total number of PWSs (1,402), and 4% of the total violations (242). One (1) NTNCWS served a population of 50 representing <1% of the total population (4,527,360), <1% of the PWSs (1,402), and 5% of the total violations (242). These M/R violations will return to compliance in 2023.

Fifteen (15) MR violations (CWS-15) for failure to monitor and report disinfectant residual or to maintain certification with the State to analyze residuals occurred in 2022. The total population served by these systems was 9,013 representing <1% of the total population (4,527,360), 1% of the total PWSs (1,402), and 6% of the total violations (242). These violations are recorded as M/R Residual (DBP) on the violation chart.

There were two (2) TT violations under S1D/DBP during 2022. The violations were for failure to operate the water system by a state-approved qualified operator. These violations occurred in one (1) CWSs serving a total population of 5,771 or <1% of the total population (4,527,360). These violations represented <1% of the total PWSs (1,402) and <1% of the total violations (242). The CWSs have returned to compliance and operate with state-approved qualified operators. These violations are recorded as TT No Certif. Operator on the violation chart.

### **Surface Water Treatment**

The Surface Water Treatment Rule (SWTR), Interim Enhanced Surface Water Treatment Rule (IESWTR), Filter Backwash Recycling Rule (FBRR), Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR), and Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR) apply to surface water systems and groundwater systems under the influence of surface water. These rules improve public health protection through the control of microbial contaminants, particularly viruses, *Giardia lamblia*, and *Cryptosporidium*. South Carolina DHEC requires the PWSs to which these rules apply to self-monitor and report to DHEC through monthly operating reports.

Under SWTR there were (8) violations for eight (8) CWS serving 3,760. The violation was for failure to collect and report distribution system disinfectant concentrations. These violations represented <1% of the public water systems (1,402), <1% of the total population (4,527,360), and 3% of the total violations (242). These violations are noted on the chart as Monitoring of Treatment (SWTR).

### **Lead and Copper**

The Lead and Copper Rule (LCR) establishes an Action Level (AL) of 0.015 mg/L for Lead (Pb) and 1.3 mg/L for Copper (Cu) based on 90<sup>th</sup> percentile levels of tap water samples. An AL exceedance is not a violation but triggers other requirements that may include water quality parameter (WQP) monitoring, corrosion control treatment (CCT), source water monitoring/treatment, public education, or lead service line replacement (LSLR). The LCR applies to all CWS and NTNCWS.

Reported in Calendar Year 2022 are fifty-seven (57) M/R violations under LCR. These violations will be presented in two types, one type will be designated LCR Tap M/R which is the failure of the PWS to either (a) collect all or some of the required initial tap samples or (b) collect all or some of the required follow-up/routine tap samples. The other will be designated Lead Consumer Notice which is the failure of the PWS to provide notice of lead results to individuals served by taps used for LCR tap monitoring, in accordance with the timing, content and delivery requirements or failure to submit a sample notice and certification to the State. Monitoring and reporting violations do not represent health-based violations.

There were twenty-nine(29) LCR Tap M/R violations which occurred in twenty-six (26) PWSs (CWS-23, NTNCWS-3) serving a population of 32,145 which represents <1% of the total population (4,527,360), 2% of the total PWSs (1,402) and 11% of the total violations (242). Three (3) CWSs incurred more than one violation. Twenty-three (23) CWSs served a population of 31,695 representing 1% of the total population (4,527,360), 1% of the total number of PWSs (1,402), and 10% of the total violations (242). Three (3) NTNCWS served a population of 450 representing <1% of the total population (4,527,360), 1% of the PWSs (1,402), and 5% of the total violations (242).

There were twenty-eight (28) Lead Consumer Notice violations which occurred in twenty-eight (28) PWSs (CWS-23, NTNCWS-5) serving a population of 17,227 which represents <1% of the total population (4,527,360), 2% of the total PWSs (1,402), and 12% of the total violations (242). Twenty-three (23) CWSs served a population of 16,581 representing <1% of the total population (4,527,360), 2% of the total number of PWSs (1,402), and 14% of the total violations (242). Five (5) NTNCWS served a population of 646 representing <1% of the total population (4,527,360), <1% of the PWSs (1,402), and 2% of the total violations (242).

Two(2) TT violations under LCR occurred in 2022. These violations occurred in two (2) PWSs (CWS-2, ) serving 258 or<1% of the total population (4,527,360), <1% of the total PWSs (1,402), and 2% of the total violations (242).

One violation has been identified in the chart as WQP EP/Tap TT Non-Compliance. This violation occurred in one (1) PWSs (CWS-1, ) serving 40 or<1% of the total population (4,527,360), <1% of the total PWSs (1,402), and 2% of the total violations (242).

### **Public Notice**

The Public Notice (PN) Rule requires all public water systems (PWSs) to notify their consumers any time a PWS violates a National Primary Drinking Water Regulation or has a situation posing a risk to public health. This rule applies to all PWSs. In 2022, there were two (2) violations, PN Violation for NPDWR Violation, in two (2) PWS (NTNCWS-2). The total population served for these PWSs was 375 representing <1% of the total population (4,527,360), <1% of the total PWSs (1,402), and <1% of the total violations (242).

### **Consumer Confidence Rule**

The Consumer Confidence Reports Rule (CCR) established minimum requirements for the content of annual reports that community water systems (CWS) delivered to their customers. The reports contained information on the quality of the water delivered by the PWSs and characterized the risks (if any) from exposure to contaminants detected in the drinking water in an accurate and understandable manner. The Regulation applied only to CWS.

In addition, the CCR established that no later than the date the system was required to distribute the report to its customers, each CWS was required to mail a copy of the report to the Department, followed within three (3) months by a Certification that the report had been distributed to customers, that the information was correct and consistent with compliance monitoring data either provided by or submitted to the Department. In 2022, there were forty-eight (48) violations, Consumer Confidence Report Complete Failure to Report, in forty-eight (48) PWS (CWS-48). The total population served for these PWSs was 155,363 representing <1% of the total population (4,527,360), 3% of the total PWSs (1,402), and 20% of the total violations (242).

### **Enforcement**

The Drinking Water Enforcement Section functions to carry out enforcement actions involving all aspects of public water system compliance. The functions of the Enforcement section, combined with the efforts of the Drinking Water Compliance Monitoring Section, the Drinking Water Protection Division, the Bureau of Water, the Bureau of Environmental Health Services Regional Offices, and other areas within DHEC, work together to ensure safe drinking water for the continued health and welfare of the citizens of South Carolina. The goal is to bring PWSs back into compliance and protect the health of the public.

### **Variations and Exemptions**

Variations and exemptions to specific requirements of the Safe Drinking Water Act Amendments of 1996 may be granted under certain circumstances. If a PWS meets the specific criteria outlined in the *State Primary Drinking Water Regulation*, R.61-58, DHEC may approve such a variance or exemption. South Carolina has three (3) non-community public water systems subject to a variance for Nitrate.

### **Additional Informational Charts**

<b>Number of PWSs with Violations and Population Served</b>				
<b>Size of PWS</b>	<b>#PWSs</b>	<b>% of PWSs</b>	<b>Population Served</b>	<b>% of Total Population</b>
Large (>50,000)	0	N/A	N/A	N/A
Medium (>3,300≤50,000)	19	1%	213,995	5%
Small (≤3,300)	138	10%	60,956	1%
<b>Total</b>	<b>157</b>	<b>11%</b>	<b>274,951</b>	<b>6%</b>

<b>Number of PWSs with MCL or TT Violations (excludes M/R, M, R, Other) and Population Served</b>				
<b>Size of PWS</b>	<b>#PWSs</b>	<b>% of PWSs</b>	<b>Population Served</b>	<b>% of Total Population</b>
Large (>50,000)	0	N/A	N/A	N/A
Medium (>3,300≤50,000)	4	<1%	22,971	<1%
Small (≤3,300)	12	1%	11,923	<1%
<b>Total</b>	<b>16</b>	<b>1%</b>	<b>34,894</b>	<b>&lt;1%</b>

<b>Number of PWSs with M/R Violations (excludes Lead &amp; Copper) and Population Served</b>				
<b>Size of PWS</b>	<b>#PWSs</b>	<b>% of PWSs</b>	<b>Population Served</b>	<b>% of Total Population</b>
Large (>50,000)	0	N/A	N/A	N/A
Medium (>3,300≤50,000)	15	1%	22,726	<1%
Small (≤3,300)	84	6%	14,494	<1%
<b>Total</b>	<b>99</b>	<b>7%</b>	<b>37,220</b>	<b>&lt;1%</b>

<b>Number of PWSs with Lead and Copper M/R Violations and Population Served</b>				
<b>Size of PWS</b>	<b>#PWSs</b>	<b>% of PWSs</b>	<b>Population Served</b>	<b>% of Total Population</b>
Large (>50,000)	0	N/A	N/A	N/A
Medium (>3,300≤50,000)	3	<1%	33,775	<1%
Small (≤3,300)	43	3%	10,646	<1%
<b>Total</b>	<b>46</b>	<b>3%</b>	<b>44,421</b>	<b>&lt;1%</b>

<b>SWS/GWS Number of PWSs with MCL or TT Violations (excludes M/R, M, R, or Other) and Population Served</b>				
<b>Size of PWS</b>	<b>#PWSs</b>	<b>% of PWSs</b>	<b>Population Served</b>	<b>% of Total Population</b>
Surface (SWS)	9	1%	31,297	<1%
Groundwater (GWS)	7	1%	3,597	<1%
<b>Total</b>	<b>16</b>	<b>2%</b>	<b>34,894</b>	<b>&lt;1%</b>

<b>SWS/GWS Number of PWSs with M/R Violations (excludes Lead &amp; Copper) and Population Served</b>				
<b>Size of PWS</b>	<b>#PWSs</b>	<b>% of PWSs</b>	<b>Population Served</b>	<b>% of Total Population</b>
Surface (SWS)	22	2%	189,783	4%
Groundwater (GWS)	77	5%	79,505	2%
<b>Total</b>	<b>99</b>	<b>7%</b>	<b>269,288</b>	<b>6%</b>

<b>SWS/GWS Number of PWSs with Lead and Copper Violations and Population Served</b>				
<b>Size of PWS</b>	<b>#PWSs</b>	<b>% of PWSs</b>	<b>Population Served</b>	<b>% of Total Population</b>
Surface (SWS)	5	<1%	21,641	<1%
Groundwater (GWS)	41	3%	22,780	<1%
<b>Total</b>	<b>55</b>	<b>4%</b>	<b>44,421</b>	<b>&lt;1%</b>

### **Additional Monitoring – Per- and Polyfluoroalkyl Substances (PFAS)**

Protecting public health and ensuring the safety of South Carolina’s air, land, and water has continued to remain one of DHEC’s highest priorities. One of the challenges with this priority has been addressing chemicals for which the agency has no regulatory authority. These chemicals, referred to as emerging contaminants, are those with which we have a new awareness and understanding of how they behave in the environment and affect public health.

One class of these emerging contaminants is per- and polyfluoroalkyl substances (PFAS), a group now believed to be more than 9,000 man-made chemicals that have been used since the 1940s for their heat resistance and water-, oil-, and dirt-repellence. Because of their stability, PFAS resist breakdown by natural processes and persist in the environment indefinitely, earning them the nickname “forever chemicals.” The most common exposure route is from swallowing food or water that contains PFAS.

Additional monitoring has been ongoing for PFAS since 2020. Please visit our website for further details and data regarding per- and polyfluoroalkyl substances at: <https://scdhec.gov/BOW/perfluoroalkyl-substances-pfas>.

### **Conclusions**

In summary, South Carolina’s PWSs and South Carolina DHEC continue to work cooperatively to provide quality drinking water for South Carolinians. Of the State’s 1,402 PWSs, 1,245 PWSs, or approximately 89% were in full compliance with all regulatory requirements (health-based, monitoring and reporting, other) during Calendar Year 2022, serving a population of 4,213,616 or 83% of the total population.

**Monitoring and Reporting violations and ‘Other’ violations (Public Notice, CCR Certification) are not health-based violations. Excluding these violations (monitoring, reporting, other), South Carolina had 1,386 systems, 99% of all PWSs, that served a population of 4,492,466 or 99% of the total population that met all health-based standards. South Carolina DHEC is committed to improving the quality of life for all South Carolinians by protecting and promoting the health of the public and the environment.**

### **Report Distribution and Availability**

This report provides the consumers in the State of South Carolina information useful in assessing the quality of their drinking water and the success of South Carolina DHEC’s compliance and enforcement activities. By disseminating this information, consumers will become more aware of their individual water providers and water quality. Consumers should feel free to ask questions of their PWS or of South Carolina DHEC. In addition, community water systems produce an annual Consumer Confidence Report, which provides detailed information about chemical sampling results and drinking water violations. Any additional information not contained in this report contact South Carolina DHEC’s Freedom of Information Office at (803) 898-3880.

As required by the Safe Drinking Water Act South Carolina has made the 2022 Public Water Systems report available to public. Interested individuals can obtain a copy of the 2022 Annual Public Water Systems Report for South Carolina by accessing:



[www.dhec.sc.gov](http://www.dhec.sc.gov)

Telephone: 803-898-4300

Fax Number: 803-898-3795

E-Mail: [smithwa@dhec.sc.gov](mailto:smithwa@dhec.sc.gov)

Wendi Smith, Program Manager

Drinking Water Compliance Monitoring

Drinking Water Protection

SC DHEC Bureau of Water

2600 Bull Street

Columbia, SC 29201

SC ACR CY2022 (9 pages)

Attachment: SC ACR CY2022 Violation Chart (4 pages)

County	PWSID	PWSName	FedType	Source	Population	Violation Typ	Violation Type Description
Abbeville	SC0110002	CALHOUN FALLS TOWN OF (SC0110002)	CWS	SWP	2473	MCL	MCL Violation, Average (TTHM)
Abbeville	SC0110002	CALHOUN FALLS TOWN OF (SC0110002)	CWS	SWP	2473	MCL	MCL Violation, Average (TTHM)
Berkeley	SC0860037	SANDY RUN MHP (SC0860037)	CWS	GW	41	MCL	MCL Violation, Average (Gross Alpha)
Berkeley	SC0860037	SANDY RUN MHP (SC0860037)	CWS	GW	41	MCL	MCL Violation, Average (Gross Alpha)
Berkeley	SC0860037	SANDY RUN MHP (SC0860037)	CWS	GW	41	MCL	MCL Violation, Average (Gross Alpha)
Berkeley	SC0860037	SANDY RUN MHP (SC0860037)	CWS	GW	41	MCL	MCL Violation, Average (Gross Alpha)
Charleston	SC1050011	DEWEES UTILITIES (SC1050011)	CWS	GW	55	MCL	MCL Violation, Average (TTHM)
Charleston	SC1050011	DEWEES UTILITIES (SC1050011)	CWS	GW	55	MCL	MCL Violation, Average (TTHM)
Charleston	SC1050011	DEWEES UTILITIES (SC1050011)	CWS	GW	55	MCL	MCL Violation, Average (TTHM)
Cherokee	SC1120003	DRAYTONVILLE WATER DIST (SC1120003)	CWS	SWP	5323	MCL	MCL Violation, Average (TTHM)
Colleton	SC1560002	EAGLES RV CAMPGROUND (SC1560002)	TNCWS	GW	26	MCL	MCL E. coli (RTCR)
McCormick	SC3510001	MCCORMICK CPW (3510001)	CWS	SW	1818	MCL	MCL Violation, Average (TTHM)
McCormick	SC3510001	MCCORMICK CPW (3510001)	CWS	SW	1818	MCL	MCL Violation, Average (TTHM)
McCormick	SC3510001	MCCORMICK CPW (3510001)	CWS	SW	1818	MCL	MCL Violation, Average (TTHM)
McCormick	SC3520002	MCCORMICK CO W&SA (SC3520002)	CWS	SWP	8500	MCL	MCL Violation, Average (TTHM)
McCormick	SC3520002	MCCORMICK CO W&SA (SC3520002)	CWS	SWP	8500	MCL	MCL Violation, Average (TTHM)
McCormick	SC3520002	MCCORMICK CO W&SA (SC3520002)	CWS	SWP	8500	MCL	MCL Violation, Average (TTHM)
McCormick	SC3520002	MCCORMICK CO W&SA (SC3520002)	CWS	SWP	8500	MCL	MCL Violation, Average (TTHM)
Saluda	SC4110001	SALUDA CPW (4110001)	CWS	SWP	3377	MCL	MCL Violation, Average (TTHM)
Saluda	SC4110001	SALUDA CPW (4110001)	CWS	SWP	3377	MCL	MCL Violation, Average (TTHM)
Union	SC4410003	CARLISLE TOWN OF (4410003)	CWS	SWP	414	MCL	MCL Violation, Average (TTHM)
Union	SC4410003	CARLISLE TOWN OF (4410003)	CWS	SWP	414	MCL	MCL Violation, Average (TTHM)
Union	SC4420007	SANTUCK HEBRON WATER CO (4420007)	CWS	SWP	3097	MCL	MCL Violation, Average (TTHM)
Union	SC4420010	LOCKHART TOWN OF (SC4420010)	CWS	SWP	524	MCL	MCL Violation, Average (TTHM)
Union	SC4420010	LOCKHART TOWN OF (SC4420010)	CWS	SWP	524	MCL	MCL Violation, Average (TTHM)
Williamsburg	SC4510004	HEMINGWAY TOWN OF (SC4510004)	CWS	GW	3191	MCL	MCL Violation, Average (TTHM)
Abbeville	SC0150006	NANCE S/D #2 (SC0150006)	TNCWS	GW	63	MON	M, Additional Routine (RTCR)
Abbeville	SC0150013	COLONY EAST II (SC0150013)	CWS	GW	30	MON	M, Routine, Major (RTCR)
Charleston	SC1010007	LINCOLNVILLE TOWN OF (SC1010007)	CWS	SWP	1980	MON	M, Routine, Major (RTCR)
Clarendon	SC1470108	PAXVILLE HEAD START (SC1470108)	NTNCWS	GW	72	MON	M, Routine, Major (RTCR)
Dorchester	SC1870902	MIDDLETON PLACE (SC1870902)	NTNCWS	GW	85	MON	M, Routine, Major (RTCR)
Fairfield	SC2010001	WINNSBORO TOWN OF (2010001)	CWS	SW	7888	MON	M, Routine, Major (RTCR)
Florence	SC2170006	HANNAH RESIDENTIAL MANOR (2170006)	NTNCWS	GW	0	MON	M, Routine, Major (RTCR)
Jasper	SC2770212	TIGER EXPRESS #11 (SC2770212)	TNCWS	GW	200	MON	M, Additional Routine (RTCR)
Lexington	SC3230034	CAROLINA FABRICATORS (SC3230034)	NTNCWS	GW	49	MON	M, Additional Routine (RTCR)
Lexington	SC3250017	BGWC IDLEWOOD (SC3250017)	CWS	SWP	134	MON	M, Routine, Major (RTCR)
Lexington	SC3250020	BGWC INDIAN COVE S/D (SC3250020)	CWS	SWP	92	MON	M, Routine, Major (RTCR)
Lexington	SC3250021	BGWC DUTCHMAN SHORES (SC3250021)	CWS	SWP	335	MON	M, Routine, Major (RTCR)
Lexington	SC3250027	BGWC VANARSDALE S/D (3250027)	CWS	SWP	509	MON	M, Routine, Major (RTCR)
Lexington	SC3250029	BGWC PARKWOOD S/D (3250029)	CWS	SWP	311	MON	M, Routine, Major (RTCR)
Lexington	SC3250045	BGWC PEACHTREE ACRES (3250045)	CWS	SWP	124	MON	M, Routine, Major (RTCR)
Lexington	SC3250051	BGWC INDIAN PINES (SC3250051)	CWS	SWP	43	MON	M, Routine, Major (RTCR)
Lexington	SC3250060	SHADY ACRES (SC3250060)	CWS	SWP	73	MON	M, Routine, Major (RTCR)
Lexington	SC3250066	BGWC INDIAN FORK-40 LOVE (3250066)	CWS	SWP	367	MON	M, Routine, Major (RTCR)
Lexington	SC3260127	HIDEAWAY MHP (3260127)	CWS	GW	35	MON	M, Routine, Major (RTCR)
Lexington	SC3260183	SAND MOUNTAIN MHP (SC3260183)	CWS	GW	40	MON	M, Routine, Major (RTCR)
Lexington	SC3260183	SAND MOUNTAIN MHP (SC3260183)	CWS	GW	40	MON	M, Routine, Major (RTCR)
Lexington	SC3260187	COUNTRY PARK (SC3260187)	CWS	GW	36	MON	M, Routine, Major (RTCR)
Lexington	SC3260187	COUNTRY PARK (SC3260187)	CWS	GW	36	MON	M, Routine, Major (RTCR)
Lexington	SC3260207	HIDDEN ACRES MHP (SC3260207)	CWS	GW	74	MON	M, Routine, Major (RTCR)
Lexington	SC3260207	HIDDEN ACRES MHP (SC3260207)	CWS	GW	74	MON	M, Routine, Major (RTCR)
Lexington	SC3279014	SHIV MART #4 (3279014)	TNCWS	GW	27	MON	M, Routine, Major (RTCR)
Newberry	SC3670108	BOYS FARM INC (SC3670108)	CWS	GW	40	MON	M, Routine, Major (RTCR)
Orangeburg	SC3870116	WRIGHT WAY CDC - VANCE (SC3870116)	NTNCWS	GW	25	MON	M, Routine, Major (RTCR)
Orangeburg	SC3870116	WRIGHT WAY CDC - VANCE (SC3870116)	NTNCWS	GW	25	MON	M, Additional Routine (RTCR)
Richland	SC4050012	BGWC FARROWWOOD ESTATES (SC4050012)	CWS	SWP	356	MON	M, Routine, Major (RTCR)
Richland	SC4050014	BGWC STONEGATE (SC4050014)	CWS	SWP	352	MON	M, Routine, Major (RTCR)
Richland	SC4070650	FT JACKSON-TWIN LAKES (SC4070650)	TNCWS	GW	26	MON	M, Routine, Major (RTCR)
York	SC4660064	GLEN AT CLOVER LLC THE (SC4660064)	CWS	GW	215	MON	M, Routine, Major (RTCR)
York	SC4660064	GLEN AT CLOVER LLC THE (SC4660064)	CWS	GW	215	MON	M, Routine, Major (RTCR)
Abbeville	SC0110002	CALHOUN FALLS TOWN OF (SC0110002)	CWS	SWP	2473	MR	Follow-up Or Routine LCR Tap M/R
Aiken	SC0220001	LANGLEY W/D (SC0220001)	CWS	GW	753	MR	Monitoring, Source Water (GWR)
Aiken	SC0260038	CAMERON MHP (SC0260038)	CWS	GW	83	MR	Monitoring, Source Water (GWR)

Allendale	SC0310001	ALLENDALE TOWN OF (SC0310001)	CWS	GW	3882	MR	Monitoring, Source Water (GWR)
Allendale	SC0310001	ALLENDALE TOWN OF (SC0310001)	CWS	GW	3882	MR	Monitoring, Source Water (GWR)
Allendale	SC0310001	ALLENDALE TOWN OF (SC0310001)	CWS	GW	3882	MR	Monitoring, Source Water (GWR)
Allendale	SC0320002	ALLENDALE INDUSTRIAL PARK (SC0320002)	CWS	GW	2694	MR	Monitoring, Source Water (GWR)
Bamberg	SC0570900	NORTH AMERICAN FILTRATION CO (SC0570900)	NTNCWS	GW	37	MR	Monitoring, Source Water (GWR)
Berkeley	SC0810003	JAMESTOWN TOWN OF (SC0810003)	CWS	GW	800	MR	M/R (DBP)
Berkeley	SC0850014	O HAYNES SYSTEM (0850014)	CWS	GW	205	MR	Monitoring, Source Water (GWR)
Charleston	SC1010007	LINCOLNVILLE TOWN OF (SC1010007)	CWS	SWP	1980	MR	M/R Residual (DBP)
Charleston	SC1010007	LINCOLNVILLE TOWN OF (SC1010007)	CWS	SWP	1980	MR	Lead Consumer Notice
Charleston	SC1010007	LINCOLNVILLE TOWN OF (SC1010007)	CWS	SWP	1980	MR	Monitoring of Treatment (SWTR)
Charleston	SC1070143	ST JAMES SCHOOL (SC1070143)	NTNCWS	GW	240	MR	Follow-up Or Routine LCR Tap M/R
Charleston	SC1070256	OYSTER PARK POA (SC1070256)	NTNCWS	GW	40	MR	Monitoring, Source Water (GWR)
Charleston	SC1070256	OYSTER PARK POA (SC1070256)	NTNCWS	GW	40	MR	Lead Consumer Notice
Chester	SC1270108	N CHESTER HEADSTART (SC1270108)	NTNCWS	GW	110	MR	Follow-up Or Routine LCR Tap M/R
Clarendon	SC1450002	LAKE MARION SHORES WTR SYS (SC1450002)	CWS	GW	0	MR	M/R Residual (DBP)
Clarendon	SC1450006	SIGFIELD WATER CO INC (SC1450006)	CWS	GW	271	MR	M/R Residual (DBP)
Clarendon	SC1450009	WYBOO WATER DEPT INC (SC1450009)	CWS	GW	618	MR	M/R Residual (DBP)
Clarendon	SC1450013	CLARENDON CO W&S HWY 260 (SC1450013)	CWS	GW	3521	MR	M/R Residual (DBP)
Colleton	SC1510006	EDISTO BEACH TOWN OF (SC1510006)	CWS	GW	5568	MR	Monitoring, Source Water (GWR)
Dillon	SC1770208	SOUTH OF THE BORDER (SC1770208)	NTNCWS	GW	480	MR	Lead Consumer Notice
Dorchester	SC1810001	ST GEORGE TOWN OF (1810001)	CWS	GW	2148	MR	Follow-up Or Routine LCR Tap M/R
Dorchester	SC1820008	DCWS ASHLEY PHOSPHATE (SC1820008)	CWS	SWP	25668	MR	M/R (DBP)
Dorchester	SC1820009	DCWS HIGHWAY 17A (1820009)	NTNC	GWP	50	MR	M/R (DBP)
Dorchester	SC1870902	MIDDLETON PLACE (SC1870902)	NTNCWS	GW	85	MR	Monitoring, Source Water (GWR)
Fairfield	SC2020005	MITFORD WATER DISTRICT (SC2020005)	CWS	SWP	1878	MR	Follow-up Or Routine LCR Tap M/R
Fairfield	SC2070002	RIDGEWAY MANOR (SC2070002)	CWS	GW	158	MR	Lead Consumer Notice
Georgetown	SC2210003	ANDREWS TOWN OF (SC2210003)	CWS	GW	3334	MR	Follow-up Or Routine LCR Tap M/R
Georgetown	SC2220010	GCWSD WACCAMAW NECK (SC2220010)	C	SW	37790	MR	M/R (DBP)
Georgetown	SC2220013	GCWSD CARVERS BAY (SC2220013)	C	GW	3133	MR	M/R (DBP)
Georgetown	SC2230002	INTERFOR (2230002)	NTNCWS	GW	88	MR	Monitoring, Source Water (GWR)
Greenville	SC2350010	BGWC TROLLINGWOOD S/D (SC2350010)	CWS	GW	180	MR	Monitoring, Source Water (GWR)
Greenville	SC2370908	BALD ROCK HOA (SC2370908)	NTNCWS	GW	34	MR	Lead Consumer Notice
Hampton	SC2510004	BRUNSON TOWN OF (SC2510004)	CWS	GW	649	MR	Follow-up Or Routine LCR Tap M/R
Horry	SC2660045	THOMPSONS MHP (SC2660045)	CWS	GW	42	MR	Lead Consumer Notice
Horry	SC2670924	SAM #8 (SC2670924)	TNCWS	GW	25	MR	Monitoring, Source Water (GWR)
Laurens	SC3010003	GRAY COURT TOWN OF (SC3010003)	CWS	SWP	1069	MR	Follow-up Or Routine LCR Tap M/R
Laurens	SC3030005	LAURENS PROVING GROUND (SC3030005)	NTNCWS	GW	48	MR	Lead Consumer Notice
Laurens	SC3050008	RANCH ROAD WATER (SC3050008)	CWS	GW	40	MR	Follow-up Or Routine LCR Tap M/R
Lexington	SC3230005	US SILICA (SC3230005)	NTNCWS	GW	44	MR	Lead Consumer Notice
Lexington	SC3250014	MURRAY HILL ESTATES (SC3250014)	CWS	GW	134	MR	Lead Consumer Notice
Lexington	SC3250017	BGWC IDLEWOOD (SC3250017)	CWS	SWP	134	MR	M/R Residual (DBP)
Lexington	SC3250017	BGWC IDLEWOOD (SC3250017)	CWS	SWP	134	MR	Monitoring of Treatment (SWTR)
Lexington	SC3250020	BGWC INDIAN COVE S/D (SC3250020)	CWS	SWP	92	MR	M/R Residual (DBP)
Lexington	SC3250020	BGWC INDIAN COVE S/D (SC3250020)	CWS	SWP	92	MR	Monitoring of Treatment (SWTR)
Lexington	SC3250021	BGWC DUTCHMAN SHORES (SC3250021)	CWS	SWP	335	MR	M/R Residual (DBP)
Lexington	SC3250021	BGWC DUTCHMAN SHORES (SC3250021)	CWS	SWP	335	MR	Monitoring of Treatment (SWTR)
Lexington	SC3250022	BGWC EMMA TERRACE (SC3250022)	CWS	GW	65	MR	Monitoring, Source Water (GWR)
Lexington	SC3250027	BGWC VANARSDALE S/D (3250027)	CWS	SWP	509	MR	M/R Residual (DBP)
Lexington	SC3250027	BGWC VANARSDALE S/D (3250027)	CWS	SWP	509	MR	Monitoring of Treatment (SWTR)
Lexington	SC3250027	BGWC VANARSDALE S/D (3250027)	CWS	SWP	509	MR	M/R (DBP)
Lexington	SC3250029	BGWC PARKWOOD S/D (3250029)	CWS	SWP	311	MR	M/R Residual (DBP)
Lexington	SC3250029	BGWC PARKWOOD S/D (3250029)	CWS	SWP	311	MR	Monitoring of Treatment (SWTR)
Lexington	SC3250045	BGWC PEACHTREE ACRES (3250045)	CWS	SWP	124	MR	M/R Residual (DBP)
Lexington	SC3250050	BGWC LEXINGTON ESTATES (SC3250050)	CWS	GW	419	MR	Monitoring, Source Water (GWR)
Lexington	SC3250051	BGWC INDIAN PINES (SC3250051)	CWS	SWP	43	MR	M/R Residual (DBP)
Lexington	SC3250051	BGWC INDIAN PINES (SC3250051)	CWS	SWP	43	MR	Monitoring of Treatment (SWTR)
Lexington	SC3250066	BGWC INDIAN FORK-40 LOVE (3250066)	CWS	SWP	367	MR	M/R Residual (DBP)
Lexington	SC3250099	ROCKFORD PLACE-CHARWOOD (3250099)	CWS	GW	174	MR	Follow-up Or Routine LCR Tap M/R
Lexington	SC3250105	RIDGE POINTE S/D (SC3250105)	CWS	GW	170	MR	Lead Consumer Notice
Lexington	SC3260081	SCENIC DRIVE MHP (SC3260081)	CWS	GW	50	MR	Lead Consumer Notice
Lexington	SC3260090	HALTER ACRES MHP (SC3260090)	CWS	GW	90	MR	Follow-up Or Routine LCR Tap M/R
Lexington	SC3260138	SUNNYVALE MHP (SC3260138)	CWS	GW	65	MR	Follow-up Or Routine LCR Tap M/R
Lexington	SC3260147	PLEASANT RIDGE MHP (SC3260147)	CWS	GW	22	MR	Lead Consumer Notice
Lexington	SC3260157	PINE RIDGE MHP (SC3260157)	CWS	GW	100	MR	Lead Consumer Notice

Lexington	SC3260170	REGENCY SQUARE 2 (SC3260170)	CWS	GW	99	MR	Follow-up Or Routine LCR Tap M/R
Lexington	SC3260187	COUNTRY PARK (SC3260187)	CWS	GW	36	MR	Lead Consumer Notice
Lexington	SC3260207	HIDDEN ACRES MHP (SC3260207)	CWS	GW	74	MR	Monitoring, Source Water (GWR)
Lexington	SC3270011	RAPHA RESIDENTIAL CARE (3270011)	CWS	GW	69	MR	Follow-up Or Routine LCR Tap M/R
Lexington	SC3270301	LAKE LODGE APARTMENTS (3270301)	CWS	GW	130	MR	Lead Consumer Notice
Lexington	SC3270304	BOARDWALK VILLA (SC3270304)	CWS	GW	104	MR	Follow-up Or Routine LCR Tap M/R
Lexington	SC3270304	BOARDWALK VILLA (SC3270304)	CWS	GW	104	MR	Follow-up Or Routine LCR Tap M/R
Lexington	SC3270802	SIESTA COVE RV PARK MARINA (SC3270802)	CWS	GW	40	MR	Follow-up Or Routine LCR Tap M/R
Lexington	SC3279014	SHIV MART #4 (3279014)	TNCWS	GW	27	MR	Monitoring, Source Water (GWR)
Newberry	SC3670108	BOYS FARM INC (SC3670108)	CWS	GW	40	MR	Monitoring, Source Water (GWR)
Newberry	SC3670108	BOYS FARM INC (SC3670108)	CWS	GW	40	MR	Monitoring, Source Water (GWR)
Newberry	SC3670108	BOYS FARM INC (SC3670108)	CWS	GW	40	MR	Lead Consumer Notice
Oconee	SC3750027	BAY RIDGE S/D (SC3750027)	C	GW	62	MR	M/R (DBP)
Orangeburg	SC3810003	ELLOREE WATER SYSTEM (SC3810003)	CWS	GW	1498	MR	Monitoring, Source Water (GWR)
Orangeburg	SC3810008	NORWAY TOWN OF (3810008)	CWS	SWP	775	MR	Follow-up Or Routine LCR Tap M/R
Orangeburg	SC3820002	SILVER SPRINGS W/D (SC3820002)	CWS	SWP	2536	MR	Monitoring, Source Water (GWR)
Orangeburg	SC3870116	WRIGHT WAY CDC - VANCE (SC3870116)	NTNCWS	GW	25	MR	Monitoring, Source Water (GWR)
Pickens	SC3910004	CLEMSON CITY OF (SC3910004)	CWS	SWP	17896	MR	Follow-up Or Routine LCR Tap M/R
Pickens	SC3950005	RIVER BLUFF S/D (SC3950005)	CWS	GW	133	MR	Lead Consumer Notice
Pickens	SC3950007	ROCK POINT HOA (SC3950007)	CWS	GW	70	MR	Lead Consumer Notice
Pickens	SC3950007	ROCK POINT HOA (SC3950007)	C	GW	70	MR	M/R (DBP)
Pickens	SC3950008	GAULEY FALLS 2 4 5 6 (SC3950008)	CWS	GW	23	MR	Follow-up Or Routine LCR Tap M/R
Pickens	SC3950009	CLIFFS AT KEOWEE (SC3950009)	CWS	SWP	23	MR	Lead Consumer Notice
Pickens	SC3970300	TABLE ROCK RESORT (SC3970300)	CWS	GW	33	MR	Lead Consumer Notice
Pickens	SC3970303	CRAWFORD EDGE (SC3970303)	C	SWP	552	MR	M/R (DBP)
Richland	SC4050012	BGWC FARROWWOOD ESTATES (SC4050012)	CWS	SWP	356	MR	M/R Residual (DBP)
Richland	SC4050012	BGWC FARROWWOOD ESTATES (SC4050012)	CWS	SWP	356	MR	Monitoring of Treatment (SWTR)
Richland	SC4050014	BGWC STONEGATE (SC4050014)	CWS	SWP	352	MR	M/R Residual (DBP)
Richland	SC4060005	FREEWAY MHP (SC4060005)	CWS	GW	80	MR	Lead Consumer Notice
Richland	SC4060006	PALMETTO PARK (4060006)	CWS	GW	132	MR	Monitoring, Source Water (GWR)
Richland	SC4060008	WINSOR VALLEY MHP (SC4060008)	CWS	GW	68	MR	Monitoring, Source Water (GWR)
Richland	SC4060009	BELAIRE MHP (SC4060009)	CWS	GW	34	MR	Monitoring, Source Water (GWR)
Richland	SC4060009	BELAIRE MHP (SC4060009)	CWS	GW	34	MR	Follow-up Or Routine LCR Tap M/R
Richland	SC4060019	SILVER HILL MANUF HOME COMM. (SC4060019)	CWS	GW	180	MR	Monitoring, Source Water (GWR)
Richland	SC4060019	SILVER HILL MANUF HOME COMM. (SC4060019)	CWS	GW	180	MR	Lead Consumer Notice
Richland	SC4060024	PINE VALLEY COMMUNITY (SC4060024)	CWS	GW	21	MR	Monitoring, Source Water (GWR)
Richland	SC4060035	CEDAR CREEK MHP (4060035)	CWS	GW	26	MR	Follow-up Or Routine LCR Tap M/R
Richland	SC4060038	BEVERLY HILLS INC (SC4060038)	CWS	GW	64	MR	Lead Consumer Notice
Richland	SC4060052	PINEY LANE MHP (SC4060052)	CWS	GW	32	MR	Monitoring, Source Water (GWR)
Sumter	SC4320003	HIGH HILLS RURAL WATER CO INC (4320003)	CWS	GW	12545	MR	Lead Consumer Notice
Williamsburg	SC4510002	KINGSTREE TOWN OF (SC4510002)	CWS	GW	6009	MR	Monitoring, Source Water (GWR)
Williamsburg	SC4510002	KINGSTREE TOWN OF (SC4510002)	CWS	GW	6009	MR	Monitoring, Source Water (GWR)
Williamsburg	SC4550001	BGWC ROCK BLUFF S/D (4550001)	C	GW	45	MR	M/R (DBP)
York	SC4610005	SHARON TOWN OF (SC4610005)	CWS	GW	573	MR	Follow-up Or Routine LCR Tap M/R
York	SC4650015	PINETUCK S/D (SC4650015)	TNCWS	GW	33	MR	Follow-up Or Routine LCR Tap M/R
York	SC4650042	BGWC OLD FARM (SC4650042)	C	GW	50	MR	M/R (DBP)
York	SC4660003	PECAN GROVE COMMONS (SC4660003)	CWS	GW	58	MR	Follow-up Or Routine LCR Tap M/R
York	SC4660003	PECAN GROVE COMMONS (SC4660003)	CWS	GW	58	MR	Follow-up Or Routine LCR Tap M/R
York	SC4660008	MCAFEES MHP (4660008)	CWS	GW	45	MR	Follow-up Or Routine LCR Tap M/R
York	SC4660008	MCAFEES MHP (4660008)	CWS	GW	45	MR	Follow-up Or Routine LCR Tap M/R
York	SC4660009	CEDAR VALLEY MHP (SC4660009)	CWS	GW	290	MR	Lead Consumer Notice
York	SC4660055	WHITLEY ESTATES (4660055)	CWS	GW	93	MR	Lead Consumer Notice
York	SC4660077	CHUCKS MHP (SC4660077)	CWS	GW	168	MR	Monitoring, Source Water (GWR)
York	SC4660077	CHUCKS MHP (SC4660077)	CWS	GW	168	MR	Monitoring, Source Water (GWR)
York	SC4660077	CHUCKS MHP (SC4660077)	CWS	GW	168	MR	Lead Consumer Notice
York	SC4660112	FOREST ESTATES MHP (SC4660112)	CWS	GW	40	MR	Lead Consumer Notice
York	SC4670120	BETHESDA PRSBYTRN CHILDRN PLANT (4670120)	NTNCWS	GW	100	MR	Follow-up Or Routine LCR Tap M/R
Abbeville	SC0110002	CALHOUN FALLS TOWN OF (SC0110002)	CWS	SWP	2473	Other	Consumer Confidence Report Complete Failure to Report
Aiken	SC0210005	SALLEY TOWN OF (SC0210005)	CWS	GW	456	Other	Consumer Confidence Report Complete Failure to Report
Allendale	SC0310001	ALLENDALE TOWN OF (SC0310001)	CWS	GW	3882	Other	Consumer Confidence Report Complete Failure to Report
Allendale	SC0310004	FAIRFAX TOWN OF (SC0310004)	CWS	GW	1962	Other	Consumer Confidence Report Complete Failure to Report
Bamberg	SC0510004	OLAR GOVAN WATER SYSTEM (0510004)	CWS	GW	257	Other	Consumer Confidence Report Complete Failure to Report
Barnwell	SC0610002	WILLISTON TOWN OF (SC0610002)	CWS	GW	3251	Other	Consumer Confidence Report Complete Failure to Report
Barnwell	SC0610003	BLACKVILLE TOWN OF (SC0610003)	CWS	GW	1925	Other	Consumer Confidence Report Complete Failure to Report

Charleston	SC1070103	CCSD LINCOLN HIGH CAMPUS (SC1070103)	NTNCWS	GW	350	Other	Public Notification Violation for NPDWR Violation
Clarendon	SC1410003	SUMMERTON TOWN OF (SC1410003)	CWS	GW	2096	Other	Consumer Confidence Report Complete Failure to Report
Clarendon	SC1450005	GIN POND SHORES WATER CO (SC1450005)	CWS	GW	72	Other	Consumer Confidence Report Complete Failure to Report
Clarendon	SC1450006	SIGFIELD WATER CO INC (SC1450006)	CWS	GW	271	Other	Consumer Confidence Report Complete Failure to Report
Clarendon	SC1470863	NORTH SHORE WATER SYS (SC1470863)	CWS	GW	272	Other	Consumer Confidence Report Complete Failure to Report
Colleton	SC1510006	EDISTO BEACH TOWN OF (SC1510006)	CWS	GW	5568	Other	Consumer Confidence Report Complete Failure to Report
Colleton	SC1550002	FISHING CREEK POA (SC1550002)	CWS	GW	98	Other	Consumer Confidence Report Complete Failure to Report
Darlington	SC1610001	DARLINGTON CITY OF (SC1610001)	CWS	GW	7204	Other	Consumer Confidence Report Complete Failure to Report
Darlington	SC1610003	HARTSVILLE CITY OF (SC1610003)	CWS	GW	8655	Other	Consumer Confidence Report Complete Failure to Report
Dorchester	SC1810001	ST GEORGE TOWN OF (1810001)	CWS	GW	2148	Other	Consumer Confidence Report Complete Failure to Report
Fairfield	SC2020001	JENKINSVILLE WATER COMPANY (SC2020001)	CWS	GW	2550	Other	Consumer Confidence Report Complete Failure to Report
Georgetown	SC2210003	ANDREWS TOWN OF (SC2210003)	CWS	GW	3334	Other	Consumer Confidence Report Complete Failure to Report
Hampton	SC2510008	SCOTIA TOWN OF (SC2510008)	CWS	GW	161	Other	Consumer Confidence Report Complete Failure to Report
Horry	SC2610011	N MYRTLE BEACH CITY OF (SC2610011)	CWS	SWP	40625	Other	Consumer Confidence Report Complete Failure to Report
Horry	SC2660045	THOMPSON MHP (SC2660045)	CWS	GW	42	Other	Consumer Confidence Report Complete Failure to Report
Jasper	SC2760013	PALMETTO MHP 2 (SC2760013)	CWS	GW	48	Other	Consumer Confidence Report Complete Failure to Report
Lexington	SC3260027	ROLLING MEADOWS MHP (3260027)	CWS	GW	1056	Other	Consumer Confidence Report Complete Failure to Report
Lexington	SC3260090	HALTER ACRES MHP (SC3260090)	CWS	GW	90	Other	Consumer Confidence Report Complete Failure to Report
Lexington	SC3260132	CHAPPEL MHP (3260132)	CWS	GW	0	Other	Consumer Confidence Report Complete Failure to Report
Lexington	SC3260138	SUNNYVALE MHP (SC3260138)	CWS	GW	65	Other	Consumer Confidence Report Complete Failure to Report
Lexington	SC3260147	PLEASANT RIDGE MHP (SC3260147)	CWS	GW	22	Other	Consumer Confidence Report Complete Failure to Report
Lexington	SC3260182	MIDLAND HILLS MHP (SC3260182)	CWS	GW	66	Other	Consumer Confidence Report Complete Failure to Report
Lexington	SC3260187	COUNTRY PARK (SC3260187)	CWS	GW	36	Other	Consumer Confidence Report Complete Failure to Report
Lexington	SC3270011	RAPHA RESIDENTIAL CARE (3270011)	CWS	GW	69	Other	Consumer Confidence Report Complete Failure to Report
McCormick	SC3510001	MCCORMICK CPW (3510001)	CWS	SW	1818	Other	Consumer Confidence Report Complete Failure to Report
Oconee	SC3750022	TURTLEHEAD AT KEOWEE S/D (SC3750022)	CWS	GW	32	Other	Consumer Confidence Report Complete Failure to Report
Orangeburg	SC3810006	EUTAWVILLE TOWN OF (3810006)	CWS	GW	555	Other	Consumer Confidence Report Complete Failure to Report
Orangeburg	SC3870116	WRIGHT WAY CDC - VANCE (SC3870116)	NTNCWS	GW	25	Other	Public Notification Violation for NPDWR Violation
Richland	SC4060001	CRESTHAVEN MHP (SC4060001)	CWS	GW	37	Other	Consumer Confidence Report Complete Failure to Report
Richland	SC4060009	BELAIRE MHP (SC4060009)	CWS	GW	34	Other	Consumer Confidence Report Complete Failure to Report
Richland	SC4060014	MEADOW LANE MHP (SC4060014)	CWS	GW	35	Other	Consumer Confidence Report Complete Failure to Report
Richland	SC4060038	BEVERLY HILLS INC (SC4060038)	CWS	GW	64	Other	Consumer Confidence Report Complete Failure to Report
Richland	SC4060052	PINEY LANE MHP (SC4060052)	CWS	GW	32	Other	Consumer Confidence Report Complete Failure to Report
Saluda	SC4160011	RICHARD DEASON MHP (SC4160011)	CWS	GW	55	Other	Consumer Confidence Report Complete Failure to Report
Sumter	SC4310002	PINEWOOD TOWN OF (SC4310002)	CWS	GW	455	Other	Consumer Confidence Report Complete Failure to Report
Sumter	SC4320003	HIGH HILLS RURAL WATER CO INC (4320003)	CWS	GW	12545	Other	Consumer Confidence Report Complete Failure to Report
Union	SC4410002	JONESVILLE TOWN OF (SC4410002)	CWS	SWP	1909	Other	Consumer Confidence Report Complete Failure to Report
York	SC4620002	YORK COUNTY EAST WD (SC4620002)	CWS	SWP	30225	Other	Consumer Confidence Report Complete Failure to Report
York	SC4620003	YORK COUNTY WEST WD (SC4620003)	CWS	SWP	18273	Other	Consumer Confidence Report Complete Failure to Report
York	SC4660045	WATERLYNN DOWNS (SC4660045)	CWS	GW	92	Other	Consumer Confidence Report Complete Failure to Report
York	SC4660064	GLEN AT CLOVER LLC THE (SC4660064)	CWS	GW	215	Other	Consumer Confidence Report Complete Failure to Report
York	SC4660077	CHUCKS MHP (SC4660077)	CWS	GW	168	Other	Consumer Confidence Report Complete Failure to Report
York	SC4660111	HENSON MHP (4660111)	CWS	GW	65	Other	Consumer Confidence Report Complete Failure to Report
Abbeville	SC0110001	ABBEVILLE CITY OF (0110001)	CWS	SW	5771	TT	TT No Certif. Operator
Abbeville	SC0110001	ABBEVILLE CITY OF (0110001)	CWS	SW	5771	TT	TT No Certif. Operator
Berkeley	SC0870851	HILLS LANDING (SC0870851)	TNCWS	GW	26	TT	Treatment Technique, Level 2 Assessment (BTR)
Colleton	SC1560002	EAGLES RV CAMPGROUND (SC1560002)	TNCWS	GW	26	TT	Treatment Technique, Level 2 Assessment (BTR)
Lexington	SC3250024	HILTON SOUND (SC3250024)	CWS	GW	50	TT	WQP Entry Point/Tap Treatment Technique Non-Compliance (BTR)
Lexington	SC3270304	BOARDWALK VILLA (SC3270304)	CWS	GW	104	TT	Treatment Technique, Level 1 Assessment (BTR)
Orangeburg	SC3870116	WRIGHT WAY CDC - VANCE (SC3870116)	NTNCWS	GW	25	TT	Treatment Technique, Level 1 Assessment (BTR)
Richland	SC4050019	BGWC OAKRIDGE HUNT CLUB (SC4050019)	CWS	GW	208	TT	WQP Entry Point/Tap Treatment Technique Non-Compliance