



Catherine B. Templeton, Director

Promoting and protecting the health of the public and the environment

June 19, 2013

Patricia M Allen
SAVANNAH RIVER REMEDIATION
BLDG 766-H RM 2308
Aiken, SC 29808

Re: Construction Permit No. 19673-IW
USDOE/SRS/AIKEN/H-BASIN DISCHARGE TIE-IN TO ETP TREATED WATER LINE
Aiken County

Dear Ms. Allen:

Enclosed is a SC Wastewater Construction Permit for the above referenced project. Construction is to be performed in accordance with this permit and supporting engineering report, plans, and specifications approved by this Office.

This system cannot be placed into operation until final approval is granted by the appropriate Bureau of Environmental Health Services (BEHS) Regional Office. Your Regional contact is Joshua C Yon, in the MIDLANDS REGION BEHS AIKEN. This regional office should be notified when construction begins at the following address and phone number: 206 BEAUFORT ST NE, AIKEN SC 29801-4476, 803-642-1637.

Upon completion of any construction, a letter must be submitted to the BEHS Regional Office from the registered engineer certifying that the construction has been completed in accordance with the approved plans and specifications. An inspection may then be scheduled. The BEHS Regional Office will approve the system for operation upon successful completion of this project.

Sincerely,

Melinda G Vickers
Industrial Wastewater Permitting Section
Water Facilities Permitting Division

ec: Joshua C Yon, MIDLANDS REGION BEHS AIKEN
Paul Wise, BOW Enforcement

Wastewater Construction Permit Bureau of Water



PROJECT NAME: USDOE/SRS/AIKEN/H-BASIN DISCHARGE TIE-IN TO ETP TREATED WATER LINE

COUNTY: AIKEN

**PERMISSION IS HEREBY GRANTED TO: Savannah River Remediation
Bldg 766-H Rm 2308
Aiken SC 29808**

for the construction of an upgrade to an existing wastewater treatment plant in accordance with the construction plans, specifications, engineering report and the Construction Permit Application signed by Michael B. Wood PE, Registered Professional Engineer, S.C. Registration Number: 22845.

PROJECT DESCRIPTION: Connection of piping to allow 281-8H Basin water to discharge through the Effluent Treatment Project (ETP) treated water line. Existing pumps will be used to transfer water with the addition of approximately 12 feet of 4-inch carbon steel piping, 2 feet of 6-inch carbon steel piping, 50 feet of 6-inch stainless steel piping, 20 feet of 6-inch polyethylene piping and associated backflow preventers, valves and appurtenances.

The effluent will be discharged to Upper Three Runs Creek at a daily average rate of 432,000 gallons per day.


The effluent concentrations of those constituents the wastewater treatment system is designed to remove or reduce are contained in NPDES Permit #SC0000175.

Conditions: 1. The permittee shall provide for the performance of routine collection system inspections. The inspection should include, but is not limited to, areas which require a visual observation to determine efficient operations and for which immediate corrective measures can be taken.

2. In accordance with Regulation 61-67, Standards for Wastewater Facility Construction, all wastewater treatment facilities shall be closed out within one hundred eighty (180) days when the facility is closed or the effluent disposal permit is inactivated, terminated or revoked, unless otherwise determined by the Department. Closure of wastewater treatment facilities necessitates the submittal of a closure plan and approval of the plan by the Department in accordance with R.61-82 prior to closure of any wastewater treatment unit(s).

In accepting this permit, the owner agrees to the admission of properly authorized persons at all reasonable hours for the purpose of sampling and inspection. This is a permit for construction only and does not constitute DHEC approval, temporary or otherwise, to place the system in operation. An Approval to Place in Operation is required and can be obtained following the completion of construction by contacting the AIKEN EQC OFFICE at 803-641-7670. Additional permits may be required prior to construction (e.g., Stormwater).

PERMIT NUMBER:	19673-IW
ISSUANCE DATE:	June 19, 2013
EXPIRATION DATES:	June 19, 2015 (to begin construction) June 19, 2016 (to obtain Approval to Place in Operation)


Jeffrey P. deBessonet, P.E., Director
Water Facilities Permitting Division

MGV



Construction Permit Application Water/Wastewater Facilities

BUREAU OF WATER

DELEGATED REVIEW PROJECT SUBMITTAL: Yes EXPEDITED REVIEW PROGRAM SUBMITTAL: Yes
SELECT ONE Water Facilities Wastewater Facilities Combined Water & Wastewater Facilities

I. **Project Name:** H-Basin Discharge Tie-In to ETP Treated Water Line County: Aiken

II. **Project Location** (street names, etc.): Savannah River Site, Aiken, South Carolina

III. **Project Description(s):** Water System:

RECEIVED
JUN 14 2013
WATER FACILITIES PERMITTING DIVISION

Wastewater System: Connection of piping to allow discharge of 281-8H Basin water through the Effluent Treatment Project (ETP) treated water line (Construction Permit No.:18,833-IW) and the ETP diffuser (Construction Permit No.:14,379) to an Outfall (currently, the location of H-16 under NPDES Permit No.: SC0000175).

Project Type (A-Z): Water: Wastewater: Z (See instructions for the appropriate project code)

IV. **Initial Owner:** [Time of Application] Name/Organization: USDOE-Owner/Savannah River Remediation(SRR) Operator
Address: Bldg 766-H Rm 2308 (Attn.: P.M. Allen) City: Aiken State: SC Zip: 29808

Phone #: (803) 208-3152 E-mail (Initial Owner): patricia.allen@srs.gov

V. **Final Owner:** [After Construction] Name/Organization: Same As Initial Owner Above

Address: Bldg 766-H Rm 2308 (ATTN.: P.M. Allen) City: Aiken State: SC Zip: 29808

Phone #: (803) 208-3152 E-mail (Final Owner): patricia.allen@srs.gov

VI. **Entity Responsible for Final Operation & Maintenance of System:**

Water System: Name: _____ Address: _____

City: _____ State: _____ Zip: _____ Phone #: () _____ Fax #: () _____

Wastewater System: Name: USDOE-Owner / SRR-Operator Address: Bldg 766-H Rm 2309; Attn. P.M. Allen

City: Aiken State: SC Zip: 29808 Phone #: (803) 208-3152 Fax #: (803) 208-1248

VII. **Engineering Firm:** Name: _____ Address: _____

City: _____ State: _____ Zip: _____ Phone #: () _____ Fax #: () _____

E-mail (Design Engineer): _____

VIII. **Is this project:** A) Part of a phased project? No Yes . If Yes, Phase _____ of _____

B) A revision to a previously permitted project? No Yes . If Yes, Permit #: 18,833-IW and 14379

Date Approved: 12/12/2003 Project name (if different): F/H-Area Effluent Treatment Project Facility

C) Submitted based on a Schedule of Compliance or Order issued by DHEC? No Yes . Order #: _____

D) Anticipating funding by the State Revolving Fund (SRF)? No Yes .

E) Crossing a water body (e.g., river, creek)? No Yes . If Yes, Name of water body: _____

IX. **Are Standard Specifications approved by DHEC being used on this project?** No Yes . If Yes:

Water: Date Approved: _____ Approved for whom: _____

Wastewater: Date Approved: _____ Approved for whom: _____

X. **Wastewater Systems:** A) Type: Domestic Process (Industrial) Combined (Domestic & Process)

B) Average Design Flow 1. Project: 432,000 GPD 2. Treatment system: _____ GPD

C) Sewers or Pretreatment 1. Name of facility (e.g., POTW) treating the wastewater: _____

2. NPDES/ND Number of facility in Item #1: _____

Treatment Systems 3. Date Preliminary Engineering Report (PER) approved: _____

4. NPDES/ND application submitted? No Yes . If Yes, Date: _____

Disposal Sites 5. Effluent Disposal Site (Description): NPDES Permit No.: SC0000175 as amended

6. Sludge Disposal Site (Description): _____

XI. **Water Systems:** Project located within city limits? No Yes .

Public water system providing water. Name: _____ System #: _____

New water system (including master meter)? No Yes . If Yes, System name: _____

XII. **Type of Submittal:** Complete Section A (Standard) or Section B (Delegated Review Program - DRP).

A) Standard Submittal *must* include the following:

- 1. A transmittal letter outlining the submittal package.
- 2. The original construction permit application, properly completed, with one (1) copy.
- 3. Three (3) sets of signed and sealed plans and one (1) set of construction specifications. Specifications may be omitted if approved standard specifications are on file with DHEC. Four (4) sets of plans are required for a combined submittal, if the project includes a wastewater treatment facility.
- 4. One (1) set of the appropriate design calculations. **WASTEWATER:** Design flow (based on R.61-67, Appendix A), pump station calc's. and pump curve. **WATER:** Recent flow test from a location near the tie-on site, design calc's. indicating pressure maintained in the distribution system during max. instantaneous demand, fire flow and flushing velocities achieved. Number/types of service connections, well record form, pumping test results, etc.
- 5. Three (3) copies of a detailed 8 1/2" x 11" location map, separate from the plans.
- 6. Two (2) copies of construction easements unless the project owner has the right of eminent domain.
- 7. A letter(s) from the entity supplying water and/or providing wastewater treatment stating their willingness and ability to serve the project, (state the flow, number of lots, etc.), including pretreatment permits, if applicable.
- 8. A letter(s) from the entity agreeing to be responsible for the operation and maintenance (O&M) of the systems.
- 9. Application fee enclosed \$ 400.00. (Refer to Instructions).
- 10. **WATER SYSTEMS:** a) A letter from the local government which has potable water planning authority over the area, if applicable, in which the project is located, stating project consistency with water supply service plan for area. b) For wells, four (4) copies of a wellhead protection area inventory. c) For new wells, a viability demonstration is required in accordance with Regulation 61-58.1.B.(4).

Note: Other approvals may include 208 (wastewater only) and OCRM certification, and navigable waterway permitting. To expedite the project review, the 208 and OCRM certification may be included with the project submittal.

B) DRP submittal *must* include the following:

- 1. A transmittal letter, signed by the professional engineer representing the DRP entity, noting this is a DRP submittal. The letter should state that the project has been reviewed and complies with R.61-58 and/or R.61-67.
- 2. The original construction permit application, properly completed, with one (1) copy.
- 3. Two (2) sets of the signed and sealed plans.
- 4. One (1) set of the appropriate design calculations. **WASTEWATER:** Same information as required under Section XII.A.4. above. **WATER:** Same information as required under Section XII.A.4. above.
- 5. One (1) copy of a detailed 8 1/2" x 11" location map, separate from the plans.
- 6. Two (2) copies of construction easements, unless the project owner has the right of eminent domain.
- 7. DHEC's Ocean and Coastal Resource Management certification (for projects in applicable counties).
- 8. DHEC's Water Quality permit or conditions for placement in navigable waters, and other Agency approvals.
- 9. **WASTEWATER SYSTEMS:** a) A letter of acceptance from the entity providing the treatment of the wastewater that includes the specific flow and, when applicable, the specific number of lots being accepted. b) A letter from the organization agreeing to be responsible for the O&M of the wastewater system. c) The 208 Plan certification from the appropriate Council of Governments (designated 208 areas), or from DHEC on the non-designated 208 areas.
- 10. **WATER SYSTEMS:** A letter from the local government which has potable water planning authority over the area, if applicable, in which the project is located, stating project consistency with water supply service plan for area.
- 11. Fee of \$75 for water and \$75 for wastewater (\$150 if combined).

Note: The DRP entity should ensure that a copy of the final approved plans are returned to the design engineer.

XIII. Construction plans, material and construction specifications, the engineering report including supporting design data and calculations are herewith submitted and made a part of this application. I have placed my signature and seal on the engineering documents submitted, signifying that I accept responsibility for the design of this system, and that I have submitted a complete administrative package.

Engineer's Name (Printed): Michael B. Wood, P.E. Signature: Michael B. Wood 6.5.13
S.C. Registration Number: 22845


XIV. Prior to final approval, I will submit a statement certifying that construction is complete and in accordance with the approved plans and specifications, to the best of my knowledge, information and belief. This certification will be based upon periodic observations of construction and a final inspection for design compliance by me or a representative of this office who is under my supervision.

Engineer's Name (Printed): Andrew R. Redwood, P.E. Signature: Andrew R. Redwood 6/10/13
S.C. Registration Number: 20525

XV. I hereby make application for a permit to construct the project as described above and have read this application and agree to the requirements and conditions and agree to the admission of properly authorized persons at all reasonable hours for the purpose of sampling and inspection.

Owner's Name (Printed): Patricia M. Allen Signature: Patricia M. Allen
Owner's Title: Manager ESH&QA&CA Date: 6/11/13

ON BEHALF OF DOE, APPLICANT FOR





Vickers, Melinda <vickermg@dhec.sc.gov>

Re: SRS H Retention Basin Treated Water Line Modification Permit Application (U)

1 message

keith.liner@srs.gov <keith.liner@srs.gov>
To: "Vickers, Melinda" <vickermg@dhec.sc.gov>
Cc: Owen.Stevens@srs.gov, stuart.stinson@srs.gov

Mon, Jun 10, 2013 at 1:50 PM

Melinda,
Thanks so much for the input. I will get the engineers working on the changes.

Attachment 9.3, page 12, is intended to be an equipment list and is similar to your request for a list of components. Will this work for you?

The flow number is based on the maximum flow from the NPDES Permit. Please let me know if this is a problem.

Hope you are feeling better.

Have a nice day!

From: "Vickers, Melinda" <vickermg@dhec.sc.gov>
To: keith.liner@srs.gov,
Cc: Owen.Stevens@srs.gov, stuart.stinson@srs.gov
Date: 06/10/2013 01:06 PM
Subject: Re: SRS H Retention Basin Treated Water Line Modification Permit Application (U)

Keith,

I got your voice mail but I have been out of the office sick for the past few days. I am working from home some today.

Crystal and I discussed your new email drawings and agreed you also need PE stamps on pages 34-41.

You have also changed or used another PE to stamp everything. This will necessitate you changing the PE on the construction permit application. The new PE needs to sign the certification statement on the permit application.

It would be helpful to me if you would summarize a list of all components being added as follows as an example:

- _____ linear feet 6-inch carbon steel pipe
- _____ linear feet 6-inch concrete lined pipe

___hp pump
associated valves and appurtenances

I have begun review of the project technically. Can you explain how you arrived at 432,000 gpd for the design flow? It is not clear to me from your calculations how this flow was determined.

Contact me if you have questions. I will be checking my voice mail messages and emails.

Melinda G. Vickers
Industrial Wastewater Permitting Section
Bureau of Water
SC Department of Health and Environmental Control
2600 Bull Street
Columbia, SC 29201
803-898-4186
803-898-4215 new FAX #

On Thu, Jun 6, 2013 at 8:27 AM, <keith.liner@srs.gov> wrote:

Melinda,
Sorry that we have not been able to connect via phone.

Attached is a Draft of the H Retention Basin Treated Water Line Modification Engineering Report. The Professional Engineer (PE) has stamped the Report. Can you please review the Draft to see if the PE's stamps meet SCDHEC's requirements?

Thanks and have a nice day!



Vickers, Melinda <vickermg@dhec.sc.gov>

Re: DOE SRS Corrective Action Plan for Copper Exceedences

1 message

Vickers, Melinda <vickermg@dhec.sc.gov>

Tue, Jun 11, 2013 at 12:59 PM

To: "Wise, Paul" <wisepf@dhec.sc.gov>

Cc: "Hughes, Jennifer R." <hughesjr@dhec.sc.gov>, "Rippy, Crystal" <rippycd@dhec.sc.gov>, "Hindman, Melanie" <hindmamh@dhec.sc.gov>

I have and am reviewing the construction permit application for the tie-in of the 281-8H basin to the H-16 outfall line (Item #7 in their letter).

I have no comments on anything else in the report.

Melinda G. Vickers
Industrial Wastewater Permitting Section
Bureau of Water
SC Department of Health and Environmental Control
2600 Bull Street
Columbia, SC 29201
803-898-4186
803-898-4215 new FAX #

On Tue, Jun 11, 2013 at 9:47 AM, Wise, Paul <wisepf@dhec.sc.gov> wrote:

Please advise if you have comments on the attached CAP.

Thanks - Paul

-

Paul F. Wise
SCDHEC
2600 Bull St
Columbia, SC 29201
(803) 898-4181
(803) 898-4215 (fax)

The information in this email is confidential and may be legally privileged. It is intended solely for the addressee. Access to this email by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying or distribution or any action taken or omitted in reliance on it is prohibited and may be unlawful.



Catherine B. Templeton, Director

Promoting and protecting the health of the public and the environment

RECEIVED
MAY 08 2013
WATER FACILITIES
PERMITTING DIVISION

MEMORANDUM

April 30, 2013

TO: Joshua C Yon
MIDLANDS REGION BEHS AIKEN

FROM: Crystal D Rippy
Industrial Wastewater Permitting Section
Water Facilities Permitting Division

RE: Construction Permit Application
USDOE/ SRS/ AIKEN/ H-BASIN DISCHARGE TIE-IN TO ETP
Aiken County

Are there any problems or comments which you have on the referenced project? Copies of the application and location map are enclosed.

Please return any comments that you may have by: May 10, 2013. An e-mail response is suitable if you prefer. If you have no comments, please just note so. Thanks.

COMMENTS:

No specific concerns

Josh Yon
Aiken EQC Office



Vickers, Melinda <vickermg@dhec.sc.gov>

Re: H Retention Basin Treated Water Line Modification (U)

1 message

Vickers, Melinda <vickermg@dhec.sc.gov>

Thu, Apr 25, 2013 at 10:58 AM

To: keith.liner@srs.gov

Cc: "Wilson, Shelly" <wilsonmd@dhec.sc.gov>, Crystal Rippy <rippyd@dhec.sc.gov>

We received the permit application and check you submitted on 4/19/13. It is being processed for completeness and entry into our system. If you have questions, contact me or Crystal Rippy.

A technical review has not yet begun.

Melinda G. Vickers
Industrial Wastewater Permitting Section
Bureau of Water
SC Department of Health and Environmental Control
2600 Bull Street
Columbia, SC 29201
803-898-4186
803-898-4215 new FAX #

On Fri, Apr 12, 2013 at 11:04 AM, <keith.liner@srs.gov> wrote:

Melinda,

Hope you are having a good week.

Attached is the H Retention Basin Treated Water Line Industrial Wastewater Construction Permit Application that we discussed earlier. I have put three copies into the mail to you along with a check. Please let me know if you have any questions.

Have a great day!
Keith Liner
803-208-6466

BOARD:
Allen Amsler
Chairman
Mark S. Lutz
Vice Chairman



Catherine B. Templeton, Director

Promoting and protecting the health of the public and the environment

BOARD:
R. Kenyon Wells
L. Clarence Batts, Jr.
Ann B. Kirol, DDS
John O. Hutto, Sr., MD

BUREAU OF WATER

April 30, 2013

SURENDRA K GUPTA PE
US DEPT OF ENERGY SAVANNAH RIVER SITE
BLDG 766-H RM 2308
AIKEN SC 29808

Re: **USDOE/ SRS/ AIKEN/ H-BASIN DISCHARGE TIE-IN TO ETP**
Aiken County
Application Tracking # 1053243

Dear Mr. Gupta:

The Industrial Wastewater Permitting section received an engineering submittal on the above project on 04/19/2013. In accordance with R.61-30 we have reviewed your application for completeness. Based on our review, your project application package is administratively incomplete. For this reason, your project will not be in line for a technical review until you satisfy the deficiencies noted below. As a courtesy, we have logged in your project and will keep it here pending your complete response. To complete your application package, please provide the following items:

1. A SC-registered PE must sign and seal and date all plans and design drawings and the Certificate of Authorization (COA) from the engineering firm must also be affixed near the PE seal. Please resubmit these documents with the appropriate seals. Please note: Each page of design drawings or plans must include the COA and the PE seal/signature with the date regardless of whether or not they are in a bound document that is signed, sealed, dated, and affixed with the COA.

Please return the above noted items as soon as possible. Failure to submit these items will result in significant delays in the review process.

Also, please note that any land clearing activity that is being performed in relation to this project must be permitted under the State Sediment and Erosion Control Program. For more information contact Ann Clark at (803) 898-4028.

If you have any questions, please do not hesitate to contact this office at 803-898-4300.

Sincerely,

Linda S Harrell
Industrial Wastewater Permitting Section
Water Facilities Permitting Division

BOARD:
Allen Amsler
Chairman
Mark S. Lutz
Vice Chairman



Catherine B. Templeton, Director

Promoting and protecting the health of the public and the environment

BOARD:
R. Kenyon Wells
L. Clarence Batts, Jr.
Ann B. Kirol, DDS
John O. Hutto, Sr., MD

April 30, 2013

TO: Anne Rone McGovern – 208 Planning Contact

SUBJECT: 208 plan conformance (INFORMATION ONLY)
Recommendation NOT required

1. Project Name: USDOE/ SRS/ AIKEN/ H-BASIN DISCHARGE TIE-IN TO ETP
2. County: Aiken
3. Type of Project: WWC WWTP UPGRADE (QUALITY) -
4. Type Waste: Volume (GPD): 0
5. Disposal Method: US DOE/SAVANNAH RIVER SITE (NPDES SC0000175)
6. Consulting Engineer: US DEPT OF ENERGY SAVANNAH RIVER SITE/SURENDRA K GUPTA PE 803-725-2696
7. DHEC contact: Crystal D Rippy
Industrial Wastewater Permitting
Water Facilities Permitting Division
Bureau of Water



South Carolina Department of Health
and Environmental Control

Environmental Quality Control

Wastewater Application Fee
2600 Bull Street
Columbia, SC 29201

US DEPT OF ENERGY SAVANNAH RIVER SITE
BLDG 766-H RM 2308
AIKEN SC 29808

Invoice Date: 04/30/2013
Invoice Number: QY21782-8
Invoice Amount: \$400.00
Program ID: 1053243

Department Name: BOW - DOMESTIC WW PERM
Department Contact: LINDA S HARRELL
Department Phone: 803-898-4300

Qty	Description	Unit	Extended
1.00	TS => 1MGD - Modification (no expansion)	400.00	400.00
Total			\$400.00

South Carolina Department of Health and Environmental Control

Facility Name: US DEPT OF ENERGY SAVANNAH RIV
Program ID: 1053243
Invoice Number: QY21782-8 Amount Due: \$400.00

Amount Remitted: \$

To ensure proper credit, please return this portion of the invoice with your payment to the address below or you may go to our agency's website: WWW.SC.DHEC.GOV then click on **PAY INVOICES** under **quick links** or use the reverse side of this form for credit card payments. Please include the invoice number on your remittance. **Payment due upon receipt, past due 30 days from invoice date. Change of address and credit card payment forms are on the reverse side.**

SC DHEC
ATTN: BUREAU OF FINANCIAL MANAGEMENT
PO BOX 100103
COLUMBIA, SC 29202-3103

SUNTRUST BANK, ATLANTA GA

000005105



Savannah River Remediation LLC
PO Box 369
New Ellenton, SC 29809
803-952-9677

RECEIVED

APR 19 2013

DATE	CONTROL NO.	AMOUNT
03/21/2013	000005105	\$400.00

PAY Four Hundred And 00/100 Dollars

To The Order Of SOUTH CAROLINA DHEC
BUREAU OF FINANCE
2600 BULL STREET
COLUMBIA, SC 29201

WATER FACILITIES
PERMITTING DIVISION

Memo:

Jerry K. Jensen

⑈000005105⑈ ⑆061000104⑆ 1000094159182⑈

Application for Modification

Effluent Treatment Project Industrial Wastewater Treatment Permits #14,379-IW and 18,833-IW

H Retention Basin Treated Water Line Modification

Basin Water Discharge Tie-in to the Treated Water Line

January 2013

S C DEPT OF HEALTH & ENVIRONMENTAL CONTROL
BUREAU OF WATER

WASTEWATER FACILITIES

APPROVED FOR CONSTRUCTION

(SUBJECT TO ANY PROVISIONS WHICH MAY
APPEAR IN THE CONSTRUCTION PERMIT.)

FINAL WRITTEN APPROVAL FOR OPERATION MUST
BE OBTAINED FROM THIS OFFICE AFTER COM-
PLETION OF CONSTRUCTION.

PERMIT NO. 19673-IW DATE 6-19-13


DIRECTOR, WATER FACILITIES PERMITTING DIVISION



Savannah River
Remediation

A URS COMPANY TEAMED WITH BECHTEL | CH2M HILL | BSW | AREVA



Savannah River Site, Aiken, SC, 29808

1

**Transmittal
Letter**

2

**Construction
Permit
Application**

3

**Location
Map**

4

**Engineering
Report**

5

RECEIVED

APR 19 2013

WATER FACILITIES
PERMITTING DIVISION

June 11, 2013

SRR-ESH-2013-00079

Ms. Melinda Vickers
South Carolina Department of Health and
Environmental Control
2600 Bull Street
Columbia, South Carolina 29201-1208

RECEIVED

JUN 14 2013

WATER FACILITIES
PERMITTING DIVISION

**Application for Modification – F/H-Area Effluent Treatment Project
Facility – Revision 1 (U)**

Reference:

1. Application for Modification – F/H-Area Effluent Treatment Project Facility –
Revision 0, SRR-ESH-2013-00033, M-TRT-H-00083, 4/4/13

Based on our discussions Reference 1 has been revised and is included within this
modification package.

Savannah River Remediation (SRR) is planning to modify the F/H-Area Effluent
Treatment Project Facility. The enclosed modification package (three copies) is being
submitted for your review and approval. This package includes an engineering report,
equipment list, equipment specifications, design calculations, location map, construction
permit application, and fee (submitted with Reference 1). The enclosed, Application for
Modification - F/H-Area Effluent Treatment Project Facility, is part of the SRS Outfall
H-12 Corrective Action Plan.

Your timely review and processing of the enclosed modification package is requested.

If you have any questions, please contact Keith Liner of my staff at (803) 208-6466.

Sincerely,

Patricia M. Allen

Patricia M. Allen, Manager
Environment, Safety, Health, Quality Assurance and Contractor Assurance
Savannah River Remediation, LLC

Electronic copy cc:

M.D. Wilson, SCDHEC, Columbia SC
J.R. Hughes, SCDHEC, Aiken SC

T.J. Spears, DOE, 704-S, Rm. 29
P. Giles Jr., DOE, 704-S, Rm. 39
P.C. Suggs, DOE, 704-S, Rm. 37
C.H. Pang, DOE, 704-S, Rm. 53
A.I. Watson, DOE, 730-B, Rm. 3429


L.D. Olson, SRR, 766-H, Rm. 2407
S.A. Macvean, SRR, 766-H, Rm. 2408
K.H. Subramanian, SRR, 241-156H, Rm. 6
C.J. Winkler, SRR, 766-H, Rm. 2003
R.E. Edwards Jr., SRR, 766-H, Rm. 2404
J.E. Dickenson, SRR, 766-H, Rm. 2412
J.C. Tseng, SRR, 705-1C, Rm. 3
V.G. Dickert, SRR, 766-H, Rm. 2402
N.R. Davis, SRR, 704-56H, Rm. 103
B.A. Green, SRR, 704-56H, Rm. 164
J.E. Occhipinti, 704-56H, Rm. 119
M.T. Keefer, 704-56H, Rm. 161
C.N. Combs, 742-14G, Rm. 11
T.L. Allen, 742-14G, Rm. 4
M.B. Wood, 742-13G, Rm. 5
J.M. Suthar, 742-13G, Rm. 8
O.D. Stevens, SRR, 766-H, Rm. 2440
D.P. Skiff, SRR, 766-H, Rm. 2470
V.A. Franklin, SRR, 705-1C, Rm. 7
K.A. Hauer, SRR, 705-1C, Rm. 1
S.A. Thomas, SRR, 705-1C, Rm. 18
T.F. England, SRR, 705-1C, Rm. 17

M.A. Flora, SRNS, 730-4B, Rm. 328
K.M. Kostelnik, SRNS, 730-4B, Rm. 316
J.M. Griffith, SRNS, 730-4B, Rm. 3134
V.E. Millings III, SRNS, 730-4B, Rm. 3062

File Info:

SCDHEC, Saltstone
10666, DOE/ADM
16-1.5(a) Permanent

Location Map




Disclaimer: The RPE has reviewed this map for technical adequacy.

**United States Department of Energy
Savannah River Site
Aiken, South Carolina**

**ENGINEERING REPORT
M-TRT-H-00083**

**South Carolina Department of Health and
Environmental Control**

**H Retention Basin Treated Water Line Modification
Basin Water Discharge Tie-in to the Treated Water Line**



Signed: MICHAEL B. WOOD S.C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL
BUREAU OF WATER 22845
S.C. Registration No. WASTEWATER FACILITIES

APPROVED FOR CONSTRUCTION
(SUBJECT TO ANY PROVISIONS WHICH MAY
APPEAR IN THE CONSTRUCTION PERMIT)
FINAL WRITTEN APPROVAL FOR OPERATION MUST
BE OBTAINED FROM THIS OFFICE AFTER COM-
PLETION OF CONSTRUCTION.

PERMIT NO. 19673-IW DATE 6-19-13
Jeff P. LeB...
DIRECTOR WATER FACILITIES

DISCLAIMER

This report was prepared by Savannah River Remediation LLC (SRR) for the United States Department of Energy under Contract No. DE-AC09-09SR22505 and is an account of work performed under that contract. Neither the United States Department of Energy, nor SRR, nor any of their employees makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, or product or process disclosed herein or represents that its use will not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trademark, name, manufacturer or otherwise does not necessarily constitute or imply endorsement, recommendations, or favoring of same by SRR or by the United States Government or any agency thereof. The views and opinions of the authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

... DIVISION

APPROVAL SHEET

APPROVED BY:

Originator	<u>Terry L. Allen</u> Terry L. Allen Mechanical Engineer PD&CS/ Design Services	<u>6.5.13</u> Date
Reviewer	<u>Jagdish M. Suthar</u> Jagdish M. Suthar Process / Mechanical Engineer PD&CS/ Design Services	<u>6/5/13</u> Date
Reviewer	<u>Keith R. Limer</u> Keith R. Limer Environmental Compliance Authority	<u>6/11/13</u> Date
Reviewer	<u>Mark T. Keefer</u> Mark T. Keefer Manager - Tank Farm Engineering	<u>6/6/13</u> Date
Reviewer	<u>Brenda L. Green</u> Brenda L. Green Manager - Operations	<u>6/6/2013</u> Date
Verifier	<u>Michael B. Wood</u> Michael B. Wood, PE Mechanical Lead Engineer PD&CS/ Design Services	<u>6.5.13</u> Date
Project Manager	<u>C. Neil Combs</u> C. Neil Combs Project Manager PD&CS/ Projects	<u>6/11/13</u> Date

SUMMARY OF REVISIONS

Rev. No.	Reason for Change	Pages Affected	Issue Date
0	Initial Issue	N/A	3/27/13
1	Register Professional Engineer re-stamp in proper locations and added disclaimer.	Pages 1, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22 and 23.	6/11/13

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
Approval Sheet	3
Summary of Revisions	4
List of Acronyms	6
1.0 Engineering Report	7
2.0 Background Information	7
3.0 Location and Facility Layout	7
4.0 Project Description	7
5.0 Process Description	8
6.0 Modification Design	8
7.0 Operations / Maintenance	8
8.0 Air Emissions	8
9.0 Attachments	9

LIST OF ACRONYMS

BWL	Basin Water Line
ER	Engineering Report
ETP	Effluent Treatment Project
IWT	Industrial Wastewater Treatment
NPDES	National Pollutant Discharge Elimination System
RPE	Registered Professional Engineer
SCR	South Carolina Regulation
SCDHEC	South Carolina Department of Health and Environmental Control
SRR	Savannah River Remediation
SRS	Savannah River Site
TWL	Treated Water Line
UTRC	Upper Three Runs Creek

1.0 ENGINEERING REPORT

This Engineering Report (ER) is being submitted pursuant to South Carolina Regulation (SCR) 61-67, *Standards for Wastewater Facility Construction* to allow discharge of the 281-8H (8H) Basin. This ER describes the location, industrial wastewater treatment processes and configuration of the proposed 8H Basin Water Tie-in to the Treated Water Line (TWL) Modification at Savannah River Site (SRS).

This modification will allow for a discharge from the 8H Basin directly to Upper Three Runs Creek (UTRC) via the existing H-16 outfall discharge pipe. An NPDES 2C application has been initiated to create a new outfall (identification to be designated later) for the 8H Basin contents that will be discharged at the H-16 discharge location. For this to be a viable option, the Effluent Treatment Project (ETP) facility is being modified to have the ability to pump the basin water to UTRC by tying into the existing TWL.

2.0 BACKGROUND INFORMATION

This ER describes a modification to the ETP facility's industrial wastewater treatment (IWT) permit number 18,833-IW and 14,379 issued by the SCDHEC. The ETP process remains unchanged, only the TWL running to the UTRC is being altered. The waste stream characterization and treatment at the ETP and the ultimate disposal of these treated wastes do not change, nor is any new equipment other than piping and fittings required to implement this modification.

3.0 LOCATION AND FACILITY LAYOUT

The ETP is located in H-Area along E Road. The existing TWL runs from the three treated water storage tanks to UTRC. The water is gravity discharged in to the creek west of the bridge. The BWL will be tied in to the TWL near the east end of the 8H Basin along E Road. The general Site location of the modification is shown in Attachment 9.1.

4.0 PROJECT DESCRIPTION

The proposed piping and equipment layout is shown in Attachment 9.2. The BWL Discharge Tie-in Modification installs:

- A section of pipe downstream of an existing gamma monitor at the pumping station with an isolation valve. See Attachments 9.2 and 9.9.
- A section of pipe from the existing lift station line to the existing TWL. This line will contain a backflow preventer with two isolation valves. See Attachments 9.2 and 9.10.
- Double isolation valves will be installed in the lift station line to prevent transfers of basin water to this process area. See Attachments 9.2 and 9.11.
- Double isolation valves will be installed in the existing TWL to prevent basin water from being transfer to the treated water storage tanks at ETP. These valves will be installed in a concrete box for ease of maintenance and inspection. See Attachments 9.2 and 9.11.

5.0 PROCESS DESCRIPTION

ETP will continue to pump the treated water through Outfall H-16 to UTRC when required. This modification makes no changes to the existing ETP process. When required, due to the accumulation of rain water run-off, the basin water will be pumped to UTRC using one of two pumps at a rate between 175 gpm and 225 gpm. This rate is similar to the existing rate of the treated water discharge. The suitability of the pumps is documented in Attachment 9.12. Between 250,000 to 320,000 gallons of water may be pumped daily, as required.

6.0 MODIFICATION DESIGN

The BWL Tie-in Modification design involves the modification of two existing water transfer lines as described above. The material specifications for the new piping and equipment to be installed by this modification are provided in Attachments 9.3 through 9.10.

7.0 OPERATIONS / MAINTENANCE

Trained Operations personnel will be required during basin water pumping, including valve operations, start-up and shutdown.

Required maintenance will be performed by trained Maintenance and E&I Mechanics assigned to the ETP or F & H Tank Farms


8.0 AIR EMISSIONS

This modification will not generate any air emissions.

9.0 ATTACHMENTS




- 9.1 Location Map
- 9.2 Basin Water Line Tie-in Modification Overview
- 9.3 Equipment List and Piping Specification
- 9.4 Piping Specification 101 for New Pipe
- 9.5 Piping Specification 200 for New Pipe
- 9.6 Piping Specification 502 for New Pipe
- 9.7 Watts Double Check Valve Assembly
- 9.8 Flow Isolation Ball Valves
- 9.9 Pipe Tie-In at Pump Pad for New BWL
- 9.10 New Backflow Preventer and Lift Station Isolation Valves
- 9.11 New Concrete Valve Box and TWL Isolation Valves
- 9.12 M-CLC-H-03203, Revision 1, Basin Water-Treated Water Piping System

Attachment 9.1
General Location Map





Disclaimer: The RPE has reviewed this map for technical adequacy.

Attachment 9.2
 Basin Waste Line Tie-In Modification Overview



**Attachment 9.3
 Equipment List and Piping Specifications**

Item	Description	Type, Size, Capacity	Quantity	Specification
1	Pipe	Carbon Steel, 4 inch	≈12 feet	Pipe Specification PS101B (Attachment 9.4)
2	Pipe	Carbon Steel, 6 inch	≈2 feet	Pipe Specification PS101B (Attachment 9.4)
3	Pipe	Stainless Steel, 6 inch	≈50 feet	Pipe Specification PS200C (Attachment 9.5)
4	Pipe	Polyethylene, 6 inch	≈20 feet	Pipe Specification PS502F (Attachment 9.6)
5	Backflow Preventer with Gate Valves	Carbon Steel, 6 inch	1	Watts – 709-OSY or equivalent (Attachment 9.7)
6	Ball Valve for Metal Valve Box	Carbon Steel, 6 inch	2	Cam-Tite or equivalent (Attachment 9.8)
7	Ball Valve for Concrete Valve Box	Stainless Steel, 6 inch	2	Cam-Tite or equivalent (Attachment 9.8)



Attachment 9.4
 Piping Specification PS101

SRS Engineering Practices Manual	Manual : WSRC-IM-95-58	
	GUIDE NO: 15060-G APPENDIX A	PAGE 47
	DATE: 10/1/2011	REVISION: 7
	ESB TECH COMMITTEE: Piping and Valves	
APPLICATION OF ASME B31.3		

APPENDIX A
 Piping Specifications

Piping Specification PS101	Page 1 of 1
----------------------------	-------------

Design Parameters

P-Spec	PS101(A, B, C, D)						
Design Pressure (psig)	285	260	230	200	170	140	125
Design Temperature (°F)	100	200	300	400	500	600	650
Minimum Temperature (°F)	-20	-20	-20	-20	-20	-20	-20
Minimum Test Pressure (psig)	430	390	345	300	270	245	220
Maximum Test Pressure (psig)	820						

Calculation Reference:	M-CLC-G-00231
Code of Reference:	B31.3 - 2010
Fluid Service:	Normal
Material:	Carbon Steel
Pressure Rating:	Class 150
External Pressure Rating:	Note 20

General Notes

Refer to General Notes 1-12, 61

Allowable Pipe Materials

Component	NPS	Rating	Standard	Material	Material Grade	Additional Requirements
Piping	¼ - 24	Schedule Tables	ASME B36.10M	ASTMA53	B	
Piping	¼ - 24	Schedule Tables	ASME B36.10	ASTMA106	B	ERW - Type E/Seamless Seamless

Required Schedules for Non-Threaded Pipe

P-Spec	Corrosion Allowance	NPS	¼	½	¾	1	1½	2	2½	3	4	6	8	10	12	14	16	18	20	24
A	0.000	Schedule	40	40	40	40	40	40	40	40	40	40	40	40	40	30	30	20	20	20
B	0.031	Schedule	40	40	40	40	40	40	40	40	40	40	40	40	40	30	30	20	20	20
C	0.063	Schedule	80	40	40	40	40	40	40	40	40	40	40	40	40	30	30	20	20	20
D	0.125	Schedule	-	XXS	160	160	160	80	80	80	40	40	40	40	40	30	30	20	20	20

Required Schedules for Threaded Pipe

P-Spec	Corrosion Allowance	NPS	¼	½	¾	1	1½	2	2½	3	4	6	8	10	12	14	16	18	20	24	
A	0.000	Schedule	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80
B	0.031	Schedule	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80
C	0.063	Schedule	-	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80
D	0.125	Schedule	-	XXS	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160

To be used for above grade pipe.

Fittings

Component	NPS	Rating	Standard	Material	Material Grade	Additional Requirements
Threaded Fittings	¼ - 4	Class 2000, Class 3000	ASME B16.11	ASTMA105	WP	Use Class 3000 for PS101-D; see Note 61
Socket-Weld Fittings	¼ - 2	Class 2000, Class 3000	ASME B16.11	ASTMA105	WP	Use Class 6000 for PS101-D
Buttweld Fittings	½ - 24	Schedule Tables	ASME B16.9	ASTMA234	WPB	
Buttweld Fittings	½ - 24	Schedule Tables	ASME B16.28	ASTMA234	WPB	

Flanges

Component	NPS	Rating	Standard	Material	Material Grade	Additional Requirements
Threaded Flange	½ - 6	Class 150	ASME B16.5	ASTMA105	N/A	
Socket-Weld Flange	½ - 2	Class 150	ASME B16.5	ASTMA105	N/A	
Weldneck Flange	½ - 24	Class 150	ASME B16.5	ASTMA105	N/A	
Slip-on Flange	½ - 24	Class 150	ASME B16.5	ASTMA105	N/A	
Blind Flange	½ - 24	Class 150	ASME B16.5	ASTMA105	N/A	
Backup Flange	½ - 24	Class 150	ASME B16.5	ASTMA105	N/A	

Mechanical Fasteners

Component	Size (in)	Standard	Material	Material Grade	Additional Requirements
Fasteners	½ - 1¼	ASME B18.2.1	ASTMA193	B7-HH	See General Note 12
Nuts	½ - 1¼	ASME B18.2.2	ASTMA194	2H-HH	

Attachment 9.5
 Piping Specification PS200 for New Pipe

SRS Engineering Practices Manual	Manual : WSRC-IM-95-58	
APPLICATION OF ASME B31.3	GUIDE NO: 15060-G APPENDIX A PAGE 53	
	DATE: 10/1/2011	REVISION: 7
	ESB TECH COMMITTEE: Piping and Valves	

APPENDIX A
Piping Specifications

Piping Specification PS200 Page 1 of 1

Design Parameters

P-Spec	PS200(A, B, C, D)						
Design Pressure (psig)	230	195	175	160	145	140	125
Design Temperature (°F)	100	200	300	400	500	600	650
Minimum Temperature (°F)	-425	-425	-425	-425	-425	-425	-425
Minimum Test Pressure (psig)	345	295	265	255	245	250	230
Maximum Test Pressure (psig)	440 for NPS ≤ 6, 360 for NPS > 6						

Calculation Reference:	M-CLC-G-00231
Code of Reference:	B31.3 - 2010
Fluid Service:	Normal
Material:	Stainless Steel (304L)
Pressure Rating:	Class 150
External Pressure Rating:	Note 20

General Notes

Refer to General Notes 1-4, 6-13, 59-61

Allowable Pipe Materials

Component	NPS	Rating	Standard	Material	Material Grade	Additional Requirements
Piping	¼ - 24	Schedule Tables	ASME B36.19	ASTMA312	TP304L	
Piping	¼ - 24	Schedule Tables	ASME B36.19	ASTMA312	TP304L	Welded
						Seamless

Required Schedules for Non-Threaded Pipe

P-Corrosion Spec Allowance	NPS	¼	¾	½	¾	1	1½	2	2½	3	4	6	8	10	12	14	16	18	20	24
A 0.00	Schedule	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S
B 0.03	Schedule	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S	10S
C 0.05	Schedule	40S	40S	10S	40S	10S	10S	10S	10S	10S	4S	40S	1S	10S	40S	-	-	-	-	-
D 0.08	Schedule	80S	80S	80S	80S	40S	40S	40S	40S	40S	40S	40S	40S	40S	40S	-	-	-	-	-

Required Schedules for Threaded Pipe

P-Corrosion Spec Allowance	NPS	¼	¾	½	¾	1	1½	2	2½	3	4
A 0.00	Schedule	40S	40S	40S	40S	40S	40S	40S	40S	40S	40S
B 0.03	Schedule	80S	80S	40S	40S	40S	40S	40S	40S	40S	40S
C 0.05	Schedule	80S	80S	80S	80S	80S	80S	80S	40S	40S	40S
D 0.08	Schedule	-	-	-	-	80S	80S	80S	80S	80S	

To be used for above and below grade pipe.

Fittings


Component	NPS	Rating	Standard	Material	Material Grade	Additional Requirements
Threaded Fittings	¼ - 4	Class 2000	ASME B16.11	ASTMA182	F304L	
Threaded Fittings	¼ - 4	Class 150	MSS SP-114	MSS SP-114	304L	See Note 61
Socket-Weld Fittings	¼ - 2	Class 3000	ASME B16.11	ASTMA182	F304L	
Socket-Weld Fittings	¼ - 2	Class 150	MSS SP-114	MSS SP-114	304L	
Buttweld Fittings	½ - 24	Schedule Tables	ASME B16.9	ASTMA403	WP304L	
Buttweld Fittings	½ - 24	Schedule Tables	ASME B16.28	ASTMA403	WP304L	

Flanges

Component	NPS	Rating	Standard	Material	Material Grade	Additional Requirements
Threaded Flange	½ - 4	Class 150	ASME B16.5	ASTMA182	F304L	
Socket-Weld Flange	½ - 2	Class 150	ASME B16.5	ASTMA182	F304L	
Weldneck Flange	½ - 24	Class 150	ASME B16.5	ASTMA182	F304L	
Slip-on Flange	½ - 24	Class 150	ASME B16.5	ASTMA182	F304L	
Blind Flange	½ - 24	Class 150	ASME B16.5	ASTMA182	F304L	
Backup Flange	½ - 24	Class 150	ASME B16.5	ASTMA105	N/A	Min Temperature - 20°F. Notes 10, 59, and 60.
Backup Flange	½ - 24	Class 150	ASME B16.42	ASTMA395	N/A	Min Temp. - 20°F. Notes 10, 59, and 60.

Mechanical Fasteners

Component	Size (in)	Standard	Material	Material Grade	Additional Requirements
Fasteners	½ - 1 ¼	ASME B18.2.1	ASTMA193	B8 Cl. 2-HH	Min Temperature - 325°F. Notes 12 and 60.
Nuts	½ - 1 ¼	ASME B18.2.2	ASTMA194	8F-HH	Notes 59 and 60.



Michael S. Bryan
 6-5-13

Attachment 9.6
 Piping Specification PS502

SRS Engineering Practices Manual	Manual : WSRC-IM-95-58	
APPLICATION OF ASME B31.3	GUIDE NO: 15060-G APPENDIX A PAGE 88	
	DATE: 10/1/2011	REVISION: 7
	ESB TECH COMMITTEE: Piping and Valves	

APPENDIX A
Piping Specifications

Piping Specification PS502 Page 1 of 1

Design Parameters

P-Spec	PS502 (A, B, C, D, E, F, G)						
Design Pressure (psig)	200	193	160	128	110	100	80
Design Temperature (°F)	73	73	73	73	73	73	73
Minimum Temperature (°F)	0	0	0	0	0	0	0
Minimum Test Pressure (psig)	300	290	240	190	165	150	120
Maximum Test Pressure (psig)	385	320	265	215	185	165	135

Calculation Reference:	M-CLC-G-00231
Code of Reference:	B31.3, 2010
Fluid Service:	Normal
Material:	Polyethylene (PE)
Pressure Rating:	200 psi
External Pressure Rating:	N/A

General Notes

Refer to General Notes 1-4, 8-12, 33-35, 37, 38.

Allowable Pipe Materials

Component	Size	Rating	Standard	Material	Material Grade	Additional Requirements
Piping	½ - 12	Design Parameters	ASTM D3035	ASTM D3035	PE3408	Note 35
Piping	½ - 12	Design Parameters	ASTM D2513	ASTM D3035	PE3408	Note 35
Tubing	¼ - 1 ¾	Design Parameters	ASTM D2513	ASTM D3035	PE3408	Note 35
Tubing	½ - 2	Design Parameters	ASTM D2737	ASTM D3035	PE3408	Note 35

Required DR Schedules for Pipe

P-Spec	Corrosion Allowance	Design Pressure at 73°	Pipe Size	DR Schedules													
				½	¾	1	1 ½	2	2 ½	3	4	6	8	10	12		
A	0.00	200	DR 9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
B	0.00	193	DR 9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3
C	0.00	160	DR 11	11	11	11	11	11	11	11	11	11	11	11	11	11	11
D	0.00	128	DR 13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5
E	0.00	110	DR 15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5
F	0.00	100	DR 17	17	17	17	17	17	17	17	17	17	17	17	17	17	17
G	0.00	80	DR 21	21	21	21	21	21	21	21	21	21	21	21	21	21	21

Required DR Schedules for Tube

P-Spec	Corrosion Allowance	Design Pressure at 73°	Pipe Size	DR Schedules													
				¼	⅜	½	¾	1	1 ¼	1 ½	1 ¾	2					
A	0.00	200	DR 9	9	9	9	9	9	9	9	9	9	9	9	9		
B	0.00	193	DR 9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3		
C	0.00	160	DR 11	11	11	11	11	11	11	11	11	11	11	11	11		
D	0.00	128	DR 13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5		
E	0.00	110	DR 15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5		
F	0.00	100	DR 17	17	17	17	17	17	17	17	17	17	17	17	17		
G	0.00	80	DR 21	21	21	21	21	21	21	21	21	21	21	21	21		

To be used for tie-in to existing TRW piping.

Fittings

Component	Size	Rating	Standard	Material	Material Grade	Additional Requirements
Butt Fusion Fittings	½ - 12	See Note 38	ASTM D3261	ASTM D1248	P34 (PE3408)	
Solvent Welded Fittings (Pipe)	¼ - 4	See Note 38	ASTM D2683	ASTM D1248	P34 (PE3408)	Type III, Class B or C Note A
Solvent Welded Fittings (Pipe)	¼ - 1 ¼	See Note 38	ASTM D2683	ASTM D1248	P34 (PE3408)	Type III, Class B or C Note A

Flanges

Component	Size	Rating	Standard	Material	Material Grade	Additional Requirements
Backup Flange	½ - 12	Class 150	ASME B16.5	ASTM A105	N/A	

Mechanical Fasteners

Component	Size	Rating	Standard	Material	Material Grade	Additional Requirements
Fasteners	½ - ¾	N/A	ASME B18.2.1	ASTM A307	Grade A	See Note 12.
Nuts	½ - ¾	N/A	ASME B18.2.2	ASTM A563	Grade B	

A. Electrofusion in accordance with ASTM F1055 or AWWA C906.



Attachment 9.7
(Page 1 of 2)
Watts Double Check Valve Assembly
With Gate Valves

ES-709L

Series 709 Double Check Valve Assemblies

Sizes: 2½" – 10" (65 – 250mm)

Series 709 Double Check Valve Assemblies are designed to prevent the reverse flow of polluted water from entering into the potable water system. This series can be applied, where approved by the local authority having jurisdiction, on non-health hazard installations. Series 709 features a modular check design concept to facilitate easy maintenance. Check with local jurisdictional authority as to installation requirements.

Features

- Replaceable bronze seats
- Maximum flow at low pressure drop
- Design simplicity for easy maintenance
- No special tools required for servicing
- Captured spring assemblies for safety
- Approved for vertical flow up installation

Models

Suffix:

NRS – non-rising stem resilient seated gate valves

OSY – UL/FM outside stem and yoke resilient seated gate valves

S-FDA – FDA epoxy coated strainer

BB – bronze body - 2½" – 3" (64 – 76mm)

QT – quarter-turn ball valves

QT-FDA – FDA epoxy coated ball valve shutoffs

LF – without shutoff valves


Specifications

A Double Check Valve Assembly shall be installed at referenced cross-connections to prevent the backflow of polluted water into the potable water supply. The cross-connections shall be determined by local inspection authority for use where a high hazard situation does not exist. Valve shall feature modular check assemblies with center stem guiding. Each check module shall have a captured spring and be accessible through a bolted cover plate. Seats shall be replaceable without special tools. It shall be a complete assembly including tight-closing resilient seated shutoff valves, test cocks, and a strainer is recommended. The assembly shall meet the requirements of ASSE No. 1015; AWWA C510-92; CSA B64.5 and UL Classified File No. EX3185. Approved by the Foundation for Cross-Connection Control and Hydraulic Research at the University of Southern California. Assembly shall be a Watts Regulator Company Series 709.

Watts product specifications in U.S. customary units and metric are approximate and are provided for reference only. For precise measurements, please contact Watts Technical Service. Watts reserves the right to change or modify product design, construction, specifications, or materials without prior notice and without incurring any obligation to make such changes and modifications on Watts products previously or subsequently sold.



709 OSY



Check Assembly Module

Series 709 features a modular design concept which facilitates complete maintenance and assembly by retaining the spring load. Also, the first and second check module are identical and can be interchanged.

**IMPORTANT: INQUIRE WITH GOVERNING AUTHORITIES
FOR LOCAL INSTALLATION REQUIREMENTS**

Now Available
WattsBox Insulated Enclosures.
For more information, send for literature ES-WB.

WATTS®

Disclaimer: The RPE has reviewed this product cut sheet for technical adequacy.

Attachment 9.7
 (Page 2 of 2)
 Watts Double Check Valve Assembly
 With Gate Valves

Materials

Check Valve Bodies: Epoxy coated cast iron
 Seats: Bronze

Pressure — Temperature

Temperatures Range: 33°F – 110°F (0.5°C – 43°C) continuous,
 140°F (60°C) intermittent
 Maximum Working Pressure: 175psi (12.1 bar)

Standards


AWWA C510-92
 IAPMO PA 31
 USC Manual for Cross-Connection Control, 8th Edition

Approvals



1015
 Approved by the Foundation for Cross-Connection Control and Hydraulic Research at the University of Southern California. Sizes 4" – 10" (100 – 250mm) approved horizontal and vertical "flow up". Size 2½" and 3" (65 – 80mm) approved horizontal only.
 Factory Mutual approved 4" – 10" (80 – 250mm) vertical "flow up" with OSY gate valves only.
 Note: Model "S" not listed

Dimensions — Weights



RETB-V-67, RETB-V-68, RETB-V-69, & RETB-V-70, respectively

Size to be used.

SIZE (DN)		DIMENSIONS															
in.	mm	A		C (OSY)		C (NRS)		D		L		U*		M		N	
		in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm
2½	65	39½	1000	16¾	416	9¾	238	3½	89	24½	613	11	279	10	254	6½	165
3	80	40¾	1025	18½	479	10¼	260	3¾	95	24½	613	14	356	10½	257	7	178
4	100	42½	1080	20½	519	11¼	282	4¼	111	24½	613	14	356	10½	257	7	178
6	150	62½	1597	30¼	765	16	406	5½	140	41½	1057	16	406	18½	470	13½	343
8	200	76	1928	37¼	938	19¼	493	6¾	169	41½	1057	21	533	21½	543	16½	419
10	250	90	2286	45¼	1162	23¼	605	8	203	64	1626	25	635	26	660	18½	470

SIZE (DN)		DIMENSIONS						WEIGHT				STRAINER					
in.	mm	N†		R		T		NRS		OSY		QT		Weight			
		in.	mm	in.	mm	in.	mm	lbs.	kgs.	lbs.	kgs.	lbs.	kgs.	lbs.	kgs.		
2½	65	10	254	4	102	16	406	3	76	167	76	170	77	154	70	28	13
3	80	10	254	5	127	16	406	3	76	167	76	170	77	162	73	34	15
4	100	12	305	6	152	16½	419	3	76	167	76	170	77	162	73	34	15
6	150	20	508	11	279	26	660	7½	191	627	284	707	321	611	277	122	55
8	200	24	610	14	354	30	762	9	229	727	328	747	338	679	308	139	62
10	250	28	711	12½	318	12½	318	10¼	260	2003	909	2073	940	2466	1119	370	168


† - Dimension required for screen removal. ♦ Quarter-turn (QT) valve dimensions.
 *Service clearance for check assembly from center.

Attachment 9.8
 (Page 1 of 2)
 Flow Isolation Ball Valves


Dimensions, Weights, & Parts Lists 3", 4" and 6" Valves

Flanged Body

See Attachment 9.11
 TRW-V-117 &
 TRW-V-118




Socket Weld & Threaded Body



NOTE:

1. Body boss can be drilled, tapped, and plugged.
2. End machining meets ANSI B16.5 for flanged ends.
3. Top two flanged bolt holes on 3" & 4" 150 lb. class valves are drilled and tapped 5/8"-11 UNC class 2B. Top two flanged bolt holes on 4" 300# Class valves are drilled and tapped 3/4"-10 UNC class 2B.
4. The design meets ANSI B16.34, MSS-SP 72 and ANSI B16.10.
5. Valve is shown in the open position. Clockwise rotation of stem closes the valve.

Butt Weld Body See Attachment 9.10 - RETB-V-65 & RETB-V-66



Item 6. 6" Buttweld End, Carbon Steel
 22 WCB Valve, 316SST Ball & Stem,
 Std. Cover, UHMW PE Seat, UHMP
 Stem Seal & Gasket.

Item 7. 6" ANSI Class 150# Flanged
 Stainless Steel Valve, 316SST Ball & Stem,
 Std. Cover, UHMW PE Seat, UHMP
 Stem Seal & Gasket.

Disclaimer: The RPE has reviewed this product cut sheet for technical adequacy.

Attachment 9.8
(Page 2 of 2)
Flow Isolation Ball Valves

Compliance With National Standards

Cam-Tite Ball Valves are designed to the following ANSI specifications:

ANSI B2.1	Pipe Threads
ANSI B16.5	Flanges and Flanged Fittings
ANSI B16.11	Socketweld and Threaded Fittings
ANSI B16.25	Buttweld Ends
ANSI B16.34*	Flanged, Threaded and Weld End Valves
ANSI B31.1	Power Piping
ANSI B31.3	Chemical Plant and Petroleum Refinery Piping

*Compliance to ANSI B16.34 is dependent on the materials of construction selected and the testing specified for each application. Consult the factory for further details.

All standard Cam-Tite Ball Valves are tested and tagged in accordance with the following specifications:

MSS-SP-25	Marking System for Valves
MSS-SP-72	Ball Valves for General Service

In addition, Cam-Tite Ball Valves can be furnished in accordance with the special requirements of the following specifications:

ANSI B31.3	Category M Service
API 598	Valve Inspection and Testing
API 607	Firetesting for Soft Seated Quarter Turn Valves
Chlorine Institute Pamphlet 6	Ball Valves for Dry Chlorine Service
NACE Standard MR01-75	Materials for Oilfield Equipment

Material Standards

All Cam-Tite body and bonnet castings are in accordance with one of the following standards:




Carbon Steel	ASTM A216 GR WCB
Carbon Steel (Low Temperature)	ASTM A352 GR LCB
Carbon Steel (Low Temperature)	ASTM A352 GR LC-1
316 Stainless Steel	ASTM A351 GR CF8M
316 L Stainless Steel	ASTM A351 GR CF3M
Alloy 20	ASTM A351 GR CN7M
Monel	ASTM A494 GR M-35-1
Hastelloy C	ASTM A494 GRs CW-6M or CW-2M
Inconel	ASTM A494 GR CY-40
Nickel	ASTM A494 GR CZ-100
Titanium	ASTM B367 GR C3

All standard Cam-Tite Ball Valve cover bolting is in accordance with the following standards:




Carbon Steel	ASTM A193 GR B7
Stainless Steel	ASTM A193 GR B8

Certified Material Test Reports (CMTRs) can be supplied on the above materials. Contact Engineered Valves for additional information on materials not listed.




Attachment 9.9
Pipe Tie-In at Pump Pad for New BWL





Attachment 9.10
New Backflow Preventer and Lift Station Isolation Valves



Attachment 9.11
New Concrete Valve Box and TWL Isolation Valves



UNCLASSIFIED			
CALCULATION COVER SHEET			
Calculation Number: M-CLC-H-03203	Revision: 1	Functional Classification: PS	Project: N/A
Title: Basin Water-Treated Water Piping System			
Calculation Type: Type 1-Confirmed		Computer Program and Version/Release No: N/A	
Purpose and Objective: Purpose: Apply accepted computational methods to determine the system head requirement for pumping Basin Water to Upper Three Runs Creek (UTRC). Objective: Verify that the existing pumps are capable of pumping the Basin Water to UTRC. If not, select a suitable pump to meet the performance requirements of Reference 5.			
Summary of Conclusion: The currently installed pumps, RETB-P-1 and RETB-P-2 are capable of pumping the basin water at the required range of 175 – 225 gpm. To meet the flow rate requirement, the discharge flow rate of RETB-P-1 must be throttled to approximate 225 gpm with a manual valve. Pump 2, RETB-P-2, is capable of pumping the basin water at a flow rate of approximately 175 gpm. A double check valve assembly is required to prevent the draining of treated water back into the basin. "This document has been verified, including evaluation against questions a-m of E7, 2.60, Section 5.2.1.1"			
Originator: ALLEN, TERRY L		Date: 4/9/2013	
		Verifier/Checker: GAUTHIER, HAROLD P	
		Date: 4/9/2013	
		Discipline: MECHANICAL	
		Verification/Checking Method: Design Check (GS/PS only)	
Contributing Reviewers:		Design Authority: N/A	
		Date: 4/9/2013	
N/A		USQ Required?: NO	
N/A			
N/A			
N/A			
N/A			
N/A			
		Responsible Manager: WOOD, MICHAEL BRYAN	
		Date: 4/10/2013	
DCRO: N/A		Date: 4/10/2013	
Guidance / Exemption: UNCLASSIFIED - Does Not Contain Unclassified Controlled Nuclear Information			



Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 2 of 42	Rev. 1
----------------------------------	----------------------	-----------

Table of Contents

Table of Contents	Sheet
1. References.....	3
2. Open Items	4
3. Introduction	4
4. Input Data	4
5. Assumptions	4
6. Analysis Method and Calculations.....	5
7. Analysis Results.....	10
8. Conclusions	11
Tables	
Table 1 - Piping and Fluid Data	6
Table 2 - Elevation Head for Flow Delivery Points	6
Table 3 - Segment Pipe Lengths, Fittings and Valves Tabulation.....	7
Figures	
Figure 1 - Proposed P&ID for Basin Water to the Treated Water Line.....	12
Figure 2 - Treated Water Line Profile	13
Figure 3 - Over View of the Basin Water Flow Path	14
Figure 4 - Piping Length from Basin to Pumps.....	15
Figure 5 - Piping Route at Pumps and to Line 4302.....	16
Figure 6 - Elevation of Piping from Basin to Pumps	17
Figure 7 - Line 4302 to Treated Water Line Tie-in Point	18
Figure 8 - Elevation of Pipe Tie-in at Treated Water Line	19
Figure 9 - System-Pump Curve for Transfer Route Using RETB-P1	20
Figure 10 - System-Pump Curve for Transfer Route Using RETB-P2	21
Attachments	
Attachment 1 – Nomenclature	22
Attachment 2 – Backflow Preventer Literature	23
Attachment 3 – Head Loss Calculation.....	26
Attachment 4 – Summary of Head Loss.....	29
Attachment 5 – Excel Spreadsheet Formulae	30

Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 3 of 42	Rev. 1
----------------------------------	----------------------	-----------

1. References

General

1. Flow of Fluids through Valves, Fittings and Pipe, Technical Paper No. 410; Crane Co., 1988, Reprinted 03/06.
2. Pump Characteristics and Applications, Volk, M. W., Marcel Dekker, Inc., 1996.
3. Handbook of Tables for Applied Engineering Science, Second Edition, Bolz, Ray E. and Tuve, George L.
4. Handbook of Polyethylene Pipe, Second Edition, Chapter 6 – Design of PE Piping Systems, Table 2-1, Plastic Pipe Institute.
5. MT-EPT-2012-00002, Rev. 0, 281-8H Retention Basin Tie into the Treated Water Line.
6. Swamee PK, Jain AK, Explicit Equations for Pipe-Flow Problems, Journal Hydraulics Division of ASCE 1976; 102(5): 657-64.
7. ASTM F714-12, Standard Specification for Polyethylene (PE) Plastic Pipe (DR-PR) Based on Outside Diameter. (Note: Used IPS based on archived DuPont Specification 4482-P216 flange requirement.)

SRS Piping and Instrumentation Diagrams (P&IDs)

8. M-M6-H-9427, Rev. 13, Effluent Treatment Facility, H Area Pump Pit, Retention Basin System, Piping and Instrument Drawing.
9. M-M6-H-9592, Rev. 4, Effluent Treatment Facility, Treated Water Transfer Pumps, Treated Water System, Piping and Instrument Drawing.
10. M-M6-H-9593, Rev. 2, Effluent Treatment Facility, Treated Water System, Piping and Instrument.

SRS Blue Print Files (BPF)

11. BPF211919, Self-Priming Mark II Durcopumps Group II (H281-100.1 / W239022)
12. BPF216672, Durco Mark III Pumps 2K 4x3US-10H, Sheets 1, 5 and 13 (H824-170-10 / W725794)

SRS Drawings

13. D186318, Rev. 27, Basins 200 F-H, Piping Details, Details, Process.
14. D186319, Rev. 37, Basins 200 F-H, Piping Details, Details, Process & Concrete.
15. D186320, Rev. 30, Basins 200 F, Piping Details, Details, Power.
16. D186325, Rev. 5, Basins 200 F-H, Piping Details, Details, Process.
17. D186328, Rev. 3, Basins 200 F-H, Piping Details, Details, Process.
18. W238897, Rev. 39, Bldg. 281-8, -9 & -10H, Contaminated Water Control, Plot Plan, Civil.
19. W238973, Rev. 23, Bldg. 281-8F & H, Contaminated Waste Control, Inlet Structure & Sump, Concrete.
20. W238978, Rev. 3, Bldg. 281-9H, Contaminated Water Control, Pump & Valve Pad, Concrete.
21. W239022, Rev. 65, Bldg. 281-9H, Contaminated Water Control, Pump Station Equip. & Piping Arrg't., Process.
22. W814332, Rev. 60, Basins – 200-H, Piping Plan, Bldg. 281-9H, Piping Arrg't., Process.

Attachment 9.12

Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 4 of 42	Rev. 1
----------------------------------	----------------------	-----------

23. W816264, Rev. 36, Area 811-F, Collection & Storage Facility OSUG Piping Profile, Sheet 1, Power.
24. W816265, Rev. 24, Area 811-F, Collection & Storage Facility OSUG Piping Profile, Sheet 2, Power.
25. W816266, Rev. 21, Area 811-F, Collection & Storage Facility OSUG Piping Profile, Sheet 3, Power.
26. W816267, Rev. 11, Area 811-F, Collection & Storage Facility OSUG Piping Profile, Sheet 4, Power.
27. W816268, Rev. 12, Area 811-F, Collection & Storage Facility OSUG Piping Profile, Sheet 5, Power.
28. W816269, Rev. 36, Area 811-F, Collection & Storage Facility OSUG Piping Profile, Sheet 6, Power.
29. W816270, Rev. 19, Area 811-H, Collection & Storage Facility OSUG Piping Profile, Sheet 1, Power.
30. W816271, Rev. 22, Area 811-H, Collection & Storage Facility OSUG Piping Profile, Sheet 2, Power.
31. W816272, Rev. 20, Area 811-H, Collection & Storage Facility OSUG Piping Profile, Sheet 3, Power.
32. W816273, Rev. 26, Area 811-H, Collection & Storage Facility OSUG Piping Profile, Sheet 4, Power.
33. W816274, Rev. 56, Area 811-H, Collection & Storage Facility OSUG Piping Profile, Sheet 5, Power.

2. Open Items
 None.

3. Introduction

R1

The new NPDES Permit for SRS will have zinc discharge limits at Outfall H-12 that will be difficult for SRR to meet. Per agreement with SCDHEC, SRR will reroute the flow from 281-8H to the discharge treated water line from ETP that leads to Outfall H-16 at Upper Three Runs Creek (UTRC). The Facility desires to use the existing pump(s) to pump the water basin to UTRC. Originally, the pumps were not designed for this application. This calculation determines if the pump(s) are adequate or must they be replaced.

4. Input Data

1. Transfer pump target flow rate range is approximately 175 – 225 gpm, (Ref. 1.5).

5. Assumptions

1. Fluid Characteristics for Basin Water is assumed to be water.
2. Pressure head (h_p) and Velocity head (h_v) are not considered in this calculation
3. All 66.6' radius bends are considered straight pipe.
4. Full port valves are used.
5. The backflow preventer as listed in Attachment 2 with an assumed head loss of approximately 3 psi (\approx 12.7 ft).

Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 5 of 42	Rev. 1
----------------------------------	----------------------	-----------

6. Analysis Method and Calculation

This calculation uses the following methodology:

1. Establish the proposed piping arrangement using general arrangement and layout drawings.
2. Determine total head loss (h_L) for the piping system as follows:
 - Determine flow through capacity range (Q).
 - Calculate Reynolds Number (R_e)
 - Determine Friction factor (f).
 - Calculate resistance coefficient (K).
 - Calculate pressure head loss (h_L) for the piping system.
3. Determine the maximum elevation head difference between the lowest basin water level and the discharge elevation at the Weir Box (h_S).
4. Develop system head requirements for the Basin Water System. (This includes elevation head minus system head loss. ($h_S - h_L$))
5. Plot the pump performance parameters obtained from references 1.11 and 1.12.
6. Evaluate the Basin Water to Upper Three Runs Creek System head requirements for the piping system with respect to pump performance, to determine the flow delivering capability of the existing Retention Basin pumps.

Pipe Route

The evaluated pipe route is shown schematically in Figure 1. Figure 2 shows the significant elevation changes of the piping from ETP to the UTRC. The overall flow path that was analyzed by this calculation is shown in Figure 3. The flow path was divided into nine segments; pipe size/type and by pump. Figures 4 through 8 show the nine pipe segments. The lengths of pipe are based on the drawings listed. Some of the lengths were scaled because a dimension could not be calculated. Table 1, Basin Water to Upper Three Runs Creek System Piping and Components, tabulates the lengths of each segment and the number of valves, elbows, tee, and etc. in each section. Table 2 contains the key elevations used in calculating the system curve.

Table 3 contains the pipe length and fitting tabulation of the calculation. There are nine segments that are categorized by the pipe size or the pump to be evaluated.

Segment Description

- 1 From Basin Inlet to 10" x 6" reducer below pad (Figures 4 and 6).
- 2 From 10" x 6" reducer below pad to inlet of RETB-P-2 (Figures 5 and 6).
- 3 From outlet of RETB-P-2 to tee above RETB-P-1 (Figures 5 and 6).
- 4 From tee above RETB-P-1 through radiation monitor to tee on line 4302 (Figures 5 and 6).
- 5 From 10" x 6" reducer below pad to inlet of RETB-P-1 (Figures 5 and 6).
- 6 From outlet of RETB-P-1 to tee above RETB-P-1 (Figures 5 and 6).
- 7 From tee on line 4302 to AG/UG connection to the underground PE pipe (Figures 7 and 8).
- 8 The PE piping starting just below grade to the tie-in to the treated water line (Figures 7 and 8).
- 9 The treated water line to the weir box at UTRC (Figures 7 and 8).

Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 6 of 42	Rev. 1
----------------------------------	----------------------	-----------

Table 1
Piping and Fluid Data

Friction Factors (f_r) (Ref. 1.1)

8 to 10-inch NPS Pipe	0.014
6-inch NPS Pipe	0.015
4-inch NPS Pipe	0.017

Absolute roughness (ϵ) pipe (Ref. 1.1):

Carbon Steel Pipe – CSP	0.00015 ft
Concrete Lined Pipe – CLP	0.01 ft

Absolute roughness (ϵ) pipe (Ref. 1.4):

Polyethylene pipe – PE	0.000005 ft
------------------------	-------------

Pipe Data	OD	ID	
10-inch 40S CLP - in.	10.750	9.520	(Ref. 1.1)
10-inch 40S Pipe - in.	10.750	10.020	(Ref. 1.1)
6-inch 40S Pipe - in.	6.625	6.065	(Ref. 1.1)
6-inch PE Pipe - in.	6.625	5.845	(Ref. 1.7)
4-inch 40S Pipe - in.	4.500	4.026	(Ref. 1.1)

Fluid Properties (Ref. 1.3)

	μ (cP)	SG	ρ (lbm/ft ³)
Water @ 68°F / 20°C	1.004	1.0	62.38

Table 2
Elevation Head for Flow Delivery Points

10" Sump suction elevation	254.05 ft
Min basin level elevation	259.50 ft
Max basin level elevation	270.00 ft
Max basin operating elevation	266.00 ft
Pump P-2 suction elevation (170-10)	271.90 ft
Pump P-1 suction elevation (EP-100H)	271.90 ft
4" Pipe Elevation Line - 4302 (max)	275.33 ft
6" Pipe Elevation Line - 4302 (max)	275.53 ft
High Point elevation	284.75 ft
Max elevation (estimated)	297.00 ft
Discharge elevation	131.75 ft

Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 7 of 42	Rev. 1
----------------------------------	----------------------	-----------

Table 3
 Segment Pipe Lengths, Fittings and Valves Tabulation

Pipe Segment				
Segment 1 - 10" Sch 40S, CLP	Total	W238897	W238978	W239022
Pipe (ft)	280.88	268.92		11.96
90° Standard Elbow	1			1
45° Standard Elbow	2	2		
Entrance, sharp edged	1	1		
Reducer 10x6	1			1
Segment 2 - 6-inch CSP Sch 40S - P-2	Total	W239022	W814332	& Figures 5 & 6
Pipe (ft)	12.41	4.31	8.09	
Butterfly Valve	1		1	
90° Standard Elbow	1		1	
Standard Tee, FTB	1		1	
Reducer 6x4	1		1	
Segment 3 - 4-inch CSP Sch 40S - P-2	Total	W814332	& Figures 5 & 6	
Pipe (ft)	13.86	13.86		
Enlarger 4x3	1	1		
Gate Valve	1	1		
Swing Check Valve (flanged)	1	1		
90° Standard Elbow	1	1		
45° Standard Elbow	2	2		
Standard Tee, FTR	2	2		
Standard Tee, FTB	1	1		
Segment 4 - 6-inch CSP Sch 40S	Total	W814332	& Figures 5 & 6	
Pipe (ft)	33.49	33.49		
Gate Valve	4	4		
90° Standard Elbow	5	5		
45° Standard Elbow	1	1		
Standard Tee, FTB	3	3		
Segment 5 - 6-inch Sch 40S - P-1	Total	W239022	W814332	& Figures 5 & 6
Pipe (ft)	6.74	4.31	2.43	
Butterfly Valve	1		1	
90° Standard Elbow	1		1	
Tee, FTB	3		3	

Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 8 of 42	Rev. 1
----------------------------------	----------------------	-----------

Table 3
 Segment Pipe Lengths, Fittings and Valves Tabulation
 (continued)

Segment 6 - 4-inch CSP Sch 40S - P-1	Total	W814332	& Figures 5 & 6
Pipe (ft)	2.77	2.77	
Gate Valve	1	1	
Standard Tee, FTB	1	1	
Segment 7 - 6-inch CSP Sch 40S	Total	W814332	& Figures 7 & 8
Pipe (ft)	257.24	257.24	
90° Standard Elbow	2	2	
Standard Tee, FTB	3	3	
Backflow Preventer	1	1	
Segment 8 - 6-inch PE Sch 40S	Total	W814332	& Figures 7 & 8
Pipe (ft)	48.17	48.17	
90° Standard Elbow	1	1	
Standard Tee, FTB	1	1	
Segment 9 - 6-inch PE Sch 40S	Total	W816274	
Pipe (ft)	762.69	762.69	
Segment 9 - 6-inch PE Sch 40S	Total	W816273	
Pipe (ft)	1500.00	1500.00	
Segment 9 - 6-inch PE Sch 40S	Total	W816272	
Pipe (ft)	1500.00	1500.00	
Segment 9 - 6-inch PE Sch 40S	Total	W816271	
Pipe (ft)	1500.00	1500.00	
Segment 9 - 6-inch PE Sch 40S	Total	W816270	
Pipe (ft)	1500.00	1500.00	
Segment 9 - 6-inch PE Sch 40S	Total	W816269	
Pipe (ft)	1500.00	1500.00	
Segment 9 - 6-inch PE Sch 40S	Total	W816268	
Pipe (ft)	1400.00	1400.00	
Segment 9 - 6-inch PE Sch 40S	Total	W816267	
Pipe (ft)	1500.00	1500.00	

Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 9 of 42	Rev. 1
----------------------------------	----------------------	-----------

Table 3
 Segment Pipe Lengths, Fittings and Valves Tabulation
 (continued)

Segment 9 - 6-inch PE Sch 40S	Total	W816266	
Pipe (ft)	1500.00	1500.00	
Segment 9 - 6-inch PE Sch 40S	Total	W816265	
Pipe (ft)	1400.00	1400.00	
Segment 9 - 6-inch PE Sch 40S	Total	W816264	D186328
Pipe (ft)	965.00	965.00	
Back Pressure Valve	1	1	

Computation

The following information establishes the methodology and formulas used to determine the head losses due to fluid flow through the piping system.

The system head curve will be based on the fluid characteristics of water as defined in Table 1. Determination of the system head curve will use the methods and equations contained in References 1, 2, and 3. The flow rate range was evaluated from 50 to 550 gpm, in 50 gpm increments. Microsoft Excel was used to generate spreadsheets and charts of the results. The system head curve is the sum of elevation head (h_s) and friction losses (h_L).

Elevation head (h_s), feet, is based on the elevation differences between the minimum liquid level of the basin and the discharge elevation at UTRC.

NOTE: A complete list of nomenclature, i.e., symbols, for this calculation is presented in Attachment 3.

Straight pipe friction losses (h_L), feet, will be calculated by the following equations.

$$h_L = 0.1863 (f L v^2 / d) \quad (\text{Ref. 1.1, Eq. 3-5})$$

Where:

$$v = q / A \quad (\text{Ref. 1.1, Eq. 1-1})$$

$$f = 0.25 / [\text{Log}_{10} (\epsilon / 3.7 d + 5.7 / R_e^{0.9})]^2 \quad (\text{Ref. 1.8})$$

Range of validity - ($5 \times 10^3 \leq R_e \leq 1 \times 10^7$) and ($1 \times 10^{-6} \leq \epsilon/D \leq 5 \times 10^{-2}$)

$$R_e = 50.6 (Q \rho / d \mu) \quad (\text{Ref. 1.1, Eq. 3-3})$$

Fittings and components frictional losses will be determined using the following equation. Note: Modified to include summation all fitting and component K values.

$$h_L = 0.00259 (Q^2 / d^4) \sum K \quad (\text{Ref. 1.1, Eq. 3-14})$$

The K values for various fittings will be determined using the methods of Reference 1, pages 3-4 and A-26 through A-29.

Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 10 of 42	Rev. 1
----------------------------------	-----------------------	-----------

NOTE: The calculated value for f will be used instead of f_T for all fittings, since the flow is not fully turbulent for the targeted flow rate.

Butterfly valve
 $K = 45 f_T$ (Ref. 1.1, A-28)

Ball valve ($\beta = 1$)
 $K = 3 f_T$ (Ref. 1.1, A-28)

Gate valve ($\beta = 1$)
 $K = 8 f_T$ (Ref. 1.1, A-27)

Swing Gate valve, flanged ($\beta = 1$)
 $K = 50 f_T$ (Ref. 1.1, A-27)

90° Standard Elbow
 $K = 30 f_T$ (Ref. 1.1, A-29)

45° Standard Elbow
 $K = 16 f_T$ (Ref. 1.1, A-29)

Tee, flow thru run (Standard Tee)
 $K = 20 f_T$ (Ref. 1.1, A-29)

Tee, flow thru branch (Standard Tee)
 $K = 60 f_T$ (Ref. 1.1, A-29)

K values for pipe entrance and exit are 0.5 and 1.0, respectively. (Ref. 1.1, A-29)

For conservatism, the resistance to flow for reducers and enlargers is as follows:

Reducers
 $K = (1 - d_1^2/d_2^2)^2$ (Ref. 1.1, Eq. 2-9)

Enlargers
 $K = 0.5 (1 - d_1^2/d_2^2)$ (Ref. 1.1, Eq. 2-9)

To verify that the existing and/or selected motor for the pump is adequate, the following equation is used to estimate the required brake horsepower:

$$\text{BHP} = Q h S / 3960 \eta \quad (\text{Ref. 1.2, Eq. 15})$$

7. Analysis Results

The system head requirements for the Basin Water to UTRC System for the two pumps are tabulated in attachment 4. The results are graphically presented in Figures 9 and 10 for comparison.

Pump RETB-P-1 has a 40 hp motor. Based on the pump-system curve at a flow rate of 350 gpm the motor efficiency (η) is approximately 0.50 (Ref. 1.11). Therefore, the required brake horse power required is:

$$\text{BHP} = 350 * 158 * 1 / 3960 * 0.50$$

$$\text{BHP} = 28$$

Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 11 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Pump RETB-P-2 has a 7.5 hp motor. Based on the pump-system curve at a flow rate of 175 gpm the motor efficiency (η) is approximately 0.50 (Ref. 1.12). Therefore, the required brake horse power required is:

$$\text{BHP} = 175 * 55 * 1 / 3960 * 0.50$$
$$\text{BHP} = 4.9$$

A backflow preventer (BFP) is required based on the tie-in point elevation to the TWL. By inspection of Figure 2, without the BFP, water would flow into the basin if the isolation valves are not closed.

8. Conclusions

Figure 9 shows the system-pump-bhp curves for the transfer route using RETB-P-1. From the data presented, it can be concluded:

- The operating point for this system is approximately 350 gpm.
- The existing motor will provide the necessary brake horse power for the above flow rate.
- When RETB-P-1 is used, flow will must be throttled using a discharge valve to meet the flow rate requirement range of 175 to 225 gpm (Input 4.2)

Figure 10 shows the system-pump-bhp curves for the transfer route using RETB-P-2.




- The operating point for this system is approximately 175 gpm.
- The existing motor will provide the necessary brake horse power for the above flow rate.

Based on the profile of the Treated Water Line in Figure 2, a back flow preventer is required to prevent the draining of treated water back into the basin.

Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 12 of 42	Rev. 1
----------------------------------	-----------------------	-----------


Figure 1
 Proposed P&ID for Basin Water Tie-in to the Treated Water Line



Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 13 of 42	Rev. 1
----------------------------------	-----------------------	-----------




Figure 2
 Treated Water Line Profile



Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 14 of 42	Rev. 1
----------------------------------	-----------------------	-----------


Figure 3
 Over View of the Basin Water Flow Path



Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 15 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Figure 4
Piping Length from Basin to Pumps





SOUTH CAROLINA
SAVANNAH RIVER
RESERVE AREA
CERTIFICATE OF AUTHORITY

SOUTH CAROLINA
LICENSED PROFESSIONAL ENGINEER
No. 22845
MICHAEL BRYAN WJOC
Michael B. Wood
6-5-13

Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 16 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Figure 5
Piping Route at Pumps and to Line 4302




Michael Wood
6.5.13

Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 17 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Figure 6
 Elevation of Piping from Basin to Pumps






SOU
 3/1/83

SOU
 LICENSED PROFESSIONAL ENGINEER
 No. 2284
 MICHAEL BRYAN
 6.5.13

Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 18 of 42	Rev. 1
----------------------------------	-----------------------	-----------


Figure 7
 Line 4302 to Treated Water Line Tie-in Point



Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 19 of 42	Rev. 1
----------------------------------	-----------------------	-----------


Figure 8
 Elevation of Pipe Tie-in at Treated Water Line



Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 20 of 42	Rev. 1
----------------------------------	-----------------------	-----------


Figure 9
 System-Pump Curve for the Transfer Route Using RETB-P-1



Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 21 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Figure 10
 System-Pump Curve for the Transfer Route Using RETB-P-2



Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 22 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Attachment 1 Nomenclature

A	Cross sectional area of pipe or orifice (ft ²)
a	Cross sectional area of pipe or orifice (in ²)
h_L	Friction head (ft)
h_v	Velocity head (ft)
h_s	Static head (ft)
h_T	Total Dynamic Head (ft)
g	Gravity acceleration constant (32.174 ft/sec ²)
f	Friction factor (Darcy)
h	Total Head (ft)
L	Length (ft)
V	Fluid velocity (ft/sec)
d	Pipe inside diameter (in)
D	Pipe inside diameter (ft)
K	Resistance coefficient
f_T	Friction factor in zone of complete turbulent flow
R_e	Reynolds Number
ρ	Density (lb _m /ft ³)
μ	Dynamic viscosity (cp)
Q	Rate of flow (gallons/min)
q	Rate of flow (ft ³ /sec)
β	Ratio of small to large diameter in contractions or enlargements in pipes
ϵ	Absolute Roughness (ft)
η	Pump Efficiency
S	Specific Gravity
C	Flow coefficient for orifice
BHP	Brake Horse Power

Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 23 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Attachment 2
Backflow Preventer Data

ES-709L

For Non-Health Hazard Applications

Job Name _____	Contractor _____
Job Location _____	Approval _____
Engineer _____	Contractor's P.O. No. _____
Approval _____	Representative _____

**Series 709
 Double Check Valve Assemblies**

Sizes: 2½" - 10" (65 - 250mm)

Series 709 Double Check Valve Assemblies are designed to prevent the reverse flow of polluted water from entering into the potable water system. This series can be applied, where approved by the local authority having jurisdiction, on non-health hazard installations. Series 709 features a modular check design concept to facilitate easy maintenance. Check with local jurisdictional authority as to installation requirements.

Features


- Replaceable bronze seats
- Maximum flow at low pressure drop
- Design simplicity for easy maintenance
- No special tools required for servicing
- Captured spring assemblies for safety
- Approved for vertical flow up installation

Models


- Suffix:
- NRS - non-rising stem resilient seated gate valves
 - OSY - UL/FM outside stem and yoke resilient seated gate valves
 - S-FDA - FDA epoxy coated strainer
 - BB - bronze body - 2½" - 3" (64 - 76mm)
 - QT - quarter-turn ball valves
 - QT-FDA - FDA epoxy coated ball valve shutoffs
 - LF - without shutoff valves

Specifications

A Double Check Valve Assembly shall be installed at referenced cross-connections to prevent the backflow of polluted water into the potable water supply. The cross-connections shall be determined by local inspection authority for use where a high hazard situation does not exist. Valve shall feature modular check assemblies with center stem guiding. Each check module shall have a captured spring and be accessible through a bolted cover plate. Seats shall be replaceable without special tools. It shall be a complete assembly including tight-closing resilient seated shutoff valves, test cocks, and a strainer is recommended. The assembly shall meet the requirements of ASSE No. 1015; AWWA C510-92; CSA B64.5 and UL Classified File No. EX3185. Approved by the Foundation for Cross-Connection Control and Hydraulic Research at the University of Southern California. Assembly shall be a Watts Regulator Company Series 709.



709 OSY



Check Assembly Module

Series 709 features a modular design concept which facilitates complete maintenance and assembly by retaining the spring load. Also, the first and second check module are identical and can be interchanged.

**IMPORTANT: INQUIRE WITH GOVERNING AUTHORITIES
 FOR LOCAL INSTALLATION REQUIREMENTS**

Now Available
WattsBox Insulated Enclosures.
 For more information, send for literature ES-WB.

All products conform to U.S. customary units and metric. All dimensions and are provided for reference only. For precise dimensions, please contact Watts Technical Service. Watts reserves the right to change or modify product design, construction, specifications, or materials without prior notice and without incurring any obligation to those who have purchased or installed Watts products previously or subsequently.



Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 24 of 42	Rev. 1
----------------------------------	-----------------------	-----------

**Attachment 2
 Backflow Preventer Data
 (continued)**

Materials

Check Valve Bodies: Epoxy coated cast iron
 Seats: Bronze

Pressure — Temperature

Temperatures Range: 33°F – 110°F (0.5°C – 43°C) continuous,
 140°F (60°C) intermittent
 Maximum Working Pressure: 175psi (12.1 bar)

Standards

AWWA C610-92
 IAPMO PA 31
 USC Manual for Cross-Connection Control, 8th Edition


Approvals



Approved by the Foundation for Cross-Connection Control and Hydraulic Research at the University of Southern California. Sizes 4" – 10" (100 – 250mm) approved horizontal and vertical "flow up" Size 2" and 3" (65 – 80mm) approved horizontal only.

Factory Mutual approved 4" – 10" (80 – 250mm) vertical "flow up" with OSY gate valves only.
 Note: Model "S" not listed

Dimensions — Weights



SIZE (DN)		DIMENSIONS													
in.	mm	A	OST	C (RS)	D	L	UP	M	N						
in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm				
2 1/2	65	39 1/2	1000	16 1/2	416	3 1/2	89	24 1/2	613	11	279	10	254	6 1/2	165
3	80	40 1/2	1025	16 1/2	429	3 1/2	89	24 1/2	613	14	356	10 1/2	267	7	178
4	100	52 1/2	1330	22 1/2	578	4 1/2	114	34 1/2	867	14	356	12 1/2	308	8 1/2	210
6	150	62 1/2	1597	30 1/2	765	6 1/2	140	41 1/2	1057	16	406	18 1/2	470	13 1/2	343
8	200	75 1/2	1905	37 1/2	950	8 1/2	165	52 1/2	1321	21	533	21 1/2	549	15 1/2	394
10	250	99	2266	49 1/2	1162	10 3/4	260	64 1/2	1628	25	635	26	660	18 1/2	470

SIZE (DN)		DIMENSIONS						WEIGHT				STRAINER					
in.	mm	HT	R	Ro	T	NSC	NSC	OT	OT	NSC	OT	NSC	OT				
in.	mm	in.	mm	in.	mm	lbs.	kg	lbs.	kg	lbs.	kg	lbs.	kg				
2 1/2	65	10	254	4	102	16	406	3	76	167	76	170	77	154	70	28	13
3	80	10	254	5	127	16	406	3	76	167	76	170	77	162	73	34	15
4	100	12	305	6	152	19 1/2	502	6	152	368	167	383	174	275	125	50	27
6	150	20	508	11	279	26	660	11	279	627	284	707	321	611	277	122	55
8	200	22 1/2	578	11 1/2	286	11 1/2	286	9	229	1201	545	1307	593	1419	644	247	112
10	250	28	711	12 1/2	318	12 1/2	318	10 3/4	260	2003	907	2073	940	2466	1119	370	168

† - Dimension required for screen removal. † Quarter-turn (QT) valve dimensions.
 *Service clearance for check assembly from center.


Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 25 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Attachment 2
 Backflow Preventer Data
 (continued)

Capacity

*Typical maximum system flow rate (7.5 feet/sec.) **UL rated flow



Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 26 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Attachment 3
 Head Loss Calculation

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Basin Water																
3	$p =$	62.38	lbs _m /ft ³														
4	$\mu =$	1.004	cP														
5	Segment 1 - 10" Sch 40S, CLP																
6	$e =$	0.01	ft														
7	$d =$	9.520	inches														
8	$D =$	0.7933	feet														
9	$L =$	280.88	feet														
10	Q (gpm) =	50		150		200		250		300		350		400		450	
11	v (fps) =	0.23		0.45		0.66		0.90		1.13		1.35		1.58		1.80	
12	$R_e =$	16,512		33,024		49,535		66,047		82,559		99,071		115,583		132,095	
13	$f =$	0.0293		0.0258		0.0243		0.0229		0.0222		0.0220		0.0218		0.0216	
14	h_f (ft) =	0.01		0.03		0.06		0.10		0.16		0.23		0.30		0.39	
15	h_f Pipe (ft) =	0.00		0.01		0.02		0.03		0.04		0.06		0.08		0.11	
16	h_f Fittings (ft) =	0.01		0.04		0.08		0.13		0.20		0.29		0.39		0.50	
17	Total h_f (ft) =																
18																	
19																	
20	Segment 2 - 6-inch CSP Sch 40S - P-2																
21	$e =$	0.00015	ft														
22	$d =$	6.065	inches														
23	$D =$	0.5054	feet														
24	$L =$	12.41	feet														
25	Q (gpm) =	50		100		150		200		250		300		350		400	
26	v (fps) =	0.56		1.11		1.67		2.22		2.78		3.33		3.89		4.44	
27	$R_e =$	25,918		51,836		77,754		103,672		129,590		155,508		181,426		207,344	
28	$f =$	0.0242		0.0207		0.0189		0.0179		0.0171		0.0165		0.0160		0.0156	
29	h_f (ft) =	0.00		0.01		0.02		0.03		0.05		0.07		0.09		0.12	
30	h_f Pipe (ft) =	0.00		0.00		0.00		0.00		0.00		0.00		0.00		0.00	
31	h_f Fittings (ft) =	0.02		0.06		0.12		0.21		0.31		0.43		0.57		0.73	
32	Total h_f (ft) =	0.02		0.07		0.14		0.24		0.36		0.50		0.66		0.85	
33																	
34																	
35																	
36																	
37																	
38	Segment 3 - 4-inch CSP Sch 40S - P-2																
39	$e =$	0.00015	ft														
40	$d =$	4.026	inches														
41	$D =$	0.3355	feet														
42	$L =$	13.86	feet														
43	Q (gpm) =	50		100		150		200		250		300		350		400	
44	v (fps) =	1.26		2.52		3.78		5.04		6.30		7.56		8.82		10.08	
45	$R_e =$	39,044		78,089		117,133		156,177		195,222		234,266		273,311		312,355	
46	$f =$	0.0221		0.0190		0.0175		0.0166		0.0159		0.0154		0.0150		0.0147	
47	h_f (ft) =	0.02		0.08		0.16		0.27		0.41		0.57		0.75		0.96	
48	h_f Pipe (ft) =	0.07		0.24		0.51		0.85		1.29		1.80		2.39		3.06	
49	h_f Fittings (ft) =	0.09		0.32		0.67		1.12		1.69		2.36		3.14		4.01	
50	Total h_f (ft) =																
51																	
52																	
53																	
54																	
55																	
56																	
57																	
58																	
59																	
60																	

Segment 1 - 10" Sch 40S, CLP	P	Q	R
Fittings			
90° Standard Elbow	30	1	30.0
45° Standard Elbow	16	2	32.0
Total			62.0

Segment 1 - 10" Sch 40S, CLP	K-factor	Number	Sub-total
Entrance, sharp edged	0.5	1	0.5
Reducer 10x6	0.317	1	0.317
Total			0.8

Segment 2 - 6-inch CSP Sch 40S - P-2	P	Q	R
Fittings			
Butterfly Valve	45	1	45.0
90° Standard Elbow	30	1	30.0
Standard Tee, FTB	60	1	60.0
Total			135.0

Segment 2 - 6-inch CSP Sch 40S - P-2	K-factor	Number	Sub-total
Reducer 6x4	0.280	1	0.280
Total			0.3

Segment 3 - 4-inch CSP Sch 40S - P-2	P	Q	R
Fittings			
Gate Valve	8	1	8.0
Swing Check Valve (flanged)	50	1	50.0
90° Standard Elbow	30	1	30.0
45° Standard Elbow	16	2	32.0
Standard Tee, FTB	20	2	40.0
Standard Tee, FTB	60	1	60.0
Total			120.0

Segment 3 - 4-inch CSP Sch 40S - P-2	K-factor	Number	Sub-total
Enlarger 4x3	0.176	1	0.176
Total			0.176

Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 28 of 42	Rev. 1
---	------------------------------	------------------

**Attachment 3
 Head Loss Calculation**

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
125	Segment 7 - 6-inch CSP Sch 40S																
126	ϵ	= 0.00015 ft															
127	d	= 6.065 inches															
128	D	= 0.5054 feet															
129	L	= 257.24 feet															
130	Q (gpm)	= 50	100	150	200	250	300	350	400	450	500	550					
131	v (fps)	= 0.56	1.11	1.67	2.22	2.78	3.33	3.89	4.44	5.00	5.55	6.11					
132	R _s	= 25,918	51,836	77,754	103,672	129,590	155,508	181,425	207,344	233,262	259,180	285,098					
133	f	= 0.0242	0.0207	0.0189	0.0179	0.0171	0.0165	0.0160	0.0156	0.0153	0.0150	0.0148					
134	h _L Pipe (ft)	= 0.06	0.20	0.42	0.70	1.04	1.45	1.91	2.44	3.02	3.66	4.35					
135	h _L Fittings (ft)	= 0.03	0.09	0.20	0.33	0.49	0.68	0.90	1.15	1.42	1.72	2.05					
136	h _L BFP (ft)	= 12.69	12.69	12.69	12.69	12.69	12.69	12.69	12.69	12.69	12.69	12.69					
137	Total h _L (ft)	= 12.77	12.98	13.30	13.71	14.22	14.82	15.50	16.27	17.13	18.07	19.09					
138																	
139																	
140																	
141																	
142																	
143																	
144																	
145																	
146																	
147																	
148																	
149																	
150																	
151																	
152	Segment 8 - 6-inch PE Sch 40S																
153	ϵ	= 0.000005 ft															
154	d	= 5.845 inches															
155	D	= 0.4871 feet															
156	L	= 48.17 feet															
157	Q (gpm)	= 50	100	150	200	250	300	350	400	450	500	550					
158	v (fps)	= 0.60	1.20	1.79	2.39	2.99	3.59	4.19	4.78	5.38	5.98	6.58					
159	R _s	= 26,894	53,787	80,681	107,574	134,468	161,361	188,255	215,148	242,042	268,935	295,829					
160	f	= 0.0240	0.0204	0.0187	0.0176	0.0168	0.0162	0.0157	0.0153	0.0150	0.0147	0.0144					
161	h _L Pipe (ft)	= 0.01	0.04	0.09	0.15	0.23	0.32	0.42	0.54	0.66	0.80	0.96					
162	h _L Fittings (ft)	= 0.01	0.04	0.07	0.12	0.18	0.25	0.33	0.42	0.52	0.63	0.75					
163	Total h _L (ft)	= 0.02	0.08	0.16	0.28	0.41	0.57	0.75	0.96	1.19	1.44	1.71					
164																	
165																	
166																	
167																	
168																	
169																	
170																	
171																	
172	Segment 9 - 6-inch PE Sch 40S																
173	ϵ	= 0.000005 ft															
174	d	= 5.845 inches															
175	D	= 0.4871 feet															
176	L	= 15,027.69 feet															
177	Q (gpm)	= 50	100	150	200	250	300	350	400	450	500	550					
178	v (fps)	= 0.60	1.20	1.79	2.39	2.99	3.59	4.19	4.78	5.38	5.98	6.58					
179	R _s	= 26,894	53,787	80,681	107,574	134,468	161,361	188,255	215,148	242,042	268,935	295,829					
180	f	= 0.0240	0.0204	0.0187	0.0176	0.0168	0.0162	0.0157	0.0153	0.0150	0.0147	0.0144					
181	h _L Pipe (ft)	= 4.10	13.97	28.76	48.14	71.86	99.76	131.72	167.64	207.43	251.02	298.35					
182	h _L Fittings (ft)	= 135.00	135.00	135.00	135.00	135.00	135.00	135.00	135.00	135.00	135.00	135.00					
183	Total h _L (ft)	= 139.10	148.97	163.76	183.14	206.86	234.76	266.72	302.64	342.43	386.02	433.35					
184																	

Segment 7 - 6-inch CSP Sch 40S	P	Q	R
Fittings	K-multiple	Number	Sub-Total
90° Standard Elbow	30	2	60.0
Standard Tee, FTB	60	3	180.0
	Total		240.0

Segment 8 - 6-inch PE Sch 40S	P	Q
Fittings	K-multiple	Number
90° Standard Elbow	30	1
Standard Tee, FTB	60	1
	Total	

Attachment 9.12

Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 29 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Attachment 4
 Summary of Head Loss

A	B	C	D	E	F	G	H	I	J	K	L	M
191	System Curve - RETB- P-1											
192	Summary of h_L (ft)											
193	Q (gpm) =	50	100	150	200	250	300	350	400	450	500	550
194	Total h_L (ft) Segment 1 =	0.01	0.04	0.08	0.13	0.20	0.29	0.39	0.50	0.63	0.77	0.93
195	Total h_L (ft) Segment 5 =	0.03	0.11	0.22	0.37	0.55	0.76	1.01	1.28	1.59	1.93	2.29
196	Total h_L (ft) Segment 6 =	0.01	0.04	0.08	0.14	0.21	0.29	0.39	0.50	0.62	0.75	0.89
197	Total h_L (ft) Segment 7 =	12.77	12.98	13.30	13.71	14.22	14.82	15.50	16.27	17.13	18.07	19.09
198	Total h_L (ft) Segment 8 =	0.02	0.08	0.16	0.28	0.41	0.57	0.75	0.96	1.19	1.44	1.71
199	Total h_L (ft) Segment 9 =	139.10	148.97	163.76	183.14	206.86	234.76	266.72	302.64	342.43	386.02	433.35
200	h_L Static (ft) =	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75
201	h_L Pressure (ft) =	0	0	0	0	0	0	0	0	0	0	0
202	h_L Velocity (ft) =	0	0	0	0	0	0	0	0	0	0	0
203	Total h_L (ft)	24.20	34.46	49.86	70.02	94.70	123.74	157.02	194.41	235.84	281.24	330.52

A	B	C	D	E	F	G	H	I	J	K	L	M
209	System Curve - RETB- P-2											
210	Summary of h_L (ft)											
211	Q (gpm) =	50	100	150	200	250	300	350	400	450	500	550
212	Total h_L (ft) Segment 1 =	0.01	0.04	0.08	0.13	0.20	0.29	0.39	0.50	0.63	0.77	0.93
213	Total h_L (ft) Segment 2 =	0.02	0.07	0.14	0.24	0.36	0.50	0.66	0.85	1.05	1.28	1.53
214	Total h_L (ft) Segment 3 =	0.09	0.32	0.67	1.12	1.69	2.36	3.14	4.01	4.99	6.07	7.24
215	Total h_L (ft) Segment 4 =	0.01	0.03	0.05	0.09	0.14	0.19	0.25	0.32	0.39	0.48	0.57
216	Total h_L (ft) Segment 7 =	12.77	12.98	13.30	13.71	14.22	14.82	15.50	16.27	17.13	18.07	19.09
217	Total h_L (ft) Segment 8 =	0.02	0.08	0.16	0.28	0.41	0.57	0.75	0.96	1.19	1.44	1.71
218	Total h_L (ft) Segment 9 =	139.10	148.97	163.76	183.14	206.86	234.76	266.72	302.64	342.43	386.02	433.35
219	h_L Static (ft) =	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75	-127.75
220	h_L Pressure (ft) =	0	0	0	0	0	0	0	0	0	0	0
221	h_L Velocity (ft) =	0	0	0	0	0	0	0	0	0	0	0
222	Total h_L (ft)	24.28	34.73	50.42	70.96	96.13	125.74	159.67	197.81	240.07	286.38	336.67

Attachment 9.12
Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 31 of 42	Rev. 1
---	------------------------------	------------------

A41	B	C	D	E	F
42	Pipe Segment	Total			
43	Segment 1 - 10" Sch 40S, CLP	Total	W238897	W238978	W239022
44	Pipe (ft)	280.88	268.92		11.96
45	90° Standard Elbow	1			
46	45° Standard Elbow	2	2		1
47	Entrance, sharp edged	1	1		
48	Reducer 10x6	1			1
49	Segment 2 - 6-inch CSP Sch 40S - P-2	Total	W239022	W814332	& Figures 5 & 6
50	Pipe (ft)	12.41	4.31	8.09	
51	Butterfly Valve	1		1	
52	90° Standard Elbow	1		1	
53	Standard Tee, FTB	1		1	
54	Reducer 6x4	1		1	
55	Segment 3 - 4-inch CSP Sch 40S - P-2	Total	W814332	& Figures 5 & 6	
56	Pipe (ft)	13.86	13.86		
57	Enlarger 4x3	1	1		
58	Gate Valve	1	1		
59	Swing Check Valve (flanged)	1	1		
60	90° Standard Elbow	1	1		
61	45° Standard Elbow	2	2		
62	Standard Tee, FIR	2	2		
63	Standard Tee, FTB	1	1		
64	Segment 4 - 6-inch CSP Sch 40S	Total	W814332	& Figures 5 & 6	
65	Pipe (ft)	33.49	33.49		
66	Gate Valve	4	4		
67	90° Standard Elbow	5	5		
68	45° Standard Elbow	1	1		
69	Standard Tee, FTB	3	3		
70	Segment 5 - 6-inch Sch 40S - P-1	Total	W239022	W814332	& Figures 5 & 6
71	Pipe (ft)	6.74	4.31	2.43	
72	Butterfly Valve	1		1	
73	90° Standard Elbow	1		1	
74	Tee, FTB	3		3	
75	Segment 6 - 4-inch CSP Sch 40S - P-1	Total	W814332	& Figures 5 & 6	
76	Pipe (ft)	2.77	2.77		
77	Gate Valve	1	1		
78	Standard Tee, FTB	1	1		
79	Segment 7 - 6-inch CSP Sch 40S	Total	W814332	& Figures 7 & 8	
80	Pipe (ft)	257.24	257.24		
81	90° Standard Elbow	2	2		
82	Standard Tee, FTB	3	3		
83	Backflow Preventer	1	1		
84	Segment 8 - 6-inch PE Sch 40S	Total	W814332	& Figures 7 & 8	
85	Pipe (ft)	48.17	48.17		
86	90° Standard Elbow	1	1		
87	Standard Tee, FTB	1	1		
88	Segment 9 - 6-inch PE Sch 40S	Total	W816274		
89	Pipe (ft)	762.69	762.69		
90	Segment 9 - 6-inch PE Sch 40S	Total	W816273		
91	Pipe (ft)	1500.00	1500.00		
92	Segment 9 - 6-inch PE Sch 40S	Total	W816272		
93	Pipe (ft)	1500.00	1500.00		
94	Segment 9 - 6-inch PE Sch 40S	Total	W816271		
95	Pipe (ft)	1500.00	1500.00		
96	Segment 9 - 6-inch PE Sch 40S	Total	W816270		
97	Pipe (ft)	1500.00	1500.00		
98	Segment 9 - 6-inch PE Sch 40S	Total	W816269		
99	Pipe (ft)	1500.00	1500.00		
100	Segment 9 - 6-inch PE Sch 40S	Total	W816268		
101	Pipe (ft)	1400.00	1400.00		
102	Segment 9 - 6-inch PE Sch 40S	Total	W816267		
103	Pipe (ft)	1500.00	1500.00		
104	Segment 9 - 6-inch PE Sch 40S	Total	W816266		
105	Pipe (ft)	1500.00	1500.00		
106	Segment 9 - 6-inch PE Sch 40S	Total	W816265		
107	Pipe (ft)	1400.00	1400.00		
108	Segment 9 - 6-inch PE Sch 40S	Total	W816264	D186328	
109	Pipe (ft)	965.00	965.00		
110	Back Pressure Valve	1	1		

Attachment 5
 Excel Spreadsheet Formulae

Attachment 9.12
 Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 32 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Attachment 5
 Excel Spreadsheet Formulae

A	B	C	D	E	F	G	H	I	J	K	L	M
2	Basin Water											
3	ρ	=DATA!\$E3	lbs./ft ³									
4	μ	=DATA!\$C3	cP									
5	=DATA!\$B43											
6	e	=DATA!\$C312	ft									
7	d	=DATA!\$D16	Inches									
8	D	=C7/12	feet									
9	L	=DATA!\$C344	feet									
10	Q (gpm)	=DATA!\$D324										
11	v (fps)	= $(C10^4 * 144) / (7.48 * 60 * (\$C37^A) / 2 * \pi * D)$										
12	R _e	= $(50.6 * C10 * (\$C33) / (\$C37 * (\$C34)))$										
13	f	= $0.25 / (\text{LOG}10((\$C36 / (3.7 * (\$C37 + 5.7 / (C12 * 0.9)) / 2)))$										
14	h _L Pipe (ft)	= $0.1863 * C13 * (\$C39 * C11 / 2) / (\$C37)$										
15	h _L Fittings (ft)	= $0.00259 * (C10^2 / (\$C37^4)) * (\$R36 * C13 + (\$R31))$										
16	Total h _L (ft)	=SUM(C15:C16)										
17												

N	O	P	Q	R
2	=DATA!\$B43		Number	Sub-total
3	Fittings	K-multiple		
4	=DATA!\$B45	30	=DATA!\$C45	=P4*Q4
5	=DATA!\$B46	16	=DATA!\$C46	=P5*Q5
6			Total	=SUM(R4:R5)
7	=DATA!\$B43		Number	Sub-total
8	Fittings	K-factor		
9	=DATA!\$B47	0.5	=DATA!\$C47	=P8 * Q8
10	=DATA!\$B48	= 0.5 * (1-DATA!\$D19/2/DATA!\$D31/72)	=DATA!\$C48	=P10*Q10
11			Total	=SUM(R8:R10)

Attachment 9.12
 Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 33 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Attachment 5
 Excel Spreadsheet Formulae

A	B	C	D	E	F	G	H	I	J	K	L	M
28	=DATA!B49											
29	e =	=DATA!C\$11	ft									
30	d =	=DATA!D19	inches									
31	D =	=C30/12	feet									
32	L =	=DATA!C50	feet									
33	=B\$10	=DATA!C\$24	=DATA!D\$24	=DATA!E\$24	=DATA!F\$24	=DATA!G\$24	=DATA!H\$24	=DATA!I\$24	=DATA!J\$24	=DATA!K\$24	=DATA!L\$24	=DATA!M\$24
34	=B\$11	= (C33*4*144)/(48*60*(C\$30^2)*PI())	= (D33*4*144)/(48*60*(C\$30^2)*PI())	= (E33*4*144)/(48*60*(C\$30^2)*PI())	= (F33*4*144)/(48*60*(C\$30^2)*PI())	= (G33*4*144)/(48*60*(C\$30^2)*PI())	= (H33*4*144)/(48*60*(C\$30^2)*PI())	= (I33*4*144)/(48*60*(C\$30^2)*PI())	= (J33*4*144)/(48*60*(C\$30^2)*PI())	= (K33*4*144)/(48*60*(C\$30^2)*PI())	= (L33*4*144)/(48*60*(C\$30^2)*PI())	= (M33*4*144)/(48*60*(C\$30^2)*PI())
35	R _e =	= (50.6 * C33 * C\$30) / (C\$30 * C\$34)	= (50.6 * D33 * C\$30) / (C\$30 * C\$34)	= (50.6 * E33 * C\$30) / (C\$30 * C\$34)	= (50.6 * F33 * C\$30) / (C\$30 * C\$34)	= (50.6 * G33 * C\$30) / (C\$30 * C\$34)	= (50.6 * H33 * C\$30) / (C\$30 * C\$34)	= (50.6 * I33 * C\$30) / (C\$30 * C\$34)	= (50.6 * J33 * C\$30) / (C\$30 * C\$34)	= (50.6 * K33 * C\$30) / (C\$30 * C\$34)	= (50.6 * L33 * C\$30) / (C\$30 * C\$34)	= (50.6 * M33 * C\$30) / (C\$30 * C\$34)
36	f =	= 0.25 / (LOG10(C\$28 / (3.7 * C\$30 + 5.7 / (C35*0.9)))^2)	= 0.25 / (LOG10(C\$29 / (3.7 * C\$30 + 5.7 / (D35*0.9)))^2)	= 0.25 / (LOG10(C\$30 / (3.7 * E\$30 + 5.7 / (E35*0.9)))^2)	= 0.25 / (LOG10(C\$31 / (3.7 * F\$30 + 5.7 / (F35*0.9)))^2)	= 0.25 / (LOG10(C\$32 / (3.7 * G\$30 + 5.7 / (G35*0.9)))^2)	= 0.25 / (LOG10(C\$33 / (3.7 * H\$30 + 5.7 / (H35*0.9)))^2)	= 0.25 / (LOG10(C\$34 / (3.7 * I\$30 + 5.7 / (I35*0.9)))^2)	= 0.25 / (LOG10(C\$35 / (3.7 * J\$30 + 5.7 / (J35*0.9)))^2)	= 0.25 / (LOG10(C\$36 / (3.7 * K\$30 + 5.7 / (K35*0.9)))^2)	= 0.25 / (LOG10(C\$37 / (3.7 * L\$30 + 5.7 / (L35*0.9)))^2)	= 0.25 / (LOG10(C\$38 / (3.7 * M\$30 + 5.7 / (M35*0.9)))^2)
37	h ₁ Pipe (ft)	= 0.1863 * C38 * C\$32 * C34^2 / C\$30	= 0.1863 * D38 * C\$32 * D34^2 / C\$30	= 0.1863 * E38 * C\$32 * E34^2 / C\$30	= 0.1863 * F38 * C\$32 * F34^2 / C\$30	= 0.1863 * G38 * C\$32 * G34^2 / C\$30	= 0.1863 * H38 * C\$32 * H34^2 / C\$30	= 0.1863 * I38 * C\$32 * I34^2 / C\$30	= 0.1863 * J38 * C\$32 * J34^2 / C\$30	= 0.1863 * K38 * C\$32 * K34^2 / C\$30	= 0.1863 * L38 * C\$32 * L34^2 / C\$30	= 0.1863 * M38 * C\$32 * M34^2 / C\$30
39	h ₁ Fittings (ft)	= 0.00259 * (C39^2 / (C\$30^4) * (R\$33 * C38 + R\$37))	= 0.00259 * (D39^2 / (C\$30^4) * (R\$33 * D38 + R\$37))	= 0.00259 * (E39^2 / (C\$30^4) * (R\$33 * E38 + R\$37))	= 0.00259 * (F39^2 / (C\$30^4) * (R\$33 * F38 + R\$37))	= 0.00259 * (G39^2 / (C\$30^4) * (R\$33 * G38 + R\$37))	= 0.00259 * (H39^2 / (C\$30^4) * (R\$33 * H38 + R\$37))	= 0.00259 * (I39^2 / (C\$30^4) * (R\$33 * I38 + R\$37))	= 0.00259 * (J39^2 / (C\$30^4) * (R\$33 * J38 + R\$37))	= 0.00259 * (K39^2 / (C\$30^4) * (R\$33 * K38 + R\$37))	= 0.00259 * (L39^2 / (C\$30^4) * (R\$33 * L38 + R\$37))	= 0.00259 * (M39^2 / (C\$30^4) * (R\$33 * M38 + R\$37))
40	Total h ₁ (ft)	= SUM(C38:C39)	= SUM(D38:D39)	= SUM(E38:E39)	= SUM(F38:F39)	= SUM(G38:G39)	= SUM(H38:H39)	= SUM(I38:I39)	= SUM(J38:J39)	= SUM(K38:K39)	= SUM(L38:L39)	= SUM(M38:M39)

N	O	P	Q	R
28	=DATA!B\$49			
29	Fittings	K-multiple	Number	Sub-total
30	=DATA!B\$51	45	=DATA!C\$51	=P30*Q30
31	=DATA!B\$52	30	=DATA!C\$52	=P31*Q31
32	=DATA!B\$53	60	=DATA!C\$53	=P32 * Q32
33			Total	=SUM(R30:R32)
34	=DATA!B\$49			
35	Fittings	K-factor	Number	Sub-total
36	=DATA!B\$54	= 0.5 * (1-DATA!D\$21/DATA!D\$19)^2	=DATA!C\$54	=P36*Q36
37			Total	=SUM(R36:R38)

Attachment 9.12
 Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 34 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Attachment 5
 Excel Spreadsheet Formulae

A	B	C	D	E	F	G	H	I	J	K	L	M
48	=DATA!B\$5											
49	k =	=DATA!C\$11	R									
50	d =	=DATA!D21	inches									
51	D =	=C50/12	feet									
52	L =	=DATA!C36	feet									
53	=B\$10	=DATA!C\$24										
54	=B\$11	= (C53*4*144) / (7.48*60*(C\$350 - 2)*PI())										
55	R _a =	= (50.6 * C53 * C\$33) / (C\$350 * C\$34)										
56	f =	= 0.25 / (LOG10(C\$349 / (3.7 / C\$350 + 5.7 / (55*0.9)))^2)										
57												
58	h ₁ Pipe (ft)	= 0.1863 * C56 * C\$352 * C54^2 / C\$350										
59	N ₁ Fittings (ft)	= 0.00259 * (C53^2 / C\$350^4) * (R\$556 * C56 + R\$1860)										
60	Total h ₁ (ft)	=SUM(C58:C59)										

N	O	P	Q	R
48	=DATA!B\$5			
49	Fittings	K-multiple	Number	Sub-total
50	=DATA!B\$58	8	=DATA!C\$58	=P50*Q50
51	=DATA!B\$59	50	=DATA!C\$59	=P51*Q51
52	=DATA!B\$60	30	=DATA!C\$60	=P52*Q52
53	=DATA!B\$61	16	=DATA!C\$61	=P53 * Q53
54	=DATA!B\$62	20	=DATA!C\$62	=P54 * Q54
55	=DATA!B\$63	60	=DATA!C\$63	=P55 * Q55
56			Total	=SUM(R50:R53)
57	=DATA!B\$55			
58	Fittings	K-factor	Number	Sub-total
59	=DATA!B\$57	= (1-DATA!D\$22*2)/DATA!D\$421*2)^2	=DATA!C57	=P59*Q59
60			Total	=SUM(R59:R59)

Attachment 9.12
 Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 35 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Attachment 5
 Excel Spreadsheet Formulae

A	B	C	D	E	F	G	H	I	J	K	L	M
69	=DATAIB64											
70	$\epsilon =$	=DATAIC\$11	ft									
71	d =	=DATAID19	inches									
72	D =	=C71/12	feet									
73	L =	=DATAIC85	feet									
74	=SBS10	=DATAIC824										
75	=SBS11	=(C74*4^144)/(7.48*60*(SC\$71^2)*PI())		=DATAIE\$24	=DATAIF\$24	=DATAIG\$24	=DATAIH\$24	=DATAII\$24	=DATAIJ\$24	=DATAIK\$24	=DATAIL\$24	=DATAIM\$24
76	$R_s =$	= (50.6 * C74 * SC\$3) / (SC\$71 * SC\$4)		= (E74 * E74 * SC\$3) / (SC\$71 * SC\$4)	= (F74 * F74 * SC\$3) / (SC\$71 * SC\$4)	= (G74 * G74 * SC\$3) / (SC\$71 * SC\$4)	= (H74 * H74 * SC\$3) / (SC\$71 * SC\$4)	= (I74 * I74 * SC\$3) / (SC\$71 * SC\$4)	= (J74 * J74 * SC\$3) / (SC\$71 * SC\$4)	= (K74 * K74 * SC\$3) / (SC\$71 * SC\$4)	= (L74 * L74 * SC\$3) / (SC\$71 * SC\$4)	= (M74 * M74 * SC\$3) / (SC\$71 * SC\$4)
77	f =	= 0.25 / (LOG10(SC\$70 / (3.7 / SC\$71 + 5.7 / (C78*0.9)))^2)		= 0.25 / (LOG10(SC\$70 / (3.7 / SC\$71 + 5.7 / (E78*0.9)))^2)	= 0.25 / (LOG10(SC\$70 / (3.7 / SC\$71 + 5.7 / (F78*0.9)))^2)	= 0.25 / (LOG10(SC\$70 / (3.7 / SC\$71 + 5.7 / (G78*0.9)))^2)	= 0.25 / (LOG10(SC\$70 / (3.7 / SC\$71 + 5.7 / (H78*0.9)))^2)	= 0.25 / (LOG10(SC\$70 / (3.7 / SC\$71 + 5.7 / (I78*0.9)))^2)	= 0.25 / (LOG10(SC\$70 / (3.7 / SC\$71 + 5.7 / (J78*0.9)))^2)	= 0.25 / (LOG10(SC\$70 / (3.7 / SC\$71 + 5.7 / (K78*0.9)))^2)	= 0.25 / (LOG10(SC\$70 / (3.7 / SC\$71 + 5.7 / (L78*0.9)))^2)	= 0.25 / (LOG10(SC\$70 / (3.7 / SC\$71 + 5.7 / (M78*0.9)))^2)
78	h _L Pipe (ft)	= 0.1863 * C77 * SC\$73 * C75^2 / SC\$71		= 0.1863 * E77 * SC\$73 * E75^2 / SC\$71	= 0.1863 * F77 * SC\$73 * F75^2 / SC\$71	= 0.1863 * G77 * SC\$73 * G75^2 / SC\$71	= 0.1863 * H77 * SC\$73 * H75^2 / SC\$71	= 0.1863 * I77 * SC\$73 * I75^2 / SC\$71	= 0.1863 * J77 * SC\$73 * J75^2 / SC\$71	= 0.1863 * K77 * SC\$73 * K75^2 / SC\$71	= 0.1863 * L77 * SC\$73 * L75^2 / SC\$71	= 0.1863 * M77 * SC\$73 * M75^2 / SC\$71
79	h _L Filings (ft)	= 0.00259 * (C74^2 / SC\$50^4) * (0) = SUM(C79:C80)		= 0.00259 * (E74^2 / SC\$50^4) * (0) = SUM(E79:E80)	= 0.00259 * (F74^2 / SC\$50^4) * (0) = SUM(F79:F80)	= 0.00259 * (G74^2 / SC\$50^4) * (0) = SUM(G79:G80)	= 0.00259 * (H74^2 / SC\$50^4) * (0) = SUM(H79:H80)	= 0.00259 * (I74^2 / SC\$50^4) * (0) = SUM(I79:I80)	= 0.00259 * (J74^2 / SC\$50^4) * (0) = SUM(J79:J80)	= 0.00259 * (K74^2 / SC\$50^4) * (0) = SUM(K79:K80)	= 0.00259 * (L74^2 / SC\$50^4) * (0) = SUM(L79:L80)	= 0.00259 * (M74^2 / SC\$50^4) * (0) = SUM(M79:M80)
80	Total h _L (ft)	= SUM(C79:C80)		= SUM(E79:E80)	= SUM(F79:F80)	= SUM(G79:G80)	= SUM(H79:H80)	= SUM(I79:I80)	= SUM(J79:J80)	= SUM(K79:K80)	= SUM(L79:L80)	= SUM(M79:M80)

N	O	P	Q	R
69	=DATAIB\$64			
70	Filings	K-multiple	Number	Sub-total
71	=DATAIB\$66	8	=DATAIC\$66	=P71*Q71
72	=DATAIB\$67	30	=DATAIC\$67	=P72*Q72
73	=DATAIB\$68	16	=DATAIC\$68	=P73*Q73
74	=DATAIB\$69	60	=DATAIC\$69	=P74*Q74
75			Total	=SUM(R71:R74)

Attachment 9.12
 Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 36 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Attachment 5
 Excel Spreadsheet Formulae

A	B	C	D	E	F	G	H	I	J	K	L	M
92	=DATA!B70											
93	a =	=DATA!C\$11	r									
94	d =	=DATA!D\$19	inches									
95	D =	=C\$4/12	feet									
96	L =	=DATA!C71	feet									
97	=B\$710	=DATA!B\$24										
98	=B\$811	=(C\$7*4*144)/(48*60*(C\$394)^2)*PI()										
99	R _s =	=(50.6 * C\$7 * C\$33) / (C\$394 * C\$34)										
100	f =	= 0.25 / (LOG10((C\$393 / (3.7 * C\$394 + 5.7 / (C\$9*0.9))^2))										
101												
102	h _t Pipe (ft) =	=0.1863 * C100 * C\$396 * C\$82 / C\$394										
103	h _t Fittings (ft) =	=(C\$7/2) * (C\$394/4) * (F\$397 * C100) / (F\$397 * D100)										
104	Total h _t (ft) =	=SUM(C102:C103)										

N	O	P	Q	R
92	=DATA!B\$70			
93	Fittings	K=multiplies	Number	Sub-total
94	=DATA!B\$72	45	=DATA!C\$72	=P\$4*Q\$4
95	=DATA!B\$73	30	=DATA!C\$73	=P\$5*Q\$5
96	=DATA!B\$74	60	=DATA!C\$74	=P\$6*Q\$6
97			Total	=SUM(R\$4:R\$6)

Attachment 9.12
 Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 37 of 42	Rev. 1
----------------------------------	-----------------------	-----------

A	B	C	D	E	F	G	H	I	J	K	L	M
112	=DATA!B75											
113	r =	=DATA!\$C\$11	r									
114	d =	=DATA!\$D\$21	Inches									
115	D =	=C114/12	feet									
116	L =	=DATA!C76	feet									
117	=#B\$10	=DATA!\$C\$24										
118	=#B\$11	= (C117*4*144)/(7.48*60*(SC\$114^2)*PI())										
119	R _w =	= (50.6 * C17 * SC\$3) / (SC\$114 * SC\$4)										
120	f =	= 0.25 / (LOG10(SC\$113 / (3.7 / SC\$114 + 5.7 / D118*0.9))^2)										
121												
122	h _p Pipe (ft) =	= 0.1863 * C120 * SC\$116 * C118^2 / SC\$114										
123	h _f Fittings (ft) =	= 0.00259 * (C117^2 / SC\$94^4) * (R\$116 * D120)										
124	Total h _f (ft) =	= SUM(C122:C123)										

Attachment 5
 Excel Spreadsheet Formulae

N	O	P	Q	R
112	=DATA!B\$75			
113	Fittings	K-multiple	Number	Sub-total
114	=DATA!B\$77	B	=DATA!C\$77	=P114*Q114
115	=DATA!B\$78	60	=DATA!C\$78	=P115*Q115
116			Total	=SUM(R13:R15)

Attachment 9.12
 Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 38 of 42	Rev. 1
----------------------------------	-----------------------	-----------

A	B	C	D	E	F	G	H	I	J	K	L	M
132	=DATA!B79											
133	$\epsilon =$	=DATA!C811	r									
134	$d =$	=DATA!D819	inches									
135	$D =$	=C134/12	feet									
136	$L =$	=DATA!C80	feet									
137	$\epsilon_{BS10} =$	=DATA!C824										
138	$\epsilon_{BS11} =$	=C137*4*144/W7.4 48*60*(C8134*2) PI()										
139	$R_s =$	= (50.6 * C137 * C833) / (C8134 * C834)										
140	$f =$	= 0.25 / (LOG10(C8133 / 3.7 / C8134 + 5.7 / /E139*0.9))^2										
141												
142	h_p Pipe (ft)	= 0.1863 * C140 * C8136 * C138^2 / C8134										
143	h_f Fittings (ft)	= 0.00259 * C137^2 / C8394*4 * C8136 * C140										
144	h_{BFP} (ft)	= 5.5 * 2.3067										
145	Total h_t (ft)	=SUM(C142:C144)										

Attachment 5
 Excel Spreadsheet Formulae

N	O	P	Q	R
132	=DATA!B79			
133	Fittings	K-multiple	Number	Sub-total
134	=DATA!B81	30	=DATA!C81	=P134*Q134
135	=DATA!B82	60	=DATA!C82	=P135*Q135
136			Total	=SUM(R134:R135)

Attachment 9.12
 Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 39 of 42	Rev. 1
----------------------------------	-----------------------	-----------

Attachment 5
 Excel Spreadsheet Formulae

A	B	C	D	E	F	G	H	I	J	K	L	M
152	=DATAIB84											
153	e =	=DATAIB83										
154	d =	=DATAIB820										
155	D =	=C154/12										
156	L =	=DATAIC85										
157	=S8810	=DATAIS824										
158	=S8811	= (E157*(144)/7.4 8*60*(SC3154^2) PI())										
159	R _s =	= (50.6 * C157 * SC33) / (SC3154 * SC34)										
160	f =	= 0.25 / (LOG10(SC3153 / 3.7 / SC3154 + 5.7 / C159*0.9))^2										
161												
162	h ₁ Pipe (ft)	= 0.1863 * C160 * SC3156 * D158^2 / SC3154										
163	h ₁ Fittings (ft)	= 0.00259 * (C157^2 / SC394^4) * C160										
164	Total h ₁ (ft)	=SUM(C162:C163)										

N	O	P	Q	R
152	=DATAIB84			
153	Fittings	K-multiple	Number	Sub-total
154	=DATAIB86	30	=DATAIC86	=P154*Q154
155	=DATAIB87	60	=DATAIC87	=P155*Q155
156		Total		=SUM(R154:R155)

Attachment 9.12

Calculation Continuation Sheet

Calculation No. M-CLC-H-03203		Sheet No. 40 of 42		Rev. 1								
A	B	C	D	E	F	G	H	I	J	K	L	M
172	=DATA18B											
173	e =	=DATA5C13										
174	d =	=DATA8D320	R Inches									
175	D =	=C174/12	feet									
176	L =	=DATA1C99 + DATA1C93 + DATA1C95 + DATA1C97 + DATA1C98 + DATA1C101 + DATA1C103 + DATA1C105 + DATA1C108	feet									
177	=S8510	=DATA5C324	=DATA5D324	=DATA5E324	=DATA5F324	=DATA5G324	=DATA5H324	=DATA5I324	=DATA5J324	=DATA5K324	=DATA5L324	=DATA5M324
178	=S8511	=C177*4*144/W7.4 48*90*(SC3154^2) PI()	=D177*4*144/W7.4 48*90*(SC3154^2) PI()	=E177*4*144/W7.4 48*90*(SC3154^2) PI()	=F177*4*144/W7.4 48*90*(SC3154^2) PI()	=G177*4*144/W7.4 48*90*(SC3154^2) PI()	=H177*4*144/W7.4 48*90*(SC3154^2) PI()	=I177*4*144/W7.4 48*90*(SC3154^2) PI()	=J177*4*144/W7.4 48*90*(SC3154^2) PI()	=K177*4*144/W7.4 48*90*(SC3154^2) PI()	=L177*4*144/W7.4 48*90*(SC3154^2) PI()	=M177*4*144/W7.4 48*90*(SC3154^2) PI()
179	R _e =	= (50.6 * C177 * SC33) / (SC3174 * SC34)	= (50.6 * D177 * SC33) / (SC3174 * SC34)	= (50.6 * E177 * SC33) / (SC3174 * SC34)	= (50.6 * F177 * SC33) / (SC3174 * SC34)	= (50.6 * G177 * SC33) / (SC3174 * SC34)	= (50.6 * H177 * SC33) / (SC3174 * SC34)	= (50.6 * I177 * SC33) / (SC3174 * SC34)	= (50.6 * J177 * SC33) / (SC3174 * SC34)	= (50.6 * K177 * SC33) / (SC3174 * SC34)	= (50.6 * L177 * SC33) / (SC3174 * SC34)	= (50.6 * M177 * SC33) / (SC3174 * SC34)
180	f =	= 0.25 / (LOG10(SC3173 / 3.7 / SC3174 + 5.7 / C179*0.9))^2	= 0.25 / (LOG10(SC3173 / 3.7 / SC3174 + 5.7 / D179*0.9))^2	= 0.25 / (LOG10(SC3173 / 3.7 / SC3174 + 5.7 / E179*0.9))^2	= 0.25 / (LOG10(SC3173 / 3.7 / SC3174 + 5.7 / F179*0.9))^2	= 0.25 / (LOG10(SC3173 / 3.7 / SC3174 + 5.7 / G179*0.9))^2	= 0.25 / (LOG10(SC3173 / 3.7 / SC3174 + 5.7 / H179*0.9))^2	= 0.25 / (LOG10(SC3173 / 3.7 / SC3174 + 5.7 / I179*0.9))^2	= 0.25 / (LOG10(SC3173 / 3.7 / SC3174 + 5.7 / J179*0.9))^2	= 0.25 / (LOG10(SC3173 / 3.7 / SC3174 + 5.7 / K179*0.9))^2	= 0.25 / (LOG10(SC3173 / 3.7 / SC3174 + 5.7 / L179*0.9))^2	= 0.25 / (LOG10(SC3173 / 3.7 / SC3174 + 5.7 / M179*0.9))^2
181												
182	h _n Pipe (ft)	= 0.1863 * C180 * SC3176 * C178^2 / SC3174	= 0.1863 * D180 * SC3176 * D178^2 / SC3174	= 0.1863 * E180 * SC3176 * E178^2 / SC3174	= 0.1863 * F180 * SC3176 * F178^2 / SC3174	= 0.1863 * G180 * SC3176 * G178^2 / SC3174	= 0.1863 * H180 * SC3176 * H178^2 / SC3174	= 0.1863 * I180 * SC3176 * I178^2 / SC3174	= 0.1863 * J180 * SC3176 * J178^2 / SC3174	= 0.1863 * K180 * SC3176 * K178^2 / SC3174	= 0.1863 * L180 * SC3176 * L178^2 / SC3174	= 0.1863 * M180 * SC3176 * M178^2 / SC3174
183	h _f Frings (ft)	= 135	= 135	= 135	= 135	= 135	= 135	= 135	= 135	= 135	= 135	= 135
184	Total h _f (ft)	=SUM(C182:C183)	=SUM(D182:D183)	=SUM(E182:E183)	=SUM(F182:F183)	=SUM(G182:G183)	=SUM(H182:H183)	=SUM(I182:I183)	=SUM(J182:J183)	=SUM(K182:K183)	=SUM(L182:L183)	=SUM(M182:M183)

Attachment 5
 Excel Spreadsheet Formulae

Calculation Continuation Sheet

Calculation No. M-CLC-H-03203	Sheet No. 41 of 42	Rev. 1
----------------------------------	-----------------------	-----------

A	B	C	D	E	F	G	H	I	J	K	L	M
191	System Curve - RETB-P-4											
192	Summary of h _t (ft)											
193	Total h _t (ft) Segment 1 =	=B310	=DATAH24	=DATAH24	=DATAH24	=DATAH24	=DATAH24	=DATAH24	=DATAH24	=DATAH24	=DATAH24	=DATAH24
194	Total h _t (ft) Segment 2 =	=C17	=D17	=E17	=F17	=G17	=H17	=I17	=J17	=K17	=L17	=M17
195	Total h _t (ft) Segment 3 =	=C104	=D104	=E104	=F104	=G104	=H104	=I104	=J104	=K104	=L104	=M104
196	Total h _t (ft) Segment 6 =	=C124	=D124	=E124	=F124	=G124	=H124	=I124	=J124	=K124	=L124	=M124
197	Total h _t (ft) Segment 7 =	=C145	=D145	=E145	=F145	=G145	=H145	=I145	=J145	=K145	=L145	=M145
198	Total h _t (ft) Segment 8 =	=C164	=D164	=E164	=F164	=G164	=H164	=I164	=J164	=K164	=L164	=M164
199	Total h _t (ft) Segment 9 =	=C184	=D184	=E184	=F184	=G184	=H184	=I184	=J184	=K184	=L184	=M184
200	h _t Static (ft) =	= DATAH336 - DATAH327	= DATAH336 - DATAH327	= DATAH336 - DATAH327	= DATAH336 - DATAH327	= DATAH336 - DATAH327	= DATAH336 - DATAH327	= DATAH336 - DATAH327	= DATAH336 - DATAH327	= DATAH336 - DATAH327	= DATAH336 - DATAH327	= DATAH336 - DATAH327
201	h _t Pressure (ft) =	0	0	0	0	0	0	0	0	0	0	0
202	h _t Velocity (ft) =	0	0	0	0	0	0	0	0	0	0	0
203	Total h _t (ft)	=SUM(C194:C202)	=SUM(D194:D202)	=SUM(E194:E202)	=SUM(F194:F202)	=SUM(G194:G202)	=SUM(H194:H202)	=SUM(I194:I202)	=SUM(J194:J202)	=SUM(K194:K202)	=SUM(L194:L202)	=SUM(M194:M202)

Attachment 5
 Excel Spreadsheet Formulae

Attachment 9.12
 Calculation Continuation Sheet

Calculation No. M-CLC-H-03203		Sheet No. 42 of 42		Rev. 1								
A	B	C	D	E	F	G	H	I	J	K	L	M
209	System Curve - RETB- P-2											
210	Summary of h _t (ft)											
211	=B9*10	=DATA\$C324	=DATA\$D324	=DATA\$E324	=DATA\$F324	=DATA\$G324	=DATA\$H324	=DATA\$I324	=DATA\$J324	=DATA\$K324	=DATA\$L324	=DATA\$M324
212	Total h _t (ft) Segment 1 =	=C17	=D17	=E17	=F17	=G17	=H17	=I17	=J17	=K17	=L17	=M17
213	Total h _t (ft) Segment 2 =	=C40	=D40	=E40	=F40	=G40	=H40	=I40	=J40	=K40	=L40	=M40
214	Total h _t (ft) Segment 3 =	=C80	=D80	=E80	=F80	=G80	=H80	=I80	=J80	=K80	=L80	=M80
215	Total h _t (ft) Segment 4 =	=C81	=D81	=E81	=F81	=G81	=H81	=I81	=J81	=K81	=L81	=M81
216	Total h _t (ft) Segment 7 =	=C145	=D145	=E145	=F145	=G145	=H145	=I145	=J145	=K145	=L145	=M145
217	Total h _t (ft) Segment 8 =	=C164	=D164	=E164	=F164	=G164	=H164	=I164	=J164	=K164	=L164	=M164
218	Total h _t (ft) Segment 9 =	=C184	=D184	=E184	=F184	=G184	=H184	=I184	=J184	=K184	=L184	=M184
219	h _t Static (ft) =	=DATA\$C336 - DATA\$C327	=DATA\$C336 - DATA\$C327	=DATA\$C336 - DATA\$C327	=DATA\$C336 - DATA\$C327	=DATA\$C336 - DATA\$C327	=DATA\$C336 - DATA\$C327	=DATA\$C336 - DATA\$C327	=DATA\$C336 - DATA\$C327	=DATA\$C336 - DATA\$C327	=DATA\$C336 - DATA\$C327	=DATA\$C336 - DATA\$C327
220	h _t Pressure (ft) =	0	0	0	0	0	0	0	0	0	0	0
221	h _t Velocity (ft) =	0	0	0	0	0	0	0	0	0	0	0
222	Total h _t (ft) =	=SUM(C210:C219)	=SUM(D210:D219)	=SUM(E210:E219)	=SUM(F210:F219)	=SUM(G210:G219)	=SUM(H210:H219)	=SUM(I210:I219)	=SUM(J210:J219)	=SUM(K210:K219)	=SUM(L210:L219)	=SUM(M210:M219)

Attachment 5
 Excel Spreadsheet Formulae